



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

September 3, 1980

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Units 1 and 2
Docket Nos. 50-416/417
File 0260/15525/15526
PRD-80/46, Interim Report #1,
Expansion Anchors
AECM-80/205

On August 4, 1980, Mississippi Power & Light notified Mr. C. R. McFarland of your office of a Potentially Reportable Deficiency (PRD) at the Grand Gulf Nuclear Station construction site. The deficiency concerns installation of expansion anchors for conduit hangers, instrument process tubing, and air supply supports without proper approval.

The constructor is currently evaluating the extent of the deficiency and impact on safe operations of the plant. Procedures for installing expansion anchors have been revised and training sessions have been conducted to prevent recurrence.

We expect to complete our evaluation and provide you our final report on this deficiency by November 11, 1980.

Yours truly,

For J. P. McGaughy, Jr.
Assistant Vice President,
Nuclear Production

WDH:mt

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. Victor Stallo, Director
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

13019
S/10

8009100 486