

USNRC REGION III
ATLANTA, GEORGIA

20 AUG 25 A 9:36

TIC

**Florida
Power**
CORPORATION

August 21, 1980

File: 3-0-3-a-4

Mr. J. P. O'Reilly
Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Suite 3100
101 Marietta Street N. W.
Atlanta, GA 30303

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License NO. DPR-72
I.E. Bulletin 80-19; Rev. 0 and Rev. 1
FAILURE OF MERCURY-WETTED MATRIX RELAYS IN REACTOR
PROTECTIVE SYSTEMS OF OPERATING NUCLEAR POWER PLANTS
DESIGNED BY COMBUSTION ENGINEERING

Dear Mr. O'Reilly

In response to the subject Bulletin, we have determined that no C.P. Clare Model HG2X-1011 Mercury-wetted Matrix Relays are in use in the logic matrix of the RPS at Crystal River Unit No. 3. Therefore, no additional information will be provided.

As you requested, the approximate manhours expended on this Bulletin by Plant and Engineering personnel, in conduct of the review and preparation of the report is 24 hours.


8009100933

August 21, 1980

Please contact this office if you require any additional discussion concerning our response.

Very truly yours,

FLORIDA POWER CORPORATION


Ronald M. Bright
Acting Manager
Nuclear Support Services

RMBekcR01(D8-3)

cc: Director
Division of Reactor Operations Inspection
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555