



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CONSUMERS POWER COMPANY

DOCKET NO. 50-255

PALISADES PLANT

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 59
License No. DPR-20

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Consumers Power Company (the licensee) dated May 14, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8009110 581


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B of Provisional Operating License No. DPR-20 is hereby amended to read as follows:

"B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 59, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications."

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 29, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 59

PROVISIONAL OPERATING LICENSE NO. DPR-20

DOCKET NO. 50-255

Revise Appendix A Technical Specifications by removing the following page and by inserting the enclosed page. The revised page contains the captioned amendment number and a marginal line indicating the area of change.

Page

4-7

TABLE 4.1.2
Minimum Frequencies for Checks, Calibrations and Testing of
Engineered Safety Feature Instrumentation Controls (Contd)

<u>Channel Description</u>	<u>Surveillance Function</u>	<u>Frequency</u>	<u>Surveillance Method</u>
5. Containment High Radiation Channels (Contd)	c. Test	H ⁽²⁾	c. Remote-operated integral radiation check source used to verify instrument operation.
	d. Test	R	d. Simulation of CHR 2/4 logic trip with test switch to verify actuation relays, including containment isolation.
6. Manual SIS Initiation	a. Test	R	a. Manual push-button test.
7. Manual Containment Isolation Initiation	a. Test	R	a. Manual push-button test.
	b. Check	R	b. Observe isolation valves closure.
8. Manual Initiation Containment Spray Pumps and Valves	a. Test	R	a. Manual switch operation.
9. DBA Sequencers	a. Test	Q	a. Proper operation will be verified during SIS actuation test of Item 3(a) above.
10. Normal Shutdown Sequencers	a. Test	R	a. Simulate normal actuation with test-operate switch and verify equipment starting circuits.
11. Diesel Start	a. Test	M	a. Manual initiation followed by synchronizing and loading.
	b. Test	R	b. Diesel start, load shed, synchronizing and loading will be verified during Item 3(b) above.
	c. Test	P	c. Diesel auto start initiating circuits.
12. SIFW Tank Level Switch Interlocks	a. Test	R	a. Level switches removed from fluid to verify actuation logic.