

NUCLEAR REGULATORY COMMISSION


ORIGINAL

COMMISSION MEETING

In the Matter of: PUBLIC MEETING

DISCUSSION OF SECY-80-399 PROPOSED INTERIM
AMENDMENTS TO PART 50 RELATED TO HYDROGEN
CONTROL AND CERTAIN DEGRADED CORE
CONSIDERATIONS

DATE: September 4, 1980 PAGES: 1 - 86
AT: Washington, D. C.

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8009260

443

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

PUBLIC MEETING

DISCUSSION OF SECY-80-399
PROPOSED INTERIM AMENDMENTS TO PART 50
RELATED TO HYDROGEN CONTROL AND CERTAIN DEGRADED CORE
CONSIDERATIONS

- - -

Nuclear Regulatory Commission
Room 1130
1717 H Street, N.W.
Washington, D. C.

Thursday, September 4, 1980

The Commission met, pursuant to notice, at 2:00 p.m.

BEFORE:

- JOHN F. AHEARNE, Chairman of the Commission
- VICTOR GILINSKY, Commissioner
- PETER A. BRADFORD, Commissioner
- JOSEPH HENDRIE, Commissioner

NRC STAFF PRESENT:

- LEONARD BICKWIT
- HOYLE
- D. ROSS
- W. DIRCKS

- 1 M. MALSCH
- 2 J. NORBERG
- 3 E. HANRAHAN
- 4 R. MINOGUE
- 5 G. ARLOTTI
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

DISCLAIMER

This is an unofficial transcript of a meeting of the United States Nuclear Regulatory Commission held on September 4, 1980 in the Commission's offices at 1717 H Street, N. W., Washington, D. C. The meeting was open to public attendance and observation. This transcript has not been reviewed, corrected, or edited, and it may contain inaccuracies.

The transcript is intended solely for general informational purposes. As provided by 10 CFR 9.103, it is not part of the formal or informal record of decision of the matters discussed. Expressions of opinion in this transcript do not necessarily reflect final determinations or beliefs. No pleading or other paper may be filed with the Commission in any proceeding as the result of or addressed to any statement or argument contained herein, except as the Commission may authorize.

POOR ORIGINAL

P R O C E E D I N G S

(2:00 p.m.)

1
2
3 CHAIRMAN AHEARNE: This afternoon we meet to
4 address a paper sent to us by Standards Office to the
5 Executive Director. It addresses an item which has sort of
6 achieved prominence as a result of the reviews of what
7 happened in Three Mile Island; and namely, this is just one
8 element of a series of actions. Perhaps we will get to
9 another later during affirmation session. But this
10 particular one is interim amendments Part 50 relating to
11 hydrogen control and certain degraded core considerations.

12 What we have in front of us is a Commission paper
13 requesting approval for publication of proposed amendments.

14 Bill?

15 MR. DIRCKS: I was just going to point out what
16 you just pointed out, John. This is one part of three
17 actions that you are going to be faced with dealing with
18 hydrogen control. The first one was the advanced notice on
19 rulemaking concerning the degraded core rulemaking action.

20 CHAIRMAN AHEARNE: people seem to be having
21 difficulty hearing you.

22 MR. DIRCKS: Okay. I was just pointing out these
23 are three actions that the Commission grappled with at the
24 same time. One is the advanced notice of rulemaking on
25 degraded core. The other one is the interim rule today.

1 The third is the hydrogen control aspects of the license you
2 will be considering for Sequoyah.

3 That is a subject of discussion on the part of the
4 ACRS this week, and you will be meeting with them on that
5 subject. So while you are listening to this I guess you got
6 to keep in mind the other two aspects, the other three
7 aspects are going on at the same time.

8 If you had a sequence of decisions I guess to be
9 made in this matter, probably the first one is the decision
10 regarding the Sequoyah license, because that is where the
11 impact of it all will be felt. Second is some of the
12 applications as a result of that decision, the logic of that
13 decision to the hydrogen control aspects of this interim
14 rule, and finally summing it all up is how you apply one and
15 two to the degraded core rulemaking.

16 So it is an extremely complicated set of trends
17 that are to be woven together here, and I think with that
18 sort of in mind it gives Jim Norberg here a very difficult
19 time of going into this subject.

20 But I just wanted to point out the
21 interrelationship of all these things.

22 MR. NORBERG: I am James Norberg of the Office of
23 Standards Development, and I will brief you on the proposed
24 interim rule, or interim amendments to 10 CFR Part 50
25 related to hydrogen control and certain degraded core

1 considerations.

2 Dr. Ross of the Office of Nuclear Reactor
3 Regulation is here to assist in answering any questions you
4 may have regarding this rulemaking action.

5 The presentation I have will run about 30 minutes
6 barring any interruption, so it will give you some feel for
7 the length of it.

8 In presenting this proposed rule I would first
9 like to briefly discuss its background and then go into the
10 major aspects of the rule, including each of its
11 requirements.

12 Slide one, please.

13 As you know, following the TMI-2 accident the NRC
14 initiated a number of actions to assess the design and
15 operational aspects of nuclear power plants and the
16 emergency procedures for coping with potential accidents.
17 One of these actions, the Lessons Learned Task Force, was
18 established by NRR to identify and evaluate those safety
19 concerns from the TMI-2 accident that require licensing
20 actions beyond those already imposed by IE bulletins and
21 Commission orders for presently operating reactors as well
22 as those pending operating licenses and construction permit
23 applications.

24 In performing its mission, the Lessons Learned
25 Task Force considered investigative information, staff

1 evaluation of responses to IE bulletins and orders,
2 Commission recommendations, ACRS recommendations,
3 recommendations from staff studies such as from NUREG 0560,
4 which was the staff report on feedwater transients in BMW
5 plants, and recommendations from outside the NRC.

6 The Lessons Learned Task Force was charged with
7 identifying, analyzing and recommending changes to licensing
8 requirements, and the licensing process for nuclear power
9 plants based on the lessons learned from the TMI-2 accident.

10 The short-term actions recommended by the Lessons
11 Learned Task Force, when combined with the requirements
12 associated with the recommendations of the IE bulletins on
13 TMI-2, including generic status reports by the bulletins and
14 orders task force, are intended to constitute a sufficient
15 set of short-term requirements to ensure the safety of
16 operating plants and those to be operated in the near future.

17 The initial findings of the Lessons Learned Task
18 Force were published in NUREG 0578 in July 1979. These
19 findings included about 23 recommendations in 12 broad
20 areas. Nine were related to design and three related to
21 operations.

22 Three rulemaking actions were recommended, two
23 related to hydrogen management and required modification to
24 10 CFR 50.44. The other concerned limiting conditions for
25 operation and was related to 10 CFR 50.36. Only the

1 rulemaking recommendations related to 10 CFR 50.44 are
2 addressed in this proposed rulemaking.

3 The final report on the Lessons Learned Task Force
4 was published as NUPEG 0585 dated October 1979. This report
5 addressed safety questions of a more fundamental policy
6 nature regarding design, operations, and the regulatory
7 process itself. This report also recommended that an NRC
8 action plan be developed and forwarded to the Commission for
9 approval.

10 In September 1979 letters were sent by NRR to all
11 licensees of operating nuclear power plants and operating
12 license applicants, licensees with plants under
13 construction, and CP applicants, informing them of the
14 followup actions that should be taken in light of the
15 lessons learned from TMI-2.

16 These actions basically were those recommended by
17 the Lessons Learned Task Force except for those requiring
18 rule changes to 50.44 and 50.36. In addition, three more
19 instrumentation requirements were added, and the requirement
20 for highpoint vents in the primary coolant system was
21 added. Those additional requirements were developed during
22 the ACRS review of NUREG 0578.

23 During the week of September 24, 1979 seminars
24 were held in four regions of the country to encourage
25 industry feedback and dialogue on each short-term

1 requirement. As a result of these seminars four topical
2 meetings were held in Bethesda to discuss certain issues in
3 more detail.

4 On October 30, 1979 letters were again sent out to
5 all concerned, further clarifying the short-term NRC staff
6 recommendations.

7 The TMI-2 action plan, NUREG 0660, dated May 1980,
8 was extensively reviewed and endorsed by the Commission. In
9 this plan Section 2(b), consideration of degraded or melted
10 cores and safety review, identifies a number of actions that
11 involve developing and implementing a phase program to
12 consider core degradation and melting beyond the current
13 design basis.

14 One of these actions is Section 2(b)(8),
15 rulemaking proceeding on degraded core accidents. As you
16 know, two rulemakings are involved. One is a long-term
17 rulemaking, which is preceded by an advanced notice of
18 proposed rulemaking.

19 This ANR was provided to the Commission in
20 SECY-80-357 and is one of the items for today's affirmation
21 session. Hopefully.

22 The other, which is the subject of this briefing,
23 is an interim rule based on a number of recommendations of
24 the above discussed actions that are specifically related to
25 degraded core accidents.

1 These recommendations have been determined by the
2 staff to be of such safety significance that they should be
3 codified by regulation. The staff believes that the changes
4 resulting from these requirements will improve the
5 capability of nuclear power plants to deal with TMI-2 type
6 accidents.

7 The requirements being proposed in this interim
8 rule involve hydrogen management and specific design and
9 other requirements to mitigate the consequences of degraded
10 core accidents and LWR's. The staff position on hydrogen
11 management has been presented to the Commission in
12 SECY-80-107, 107-A and 107-B. The proposed interim rule is
13 consistent with these papers and also represents the
14 rulemaking mentioned in Section 2(b)(7) of the action plan.

15 It should be noted that the implementation dates
16 specified in the proposed rule are consistent with the
17 licensing letters. However, these dates are now being
18 reconsidered and new dates will be provided before the
19 proposed rule is issued.

20 With this background on the basis for the proposed
21 interim rule, I would now like to discuss the rule itself.
22 The second slide, please.

23 The TMI-2 accident revealed serious design and
24 operational limitations that existed relative to mitigating
25 the consequences of the accident and determining the status

1 of the facility during and following the accident. The rule
2 covers three general aspects of dealing with degraded core
3 accidents.

4 First, there are information requirements for
5 timely determination that a degraded core situation could or
6 has occurred and for a decisionmaking relative to how best
7 to cope with the situation and mitigate the consequences.

8 Second, there are requirements related to in plant
9 radioactivity considerations.

10 COMMISSIONER GILINSKY: Could you just explain
11 that first one again?

12 MR. NORBERG: The first? Okay. The three general
13 aspects that the various parts of this rule addressed, the
14 first being that for information requirements for the
15 operators to be able to determine in a timely manner that
16 you are --

17 COMMISSIONER GILINSKY: Oh, I see.

18 MR. NORBERG: -- having --

19 COMMISSIONER GILINSKY: Okay, that in fact they
20 are in that situation?

21 MR. NORBERG: Yes, you got a problem.

22 COMMISSIONER GILINSKY: Okay.

23 MR. NORBERG: And what to do about it.

24 Third, there are in turn interim requirements for
25 hydrogen management. The staff believes that the specific

1 items addressed by this proposed interim rule along with
2 other actions taken by I&E bulletins and orders and other
3 rulemakings represent those short-term requirements that are
4 most important to plant safety and provide time to study the
5 overall question of degraded core accidents more
6 thoroughly.

7 I would now like to briefly discuss each item of
8 the rule as it relates to the three general aspects of
9 dealing with degraded core accidents.

10 Next slide, please.

11 The specific items of the proposed rule that
12 relate to information and decisionmaking are training to
13 recognize control and mitigate degraded core accidents. The
14 TMI-2 accident pointed out the need to train operating
15 personnel to better recognize, diagnose, control and
16 mitigate the consequences of accidents that could lead to or
17 have resulted in a degraded reactor core.

18 The purpose of this proposed amendment is to
19 require additional training for all operating personnel in
20 the use of all available instrumentation and equipment to
21 properly respond to such accidents.

22 Detection of inadequate core cooling. As you
23 know, during the TMI-2 accident the condition of inadequate
24 core cooling was not recognized for a long period of time
25 and certainly not before the reactor core sustained severe

1 damage. This problem was the result of a number of factors,
2 including insufficient range of existing instrumentation,
3 inadequate emergency procedures and operator training, and
4 perhaps insufficient instrumentation.

5 This proposed amendment will require for all LWR
6 power reactors the development and implementation of
7 procedures and training to be used by operators to recognize
8 the existence of degraded cooling in the core using
9 available instrumentation.

10 It will also require that qualified
11 instrumentation be provided to supply the control room with
12 a recorded unambiguous direct indication of inadequate core
13 cooling, such as reactor vessel water level.

14 It should be noted that a correction was recently
15 sent down regarding this proposed rule amendment.

16 The implication in the previous version of this
17 rule, that core exit thermocouples could provide this
18 particular function, is incorrect, and the words "or core
19 exit thermocouples" have been deleted from that particular
20 requirement. What was intended there is a water vessel
21 level indication.

22 Another is accident monitoring instrumentation.
23 The TMI-2 accident demonstrated that conditions can arise
24 that are more severe than those that were postulated for
25 design purposes. Key information was either not readily

1 available to the operators or not recognized by the
2 operators as being critical to understanding the accident,
3 or in some cases the accident conditions were beyond the
4 measurement capabilities of the instrumentation.

5 This proposed amendment requires that LWR's shall
6 have the capability during and following an accident for
7 providing and recording in the control room a continuous
8 indication of containment pressure, hydrogen concentration
9 in the containment atmosphere, containment water level,
10 containment radiation level, radioactive noble gas
11 concentration in the plant effluence, and quantifying the
12 concentration of radiiodine and radioactive particulants in
13 the airborne effluence at each anticipated release points.

14 All of these instruments and monitoring systems
15 shall be designed and qualified with extended ranges to
16 perform their function under anticipated accident
17 conditions.

18 Reg Guide 1.97, Revision 2, instrumentation for
19 LWR's to assess plant and environment conditions during and
20 following an accident, gives guidance on the ranges and
21 specification of the accident monitoring instrumentation
22 required by this section.

23 CHAIRMAN AHEARNE: Now I notice you mention in
24 here that that is out for public comment. I knew you were
25 having, or whoever was running it was having extensive

1 discussions with the ACRS.

2 MR. NORBERG: Yes, that is correct.

3 CHAIRMAN AHEARNE: But it has, you say, gone out
4 for public comment?

5 MR. NORBERG: It has been out for public comment.
6 We have received the public comments, and the ACRS comments
7 are now being resolved.

8 MR. ARLOTTO: The discussion with the ACRS is
9 basically to go effective with the guides --

10 CHAIRMAN AHEARNE: Well, their latest comments on
11 it were more aimed at it was unclear.

12 MR. ARLOTTO: Yes.

13 CHAIRMAN AHEARNE: Previously they had been unable
14 to get it out and --

15 MR. ARLOTTO: I would point out that it is in the
16 context of going (inaudible).

17 MR. NORBERG: Yes.

18 CHAIRMAN AHEARNE: Yes.

19 MR. NORBERG: I think the most important thing
20 here is that the ACRS comments really did not address the --
21 had no disagreement with the ranges of these instruments.

22 CHAIRMAN AHEARNE: Right.

23 MR. NORBERG: Or the specifications. It was more
24 in the format and the way this guide was presented and this
25 sort of thing, is my understanding.

1 So it wasn't the technical content of the guide.
2 It is still correct in the guidance that is referenced here.

3 Another is sampling during and following an
4 accident. One of the problems faced by the TMI-2 operators
5 during and following the accident was the difficulty they
6 had in obtaining and analyzing samples of the highly
7 radioactive reactor coolant and containment atmosphere.

8 There was no capability at TMI-2 to obtain and
9 analyze in a timely manner those highly radioactive
10 samples. This lack of sampling capability resulted in
11 significant delays in obtaining critically needed
12 information which could have assisted the operators in
13 recognizing and coping with the accident.

14 This proposed amendment requires that LWR's are
15 provided with the capability for personnel to promptly and
16 safely obtain and analyze a reactor coolant or containment
17 atmosphere sample during and following an accident.

18 These capabilities must include either on line or
19 on site radiological and chemical analysis facilities to
20 determine the degree of core damage, hydrogen in the
21 containment atmosphere, total dissolved gasses and dissolved
22 hydrogen in the reactor coolant, and the boron and chloride
23 content of the reactor coolant.

24 In plant iodine instrumentation. 10 CFR Part 20
25 provides criteria for control of personnel exposures to

1 radiation in restricted areas, including airborne
2 radioiodine. Whenever airborne radioiodine concentration
3 exceeds specified limits, exposed personnel must take
4 precautions, such as wearing respiratory protective
5 equipment.

6 Such actions, particularly for control room
7 personnel, can sharply limit communication capability and
8 may even diminish their performance capability.

9 Because of the method used at TMI to determine
10 radioiodine concentrations, these concentrations were
11 greatly overestimated and resulted in control room personnel
12 needlessly wearing respiratory protective equipment with its
13 associated operational problems.

14 The purpose of this proposed amendment is to
15 require improved accuracy for the measurement of airborne
16 radioiodine concentration within nuclear power plants.

17 Next slide, please.

18 The second area, specifications in the proposed
19 interim rule that relate to in plant radioactive activity
20 considerations are: protection of safety equipment and
21 areas which may be used during and following an accident.

22 This proposed amendment addresses two aspects of
23 radiation problems encountered at the TMI-2 accident and
24 relative to any degraded core accident.

25 The release of large amounts of highly radioactive

1 material from the core can result in high radiation fields
2 wherever this material may be carried in the course of the
3 accident.

4 Systems and components that were not designed to
5 accommodate large radiation fields may be severely
6 degraded. Also, safe access of personnel for operation of
7 vital equipment needed to cope with the accident may be
8 jeopardized because of high radiation fields.

9 The purpose of this proposed design requirement is
10 to facilitate operations during and following an accident in
11 areas affected by systems that may contain abnormally high
12 levels of radioactivity and to ensure that the equipment,
13 the safety equipment in proximity to the resulting radiation
14 fields are not unduly degraded.

15 Leakage integrity outside containment. Several of
16 the engineered safety features and auxiliary systems located
17 outside reactor containment will or may be called upon to
18 function during and following a degraded core accident.
19 These systems may carry highly radioactive fluids, and the
20 leakage from such systems must be minimized to prevent the
21 release of significant amounts of radioactivity to the
22 environment.

23 The purpose of this proposed amendment, purposes,
24 are to require that every reasonable effort be made to
25 eliminate or reduce leakage from these systems by requiring

1 a preventive maintenance program and periodic test to ensure
2 that leakage is kept to the minimum and to provide the plant
3 staff with current knowledge of the system leakage rates.

4 The source term to be considered for all of the
5 above requirements as may be applicable is specified in the
6 proposed amendment on protection of safety equipment and
7 areas which may be used during and following an accident.

8 This source term is essentially the same that has
9 been used in evaluating compliance with 10 CFR Part 100.
10 That is --

11 CHAIRMAN AHEARNE: 75 percent?

12 MR. NORBERG: No, Part 100.

13 CHAIRMAN AHEARNE: I know, but --

14 MR. NORBERG: That is 100 percent release of core
15 equilibrium noble gas inventory, 50 percent of core
16 equilibrium halogen inventory, and 1 percent of the
17 remaining core fission products are released from the fuel
18 to the primary system.

19 It further specifies that for the containment and
20 areas affected by its atmosphere it shall be assumed that
21 100 percent of the core noble gas inventory and 25 percent
22 of the core halogen inventory are uniformly dispersed in the
23 containment atmosphere and that an additional 25 percent of
24 the core halogen inventory and 1 percent of the remaining
25 core fission products are uniformly distributed on surfaces

1 exposed to the containment atmosphere.

2 COMMISSIONER GILINSKY: What is approximately the
3 core halogen inventory?

4 MR. NORBERG: In terms of curies?

5 COMMISSIONER GILINSKY: Yes.

6 MR. NORBERG: Oh, boy, do you know?

7 MR. ROSS: 100 and some million.

8 COMMISSIONER GILINSKY: About a 100 million.

9 MR. ROSS: I could give it to you in pounds.

10 COMMISSIONER GILINSKY: 150 million curies.

11 MR. ROSS: I understand it is about 35 pounds.

12 COMMISSIONER GILINSKY: Well, it is on the order
13 of 100, 200 million, 150 million.

14 MR. ROSS: It seems to me.

15 COMMISSIONER GILINSKY: Okay, that is good enough.

16 MR. NORBERG: It should be noted that this source
17 term will be reevaluated during the long-term rulemaking on
18 the consideration of degraded core or melted core in safety
19 regulations.

20 Next slide, please.

21 CHAIRMAN AHEARNE: Are you going to get into in
22 this discussion how you arrived at the eight hour 75 percent?

23 MR. NORBERG: That comes at the end of this
24 discussion, yes.

25 CHAIRMAN AHEARNE: Fine.

1 MR. NORBERG: Early in the course of events of the
2 TMI-2 accident, when it was recognized that substantial core
3 damage had occurred, it was also recognized that a large
4 amount of hydrogen had been generated as a result of fuel
5 clad water reaction.

6 Subsequent assessments of the accident by the
7 Lessons Learned Task Force and others pointed out the
8 discrepancy in the current regulations on hydrogen control
9 in 10 CFR Part 50.44, and the resulting conditions at
10 TMI-2.

11 As you know, 10 CFR 50.44 requires that all LWR's
12 must be designed such that one, an uncontrolled
13 hydrogen-oxygen recombination will not take place in the
14 containment, or, two, the plant can withstand the
15 consequences of uncontrolled hydrogen-oxygen recombination
16 without loss of safety. If neither of these conditions can
17 be shown the containment must be provided with an inerted
18 atmosphere or an oxygen-deficient condition in order to
19 provide protection against hydrogen burning or explosions
20 during this time.

21 Prior to the promulgation of 50.44 in 1978 --

22 COMMISSIONER GILINSKY: How do you interpret
23 without loss of safety? Is that when you stay within the
24 safety margins, the design margins?

25 MR. NORBERG: Yes, that is how I would interpret

1 it.

2 COMMISSIONER HENDRIE: Well, without loss of
3 safety functions.

4 COMMISSIONER GILINSKY: Yes.

5 COMMISSIONER HENDRIE: The concern in particular
6 was that a flammable event in the containment might take out
7 essential, both trains of essential safety systems that you
8 needed to control the core, keep it cool after shutdown, et
9 cetera, or in the event of an accident to keep the
10 containment in shape, containment sprays and so on.

11 MR. NORBERG: Or not fail the containment itself.

12 COMMISSIONER HENDRIE: Keep the heat --

13 COMMISSIONER GILINSKY: Well, actually what I am
14 asking is, is it containment failure, is it containment --
15 in terms of interpreting the rule, or is it staying within
16 design margins?

17 MR. BOSS: I don't think prior to the last couple
18 of months we had ever focused on beyond design pressure
19 capabilities. As far as pressure would be concerned, it
20 would be design, not failure.

21 COMMISSIONER GILINSKY: In interpreting 50.44?

22 MR. BOSS: Yes.

23 COMMISSIONER GILINSKY: Yes.

24 MR. NORBERG: Prior to the promulgation of 50.44
25 in 1978 all Mark I BWR's were required to inert in order to

1 comply with safety guide 7, control of combustible gas
2 concentration and containment.

3 This guide specifies that a 5 percent fuel clad
4 water reaction should be considered to take place during the
5 LOCA blowdown; that is, within about the first two minutes
6 of a large break LOCA.

7 The guide recommends inerting of small
8 containments to provide sufficient time for combustible gas
9 control systems to reduce the hydrogen concentration
10 following a LOCA.

11 10 CFR 50.44 gives credit for ECCS performance.
12 This boils down to the design basis of approximately 1
13 percent fuel clad water reaction or five times the amount of
14 such reaction as determined in complying with the ECCS
15 acceptance criteria of 10 CFR 5046, whichever is the greater.

16 Now what this means is that if a plant just
17 complies with the ECCS criteria which specifies a 1 percent
18 metal-water reaction, then this criteria would require that
19 the fuel clad water reaction would be 5 percent. However,
20 as stated before, a lower limit is established of 1 percent
21 in any case.

22 COMMISSIONER GILINSKY: And typically what is the
23 limit for most plants?

24 COMMISSIONER HENDRIE: One percent, because all
25 of these ECCS analyses come out well below --

1 COMMISSIONER GILINSKY: Well below .2 percent?

2 COMMISSIONER HENDRIE: Below .2 percent, yes.

3 MR. ROSS: No, there is two types of plants that
4 come close to being limited by the 1 percent metal-water
5 reaction instead of peak clad temperature, the nonjet pump
6 BWR, because it has a long heatup before the core spray
7 turns the temperature around, and the system 80 design.
8 Both of those come very close to being limited by the 1
9 percent, and in which case times 5 would take them up to 5
10 percent.

11 Of course the system 80 has a large dry
12 containment, so even 5 percent is not a big problem for
13 them.

14 COMMISSIONER GILINSKY: But you say the effective
15 number for most of them is 1 percent, most of the plants?

16 COMMISSIONER HENDRIE: I think so, yes.

17 MR. ROSS: Well, no, I think most -- even what I
18 would call a good PWR probably gives more than .2 of a
19 percent corewide metal-water reaction. I would have to
20 check, but some typical number is .3, .4.

21 COMMISSIONER GILINSKY: I see. So it is somewhere
22 between 1 and 5?

23 MR. ROSS: Yes.

24 COMMISSIONER HENDRIE: Denny, I thought it didn't
25 and that there were --

1 COMMISSIONER GILINSKY: Well, it still sounds like
2 between 1 and 3 percent.

3 COMMISSIONER HENDRIE: -- the 50.46 calculations
4 typically ended up low enough so that the 1 percent was what
5 counted.

6 MR. ROSS: I would say generally the numbers, the
7 corewide metal-water reaction is generally above .2 and for
8 later plants it is pushing 1.

9 COMMISSIONER HENDRIE: Really?

10 MR. ROSS: Yes.

11 MR. NORBERG: So you are getting up towards 5
12 percent then?

13 MR. ROSS: Yes. The Mark III I don't have a
14 number for. I really don't know what that is. If it is
15 important I could get the number in a few minutes.

16 COMMISSIONER GILINSKY: This is because of a
17 flattened flux distribution or what?

18 MR. ROSS: Well, the system 80 just happens to
19 have a low reflood rate and it takes a long time to turn
20 around. Their flux isn't any different than any other PWR.

21 COMMISSIONER HENDRIE: But those boilers must have
22 been pretty low, because my understanding at the time we
23 made, worked out the revision to Reg Guide 1.7 and that
24 subsequently became 50.44 was that the 50.46 ECCS
25 calculation metal-water was low enough so that they would be

1 working at or slightly above 1 percent metal-water reaction
2 under 50.44 and would be -- and that was low enough to allow
3 them to deinert, not to inert a containment.

4 MR. ROSS: That is probably true. It is the
5 nonjet pump BWR that I am sure that is near 1 percent. That
6 is the only one I am sure is high.

7 MR. NORBERG: I think, Dr. Hendrie, that if it
8 calculates somewhere below about .5 percent that they would
9 not have to inert their BWR, their containment.

10 COMMISSIONER HENDRIE: So a 2 1/2 percent
11 metal-water is accommodated?

12 MR. NORBERG: Yes, or 3 percent would be
13 accommodated without inerting. So they can come -- you
14 know, in they are well within the ECCS calculation of 1
15 percent, then chances are they won't have to inert, and it
16 is the staff's view --

17 COMMISSIONER GILINSKY: What is the crossover
18 point for inerting or not inerting under 50.44?

19 MR. NORBERG: It is 4 percent.

20 COMMISSIONER HENDRIE: 4 percent hydrogen in the
21 containment.

22 COMMISSIONER GILINSKY: So most of the Mark I's --

23 MR. NORBERG: Most of the Mark I's --

24 COMMISSIONER GILINSKY: -- must not be making
25 anywhere near the numbers that you are --

1 COMMISSIONER HENDRIE: Yes, they are.

2 COMMISSIONER GILINSKY: Then why are they inerted?

3 COMMISSIONER HENDRIE: Because they hadn't

4 collected themselves speedily when 50.44 was passed in order

5 to come in and ask for deinerting.

6 COMMISSIONER GILINSKY: Oh, and present the

7 analysis?

8 MR. NORBERG: That is right.

9 COMMISSIONER HENDRIE: Yes, just so. And then

10 once we got started --

11 COMMISSIONER GILINSKY: I see.

12 COMMISSIONER HENDRIE: Once Three Mile happened,

13 why --

14 COMMISSIONER GILINSKY: So in a way 50.44 opened

15 the door to deinerting?

16 COMMISSIONER HENDRIE: That is right.

17 MR. NORBERG: That is right. That is what it did.

18 COMMISSIONER GILINSKY: Okay.

19 COMMISSIONER HENDRIE: In fact, the revisions to

20 Reg Guide 1.7 opened the door to deinerting for most of

21 those plants. I have got a notion that the reason most of

22 them didn't come in and do it was -- on the Reg Guide was

23 that it meant that they would have to petition the

24 Commission for reconsideration of their license conditions

25 which would have inerting in it, and then they would be

1 vulnerable to a hearing and there was practically nothing
2 they wanted to do less than come to a hearing.

3 CHAIRMAN AHEARNE: You don't do it unless it is
4 absolutely necessary.

5 COMMISSIONER HENDRIE: So there was a reluctance.
6 Then when it became a regulation why it seems to me they --

7 CHAIRMAN AHEARNE: Well, they were when one of
8 these earlier papers, when these guys were in, industry reps
9 did mention at our meeting here, they were preparing to come
10 in, except then the Three Mile Island came along.

11 COMMISSIONER HENDRIE: Well, I think GE was
12 encouraging them to do it because they would have liked, I
13 think, to have been relieved of the burden of having inerted
14 containments, at least for most of their plants, and I
15 wouldn't be surprised what they were, had some sort of an
16 owners group that met occasionally and made -- were
17 preparing to move in that direction.

18 COMMISSIONER GILINSKY: Is Hatch not inerted
19 because it has made an application --

20 COMMISSIONER HENDRIE: Hatch 2 came along
21 sufficiently late so it rode 50.44 and didn't inert.

22 COMMISSIONER GILINSKY: I see.

23 COMMISSIONER HENDRIE: Vermont is not inerted
24 because they beat us before the Appeal Board.

25 COMMISSIONER GILINSKY: Not us.

1 (Laughter.)

2 MR. NORBERG: Those are the only two operating --

3 COMMISSIONER GILINSKY: What do you mean we?

4 MR. NORBERG: Those are the only two operating
5 PWR's that are not inerted, Hatch and Vermont.

6 COMMISSIONER HENDRIE: Yes.

7 COMMISSIONER GILINSKY: Well, what was the
8 argument of the Appeal Board on why it was okay?

9 COMMISSIONER HENDRIE: What happened, the staff,
10 before the licensing board, the staff just assumed that they
11 would inert like everybody else, and the Vermont Yankee
12 people grumped about it and the staff just shrugged and
13 said, you know, you will have to do it. It just that all of
14 the others are inerted, and we insist you inert, and that is
15 that.

16 So the staff didn't bother to present much in the
17 way of evidence. They just said, we the staff think it
18 ought to be inerted. You know, so ordered. And the
19 applicant came in and put on two days of witnesses about how
20 negative for safety it was to inert because of the
21 difficulty of getting into containment. The board allowed
22 the hearing record to close in that fashion, and here was
23 the staff with essentially no substantive evidence on the
24 record versus the applicant's substantial case, and the
25 Appeal Board looked at that and said haha, they win.

1 COMMISSIONER GILINSKY: Well, how could --

2 COMMISSIONER HENDRIE: You know, weight of the
3 evidence.

4 COMMISSIONER GILINSKY: How could they ignore the
5 regulation?

6 COMMISSIONER HENDRIE: Because there wasn't a
7 regulation at that time.

8 COMMISSIONER GILINSKY: Oh, I see.

9 COMMISSIONER HENDRIE: It was Reg Guide 1.7, and
10 the staff and the ACRS were muscling people by saying we
11 won't support your application unless you knuckle under.

12 COMMISSIONER GILINSKY: Okay.

13 COMMISSIONER HENDRIE: Vermont on this particular
14 point didn't knuckle.

15 MR. MALSCH: I think also the Appeal Board went
16 off on a theory that you couldn't assume degraded ECCS
17 performance because that was a challenge of the ECOS
18 criteria and to require inerting somehow entailed that
19 assumption that the ECCS wouldn't work and that wasn't
20 permissible.

21 COMMISSIONER HENDRIE: Yes. But that was another
22 aspect of the Appeal Board attack on the thing. It was much
23 more troublesome than the specific decision in the Vermont
24 case, because when the Commission later reversed it was to
25 reverse that general philosophical argument and not the

1 particular Vermont decision, which --

2 COMMISSIONER GILINSKY: How could they avoid
3 inerting after 50.44 came in?

4 COMMISSIONER HENDRIE: Because they weren't
5 inerted. They were given a license and not required to
6 inert to operate, and when 50.44 came in, if the staff had
7 tried to once more inert them they would have produced an
8 analysis that showed that they fell under -- fell in the
9 clear under 50.44.

10 MR. ROSS: It would be like Hatch, would it?

11 COMMISSIONER HENDRIE: Yes, just like Hatch. It
12 would have been just like Hatch.

13 MR. MINOGUE: During this same period the
14 metal-water fraction that uses the basis change from 5
15 percent down to effectively for these plants a 1 percent
16 figure.

17 COMMISSIONER GILINSKY: I see.

18 MR. MINOGUE: And that swung the balance back the
19 other way.

20 COMMISSIONER HENDRIE: In fact, we had to go up to
21 the Appeal Board and argue on the one hand that Vermont
22 ought to inert even though we were in the process of
23 promulgating a reg guide under which it could then promptly
24 deinert, and the Appeals Board -- you know, it was all quite
25 clear to us, but the Appeals Board seemed to have some

1 trouble with following the logic.

2 MR. NORBERG: As we all know, the fuel clad water
3 reaction at TMI-2 may have been considerably higher than
4 what is called for in the current regulations, and it has
5 been estimated it could be as high as maybe 50 percent.

6 So in view of --

7 CHAIRMAN AHEARNE: Do we have -- I know each time
8 we hear these kinds of presentations we have that kind of a
9 statement -- are we pinning down any more specifically or
10 will it wait until we actually get a look at the core?

11 MR. ROSS: I asked our coperformance branch chief,
12 Dr. Johnston, that the other day, if he had any new insight
13 from various, the answer was no and they really didn't get
14 expect to get anything until we start looking at the core.
15 There has been no new information. Speculation only.

16 CHAIRMAN AHEARNE: And that is a speculative
17 number also of course.

18 MR. NORBERG: In view of the TMI-2 accident, the
19 staff now believes that 10 CFR 50.44 needs to be modified
20 and that it is prudent to require all Mark I and II
21 containments to be inerted.

22 COMMISSIONER GILINSKY: Can you tell me how many
23 Mark I's and Mark II's there are?

24 MR. NORBERG: There are, I think, a total of 36.
25 There are 16 new ones coming in and 20 that are operating

1 now, is my understanding.

2 MR. ROSS: Did you refer just to operating plants?

3 COMMISSIONER GILINSKY: Well, no, the total.

4 MR. ROSS: That is the total, I think.

5 COMMISSIONER GILINSKY: There are still 16 Mark
6 I's and Mark II's --

7 MR. NORBERG: But of which about 18 of those --

8 MR. ROSS: I think there is only one Mark I left,
9 I believe, and I think that is FERMI, that is not running.

10 COMMISSIONER GILINSKY: Right. So there are 15
11 Mark II's and they are in the pipeline?

12 MR. NORBERG: I think that is correct. I think
13 the total -- when we were doing the value impact statement
14 there were a total of something like 36 Mark I and II's, and
15 I believe that --

16 MR. ROSS: Yes, that is right.

17 MR. NORBERG: -- 18 of them, like you say, are
18 already inerted.

19 Going on then, we say for all other --

20 CHAIRMAN AHEARNE: Yes. I guess the inerting cost
21 of 16 Mark I and II plants, a total of 36 plants, so it must
22 be 20 that are already inerting.

23 MR. NORBERG: Yes. For all other LWR plants the
24 proposed rule is requiring design analyses for measures to
25 handle large amounts of hydrogen. These design analyses are

1 to consider up to 75 percent fuel clad water reaction that
2 takes place over an eight-hour period.

3 CHAIRMAN AHEARNE: Could you say a few words about
4 how you chose those two numbers?

5 MR. ROSS: Well, it is not a very scientific
6 number. When we look at -- it is certainly not related back
7 to the one datapoint we have from Three Mile.

8 CHAIRMAN AHEARNE: Which, as you have just
9 explained, is a sort of fuzzy datapoint?

10 MR. ROSS: Right. Well, no, at least we know the
11 time reasonably well, although we may not know the height of
12 the curve. But it could be as short as two hours if you
13 postulated the sequence that is going to take you all the
14 way to core melt.

15 I don't think the eight hours or two hours is
16 particularly important, and --

17 CHAIRMAN AHEARNE: It is the rate difference
18 between those two --

19 MR. ROSS: No, I don't think so, right. At least
20 I would hope that there wouldn't be a facility that could
21 stand eight but not two.

22 CHAIRMAN AHEARNE: Well, would a recombiner be
23 able to handle eight and not two?

24 MR. ROSS: No.

25 CHAIRMAN AHEARNE: Or is that still too fast for

1 them?

2 MR. ROSS: No, there are several orders of
3 magnitude. They can handle a tenth of a percent per day, so
4 it wouldn't make any difference to a recom or to a purge
5 either one.

6 So we will probably just put a short period of
7 time in there and have just as good a rule. We just want to
8 make sure it was short.

9 COMMISSIONER HENDRIE: Well, there may turn out to
10 be a substantial difference between several hours and two
11 minutes.

12 MR. ROSS: Yes, I agree.

13 COMMISSIONER HENDRIE: So if you bring the time
14 down to arbitrarily short times you in effect don't allow
15 any measurement of approaching flammability concentration,
16 actions that take place, turn on igniters or run a quench
17 system. And there is no time at all for heat removal
18 either. You have to take the full energy burden all at
19 once. And I suspect that that makes a whale of a lot of
20 difference. My own --

21 CHAIRMAN AHEARNE: But you are not saying that the
22 two to eight hours --

23 COMMISSIONER HENDRIE: Well.

24 CHAIRMAN AHEARNE: Because if you are, if there
25 really is a significant difference, then I guess one ought

1 to at least take into consideration what is the possible
2 impact if it is --

3 MR. ROSS: Here is the difficulty we are in. We
4 can postulate a sequence, for example loss of all --
5 complete station blackout, loss of AC, loss of DC, where the
6 only thing that would happen is you just sit there and boil
7 the water off, because you would have no control, no heat
8 removal, nothing.

9 If you analyze that sequence, you know the thermal
10 capacitance of the core fairly well, and you can calculate
11 reasonably well what the hydrogen production would be and it
12 would, in an hour or two you are going to get essentially
13 all the reaction. And of course this goes to core melt.

14 You could postulate though at the end -- magically
15 at the end of say 60 percent reaction and just before the
16 thing is --

17 COMMISSIONER HENDRIE: But that is just on a
18 thermal balance?

19 MR. ROSS: That is right.

20 COMMISSIONER HENDRIE: That is not taking into
21 account the availability of water vapor once you boil it out
22 of the core?

23 MR. ROSS: Well, yes, it is. There is a
24 calculation I was talking about done with a code like MARCH
25 that would have a source of steam, and it accounts for the

1 interchange, plus or minus, with the steam. In other words,
2 some portion of the core the steam would be a heat source
3 and some would be a sink.

4 But these calculations I think are reasonably
5 fictitious because they suggest that you know how you are
6 going to get the degraded core but not the molten core, and
7 I don't think we are that smart yet. But it can be used to
8 give the lower limit in time, and the lower limit is an hour
9 or two. I don't think it can get any shorter than that.

10 COMMISSIONER GILINSKY: Are you talking about the
11 time to generate the hydrogen or the time to release it to
12 the containment vent?

13 MR. ROSS: Well, I am assuming that the release
14 from the core is the same time as the release to the
15 containment, and what I am talking about is the time it
16 would take to boil the system down, heat the core up, in
17 reaction of course with the -- the metal-water reaction -- --

18 CHAIRMAN AHEARNE: -- negligible time transfer?

19 MR. ROSS: The transport time would be negligible.

20 COMMISSIONER GILINSKY: But that wasn't the case
21 at Three Mile Island, was it?

22 MR. ROSS: No, because there was some storage in
23 the -- because, you see, in this sequence I am talking about
24 the relief and safety valves are open or something that was
25 open, and you are getting a -- it is an uncontrolled

1 release, and of course TMI was a semi-controlled --

2 COMMISSIONER GILINSKY: Why do you need to get
3 into that at all? Why don't you simply assume a range of
4 times over which the material, hydrogen would be released to
5 the containment from one hour to several hours?

6 MR. ROSS: That would be okay too. I don't think
7 it would dominate the accident analysis, and over a range of
8 one to eight hours would certainly be an acceptable way to
9 phrase the rule also. It might even be preferable.

10 CHAIRMAN AHEARNE: It seems to be preferable,
11 given your answer. At least I would think so.

12 MR. ROSS: Yes.

13 COMMISSIONER HENDRIE: I think you are driving
14 down to unrealistically short times.

15 COMMISSIONER GILINSKY: You mean one hour?

16 COMMISSIONER HENDRIE: Yes. I have got a notion
17 that with that kind of -- by the time you get down to -- as
18 you come down to shorter and shorter times you pose a more
19 and more difficult design problem.

20 COMMISSIONER GILINSKY: Wasn't that roughly what
21 happened at Three Mile Island?

22 COMMISSIONER HENDRIE: Well, you got a good chunk
23 of it in that hour early in the morning, but there were some
24 other high temperature periods during the day. I remember
25 there was a time when they had it cut off later in the

1 morning. The high pressure injection cut off. And then
2 there was a time later after that when they spent some hours
3 trying to bring the pressure of the system down, and it is
4 clear that they were, you know, steam --

5 COMMISSIONER GILINSKY: Well, I would assume there
6 was release during that period. I would assume it was
7 released during that period when they were bringing it down
8 rather than at the earlier time when it was generated.

9 COMMISSIONER HENDRIE: Well, I think they probably
10 got a little early on, got some of it early on, but the
11 times during which the core must have been, elements of the
12 core must have been at temperature and able to produce
13 substantial amounts of hydrogen, the metal-water reaction, I
14 think at Three Mile was of the order of several hours rather
15 than that initial 140-odd minute period.

16 COMMISSIONER GILINSKY: Well, in any case I would
17 focus on the release rather than on the generation; I mean
18 if you believe that it is the same that --

19 MR. ROSS: I think it would be prudent to assume
20 that there is no delay anyway, storage in the system.

21 MR. NORBERG: I think the answer to Chairman
22 Ahearne's question, the reason that it was specified this
23 way in the rule is that we did not want to try to specify
24 scenarios for this situation, which is about what you would
25 have to do in order to start putting this thing in time

1 sequence.

2 CHAIRMAN AHEARNE: My concern I guess I try to
3 clumsily state it, is that if the results, the analysis and
4 the interpretation of the analysis is going to be
5 significantly dependent upon the percentage and the time,
6 then you would have to have some pretty good reasons for
7 choosing the specific numbers. And if we don't have those
8 really good reasons, then I would think you would have to at
9 least leave open the possibility of looking at a broader
10 range.

11 MR. ROSS: I only answered half the question. The
12 75 percent was based on the general feeling that that is
13 where a degraded core stops. You go much beyond that you
14 are into a molten core, and that is another rulemaking.

15 CHAIRMAN AHEARNE: Okay, but what you are saying
16 there is that the analysis should look at --

17 MR. ROSS: Right.

18 CHAIRMAN AHEARNE: You are not necessarily yet
19 saying that you have reached the conclusion that the
20 mitigating features ought to be put in place to handle that,
21 or are you?

22 MR. ROSS: Well, that is right. The analysis for
23 some reactor, for example, could well be that we can't stand
24 85 percent -- 75 percent in eight hours. That doesn't yet
25 mean anything has to be done.

1 Again, if the results were very sensitive, that I
2 could stand 75 but not a 100, then I think that is trying to
3 play it too close also. If we want protection at a 100 we
4 should want it at 75.

5 MR. NORBERG: Well, to go on, then --

6 COMMISSIONER GILINSKY: Could I just ask one more
7 question? When we talk about these percentages, it is a
8 percentage of what? When we say percent metal-water
9 reaction, are we just talking about the clad or are we
10 talking --

11 MR. ROSS: Fuel clad, yes.

12 CHAIRMAN AHEARNE: The particular percent here is
13 percent of fuel cladding.

14 COMMISSIONER GILINSKY: But there are other pieces
15 of zirconium metal in there, aren't there, and certainly --

16 MR. ROSS: A BWR has a massive amount of zirconium
17 in the --

18 COMMISSIONER HENDRIE: It is the fuel clad,
19 classically is the fuel clad around the pellets and does not
20 include the end tubes, end plugs or other zirc alloy
21 structural members, and the reason just is that you have
22 much less opportunity to raise that stuff to the kind of
23 temperatures that are needed, a couple of thousand degrees
24 Fahrenheit, to get a fairly rapid chemical reaction going.

25 In order to get metal-water reaction for the end

1 pieces and zirc alloy structural members in the core, you
2 would have to melt the whole bloody thing down and have
3 essentially a several thousand degree melt somewhere down in
4 the bottom and then in contact with water vapor, and then
5 indeed you would get some zirconium-water reaction. But
6 that is --

7 COMMISSIONER GILINSKY: Is that true of the pieces
8 in the guts of the core as well?

9 COMMISSIONER HENDRIE: Oh, yes, I think so.
10 Things like channel boxes --

11 COMMISSIONER GILINSKY: Yes.

12 COMMISSIONER HENDRIE: -- frames on the elements,
13 the cladding around the control rod fingers, for instance.
14 You just need that intimate heat transfer contact between
15 the high temperature fuel and the external world in order to
16 get the zirc alloy up there.

17 COMMISSIONER GILINSKY: And that seems reasonable
18 for end plates, but I guess I am a little surprised that it
19 is also true for zirc alloy in the center of the core.

20 COMMISSIONER HENDRIE: Companion rods and so on?

21 Well, the thing that distinguishes the fuel clad
22 in the pellet region from all other material is that that
23 material forms a boundary around the hot fuel, within which
24 the energy is being generated and is therefore the heat
25 conduction path. All the energy has to flow out through

1 that cladding. That is not true of any of the other metal,
2 and you just don't develop then the very large delta T -- --
3 because the ambient after all is going to be a few hundred,
4 four or five hundred degrees F. or something like that,
5 water and steam and the background temperature of the
6 vessel, as the radiation sink --

7 COMMISSIONER GILINSKY: Yes, but when you are
8 right in the center you can't see outside, any direction you
9 look you just see rods, I assume.

10 COMMISSIONER HENDRIE: Yes, but the thing is
11 immersed at least in a steam atmosphere.

12 CHAIRMAN AHEARNE: Have you done code runs perhaps?

13 MR. ROSS: Not to answer this question. The only
14 thing that would shed light only goes up to a point. We
15 have heat transfer tests with unfueled rods, but these tests
16 stop around 2000 degrees Fahrenheit. And they suggest that
17 the unfueled, unheated rod would lag the heated temperature
18 by two or three hundred degrees when you have a low, a
19 relatively low cooling rate.

20 The thing that is inconsistent about the
21 calculations we are talking about, if you don't want to be
22 steam limited you have to supply a lot of steam to convert
23 the zirc alloy. If you supply a lot of steam, then you are
24 probably going to keep these unheated things down near the
25 local saturation. But the thing we haven't done is do

1 individual fuel pin calculations up to the high metal-water
2 reactions, given enough steam so that the zirc alloy is not
3 steam limited. We are just not in a production basis on
4 that. I think we could be but we haven't done it yet.

5 MR. NORBERG: Well, the measures that we are
6 requiring the people to analyze include inerting, hydrogen
7 recombiners, purging, halon suppressing, filtered vent,
8 hydrogen combustion or ignition systems, water fog-spray
9 systems, and combinations of these or any other things that
10 they believe can handle this problem.

11 And for operating plants these studies are to be
12 completed six months from the effective date of the rule.

13 Another proposed modification to 50.44 is to
14 require that dedicated penetrations be provided for plants
15 that rely upon external recombiners or purge systems to meet
16 the hydrogen control requirements.

17 The TXI-2 plant had capability to connect hydrogen
18 recombiners; however, the design was susceptible to single
19 active failure and possibly even degraded performance of the
20 recombiners.

21 This modification will eliminate these problems.

22 CHAIRMAN AHEARNE: What plants does that really
23 cover? Since what, 1970. The plants have been required to
24 have recombiners?

25 MR. NORBERG: Yes, it would be those plants that

1 now have the capability to hook up a recombiner, but they
2 may not have a dedicated penetration. If you remember in
3 TMI the way they hooked up the --

4 CHAIRMAN AHEARNE: Yes, I remember that.

5 MR. NORBERG: -- was through, you know through
6 their main --

7 CHAIRMAN AHEARNE: No, I was just trying to get a
8 sense of what class of plants was that --

9 MR. NORBERG: Yes, it is those basically from I
10 guess about November 5th, 1970 on that were required to have
11 recombiner capability.

12 The ones prior to that only required purge.

13 CHAIRMAN AHEARNE: All right, and it is --

14 MR. NORBERG: I am not all of the plants have this
15 problem.

16 MR. ROSS: I don't have an inventory of which one.

17 CHAIRMAN AHEARNE: Yes, but this would be
18 requiring though for all plants to rely upon purge to put in
19 external recombiners.

20 MR. NORBERG: That is another requirement, yes,
21 that is correct.

22 MR. ROSS: But we wanted to get into a position
23 where if you had hydrogen generation like the rates of 50.44
24 is today, there was a reasonably small amount, and you had
25 radiolysis and a continuing hydrogen generation, such that

1 in a matter of weeks you were going to have to purge the
2 containment or be up at the lower combustible limit. We
3 wanted that facility not to have to purge.

4 That would mean he would have to get a
5 penetration, an external hardware shielding, but recognizing
6 that it might be weeks before he needed it, he could move in
7 a recombiner from somewhere else. And the rule as written
8 doesn't require him to have it at his facility but be ready
9 to accommodate in a few days.

10 CHAIRMAN AHEARNE: Do Hatch and Vermont have
11 recombiner capability?

12 MR. BOSS: Who, Hatch?

13 I don't know.

14 CHAIRMAN AHEARNE: Bob?

15 MR. TEDESCO: Yes, Hatch does. Vermont
16 (inaudible).

17 MR. NORBERG: I think we have two things here. We
18 are talking about requiring plants that now have the
19 recombiner capability to have dedicated penetration --

20 CHAIRMAN AHEARNE: Right.

21 MR. NORBERG: -- and those that earlier only
22 relied on purge systems to now have capability to hook up to
23 recombiners, which also has to be dedicated.

24 CHAIRMAN AHEARNE: Right, and so I am trying to
25 figure now, very briefly you have been talking about Mark I

1 and II and we also have the ice condenser issue. What of
2 these requirements would be laid on? I guess the Mark I's
3 that are inerted neither of those apply to. Is that correct?

4 MR. ROSS: That is right.

5 CHAIRMAN AHEARNE: All right, Hatch you say
6 already has the recombiner, so there it would be the issue
7 of you would have to make sure it has dedicated penetration.

8 MR. ROSS: That is right.

9 CHAIRMAN AHEARNE: Vermont Yankee, were it not to
10 be required to be inerted would then have to -- right now it
11 relies upon, would be classed as a plant relying on what?
12 The purge system?

13 MR. NORBERG: Purge, yes.

14 CHAIRMAN AHEARNE: All right, how about the ice
15 condensers, which would not be required under this to be
16 inerted? Do they have recombiners?

17 MR. ROSS: Yes, internal. So they don't have to
18 worry about either one of these.

19 CHAIRMAN AHEARNE: I see, they all have internal
20 recombiners?

21 MR. ROSS: Yes.

22 COMMISSIONER GILINSKY: Why do we have recombiners?

23 MR. ROSS: For the long-term --

24 COMMISSIONER HENDRIE: Radiolytic hydrogen.

25 MR. ROSS: -- hydrogen generation on top -- a

1 radiolysis on top of the threshold of hydrogen from the
2 50.44 assumption.

3 COMMISSIONER GILINSKY: How much can get generated
4 that way?

5 MR. ROSS: How much do you generate? It must be
6 slightly less than a tenth of a percent per day. To me --

7 COMMISSIONER GILINSKY: Because that is the
8 capacity of the recombiners?

9 MR. ROSS: It is less of a tenth of a percent per
10 day because the recombiner turns it around, and --

11 COMMISSIONER GILINSKY: What is the concern about
12 generating a tenth of a percent per day?

13 COMMISSIONER HENDRIE: Well, just that you build
14 up a flammable concentration over time.

15 MR. NORBERG: Over a long period of time.

16 MR. ROSS: There are several sources. There is
17 also a potential for a corrosion source. There is -- some
18 of these plants inject caustic -- -- and there is even a
19 tiny bit from the indigenous hydrogen that was put in there
20 to begin with, not much, but --

21 COMMISSIONER GILINSKY: Well, so over --

22 COMMISSIONER HENDRIE: But the main concern here
23 was that with a major accident, fission products distributed
24 in the water so that it wasn't just the radiolytic
25 decomposition from a core with fission products contained in

1 fuel oxide, in fuel rods, and you were just getting the
2 gamut through the shell, but if you had fission products out
3 in the water, the concern was that the radiolytic
4 decomposition rate might be high. So one went and looked at
5 the decomposition rates in various experiments and so on and
6 took you know sort of reasonable upper bound sort of values
7 and then looked at measures to be able to stand that
8 hydrogen generation rate over a long period of time.

9 MR. ROSS: In some instances 17 --

10 COMMISSIONER GILINSKY: And the concern is what,
11 that you will somehow harm equipment or what?

12 COMMISSIONER HENDRIE: No, that you will go
13 flammable in the containment and get a burning --

14 COMMISSIONER GILINSKY: No, I understand, but --

15 COMMISSIONER HENDRIE: -- or a detonation.

16 MR. ROSS: The concern was generally containment
17 pressure.

18 COMMISSIONER HENDRIE: Containment integrity
19 basically.

20 MR. ROSS: I don't recall at that time --

21 COMMISSIONER GILINSKY: Over a period -- I mean it
22 would take many months then to get --

23 COMMISSIONER HENDRIE: Well, depended on -- it
24 seems to me those -- let's see, help me out, Bob.

25 MR. ROSS: Several weeks is what I call --

1 COMMISSIONER HENDRIE: Large PWR's could get
2 flammable, sort of taking, you know sort of worst case
3 generation rates from radiolytic decomposition in what,
4 several weeks?

5 MR. ROSS: That is what I remember, yes.

6 COMMISSIONER GILINSKY: Well, it may get
7 flammable, but they are not, they can easily take the
8 pressure.

9 MR. ROSS: But barely detonable, yes, right.

10 COMMISSIONER GILINSKY: You are talking about
11 BWR's or PWR's?

12 COMMISSIONER HENDRIE: But you know, we were
13 regarding, we weren't allowing a flaming in the hydrogen in
14 those days.

15 COMMISSIONER GILINSKY: So that was just a line
16 you drew?

17 MR. ROSS: That is right.

18 COMMISSIONER HENDRIE: We just said 4 percent
19 hydrogen and that is it, you don't go up there.

20 COMMISSIONER GILINSKY: All right.

21 MR. NORBERG: Well, regarding the purge, the
22 requirements to put recombiner capability on the old plants,
23 there are about 40 plants with CP applications. Our notice
24 is prior to November 5, 1970 that this requirement would be
25 involved with. And this requirement was not included in the

1 letters to the licensees and applicants. However, the staff
2 now believes that means other than purging and venting
3 should be available to reduce the likelihood of the release
4 of radioactive material to the environment in the event of a
5 degraded core situation.

6 Another hydrogen-related requirement is proposed
7 in the rule to provide operational capability when needed to
8 enhance primary system cooling capability under accident
9 conditions.

10 This proposed requirement is for highpoint vents
11 in the reactor primary coolant system. The purpose of this
12 design requirement is to provide the operators with the
13 means for rapidly purging the primary coolant system with
14 noncondensable gasses that could accumulate and possibly
15 degrade or even prevent adequate core cooling flow,
16 particularly under natural circulation conditions. Such a
17 situation as occurred at TMI-2.

18 COMMISSIONER GILINSKY: What, you told me last
19 time, I am afraid I have forgotten the answer -- what did
20 you do about the two conflicting requirements on the one
21 hand requiring that a vent be available to vent large
22 amounts of hydrogen fairly quickly and the other that they
23 need to demonstrate that in doing so they had to stay below
24 4 percent? Was the last part dropped?

25 MR. ROSS: Right, the September 1979 or the

1 October 1979, whichever, clarification letter had mentioned
2 trying to keep, that you should try to keep the hydrogen
3 down below 4 percent or some number. On further reflection
4 we decided to excise that from the clarification package
5 that we intend to go out -- well, it was due to you today I
6 believe or tomorrow -- such that the plant operator would
7 focus solely on getting rid of the hydrogen and restoring
8 core cooling at whatever rate was appropriate, whatever rate
9 he could do it.

10 Now if you do certain calculations you could show
11 that at high pressures that would mean getting rid of enough
12 hydrogen to be equivalent to a large percent of core
13 metal-water reaction, and if you distributed it all at once
14 and didn't burn it, then you could have a high containment
15 concentration.

16 COMMISSIONER GILINSKY: Well, I don't know whether
17 this is the right time to discuss that, but I was wondering
18 how you square that with the rest of the rule.

19 VOICE: I don't think we do. We just admit that
20 it is in there.

21 MR. ROSS: Well, I don't think it is --

22 COMMISSIONER GILINSKY: A rather disarming
23 approach.

24 MR. ROSS: I don't really think it is agreed it is
25 inconsistency. It says have the ability to get rid of the

1 noncondensable in a short period of time. The alternative,
2 if you had this large amount, the alternative to getting rid
3 of it might be melting the core.

4 So it is, you know, what it does to the hydrogen,
5 to the containment later on could be the least of your
6 problems, if you had this stuff.

7 I am not sure it helped any, but there are other
8 places where regulations are not perfectly consistent and
9 that what is conservative for one may be superconservative
10 for another. And in particular, Part 100 releases versus a
11 design basis loss of coolant.

12 COMMISSIONER GILINSKY: Except I think we have
13 tended to go the other way in conservatism. If I remember
14 correctly, 50.44 or Reg Guide 1.7 or both have got some
15 statements such as it is perfectly consistent with
16 regulatory practice to be more conservative with a
17 containment than with the other parts of the system. And
18 that is where you get the factor of 5 in all that.

19 And I guess I think that that was a perfectly
20 reasonable approach. Here one is going in the opposite
21 direction.

22 VOICE: No, I don't really think it is the
23 opposite direction because what you are really trying to do
24 with this vent situation is prevent a meltdown. And if you
25 can't do that, whatever else you have is of no avail. So

1 that is where the most conservative ought to be in your
2 requirement, the way I look at it, even though that
3 conservatism might result mechanistically in loss of the
4 containment. You have got the most conservatism in place.

5 COMMISSIONER GILINSKY: Well, in terms of the
6 decision as you put it, I mean given that bad choice, you
7 make the best of it, and I guess you are probably making the
8 right decision. But that -- I guess what I am getting at --
9 we have talked about this a lot, this isn't the first time
10 we have been over this, and my point is that I guess I
11 wouldn't want to be faced with that choice and would impose
12 requirements on the containment in the first place.

13 MR. ROSS: I think the issue is kind of moot
14 because if you interrupt core cooling, your reactor system
15 pressure is going to go up and lift the relief valve and let
16 the gas out whether you want it to or not, except it may let
17 out more water than you would like it to let out, along with
18 a certain amount of hydrogen.

19 CHAIRMAN AHEARNE: Bob?

20 MR. MINOGUE: I think the key is directed at what
21 we are intending to do with this particular division, is to
22 give the operator certain capability. In a sense it is
23 inconsistent, in a sense it is not. But we are really
24 aiming at something different here. It is to provide the
25 operator with certain capability to take action in some

1 extreme case, not that they are helpless and unable to cope
2 with it.

3 The more normal mode would be to be concerned
4 about the containment. It is a question of an additional
5 element of operational flexibility to deal with an active
6 situation. That is fundamentally what this is aimed at.

7 COMMISSIONER GILINSKY: But suppose we go back to
8 Three Mile Island and clearly it would have been helpful to
9 have a vent to release the hydrogen, but yet people managed
10 to deal with it without the vent. On the other hand, had
11 there been a weak containment surrounding that primary
12 system the situation would have been very bad. I mean you
13 were telling me how many curies there were roughly in that
14 containment and some fair fraction of the inventory that you
15 gave me the number for.

16 So it would seem to me that the lesson is, first
17 of all fix up the containments where you need to because --
18 or at least help them cope with the pressures. That seems
19 to me to be the more pressing item than the core vent.

20 Now maybe the one is easier to carry out than the
21 other, and there may be reasons for proceeding a little
22 differently. But at least looking at it in a fairly simple
23 way, that is the way I come out.

24 CHAIRMAN AHEARNE: Well, let me go back to the
25 point that Bob just made, at least one argument for what

1 they are putting forth on the vent is just as Bob said, it
2 is not an instrument that you would automatically use but it
3 does give a capability for use. In the Three Mile Island
4 situation, as you point out, it would have been nice to have
5 that to be used, not saying that it was --

6 COMMISSIONER GILINSKY: Well, I am not suggesting
7 that we ought not to have the vent.

8 CHAIRMAN AHEARNE: -- automatic --



9 COMMISSIONER GILINSKY: I am talking about the
10 priorities.

11 MR. MINOGUE: If you have a lot of time, there are
12 other ways of getting rid of the hydrogen, play the game of
13 solubility and so on. But the time is relatively short,
14 foresee some change in cooling mode or some transient, you
15 really are concerned about imposing this on the plant. It
16 seems important to me, almost regardless of what this may do
17 to the containment, to give the operator some capability to
18 make sure that whatever else happens that core is not melted.



19 That really is the intent here. It is an
20 operational capability to be available in some odd set of
21 circumstances where you do not have time to get rid of the
22 hydrogen in a more leisurely way. So you must act fairly
23 promptly.

24 MR. NORBERG: I have one more slide.



25 COMMISSIONER HENDRIE: Before you charge off that





**IMAGE EVALUATION
TEST TARGET (MT-3)**




MICROCOPY RESOLUTION TEST CHART







**IMAGE EVALUATION
TEST TARGET (MT-3)**



MICROCOPY RESOLUTION TEST CHART



1 one and before we get off highpoint vents, as I read the
2 language of the supplementary information and then the rule
3 language on the highpoint vents, it sounded like you were
4 going to stick a vent on every high point in the primary
5 system. Could somebody tell me what the intent is? Is that
6 the scheme?

7 MR. ROSS: I believe that a U-tube boiler, a
8 U-tube PWR --

9 COMMISSIONER HENDRIE: No, that is dealt with
10 explicitly. The U-tube steam generators are explicitly
11 dealt with when you say you are right, you can't -- -- in
12 every damn tube --

13 MR. ROSS: No, I am just characterizing --

14 COMMISSIONER HENDRIE: -- but when I read that
15 thing why it sure sounded like every other high point in the
16 system was going to have a hole and an -- -- line.

17 MR. ROSS: Let me put it this way: the
18 Westinghouse and CE product line I believe would -- the
19 pressurizer and the upper head, and for the B&W product line
20 the top of the hot leg, in addition. I believe that is a
21 complete set.

22 And of course most pressurizers already have a
23 vent. Some people may well be venting the upper head to the
24 pressurizer and then the pressurizer would be kind of a
25 collection point. And since the pressurizer is usually

1 higher than everything else, it is possible that the B&W hot
2 leg might vent to the pressurizer also.

3 In other words, that is a possible way to get out
4 of it. And we just haven't seen specific designs.

5 COMMISSIONER HENDRIE: Okay.

6 MR. NORBERG: Okay, last slide.

7 I thought I would give some rationale for what we
8 are doing here, and the staff rationale for the hydrogen
9 management position, and particularly the requirements for
10 inerting Mark I and II only and only performing design
11 studies on the other plants is as follows:

12 Hydrogen control is largely a volume dependent
13 situation, all other factors being more or less equal. That
14 is, hydrogen combustion only occurs for a range of
15 hydrogen-oxygen mixtures, with the lower limit being about 4
16 percent hydrogen by volume.

17 It directly follows then that the larger the
18 volume in the containment, the more hydrogen it can
19 accommodate before a combustible mixture is reached.

20 The BWR Mark I and II containments have the
21 smallest volume; therefore, they can reach a combustible
22 mixture with a relatively small fuel clad-water reaction;
23 i.e., less than 5 percent.

24 Ice condensers and BWR Mark III containments have
25 larger volumes and are estimated to reach combustible

1 mixture with about 15 -- 10 to 15 percent fuel clad-water
2 reaction, and large containments can accommodate at least 40
3 percent fuel clad-water reaction without reaching a
4 combustible level.

5 Thus, the small containments have the least margin
6 for reaching a combustible mixture. Containment strength is
7 another important parameter when assessing hydrogen
8 management.

9 The staff has performed analyses that compare both
10 containment design pressure and the estimated pressure for
11 structural failure of the containment as a function of the
12 combustion of hydrogen from a given percent fuel clad-water
13 reaction. These studies have been extensively discussed in
14 the SECY-80-107 papers.

15 The bottomline is that large dry containments can
16 take combustion of hydrogen from essentially 100 percent
17 fuel clad-water reaction, Mark III and ice condensers can
18 take combustion of hydrogen from about 20 to 25 percent fuel
19 clad-water reaction and Mark I and II's can take combustion
20 of hydrogen from less than 10 percent fuel clad --

21 COMMISSIONER GILINSKY: When you say can take,
22 this is what, the failure?

23 MR. NORBERG: I think it is the failure strength,
24 to the calculated failure point, the yield point.

25 COMMISSIONER GILINSKY: Oh.

1 COMMISSIONER HENDRIE: Steady down for about the
2 same --

3 MR. NORBERG: Sorry, I think it is the ultimate
4 strength, is that right?

5 COMMISSIONER GILINSKY: Well, anyway something
6 like that.

7 MR. NORBERG: The failure strength is the ultimate?

8 MR. ROSS: Yes, right.

9 MR. NORBERG: Yes, it is the ultimate.

10 MR. ROSS: Anytime we use the word "failure" -- I
11 think we have mentioned this before; it is a very idealized
12 thing, and local failures around penetrations have not been
13 calculated. A more exact calculation might give you a
14 different number. We are talking about just ideal material.

15 COMMISSIONER GILINSKY: These are comparative --

16 MR. ROSS: Yes.

17 MR. NORBERG: And it is at the ultimate strength,
18 I think, that you calculate to, right?

19 MR. ROSS: We report two numbers on the structural
20 capabilities, yield and failure.

21 MR. NORBERG: Yes, right. This is the failure to
22 failure now.

23 And thus, there is considerable margin for large
24 containments, lesser margin for intermediate containments
25 and even less margin for the smallest containments.

1 The third factor of the staff's rationale is
2 related to operation with inerted containments. The Mark I
3 containment designs permit inerting, and there is
4 considerable satisfactory operating experience with inerted
5 Mark I containments.

6 Ice condensers have not been designed for
7 inerting, and the effects of operating in such an
8 environment are unknown. Further studies are needed before
9 such a requirement could be imposed on an ice condenser.
10 These studies should be a part of the proposed rule.

11 An ignition system has been proposed by TVA for
12 the Sequoyah ice condenser plant. This feature is not
13 called out as a requirement in the rule since the staff
14 feels more analysis is needed.

15 The staff believes that during the interim period
16 before the long-term rulemaking is completed, the issue of
17 distributed ignition systems for ice condensers should not
18 be treated by rulemaking but should be addressed on a case
19 by case basis once the decision has been reached for the
20 Sequoyah plant.

21 Probabilistic risk studies have been performed on
22 Mark I plants and conclude that the decrease in residual
23 risk is small due to inerting these containments. It is the
24 staff's view, however, that inerting would be beneficial for
25 other accidents that could lead to a severely degraded but

1 not necessarily melted core condition and that on balance
2 prudent judgment is to require inerting of these
3 containments.

4 CHAIRMAN AHEARNE: But you are, are you not, in
5 this proposed rule requiring the ice condenser plants to
6 study igniters?

7 MR. NORBERG: Yes, we are. One of the studies
8 require it.

9 This concludes my presentation of this proposed
10 rule.

11 COMMISSIONER GILINSKY: Did you say something
12 about the Mark III's? Are they like the ice condensers in
13 terms of how much equipment is in them?

14 MR. ROSS: I understand they have quite a bit more
15 stuff inside than the Mark I's and II's. So they would be
16 more like the ice condenser, and the argument about needing
17 to go into Mark III is going to be somewhat stronger than it
18 was for the Mark I and II. I don't have any details beyond
19 that.

20 COMMISSIONER HENDRIE: Well, it is going to be a
21 hell of a lot stronger unless they move a lot of equipment
22 outside because -- outside the drywell and still inside the
23 containment on the Mark III's you have got all kinds of
24 instrument goodies just as you have in an ice condenser --

25 MR. ROSS: Right.

1 COMMISSIONER HENDRIE: -- that you can't stand to
2 have zero access to, or very limited access. So if you
3 tried to inert those containments why, just as with the ice
4 condenser, you are going to have to move all kinds of things
5 out of the containment, and I am not sure, you know in
6 principle you would think that could be done but there may
7 be some knotty problems with the length of pneumatic as well
8 as electrical leads before you get to preamps and
9 transmitters and --

10 COMMISSIONER GILINSKY: Having crawled through an
11 ice condenser plant, I think I appreciate the difficulties
12 of doing that in the ice condenser plants. But still it
13 seems to me that it is something that one ought to look into
14 and get a firm answer on.

15 COMMISSIONER HENDRIE: Well, it is part of the
16 proposed analysis and discussion.

17 CHAIRMAN AHEARNE: That completes your
18 presentation. OPE had sent us a paper commenting on this
19 particular 399. I wonder, Ed, if your chairman --

20 COMMISSIONER GILINSKY: I have a question which I
21 would like to ask if I may. Do you want to take them first?

22 CHAIRMAN AHEARNE: Yes. This is a counterpoint,
23 and then I thought we would get to the --

24 COMMISSIONER GILINSKY: It is just a simple
25 factual question.

1 CHAIRMAN AHEARNE: Oh, go ahead.

2 COMMISSIONER GILINSKY: What, in requiring Mark I
3 and Mark II's to inert, do you have somewhere in the back of
4 your mind some equivalent percentage of metal-water reaction
5 at which you are drawing the line? In other words, how do
6 you translate that requirement? Does that mean you are
7 basically sticking with the 5 percent requirement or what?

8 MR. ROSS: Well, that 's all we would have to do.
9 That would be enough to produce the requirement. The 5
10 percent would be. But the Mark II is a bit --

11 COMMISSIONER HENDRIE: No, no, but once they are
12 inerted why they can go ahead and have themselves a 100
13 percent metal-water reaction and as far as hydrogen problems
14 are concerned, why it is just an additional gas in the
15 containment. It adds the pressure, but you aren't going to
16 burn it or --

17 COMMISSIONER GILINSKY: No, no, but I mean in
18 reaching the decision to inert, you are --

19 MR. ROSS: We didn't go through the numerical
20 exercise you are talking about. It was more on a value
21 impact basis that --

22 COMMISSIONER GILINSKY: Well.

23 MR. ROSS: In other words, we didn't do a
24 calculation that says we are going to get 6 percent
25 hydrogen, you had better inert or you are going to lose the

1 containment. e rather did it on one note, how to inert,
2 and it has been done reasonably successful and doesn't cost
3 much money.

4 Impending a long-term decision --

5 COMMISSIONER GILINSKY: But isn't there along with
6 that, and if you don't inert, if you get X percent
7 precisely, as you said, you are going to get into trouble?

8 MR. ROSS: Yes, in the original SECY-107 paper we
9 sent up here we showed how quickly the Mark I got to a --
10 for certain stylized access, how quickly it got to
11 combustible, and then a detonable range. It is very quick.

12 COMMISSIONER GILINSKY: And it is on the order of
13 5 percent or is it 1 percent, is it 10 percent?

14 MR. ROSS: Well, I know it is combustible. It is
15 a few percent. It is 3 or 4, right?

16 COMMISSIONER HENDRIE: Yes, a few percent.

17

18

19

20

21

22

23

24

25

Rec'd
3

1 MR. NORBERG: It's very, very quick. It's like
2 less than 5 percent. You get to the combustible, the 4
3 percent volume range of hydrogen. But you get -- the other
4 calculation that was done by the staff is to look at if you
5 burned this hydrogen then where would the containment fail.
6 And that's somewhere around a 10 percent fuel clad reaction,
7 if the hydrogen burns that has been released.

8 COMMISSIONER GILINSKY: So the (WORDS
9 UNINTELLIGIBLE) design pressures is still around 5 percent?

10 MR. ROSS: It looks like 4 percent, roughly,
11 metal-water reaction would -- well, 5 percent, roughly,
12 metal-water reaction gives about 7 percent containment
13 hydrogen concentration.

14 MR. NORBERG: Five percent for design pressure,
15 nine percent for failure is what they're asking for.

16 MR. ROSS: Yeah. But I was trying to convert this
17 amount from hydrogen concentration to corewide metal-water
18 reaction. A few percent, 3, 4 percent, brings you up to
19 combustible levels.

20 MR. HANRAHAN: But my disagreement is with the
21 decision rationale for Mark I and Mark II containments. You
22 have no other problem with the paper as presented. The
23 rationale as given is one of a small decrease in risk at
24 small cost; counterbalancing that, the ice condenser side,
25 you could have a greater decrease in risk, but the costs are

1 high, in this case that you may have a reduction in safety
2 from other aspects, but nothing in lieu of an adding is
3 suggested for ice condensers. Indeed, it's been concluded
4 that because of safety improvements associated with the
5 implementation of Lessons Learned, hydrogen control
6 requirements beyond those satisfying 10 CFR 50.44 are not
7 required, pending completion of the rule-making. And I
8 would just argue that the Mark I and Mark II that are not
9 inerted would fall into that same, logically fall into the
10 same category, by the staff's own arguments.

11 There were arguments presented by others, both in
12 favor of immediate inerting and not in favor of inerting, by
13 General Electric and others, which haven't presented
14 themselves here, either; and I would have thought some
15 discussion of those would have balanced the, or supported or
16 not supported the case here.

17 So I find it bad policy to impose a requirement
18 simply because it may have a small cost and a small
19 benefit. Even the ratio may be one, the cost/benefit ratio
20 may be one, it doesn't follow that that's necessarily a good
21 thing to do.

22 COMMISSIONER GILINSKY: So where are you coming
23 out?

24 MR. HANRAHAN: Not requiring that inerting,
25 pending rule-making -- take it up as part of the rule-making.

1 COMMISSIONER GILINSKY: But we're talking about a
2 rule-making that's going to take years.

3 MR. HANRAHAN: But, you know, we ought to discuss
4 these --

5 COMMISSIONER GILINSKY: I mean years and years. I
6 mean, this is going --

7 MR. HANRAHAN: Before that we weren't even -- we
8 were on the verge of coming into de-inert all over those
9 containments.

10 COMMISSIONER GILINSKY: I know that. But here we
11 just experienced an accident in which -- well, the numbers
12 are a little uncertain, but, at least, the going number is
13 something on the order of 50 percent metal-water reaction.
14 We've got a rule that fixes the number that we protect
15 against at something on the order of 5; in fact, it seems as
16 a practical matter less than 5. What we're talking about
17 here is going back to maybe 5. You're saying we oughtn't
18 even to do that. I'm horrified that we're stopping at 5,
19 that we're not trying to do more.

20 CHAIRMAN AHEARNE: Would you inert Sequoyah and
21 the other ice condenser?

22 COMMISSIONER GILINSKY: Well, it seems that those
23 are pretty difficult to inert. And I'm not prepared to --
24 well, let me put it this way. I think we have got to have
25 some means to deal with larger amounts of hydrogen than are

1 talked about here.

2 I just don't think we can let this thing go and to
3 be something we're just going to study for years and years
4 and have comments on and, you know, rounds of proposed rules
5 and hearings, and this is going to take a very long time to
6 come down on the whole degraded core question. It's a very
7 complex matter. And I think this aspect of it is something
8 that we need to do on a shorter time scale.

9 I think I've expressed that to you before, so it's
10 not going to surprise you that that is my view.

11 CHAIRMAN AHEARNE: I guess, though, what I think
12 the OPE point is, that just as a basic regulatory policy do
13 we have a better argument than the decrease in risk is small
14 but since the cost is also small that we ought to do it.
15 And that's really the question that --

16 MR. HANRAHAN: I think that what was presented in
17 the paper didn't sustain the argument. In fact, what's been
18 argued is that actions have been taken to reduce the risk of
19 the TMI type of hydrogen release.

20 COMMISSIONER GILINSKY: It depends -- here I think
21 I'm with NRR -- it depends on how much weight you attach to
22 these probability estimates that have been generated and to
23 what extent you want to rely on them for your regulations.
24 I think they're useful for some purposes, but they're still
25 at this point rather tentative calculations, and there are

1 just certain rules or standards you need to impose on the
2 basis of experience and just common sense. There's certain
3 notions about containments that don't flow directly from
4 probability arguments but, I think, just sound experience.

5 You know, you're basically having to decide here
6 whether you're going to rely on calculations of some person
7 in the research office or you're going to take account of
8 what happened last year. And to my mind -- I haven't seen
9 these calculations and I don't want to -- my impression is
10 that there's a certain amount of uncertainty attached to
11 them, and I don't think you can use them to cancel out a
12 fairly strong experience.

13 CHAIRMAN AHEARNE: Well, I don't think anyone is
14 -- I guess other people -- and I'm not sure where I will
15 come out -- but I would say that it's not to take account of
16 what some research calculator did and forget what happened
17 last year. I think all of us are trying to use experience
18 and common sense and to pull together what happened last
19 year and what is available in the way of calculations,
20 including those on the design strengths and the burn rates
21 and et cetera and then reach a conclusion. It's a -- as you
22 pointed out earlier, it is a complex issue. And I --
23 perhaps for some -- perhaps you have now, as you say, you, I
24 think you have seen a clear path that you believe we ought
25 to follow. I'm not sure I quite see the path as clearly.

1 Denny or Mr. Norberg, would you care to make any
2 comments on Ed's point? Or do you believe Commissioner
3 Gilinsky has answered it well?

4 MR. ROSS: Well, I think it's clear from the
5 collection of papers we've sent up that I felt processors on
6 Mark I or II were not particularly dominated by what the
7 risk studies showed. In fact, we seemingly flew in the face
8 of them, I would say.

9 One thing that we did not include, however, which
10 is -- which we discussed from time to time, is how would we
11 explain to a mother-in-law or a congressman who happened to
12 live in Baxley, Georgia, why that plant is inerting and that
13 one isn't, when they're both the same plant. That, you
14 know, we did discuss things like that, and it seems, you
15 know, I'm coming back to the consistency argument now, which
16 I --

17 COMMISSIONER HENDRIE: Steady now.

18 (Laughter)

19 MR. ROSS: -- which I threw rocks at a few minutes
20 ago.

21 COMMISSIONER HENDRIE: You start hiking up that
22 path and you're going to fall in the tiger pit before you
23 get 20 feet up it.

24 MR. ROSS: Well, I'm only at Baxley, Georgia,
25 looking at those two plants, and I can't see any further

1 than that right now.

2 COMMISSIONER HENDRIE: I wouldn't get outside
3 Baxley, if I were you. You're not going to like the results.

4 Look, there's a -- Bob, let me -- and then we'll
5 get you.

6 There's another aspect to this which hasn't --
7 which doesn't appear in the interim rule papers. The
8 rationale as presented in the interim rule papers is -- let
9 me do it considerable violence, okay? -- we'd better -- it
10 is, we ought to do something and we ought to do it in a
11 hurry; it's going to take a longer time to understand
12 everything that we might want to do and to have a
13 coordinated and sort of optimized approach to degraded core
14 matters. And there are all kinds of deep regulatory
15 questions about whether it should be in the design basis or
16 in addition to the design basis, et cetera. So I feel a
17 need to do something in a hurry.

18 Now, some of the things that I want to do in a
19 hurry are already being done out there, by virtue of orders;
20 and if we didn't have this particular rule-making coming
21 down the pike, why, I don't know as we'd particularly feel a
22 need for a rule for those things. They're, already have
23 been ordered on plants and they're being done.

24 Okay. There are some other things that are not
25 being done in the way you'd like them, some of the hydrogen

1 analysis work and related things. And then there's this
2 question of the Mark I's and II's. Here the containment's
3 at the small end of the volume scale of containments, the
4 most sensitive from a hydrogen standpoint. We've got 20 of
5 them out there operating; 18 of the 20 are inerted, two
6 aren't, and we've got a batch coming down the line. It just
7 seems like why don't we go ahead and inert those things on
8 the gut feeling that it seems like a good idea and it all
9 packages together with this thing we need, feel the need to
10 do in a hurry.

11 Now, as Ed points out, that isn't an especially
12 stunning line of logic from the standpoint of careful and
13 logical regulatory practice. And if those were the only
14 arguments, why, I think, I guess, I'd end up, as I think I
15 did once before, on the 107 paper, saying, "Wait a minute.
16 Let's understand better where we're going overall." But
17 there is another aspect to it and that's the following.

18 It seems to me that we are going to end up, sooner
19 or later, with plant features, whether they're in the design
20 basis or in a supplementary category, which will allow all
21 of these plants to ride out metal-water reaction at
22 substantially better than 5 percent. And I won't tell you
23 whether I'm going to end up voting, you know, for 20 or 30
24 or 40 or 50 or whatever you like, but I'm pretty sure it's
25 going to be more than 5 percent.

1 If it is more than 5 percent, then these small
2 containments are going to have a big problem. And I think
3 for them, because the Mark I's have been built so that they
4 could -- since, you know, since '67, or something like that,
5 '66, have been arranged so that they could be inerting, in
6 view of where instrument locations are and other equipment
7 that needs maintenance; similarly for the Mark II's, as far
8 as I know. It seems to me that these small containments
9 will find it easiest to deal with whatever eventual level of
10 hydrogen we require by inerting rather than by cranking up
11 halon systems and igniters and God knows what all.

12 Now, if they're going to have to inert, or going
13 to end up inerting in, you know, if I -- I guess, I come
14 around and say, jeez, if Vermont and HATCH-2 are going to
15 end up having to inert in two years off the degraded core
16 rule-making, I don't know as we've gained a great deal by
17 not getting them started on it now. Similarly, I guess, if
18 that's where the Mark II's that will start coming in pretty
19 quick are going to end up, they may as well get on about it.

20 So I've come, for myself, to a grudging agreement
21 with the staff thrust on this interim rule, proposed rule,
22 with regard to the Mark I's and II's, not for the reasons
23 the staff gives particularly in this paper, but just because
24 I'm looking down the road and I don't see much place else
25 for these small containments to go within any reasonable

1 range of outcomes of the degraded core rule-making which is
2 to come. So that's what drives me.

3 I think the ice condensers in Mark III's do have a
4 sufficient capability so one can hold on until the outcome
5 of that rule-making.

6 COMMISSIONER GILINSKY: But, of course, even there
7 you're, I mean, on the Mark I's and II's you're also flying
8 in the face of these probability estimates, which, I assume,
9 take account of larger --

10 COMMISSIONER HENDRIE: Yeah.

11 COMMISSIONER GILINSKY: -- (WORD UNINTELLIGIBLE)
12 and water fractions.

13 COMMISSIONER HENDRIE: That's right. What they're
14 saying, what the probability calculations are saying, in
15 effect, is that if you get certain accident scenarios going
16 which are going to give you a lot of hydrogen and a problem
17 in the small containment, they're going to give you a
18 problem in that containment because you've lost, because
19 part of the sequence is loss of containment heat removal or
20 whatever and you're going to breach the containment anyway,
21 from causes other than a hydrogen burn, just over-pressure,
22 just brute not taking the energy out fast enough, and that
23 the incremental advantage you get then by not having a
24 hydrogen burn, there's some but it's not dominant as we now
25 calculate the sequences.

1 That very well -- that aspect of the probability
2 calculations may very well dictate, and I think it is likely
3 to dictate, rather strongly increased requirements on
4 containment heat removal capability and redundancy and
5 redundancy of the power supply and heat sink and so on down
6 the line as part of the degraded core process, because not
7 only for small containments but also for the big ones, I
8 think, we're going to find that a significant fraction of
9 those scenarios that lead to real severe releases,
10 containment breaches and severe releases, could be
11 controlled if you didn't have containment heat removal
12 failure, because, I think, most of those scenarios have as
13 an essential part of the scenario that something happens and
14 you lose your ability to take the energy out of the
15 containment. If you can take the dam after-heat out of the
16 containment as it's generated and then -- and -- and cool on
17 down, you'll come a long way toward those situations even
18 with a meltdown, where, I think, you keep the core inside
19 even though it may be totally in debris.

20 So I think that those heat removal requirements,
21 we are going to find those very worthwhile to upgrade; in
22 fact, my guess at the moment is that that's going to be a
23 sort of a best buy for public safety and that we'll come
24 eventually to that decision.

25 So I think down the line, then, you're likely to

1 see containment heat removal upgrading required across the
2 board. But having done that -- and if you do that, why,
3 then the importance of not burning the hydrogen in these
4 small containments will then jump up and become much more
5 significant in terms of the risk assessment sort of
6 calculations.

7 COMMISSIONER GILINSKY: Now, I'm not sure --

8 COMMISSIONER HENDRIE: So I don't mind insetting
9 them now.

10 COMMISSIONER GILINSKY: It seems to me that in the
11 past the whole hydrogen problem got short shrift in part
12 because there was a feeling that if you get that far you'll
13 -- that it's probably an accident that is leading to a core
14 melt and you've got all kinds of other things to worry about.

15 COMMISSIONER HENDRIE: Yes.

16 COMMISSIONER GILINSKY: And it turned out at Three
17 Mile Island we discovered that there's a fairly wide range
18 -- in other words, there's an intermediate range of
19 accidents which involve core damage but not yet core
20 melting, and those --

21 COMMISSIONER HENDRIE: Well, I -- that's right.

22 COMMISSIONER GILINSKY: -- accidents happen to
23 involve generation of hydrogen.

24 COMMISSIONER HENDRIE: That's right. I think our
25 guess before Three Mile would have been that that range,

1 measuring the -- measure -- using the parameter metal-water
2 reaction would have been of the order of, I don't know,
3 something like 10, 15 percent, and if it went over that,
4 why, you were gone to hell and just weren't going to save
5 it. I can remember that kind of discussion back in Reg
6 Guide 1.7 revision days. And what's clear from Three Mile
7 Island is that these cores are tougher than we would have
8 guessed and that if you can manage to keep some steam
9 circulation going up into them, why, they'll produce a lot
10 of hydrogen but they may outlive some pretty severe
11 treatment.

12 Now, what that suggests is that hydrogen
13 mitigation measures assume probably more importance in the
14 overall scale of things than we would have thought before
15 And I think, indeed, there is a substantial range of core
16 damage, heavy core damage, beyond the design basis, in which
17 you'll still be, you still won't go to a full core melt and
18 loss of all cooling situation, but you are likely to get a
19 lot of hydrogen.

20 COMMISSIONER GILINSKY: What surprises me is that
21 in the past, when we thought that the amount of hydrogen
22 that could be generated was rather small, we took
23 considerable precautions against that, and even though the
24 ECCS code said 1 percent or effective percent, you said,
25 "Never mind, this is serious business, you got to multiply

1 by five, and you got a standard design pressure because we
2 want to have a safety margin there, so altogether you're
3 talking about a safety margin of something like a factor of
4 10. And you want to stay below flammability limits," and so
5 on. And now that we know that the amount of hydrogen that
6 can be generated can be very much larger than that, we're
7 saying, "Well, we can wait years to study the problem and
8 think about it, and it's not really a pressing matter."

9 CHAIRMAN AHEARNE: Wait. That's not quite -- Vic,
10 that could be clearly the interpretation to be put on it;
11 and if you desire you can. But there's another
12 interpretation, which might also be wrong, and that is that
13 previously many times -- and I'm not that familiar with the
14 way nuclear reactor regulation works, I'm a lot more
15 familiar with the way analysis works -- that when you are
16 trying to make a case for something you take a conservative
17 estimate or a worst-case analysis and you multiply those
18 factors together, as long as you know you're within some
19 general envelope. And so adding on a factor of five, or
20 adding on a factor of two, while you still were able to
21 contain within the basic framework of the design, may have
22 been viewed as a conservatism which is now being abandoned;
23 on the other hand, it could be viewed as a conservatism
24 which was not significant. Now, you -- in the situation
25 you're in, you're multiplying -- you're taking generation

1 rates and pressures which are now at the driving point of
2 the design, and so one -- as opposed to saying that, well,
3 we'll just, we're not going to take it seriously and we'll
4 wait several years, I think, on the other hand, what it
5 really says is, since you're now going to talk about making
6 major impact upon either operation or design of the systems,
7 that you have to be a little bit more confident that you
8 know what you're doing than you were, could have been, when
9 you were making conservative assumptions that weren't going
10 to drive the system.

11 COMMISSIONER GILINSKY: Well, I think we want to
12 know what we're doing, yes; and I assume that. But the fact
13 remains that there was that factor of 10, you multiplied the
14 amount of generation that you thought might be there, then
15 you multiplied by five, and now we're dividing by five. And
16 whereas before we were talking about holding at design
17 pressures, now we're talking about failure pressures.

18 I guess I think there is more urgency attached to
19 this problem than I have seen evidence of here today.

20 CHAIRMAN AHEARNE: Do you have any questions?

21 COMMISSIONER GILINSKY: I think I have exhausted
22 my immediate questions.

23 CHAIRMAN AHEARNE: Joe?

24 COMMISSIONER HENDRIE: Yeah, I've got a question.
25 Did I read correctly that if one cranks a proposed 50.44(c)

1 out that says notwithstanding the above inert Mark I's and
2 II's wherever they may be, that there's a January 1st, '81,
3 deadline date on it?

4 MR. ROSS: I think we mentioned earlier that on
5 the dates that we were having a clarification package coming
6 down soon, and those dates we would expect to be dominant
7 over the dates in the proposed rule. The dates in the
8 proposed rule will need changing. They were good a few
9 months ago when we were drafting up the proposal. But
10 events have somewhat overtaken it.

11 COMMISSIONER HENDRIE: Yeah, well, I recommend
12 attention --

13 SPEAKER: Yes, it says that in the proposal.

14 COMMISSIONER HENDRIE: Well, that's what I thought
15 it said. And now this is Labor Day and 30 days' comment and
16 a month to get it out of here for comment and, you know,
17 you're going to publish, at best, a little after
18 Thanksgiving and give them 30 days to put all that stuff in
19 place, and I don't think that's going to wash, unless you
20 want to start writing exemptions right off the bat.

21 MR. ROSS: Well, but the 1/1/81 appears many
22 places in the draft.

23 COMMISSIONER HENDRIE: Yes, but, at least, a
24 number of the other places, it's on provisions which were
25 ordered to be done six, eight months, a year ago, even, and

1 so there's been some forward motion, I presume. But I --
2 okay, dates to be adjusted.

3 (Pause)

4 CHAIRMAN AHEARNE: Okay, then I think without --
5 since there are no further questions, I guess the issue is,
6 we have in front of us a staff proposal to put out a
7 proposed rule. And what is your pleasure?

8 COMMISSIONER GILINSKY: Well, I guess I would not
9 approve it.

10 CHAIRMAN AHEARNE: Pardon me?

11 COMMISSIONER GILINSKY: I would not approve it.

12 CHAIRMAN AHEARNE: You would not. Would you
13 perhaps, at least, to help me, would you -- is that that you
14 disagree with it or you're not ready to vote on it? Or --

15 COMMISSIONER GILINSKY: I disagree with it.

16 CHAIRMAN AHEARNE: All right. Joe?

17 COMMISSIONER HENDRIE: I'd put it out for 30 day
18 comment as recommended as soon as we get the adjusted dates
19 which the staff thinks appropriate to a time frame, with
20 publication in the Federal Register, say, the end of
21 September.

22 CHAIRMAN AHEARNE: Peter?

23 COMMISSIONER BRADFORD: Well, let's see, I'd --
24 there are aspects of the hydrogen control question that are
25 still of considerable concern. But I don't have, I think,

1 any difficulty with putting this out for comment in the form
2 it's in now. We're going to have to grapple with hydrogen
3 control in a number of areas, but it doesn't seem to me that
4 putting this out for comment prejudices those.

5 CHAIRMAN AHEARNE: Before I vote, Vic, could you
6 explain what it is that you don't like about the rule? I am
7 surprised, because I thought you were in favor of this.

8 COMMISSIONER GILINSKY: Well, I would have a rule
9 that -- I mean, I'm in favor of the part of it that I think
10 I said I was in favor of, the inserting the Mark I's and Mark
11 II's, but I would go further and I would require that
12 reactors demonstrate a capability to deal with amounts of
13 hydrogen roughly of the order of those that were generated
14 at Three Mile Island.

15 So I agree with it as far as it goes.

16 CHAIRMAN AHEARNE: You don't think it goes far
17 enough.

18 COMMISSIONER GILINSKY: I don't think it goes far
19 enough.

20 COMMISSIONER BRADFORD: But do you see the
21 publication of this rule as prejudicing the Commission's
22 ability to impose a requirement like that?

23 COMMISSIONER GILINSKY: Well, I think so. If this
24 rule only dealt with Mark I's and Mark II's, then it would
25 be fine -- if we were just dealing with Mark I's and Mark

1 II's. But insofar as you're dealing with hydrogen control
2 for all reactors, then, I think, you're coming down and
3 saying that you think we need to deal with Mark I's and Mark
4 II's but we can leave the others as an exercise for the
5 student. And --

6 CHAIRMAN AHEARNE: Gentlemen, would you care to --
7 I'd agree with you if we were adopting it, but I don't know
8 that --

9 MR. MINOGUE: I was going to make a remark to
10 something (WORDS UNINTELLIGIBLE) I think it's important to
11 realize there's a lot more in this, there's a lot more in
12 this regulation, than we're proposing in the question of
13 inerting one capacity of containment or another. There are
14 a number of measures in here that are intended to deal with
15 an accident of high probability, an accident in which you
16 had extensive damage to the core resulting in release of
17 radioactivity and generation of hydrogen. We ought to be
18 prepared to take steps now to make sure that the plants that
19 are operating now or about to be licensed can handle that
20 kind of accident.

21 I know it's very glamorous to talk about all these
22 very extreme accidents and talk about risks and meltdown and
23 so on. I'm trying to deal in this rule with something much
24 more direct and much more pertinent -- the high probability
25 that one of these plants will have a degraded cooling

1 situation in which the core will be damaged and release
2 hydrogen and release radioactivity. We ought to be able to
3 handle that with the present plants.

4 What this rule has in it is the staff's best
5 judgment, after very careful study, of measures that can be
6 taken now with assurance that they do a lot of good.

7 I think we also all recognize that there's a much
8 bigger question, it's the one that Commissioner Gilinsky
9 keeps referring to, and I'm certainly going to be the last
10 one that says that shouldn't be addressed. But that one's
11 big, it's complex, it goes through the whole range,
12 including core melt. We don't know exactly how we're going
13 to deal with that, and we have to do that more
14 deliberately. But while we're doing it deliberately, we
15 should do something about the plants we have out there now.

16 MR. ROSS: I think if you asked us about licensing
17 strategy, should we scrap the plants to promulgate an NM
18 rule, I think the net effect would probably be fairly
19 small. If we, indeed, are going to order plants, pursuant
20 to the clarification letter after the round of meetings, to
21 do substantially what's in the rule, if that's what you do,
22 or whoever the issuing order authority is, then that lays on
23 these requirements one way or the other.

24 As far as ice condensers, we're headed down a
25 case-specific route, and as we discussed at the last

1 meeting, we now have written comments in the McGuire
2 instance to do substantially what is being done in
3 Sequoyah. So whatever the Commission wants to do on ice
4 condensers, it can do there.

5 The only thing that is left undone as a result of
6 not issuing a rule is Vermont Yankee and HATCH; that's left
7 undone. If we want to, if the Commission wants to do that,
8 it has other ways of doing that also.

9 CHAIRMAN AHEARNE: I guess where I come out is --
10 and it is a puzzle, a very complex problem of how to address
11 this hydrogen concern and what to do about the designs --
12 I'm confused a little bit by, Vic, by at the one hand I
13 thought you were saying is if we don't address the I's and
14 II's in this way, that shows that we're willing to wait for
15 years, but the other hand, here are a bunch of other items
16 that we're -- that, as Bob Minogue tried to point out, we're
17 trying to lay on, which we could go ahead and do; it doesn't
18 mean that we aren't going to still try to wrestle with that
19 larger question, but we aren't yet there, we don't know what
20 the right answer -- how to lay on those requirements. So I
21 would guess that using your admonition to remember what has
22 happened, and reluctant as I am to go into the inerting of I
23 and II, primarily from the basis that I don't share with you
24 and Joe the long-term historical having gone through these
25 previous issues, you were part of these, the existing

1 regulatory development, and so you have a better intuitive
2 grasp of these, analytically I don't think the case has
3 really yet been made to do something to I and II and not do
4 something to III and ice condensers. But I am certainly
5 willing to put this out for public comment. That's what I
6 would say.

7 So, on that basis, I guess it goes out for public
8 comment.

9 COMMISSIONER HENDRIE: Get the dates fixed and --

10 CHAIRMAN AHEARNE: Thank you.

11 But before we leave, we still have a couple of --
12 thank you, gentlemen. And if the room could sort of exit
13 quietly, the Commission has a couple of affirmation items to
14 still get to.

15 (Whereupon the public meeting was adjourned.)

16

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the
Commission Meeting

Public Meeting - Discussion of SECY-80-399 Proposed
in the matter of: Interim Amendments to Part 50 Related to Hydrogen
Control and Certain Degraded Core Considerations
Date of Proceeding: September 4, 1980

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript
thereof for the file of the Commission.

Suzanne R. Babineau

Official Reporter (Typed)

Suzanne Babineau

Official Reporter (Signature)

POOR ORIGINAL

BASIS FOR PROPOSED INTERIM RULE ON
HYDROGEN CONTROL AND CERTAIN DEGRADED CORE CONSIDERATIONS

- NUREG-0578 - TMI-2 LESSONS LEARNED TASK FORCE STATUS REPORT
AND SHORT-TERM RECOMMENDATIONS - JULY 1979

- NUREG-0585 - TMI-2 LESSONS LEARNED TASK FORCE FINAL REPORT -
OCTOBER 1979

- FOLLOWUP ACTION RESULTING FROM THE NRC STAFF REVIEWS REGARDING
THE TMI-2 ACCIDENT
LETTERS TO LICENSEES - SEPT. 13, 1979

- REGIONAL MEETINGS WITH LICENSEES TO CLARIFY LETTERS - WEEK
OF SEPT. 24, 1979

- DISCUSSION OF LESSONS LEARNED SHORT-TERM REQUIREMENTS
LETTER TO LICENSEES - OCT. 30, 1979

- NUREG-0660 - TMI-2 ACTION PLAN - MAY 1980

- SECY-80-107 & SUPPS. - PROPOSED INTERIM HYDROGEN CONTROL
REQUIREMENTS FOR SMALL CONTAINMENTS

MAJOR ASPECTS OF INTERIM RULE

- INFORMATION AND DECISION MAKING
- IN-PLANT RADIOACTIVITY CONSIDERATIONS
- HYDROGEN MANAGEMENT

INFORMATION AND DECISION MAKING

- TRAINING TO MITIGATE DEGRADED CORE ACCIDENTS
- DETECTION OF INADEQUATE CORE COOLING
- ACCIDENT MONITORING INSTRUMENTATION
- SAMPLING DURING AND FOLLOWING AN ACCIDENT
- IN-PLANT IODINE INSTRUMENTATION

IN-PLANT RADIOACTIVITY CONSIDERATIONS

- PROTECTION OF SAFETY EQUIPMENT AND AREAS WHICH MAY BE USED DURING AND FOLLOWING AN ACCIDENT
 - PROTECTION OF SAFETY EQUIPMENT AGAINST DEGRADATION BY RADIATION
 - RADIATION PROTECTION TO ASSURE NEEDED ACCESS OF OPERATORS TO VITAL AREAS

- LEAKAGE INTEGRITY OUTSIDE CONTAINMENT
 - LEAKAGE OF HIGHLY RADIOACTIVE FLUIDS OUTSIDE CONTAINMENT TO BE ELIMINATED OR MINIMIZED TO MAXIMUM EXTENT PRACTICABLE

HYDROGEN MANAGEMENT

- INERTING OF MARK I & II BWRs

- DESIGN ANALYSES FOR MEASURES TO HANDLE LARGE AMOUNTS OF HYDROGEN
 - A. MARK III BWRs
 - B. ALL PWRs

- DEDICATED PENETRATIONS FOR PLANTS THAT RELY UPON EXTERNAL RECOMBINERS OR PURGE SYSTEMS

- EXTERNAL RECOMBINER CAPABILITY FOR ALL PLANTS THAT RELY UPON PURGE SYSTEMS

- HIGH POINT VENTS IN PRIMARY COOLING SYSTEM

RATIONAL FOR HYDROGEN MANAGEMENT
POSITION IN INTERIM RULE

- INERTING OF MARK I & II BWRs
 - SMALL VOLUME
 - DESIGNS PERMIT INERTING
 - SATISFACTORY OPERATING EXPERIENCE

- ICE CONDENSERS AND MARK III BWRs
 - INTERMEDIATE VOLUME
 - NOT DESIGNED FOR INERTING

- LARGE DRY CONTAINMENTS
 - LARGE VOLUME
 - HIGH PRESSURE DESIGN