BIG ROCK POINT

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(2) LICENSEE CODE: M I B R P 1 — LICENSE NUMBER: 0 0 - 0 0 0 0 - 0 0 — LICENSE TYPE: 4 1 1 1 1 — CAT: (3) (4) (5)

CON'T

REPORT SOURCE: L (6) — DOCKET NUMBER: 0 5 0 - 0 1 5 5 (7) — EVENT DATE: 0 8 2 0 8 0 (8) — REPORT DATE: 0 9 1 2 8 0 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

Following intermittent automatic test circuit alarms, the sensor Channel D of the Reactor Depressurizing System was removed from service to vent the reactor water level transmitter LT3183. All four RDS loops remained operable for this condition with 2/3 logic instead of 2/4. No hazard occurred and the equipment was restored to operable status within 4 hours per Tech Spec 11.3.1.5.3. Similar to RO-80-25. Reportability based on Tech Spec 6.9.2.b(2).

SYSTEM CODE: S H (11) — CAUSE CODE: X (12) — CAUSE SUBCODE: Z (13) — COMPONENT CODE: Z Z Z Z Z Z (14) — COMP. SUBCODE: Z (15) — VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER — EVENT YEAR: 8 0 — SEQUENTIAL REPORT NO.: 0 2 6 — OCCURRENCE CODE: 0 3 — REPORT TYPE: L — REVISION NO.: 0

ACTION TAKEN: E (18) — FUTURE ACTION: X (19) — EFFECT ON PLANT: Z (20) — SHUTDOWN METHOD: Z (21) — HOURS (22): 0 0 0 0 — ATTACHMENT SUBMITTED: N (23) — NPRD-4 FORM SUB.: N (24) — PRIME COMP. SUPPLIER: Z (25) — COMPONENT MANUFACTURER: Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

In addition to minor conservative calibration shift occurring in the reactor water level transmitter, the setpoint for reactor low level is unduly conservative. A Technical Specification change request was submitted on 8/25/80 to provide greater margin in the trip setpoint.

FACILITY STATUS: E (28) — % POWER: 0 6 5 (29) — OTHER STATUS (30): N/A — METHOD OF DISCOVERY: A (31) — DISCOVERY DESCRIPTION (32): Operator observation of alarm

ACTIVITY RELEASED: Z (33) — CONTENT OF RELEASE: Z (34) — AMOUNT OF ACTIVITY (35): NA — LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES — NUMBER: 0 0 0 (37) — TYPE: Z (38) — DESCRIPTION (39): NA

PERSONNEL INJURIES — NUMBER: 0 0 0 (40) — DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (43) — TYPE: Z (42) — DESCRIPTION: NA

PUBLICITY — ISSUED: N (44) — DESCRIPTION (45): NA

NRC USE ONLY

POOR ORIGINAL

8009190124