

NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20656

THE TOLEDO EDISON COMPANY

AND

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

DOCKET NO. 50-346

DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 31 License No. NPF-3

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Toledo Edison Company and The Cleveland Electric Illuminating Company (the licensees) dated August 22, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

ATTACHMENT TO LICENSE AMENDMENT NO. 31

FACILITY OPERATING LICENSE NO. NPF-3

DOCKET NO. 50-346

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Pages

3/4 6/19

3/4 6/22

TABLE 3.6-2 CONTAINMENT ISOLATION VALVES (Continued)

PENE		N VALVE NUMBER	FUNCTION	ISOLATION TIME (seconds)
	67	CV5090	Hydrogen Dilution System Supply	60
	68A	SS235A	Pressurizer Quench Tank Sample	30
	68A	SS235B	Pressurizer Quench Tank Sample	30
	68B	CV5010B	Containment Air Sample	15
	68B	CV5011B	Containment Air Sample	15
	69	CV5065	Hydrogen Dilution System Supply	60
	71B	CV5010A	Containment Air Sample	15
	71B	CV5011A	Containment Air Sample	15
	710	CV1544	Core Flood Tank N2 Fill	10
	73B	CV5010C	Containment Air Sample	15
	73B	CV5011C	Containment Air Sample	15
	74B	CV5011D	Containment Air Sample	15
	74B	CV5011D	Containment Air Sample	15
В.	CONTA	AINMENT PU	RGE AND EXHAUST ISOLATION	
	33 ##	CV5005	Containment Vessel Purge Inlet Line	10
	33 ##	CV5006	Containment Vessel Purge Inlet Line	10
	34 ##	CV5007	Containment Vessel Purge Outlet Lin	ie 10
	34 ##	CV5008	Containment Vessel Purge Outlet Lin	ne 10
С.	OTHER	R		
	5 #	SW1366	Containment Air Cooling Units SW Inlet Line	N/A
	6 #	SW1368	Containment Air Cooling Units SW Inlet Line	N/A
	7 #	SW1367	Containment Air Cooling Units SW Inlet Line	N/A
	9 #	SW1356	Containment Air Cooling Units SW Outlet Line	N/A

TABLE 3.6-2 CONTAINMENT ISOLATION VALVES (Continued)

PENETRATIO NUMBER	N VALVE NUMBER	FUNCTION	ISOLATION TIME
*29 #	DH11	Decay Heat Pump Suction Line	N/A
*29	DH23	Decay Heat Pump Suction Line	N/A
29 #	PSV4849	Decay Heat Pump Suction Line	N/A
35 #	AF599	Auxiliary Feedwater Line	N/A
36 #	AF608	Auxiliary Feedwater Line	N/A
*39 #	MS107	Main Steam Line	N/A
*39 #	MS107A	Main Steam Line	N/A
*40 #	MS106	Main Steam Line	N/A
*40 #	MS106A	Main Steam Line	N/A
41	RC113	Pressurizer Quench Tank Inlet Line	N/A
42A	SA502	Service Air Supply Line	N/A
428	CV124	Containment Vessel Air Sample Return	N/A
43A	IA501	Service Air Supply Line	N/A
438	CV125	Containment Vessel Air Sample Return	N/A
44A	CF15	Core Flood Tank Fill and Nitrogen Supply Line	N/A
448	NN58	Pressurizer Quench Tank Inlet Line	N/A
*47A	CF2A	Core Flood Tank Sample Line	N/A
*47A	CF2B	Core Flood Tank Sample Line	N/A
*47B	CF5A	Core Flood Tank Vent Line	N/A
*47B	CF5B	Core Flood Tank Vent Line	N/A
49	DH87	Refueling Canal Fill Line	N/A
49	DH88	Refueling Canal Fill Line	N/A