CONTAINMENT SYSTEMS

CONTAINMENT COOLING SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.2.3 Two independent containment cooling groups shall be OPERABLE with at least one operational cooling unit in each group.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- a. With one group of the above required containment cooling units inoperable and both containment spray systems OPERABLE, restore the inoperable group of cooling units to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With two groups of the above required containment cooling units inoperable and both containment spray systems OPERABLE, restore at least one group of cooling units to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. Restore both above required groups of cooling units to OPERABLE status within 7 days of initial loss or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With one group of the above required containment cooling units inoperable and one containment spray system inoperable, restore the inoperable spray system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. Restore the inoperable group of containment cooling units to OPERABLE status within 7 days of initial loss or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- d. With any cooling unit of the above required groups inoperable because its associated fan is inoperable, verify that the OPERABLE cooling unit in that group has a service water flow rate > 1250 gpm through its cooling coils or restore the inoperable cooling unit to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

ARKANSAS - UNIT 2

3/4 6-14

8009260456

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS

- 4.6.2.3 Each containment cooling group shall be demonstrated OPERABLE:
 - a. At least once per 14 days by:
 - 1. Verifying a service water flow rate of \geq 1250 gpm to each group of cooling units.
 - Chlorinating the service water during the surveillance in 4.6.2.3.a.1 above, whenever service water temperature is between 60^oF and 80^oF.
 - b. At least once per 31 days by:
 - 1. Starting (unless already operating) each operational cooling unit from the control room.
 - Verifying that each operational cooling unit operates for at least 15 minutes.
 - c. At least once per 18 months by verifying that each cooling unit starts automatically on a CCAS test signal.

CONTAINMENT SYSTEMS

BASES

The containment cooling system and the containment spray system are redundant to each other in providing post accident cooling of the containment atmosphere. As a result of this redundancy in cooling capability, the allowable out of service time requirements for the containment cooling system have been appropriately adjusted. However, the allowable out of service time requirements for the containment spray system have been maintained consistent with that assigned other inoperable ESF equipment since the containment spray system also provides a mechanism for removing iodine from the containment atmosphere.

Service water chlorination is performed during containment cooler surveillance to prevent buildup of Asian clams in the coolers when service water is pumped through the cooling coils. This is performed when service water temperature is between 60°F and 80°F since in this water temperature range Asian clams can spawn and produce larva which could pass through service water system strainers.

3/4.6.3 CONTAINMENT ISOLATION VALVES

The OPERABILITY of the containment isolation valves ensures that the containment atmosphere will be isolated from the outside environment in the event of a release of radioactive material to the containment atmosphere or pressurization of the containment. Containment isolation within the time limits specified ensures that the release of radioactive material to the environment will be consistent with the assumptions used in the analyses for a LOCA.

3/4.6.4 COMBUSTIBLE GAS CONTROL

The OPERABILITY of the equipment and systems required for the detection and control of hydrogen gas ensures that this equipment will be available to maintain the hydrogen concentration within containment below its flammable limit during post-LOCA conditions. Either recombiner unit is capable of controlling the expected hydrogen generation associated with 1) zirconium-water reactions, 2) radiolytic decomposition of water and 3) corrosion of metals within containment. These hydrogen control systems are consistent with the recommendations of Regulatory Guide 1.7, "Control of Combustible Gas Concentrations in Containment Following a LOCA", March 1971.

The containment recirculation units are provided to ensure adequate mixing of the containment atmosphere following a LOCA. This mixing action will prevent localized accumulations of hydrogen from exceeding the flammable limit.

ARKANSAS - UNIT 2