

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C | A | R | S | I | S | 1 | 0 | 0 | 0 - | 0 | 0 | 0 | 0 | 0 | 0 - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | 1 | 1

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34

CCVT

01 | REPORT SOURCE | L | 0 | 5 | 0 | 1 | 0 | 0 | 3 | 1 | 1 | 2 | 0 | 8 | 1 | 1 | 2 | 8 | 0 | 0 | 9 | 1 | 1 | 1 | 8 | 0

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

02 | On 8/12/80 an RPS Channel "D" trip signal was received. As allowed per

03 | Technical Specifications Section 3.5.1.3, the channel was placed in "bypass"

04 | and an investigation into the cause of the trip signal ensued. It was found

05 | that the "B" RCS Loop flow indication for the "D" RPS channel was indicating

06 | zero flow. Since the remaining RPS channels flow indicator were indicating

07 | normal flow, the problem was traced to a faulty transmitter associated with

08 | the "D" channel.

09 | SYSTEM CODE | I | A | CAUSE CODE | E | CAUSE SUBCODE | F | COMPONENT CODE | I | N | S | I | T | R | U | CORR. SUBCODE | T | VALVE SUBCODE | Z

17 | LER NO. REPORT NUMBER | 8 | 0 | SEQUENTIAL REPORT NO. | 0 | 1 | 4 | 0 | OCCURRENCE CODE | 0 | 1 | 3 | REPORT TYPE | L | REVISION | 0 |

ACTION TAKEN | A | 2 | EFFECT ON PLANT | Z | SHUTDOWN METHOD | Z | HOURS | 0 | 0 | 0 | 0 | ATTACHMENT SUBMITTED | Y | NPPDA FORM 503 | Y | PRIME COMP SUPPLIER | N | COMPONENT MANUFACTURER | B | I | 0 | 4 | 5

10 | Investigation revealed that the amplifier in the electronic portion of the

11 | transmitter had failed and therefore a zero flow signal occurred. The

12 | transmitter was replaced. The replacement transmitter was calibrated and

13 | leak tested with satisfactory results prior to being returned to service.

14 |

15 | FACILITY STATUS | E | N POWER | 0 | 9 | 6 | OTHER STATUS | N/A | METHOD OF DISCOVERY | A | DISCOVERY DESCRIPTION | Operator Observation

16 | ACTIVITY RELEASED OF RELEASE | Z | AMOUNT OF ACTIVITY | N/A | LOCATION OF RELEASE | N/A

17 | PERSONNEL EXPOSURES | 0 | 0 | 0 | PERSONNEL INCLUDES | 0 | 0 | 0 |

18 | PERSONNEL INJURIES | 0 | 0 | 0 |

19 | LOSS OF CONTAINMENT TO FACILITY | Z |

20 | PUBLICITY | Y |

21 | Local newspapers and wire service

NAME OF PERSON | R. W. Colombo | PHONE | 916-452-3211