



Portland General Electric Company

David W. Cockfield Vice President, Nuclear

November 13, 1989

Trojan Nuclear Plant
Docket 50-344
License NPF-1

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington DC 20555

Dear Sir:

License Change Application 178

Attached is License Change Application (LCA) 178, requesting amendment of Operating License NPF-1. This LCA revises the operability and surveillance requirements, and the bases, for the Component Cooling Water (CCW) System.

By letter dated February 4, 1988, Portland General Electric Company (PGE) submitted LCA 164 which amended the Trojan Component Cooling Water (CCW) System Technical Specifications to provide for split-train operation and spare CCW pump operability. In addition, the February 4, 1988 letter stated that PGE would submit another LCA to revert back to the original CCW Technical Specification after completion of modifications to the Seismic Category II portions of the system.

The modifications to seismically upgrade the Seismic Category II portion of the CCW System as described in Attachment A to the LCA, were completed prior to startup from the 1989 refueling outage. The attached LCA fulfills the commitment in our February 4, 1988 letter.

Also attached is one signed copy of a Certificate of Service for LCA 178 to the chief executive of the county in which the facility is located and to the State of Oregon, Department of Energy.

8911270014 891113
PDR ADDCK 05000344
P PNU

A001
1/11

Portland General Electric Company


Document Control Desk

November 13, 1989

Page 2

The requirement to maintain split-train operation and spare CCW pump operability will cause entry into the ACTION statement of Trojan Technical Specification 3.7.3.1, "Component Cooling Water System" if a CCW pump is declared inoperable. Entry into this ACTION statement is not warranted because of the modifications which have been completed. PGE therefore requests expeditious processing of this LCA in order to avoid this situation.

Sincerely,

A handwritten signature in dark ink, appearing to be 'D. W. Smith', written in a cursive style.

Attachments

c: Mr. John B. Martin
Regional Administrator, Region V
U.S. Nuclear Regulatory Commission

Mr. R. C. Barr
NRC Resident Inspector
Trojan Nuclear Plant

Mr. David Stewart-Smith
State of Oregon
Department of Energy

Mr. Michael J. Sykes
Chairman of County Commissioners