

ORIGINAL

ACRST-1772

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission

Title: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
355TH ACRS GENERAL MEETING

Docket No.

LOCATION: Bethesda, Maryland

DATE: Thursday, November 16, 1989 PAGES: 1 - 204

ACRS Office Copy - Retain
for the Life of the Committee

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PUBLIC NOTICE BY THE
UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

DATE: THURSDAY, NOVEMBER 16, 1989

The contents of this transcript of the
proceedings of the United States Nuclear Regulatory
Commission's Advisory Committee on Reactor Safeguards,
(date) Thursday, November 16, 1989,

as reported herein, are a record of the discussions recorded at
the meeting held on the above date.

This transcript has not been reviewed, corrected
or edited, and it may contain inaccuracies.

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 ***

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5 355TH ACRS GENERAL MEETING
6

7 Nuclear Regulatory Commission
8 Room P-110
9 7920 Norfolk Avenue
10 Bethesda, Maryland

11
12 Thursday, November 16, 1989

13
14 The above-entitled proceedings commenced at 8:30
15 o'clock a.m., pursuant to notice, Forrest J. Remick, Committee
16 Chairman, presiding.

17 PRESENT FOR THE ACRS SUBCOMMITTEE:

18 Carlyle Michelson, Vice Chairman
19 James. C. Carroll, Member
20 Ivan Catton, Member
21 William Kerr, Member
22 Harold W. Lewis, Member
23 Paul G. Shewmon, Member
24 Chester P. Siess, Member
25 David A. Ward, Member

1 PARTICIPANTS:

2

3

R. Fraley

R. Barrett

4

B. Sheron

R. Palla

5

T. Lee

W. Luckas

6

E. Igne

N. Lauben

7

L. Shotkin

W. Houston

8

C. Miller

L. Donatell

9

J. Stolz

L. Thonus

10

M. Masnik

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

P R O C E E D I N G S

[8:30 a.m.]

1
2
3 MR. REMICK: Good morning, ladies and gentlemen. The
4 meeting will now come to order. This is the first day of the
5 355th meeting of the Advisory Committee on Reactor Safeguards.
6 During today's meeting, the Committee will discuss and hear
7 reports on the following: nuclear power plant accident
8 management; definition of adequate protection; review of
9 standardized PWRs; Committee future activities; Three Mile
10 Island Nuclear Station Unit 2 evaluation; integration of the
11 regulatory process.

12 Items for tomorrow's discussion are posted at the
13 back of the meeting room. The meeting is being conducted in
14 accordance with the provisions of the Federal Advisory
15 Committee Act the Government in the Sunshine Act.

16 Mr. Raymond F. Fraley is a designated Federal
17 official for the initial portion of the meeting. A transcript
18 of portions of the meeting is being kept and it is requested
19 that each speaker identify himself or herself and speak with
20 sufficient clarity and volume so that he or she can be readily
21 heard.

22 We have received no written comments or requests to
23 make all statements from members of the public regarding
24 today's meeting.

25 I'd like to start out with a couple items of current

1 interest. One, Mr. Wylie, as you know, had an accident at
2 home, but he is out of the hospital, back home, apparently
3 recovering okay.

4 It is possible that he might be out for another
5 month. He is still continuing to receive ACRS mail. It's
6 possible that, if matters come up associated with the
7 subcommittees that he is chairman of, that we'll need to
8 appoint interim chairmen until he does return, but apparently
9 he is progressing quite well.

10 MR. SHEWMON: How did it happen?

11 MR. REMICK: Apparently, he was twenty feet up on a
12 step ladder, I'm told, with a chain saw.

13 MR. WARD: He is a victim of Hurricane Hugo, you
14 realize.

15 MR. REMICK: An indirect victim, yes.

16 MR. CARROLL: He mis-cut one and swung around and it
17 knocked him off the ladder.

18 MR. REMICK: You may have read that as part of a rate
19 settlement case for the Pilgrim plant, that plant will be
20 rewarded or penalized based in part on average SALP scores and
21 relative performance indicators compared to other industry
22 BWRs.

23 Future rate increases will be tied to such things as
24 capacity factor, average SALP scores; for example, a penalty
25 for each tenth of a point above an average of 1.8 on SALP

1 scores and will be rewarded for each one-tenth of a point below
2 an average SALP score of 1.6.

3 It also will depend on their relative INPO
4 performance indicator rating on such things as person rem
5 exposure and maintenance backlog.

6 MR. LEWIS: Forrest, there really is, as you know
7 perfectly well, a batch of extremely important safety issues
8 here. Are we going to take any notice of them?

9 MR. REMICK: I think that's for the Committee to
10 decide.

11 MR. LEWIS: Will it come up?

12 MR. REMICK: There is nothing on the agenda for this
13 month on those subjects.

14 MR. LEWIS: You know the issues.

15 MR. REMICK: Absolutely. That's why I'm reporting
16 it.

17 MR. LEWIS: It has come up once before in connection
18 with not a rate settlement, but a PUC. I'm talking in
19 connection with a PUC. I don't want to belabor the point, but
20 it is important.

21 MR. REMICK: I think we all agree.

22 MR. SIESS: We have to do something.

23 MR. REMICK: The point is that local agencies are
24 providing incentives which are, in some cases, anti-correlated
25 with safety.

1 MR. SIESS: I know, but are we advising local
2 agencies or are we advising the Commission?

3 MR. REMICK: We're advising the Commission.

4 MR. SIESS: Then I think the first thing to do is
5 find out what they're doing.

6 MR. LEWIS: I don't agree that that's the first thing
7 to do.

8 MR. SIESS: If they're doing something, what advice
9 do they need from us?

10 MR. LEWIS: I don't agree that that's the first
11 thing. I think if they're doing something, we can reenforce
12 them. If they're not doing something, we can urge them.

13 MR. SHEWMON: Hal wants to spur them on in good
14 deeds, whether they're doing them already or not.

15 MR. LEWIS: I'm sorry. I'm interested in the safety
16 of the plants and people who are tinkering with it, and I think
17 we have a responsibility there.

18 MR. CARROLL: Does it sound like we want to put that
19 on the agenda for next month to find out more about it?

20 MR. REMICK: Why don't we take it up during the
21 agenda planning. Another item of interest. You probably read
22 that Atomic Safety and Licensing Board issued a decision on the
23 remaining contested issues on emergency planning for Seabrook,
24 and my understanding is that that initial decision was
25 favorable to proceeding with full power licensing.

1 The Defense Nuclear Facility Safety Board, if that's
2 the correct title, I'm just going on memory here, has been
3 confirmed and I'm told that they have had at least one meeting
4 of the full committee. That's the new what I refer to as a
5 mini-NRC, but that's not exactly correct for their functions.

6 MR. SHEWMON: Who are the members of that? Do we
7 have a list?

8 MR. REMICK: Yes. We've had a list in the past.
9 Herb Koutz, Ed Case, John Conway, and Jack Crawford and a
10 person from EG&G, and I always forget his name, and I want to
11 say Agelbert, but that's not it. It's a person who apparently
12 has seismic background from EG&G Idaho.

13 That's the Board that has a limit of 100 FTEs, if I
14 recall, and also they have an arrangement where they can call
15 upon the NRC, including ACRS, on reactor safety matters, if I
16 recall from many months ago reading the bill.

17 MR. SIESS: Are these full time jobs?

18 MR. REMICK: Those are full time jobs Yes.

19 MR. SIESS: Herb Koutz is then retired?

20 MR. REMICK: I have no idea. There are staggered
21 terms. The one I remember was Ed Case, I think, for a one year
22 term. Recollection again.

23 MR. KERR: You say the panel is a full time job?

24 MR. REMICK: That's my impression, yes. The 100 FTE
25 staff and so forth, I would sure think so.

1 MR. LEWIS: My memory, also from several months ago
2 reading the bill, is that they are also empowered to hire large
3 numbers of consultants so that they could, if they wished, set
4 up a mini-ACRS, if they wanted to.

5 MR. REMICK: The limit is 100 FTEs, including
6 consultants, I believe, and staff, is my recollection. That's
7 the current limit.

8 You probably also read that Vic Stello's confirmation
9 hearing started yesterday. It started yesterday morning,
10 continued into yesterday afternoon, and is continuing into
11 today. You probably read that five Senators have asked
12 President Bush to withdraw his nomination.

13 Also, I'm told that Drew Persinko has been replaced
14 as the NRR Coordinator with the ACRS and has been replaced by
15 Helen Pastis. Is Helen here? Yes. Welcome, Helen. This will
16 be a test of your endurance and probably the strength of the
17 teeth. You have to grit them from time to time, I'm sure, but
18 we welcome you.

19 MR. LEWIS: She's been to subcommittees and already
20 testified and came back today.

21 MR. REMICK: There is something I'd like to read to
22 you. Several members of the staff went out to California after
23 the earthquake and I'd like to read to you just a little bit
24 from the report you might find of interest. Some of it you
25 know, some of it you don't.

1 They report that a lot of damage in the downtown San
2 Francisco area, in the Marina district in particular, was due
3 to soil liquefaction and the amplification of ground motion by
4 soils. The damage from the earthquake seems to be related to
5 site-specific conditions and directionality, rather than to
6 just distance from the epicenter.

7 The elevated highway structure in Oakland suffered
8 damage primarily due to lateral motion and the severity of
9 damage can be attributed to poor design of the hinges at
10 connections of the upper deck columns and corner reinforcement
11 detailing of these columns.

12 Damage to the residential buildings in the
13 Watsonville area was mainly in the un-reinforced masonry and
14 foundations due to severe ground motion, which was estimated to
15 be in the acceleration range of .4 to .5g. The Moss Landing
16 Power Station suffered extensive damage to its 500 kilovolt
17 switch yard, with broken bus and switch gear insulators.

18 However, the other two switch yards having equipment
19 manufactured by different suppliers suffered little or no
20 damage.

21 MR. CARROLL: That's very misleading because the
22 other two switch yards are lower voltages and do not have as
23 massive insulators.

24 MR. REMICK: There was no piping and mechanical
25 equipment failure, except the raw water tank with 800,000

1 gallon capacity, which ruptured at the bottom and buckled at
2 the top. Bolts behaved very well, even those anchoring tall
3 stacks. The station was designed in the late 1950s and early
4 1960s for static lateral force of about .14g, and may have seen
5 considerably higher values.

6 There were also some indications in other locations
7 that equipment was anchored well, but it failed to function
8 after the earthquake.

9 Their conclusion. The general indication is that the
10 engineered industrial facilities survived quite well, but
11 brittle ceramic insulators failed, as they have in previous
12 events. The current NRC seismic design criteria should serve
13 us well, provided we pay attention to equipment anchorage and
14 perform plant walkdown to eliminate the observed potential weak
15 spots.

16 MR. SIESS: Can we get a copy of that?

17 MR. REMICK: Absolutely.

18 MR. WARD: Chet, you looked askance at the hinged
19 design. The fact that they were hinged was the problem.

20 MR. SIESS: It wouldn't have made any difference.
21 The fact that they were hinges, no matter how they were
22 designed. They could have been designed out of cast iron. It
23 wouldn't have made any difference. If you hinge a column top
24 and bottom, it can't take any lateral force. And these were
25 pretty good hinges. They took practically no movement.

1 MR. WARD: But they had the problem.

2 MR. CARROLL: Again, reading the accounts in the Bay
3 Area newspapers, the hinge theory is only one theory as to why
4 that section of freeway came down.

5 MR. SIESS: I'd say it's quite sufficient.

6 MR. CARROLL: The trouble, Chet, is that there were a
7 variety of designs along the length of that freeway. The
8 hinged design was not universal.

9 MR. SHEWMON: They were present where they failed,
10 weren't they?

11 MR. CARROLL: Not necessarily. I don't know.

12 MR. SHEWMON: There are currently three theories that
13 are being looked at, and I can't tell you much more than that.

14 MR. SEISS: I also heard that the strengthening of
15 the bridges after San Fernando involved tying everything
16 together, and you could have tied enough deck together that 300
17 feet that was hinged managed to take down the whole thing. I
18 won't know until I get some decent technical reports, and that
19 obviously is not one of them.

20 MR. REMICK: I figured this would raise some comments
21 from Member Seiss.

22 The next item, quoting from Tuesday's Energy daily,
23 it appears that the UK has decided not to privatize their
24 nuclear plants. It says, "In order to keep its plants and the
25 electricity supply industry intact, the Government is keeping

1 all nuclear stations in the public sector. It plans to finish
2 the only one under construction, the Sizewell B, but has shelf
3 plans for replicating this design." It goes on to say that
4 Lord Walter Marshall is therefore going to leave the industry.
5 I assume he was highly in favor of privatization and further
6 nuclear plants. This places a hold on any further nuclear
7 plants.

8 One additional time. It's been reported that
9 Combustion Engineering is to be taken over by the Swedish-Swiss
10 firm of ASEA Brown Bovari.

11 Any other items that members have? Any other items
12 from the committee members?

13 MR. IGNE: The ASLB has cleared the way for Seabrook
14 to have their full power license.

15 MR. FRALEY: They have signed off on the emergency
16 planning. The staff still has an outstanding issue with
17 respect to the operator training and their attitude and what
18 have you, which as to be resolved as a regulatory matter before
19 they are considered presumably ready to operate, and that has
20 to do with that test that they ran where they permitted the
21 pressurizer levels to go below 40 percent, or whatever it was,
22 without taking action. So they are not quite in the clear,
23 yet.

24 MR. WARD: Is there a regulation on attitude now?

25 MR. FRALEY: They are supposed to follow their

1 procedures, and I gather they didn't while they were running
2 this test.

3 MR. WARD: Okay.

4 MR. REMICK: Mr. Seiss?

5 MR. SEISS: An administrative matter, Mr. Chairman.
6 I have a handout number 10 and a handout number 13. I appear
7 to be missing one through nine, eleven and twelve, or have we
8 got a new numbering system on handouts?

9 MR. REMICK: We must. Can you explain, Mr. Fraley?

10 MR. FRALEY: Well, we've been using this numbering
11 system for several months now, but the numbers on the pink
12 sheets are supposed to go along with the basic numbering in the
13 agenda, and the handouts will be handed out as they are
14 available for specific items of the agenda. But item eleven --

15 MR. SEISS: I think that's a poor procedure, but
16 that's beside the point. I have another one that has no cover
17 sheet on it at all.

18 MR. REMICK: ACRS Activities, right.

19 MR. FRALEY: That hasn't been passed out yet, so you
20 have an advanced copy.

21 MR. SEISS: I have an advanced copy.

22 MR. REMICK: I have one, too.

23 MR. SEISS: That's because you won't feel badly
24 because I have one.

25 MR. FRALEY: You all have advanced copies. I have

1 the official copies here, yet to be passed out.

2 MR. REMICK: Well, we don't want to take that away
3 from Dr. Seiss.

4 [Laughter.]

5 MR. FRALEY: If you like, we will not give you
6 advance copies in the future, if it is confusing.

7 MR. REMICK: Any further comments from members.
8 Maybe I shouldn't ask?

9 [No response.]

10 MR. REMICK: All right. Let's then continue with the
11 first major item on the agenda. That's the discussion of
12 nuclear power plant accident management and accident management
13 strategies. Mr. Kerr is our subcommittee chairman, so, Bill, I
14 turn it over to you.

15 MR. KERR: Thank you, Mr. Chairman. You will find in
16 Tab 2, appropriately, arranged index and titled information
17 associated with the items to be discussed. You will recall
18 from our previous discussions of accident management that the
19 staff has had Brookhaven and Hanford Laboratories assisting
20 them in collecting information from a number of sources which
21 the staff believed might be helpful to licensees as they
22 undertook their IPE, particularly that part of the IPE that had
23 to do with developing accident management strategies.

24 The discussion this morning I think will be
25 concentrated on a supplement to Generic Letter 88-20, which

1 will enclose a report that gives information on these potential
2 management strategies. I think, and the staff, I hope, will
3 comment on this. They're asking for our comments on this
4 preparatory to sending it out to licensees.

5 I have no further comments on it at this point. Are
6 there questions or comments from other members of the staff who
7 may have had occasion to examine the material, other members of
8 the committee?

9 [No response.]

10 MR. KERR: If not, I will turn things over to Mr.
11 Shewmon.

12 MR. SHEWMON: One question I can bring up later, but
13 I was interested in Ivan's trip report in which he mentioned
14 the study that the Germans had done on accident management, and
15 their PRA numbers were that there was between one and two
16 orders of magnitude reduction in risk with management, as I
17 recall.

18 MR. CATTON: That's right.

19 MR. SHEWMON: I would like to ask the staff before we
20 get done whether there's any plans to do studies like that
21 here, or if they have ever tried to quantify the benefits that
22 might accrue from this.

23 MR. KERR: Other comments, or if not, I will turn
24 things over to the cognizant NRC staff person.

25 MR. BARRETT: My name is Richard Barrett. I'm chief

1 of the Risk Applications Branch in NRR. I would like to give
2 you a brief overview of past and current activities simply to
3 put today's presentation into perspective.

4 As you know, accident management is one of the
5 principal activities in the severe accident program for
6 closure of the severe accident policy statement. We believe
7 that accident management, of and by itself, can have a great --
8 has a great potential for controlling the risk of nuclear power
9 reactor operation.

10 We are aware of the German risk study, and we've also
11 seen other estimates that have been done, for instance in
12 NUREG-1150, and I believe later on, in answer to the question
13 that was raised by Mr. Shewmon, that we could possibly get some
14 insights from the Office of Research on some ongoing work, I
15 believe at Sandia? Is that correct?

16 [Slide.]

17 MR. BARRETT: The planning for accident management
18 has been going on for well over a year now, and it has evolved
19 a great deal as a result of comments that we've gotten from the
20 ACRS and from the Commission. We have briefed the ACRS on a
21 number of occasions, and we intend to keep the ACRS fully
22 informed as we progress toward implementation of our accident
23 management program.

24 We also briefed the Commission on January 23rd of
25 this year, and we have gotten back from them a staff's

1 requirement memorandum, and we have adjusted the planning of
2 this program accordingly.

3 I should also like to point out that we have had a
4 very productive ongoing interaction with the industry, namely
5 through the staff of NUMARC and EPRI, and that has also been
6 very useful to us in defining what is possible in accident
7 management and what will be useful.

8 Furthermore, we had an opportunity back in March to
9 outline our accident management plan for the entire industry at
10 the IPE workshop in Fort Worth. I believe it's fair to say
11 that the plans were fairly well received by the industry at
12 that time.

13 [Slide.]

14 MR. BARRETT: The program currently consists of two
15 major efforts. First is an effort to define and demonstrate
16 guidelines for what constitutes a successful accident
17 management framework or program on the part of a utility. We
18 have worked closely with NUMARC and EPRI to define these
19 guidelines, and the subcommittee, in September, was briefed on
20 the EPRI guidelines, the document, and also on a parallel
21 independent effort on the part of INEL, sponsored by the Office
22 of Research.

23 Our plan is to complete the demonstration of the
24 framework guidelines during this fiscal year and to issue a
25 generic letter to the industry next fall.

1 The Commission has asked that we touch base with them
2 before issuing that letter and also, we plan to keep the NCRS
3 fully informed at appropriate intervals. We do not plan to
4 discuss the framework guidelines at this meeting today.

5 Today we will focus on the other major effort, namely
6 the identification and evaluation of accident management
7 strategies. Specifically, we will discuss a near-term
8 milestone, namely, the issuance of a supplement to generic
9 letter 8820, the IPE generic letter, in which we intend to give
10 the industry our insights on the advantages and potential
11 disadvantages of a specific set of strategies which we have
12 identified based on past PRA results.

13 I would also mention that we have an ongoing effort,
14 primarily in the Office of Research, to identify and evaluate
15 additional strategies. These are primarily strategies such as
16 primary system depressurization for a PWR, for which there are
17 significant phenomenological uncertainties and for which we
18 believe additional research is needed. We do not plan to
19 discuss that effort today either.

20 MR. SHEWMON: Sir, will part of that effort be the
21 performance of the relief valves under repeated operation or is
22 it of a different sort?

23 MR. BARRETT: I think primarily that that effort is
24 to understand whether primary system depressurization will be
25 successful, under what circumstances it will be successful in

1 depressurizing.

2 MR. SHEWMON: If the valves don't operate, that would
3 be part of the lack of success or no?

4 MR. BARRETT: The primary research question is one of
5 phenomenological uncertainty rather than reliable -

6 MR. SHEWMON: Is valves not operating
7 phenomenological, I guess is my question, then.

8 MR. BARRETT: Well, I don't think that would be a
9 major focus of the research effort but it's certainly a very
10 important aspect of whether or not primary system
11 depressurization would be successful. I don't believe --
12 perhaps the Office of Research can clarify -- but I don't
13 believe that is a major question associated with this research
14 program.

15 He says I'm correct.

16 MR. KEPR: Is that because we already know that the
17 valves will operate satisfactory or just because that's not
18 being explored at this point?

19 MR. BARRETT: It's because -- it's because -- the
20 question of whether or not the valves will operate is really
21 more a question of how well they're maintained, how often
22 they're surveilled and tested rather than whether or not they
23 have been designed properly to open under system pressure.

24 MR. SHEWMON: It's not a matter of whether they'll
25 open or not. It's a matter of whether you score holes in the

1 faces that are supposed to meet with repeated use and I would
2 suspect that that might have more to do with the design and the
3 materials they put there than the maintenance.

4 MR. BARRETT: I understand now. I misunderstood your
5 question.

6 MR. MICHELSON: There has been a history of them not
7 functioning properly also because of the adjusting ring on them
8 to do the original setting. That thing seems to rotate out and
9 they stick open, for instance.

10 MR. BARRETT: Yes. Brian Sheron of the Office of
11 Research would like to address this.

12 MR. SHERON: Let me clarify. We haven't ignored the
13 whole question of valve operability. The way we're approaching
14 the whole issue, which obviously you want to depressurize to
15 avoid a direct containment heating situation -- the first thing
16 we have to do is we have to decide whether or not if one in
17 fact did have a high pressure melt ejection, that one indeed
18 would get containment failure.

19 This gets into the business of how strong is the
20 containment and what are the loads that are imposed on the
21 containment. We have a research program right now hopefully
22 that will shed light on that. We are also doing calculations,
23 looking at whether depressurization will in fact get the
24 pressure down to where one needs to have it if one is to avoid
25 this DCH, presuming that if you've got a DCH, it would lead to

1 a containment failure.

2 The initial approach on that is to assume the valves
3 operate as they are designed. If we conclude as a result of
4 our studies that it is necessary to say require all PWRs to
5 depressurize in order to avoid a DCH problem, then we would
6 have -- we would address the question of, are the valves
7 qualified. Do we have confidence that they'll work? If it
8 comes down to the point that it is required in fact to avoid
9 the early containment failures in the area, then my guess is we
10 would probably have to address that and take some action.

11 But until we kind of reach that point, I think 1150
12 for example, took into account the possibility of PORVs failing
13 when they did their studies of the deep depressurization. So,
14 that was accounted for. There was some probability assigned
15 that valves would fail.

16 [Slide.]

17 MR. BARRETT: THE NRC's accident management program
18 has from the very outset been a closely coordinated effort on
19 the part of Office of Research and NRR. The principal
20 responsibility within NRR is within the Risk Applications
21 Branch which is in turn within the Division of Radiation
22 Protection and Emergency Preparedness. Frank Congel is the
23 division director.

24 The research effort is in the reactor and plant
25 systems branch. Lou Shotkin is the branch chief and in turn,

1 that is in the Division of System Research and Brian Sheron is
2 the director of that division. The first presentation today
3 concerning the nature and schedule and other matters for the
4 generic letter, 8820 supplement, will be given by Bob Palla of
5 NRR. His presentation will be followed by a description of the
6 strategies themselves and the research work that has been done
7 to outline the disadvantages and advantages of those strategies
8 and that presentation will be given by Tim Lee of the Office of
9 Research and his contractor from Brookhaven, Bill Luckas.

10 Are there any questions at this time before I turn
11 the microphone over to Bob Palla?

12 MR. WARD: Richard, you said you're with -- are you
13 with NRR?

14 MR. BARRETT: I am the chief of the Risk Applications
15 Branch. My branch has principal responsibility within NRR for
16 this program.

17 MR. KERR: I have a question, Mr. Barrett.

18 As I read the draft report, I guess it is from
19 Brookhaven, I have difficulty knowing where emergency operating
20 procedures end and risk management and accident management
21 begins. Perhaps that dividing line is not important but it
22 seems to me it is confusing since if we don't have a dividing
23 line, since there already exists emergency operating procedure
24 guidelines and emergency operating procedures and it appears to
25 me that much of what is in this preliminary report could

1 readily if it does not almost automatically fall into that
2 category.

3 On the one hand, there's a group within NRC that's
4 investigating carefully emergency operating procedures. Now
5 apparently there is another group that is investigating
6 accident management strategies and it appears to me that there
7 is a considerable overlap between these two. Is there some way
8 that one can avoid what appears to me at least to be a possible
9 area of considerable confusion?

10 MR. BARRETT: You are absolutely right. We have not
11 defined any clear interface between where accident management
12 starts and the EOPs end. With regard to these specific
13 strategies that we'll discuss today, some of them will be
14 perhaps in emergency operating procedures in the future in
15 certain plants. In fact, many of them are already in the
16 emergency operating procedures at some plants.

17 Others of these procedures will be implemented
18 separately for a number of reasons, I can see. For instance, a
19 procedure which overrides an interlock or which cross ties
20 systems, you might want to reserve that procedure for your tech
21 support center. You might want to have your engineering staff
22 do an assessment on the spot before you implemented a procedure
23 like that rather than putting it into the symptom-oriented
24 procedures in the control room.

25 But you're absolutely right. There is no clear

1 boundary. Now, to avoid overlap, we have tried to involve the
2 people in NRR who are involved with the EPGs, the emergency
3 procedure guidelines, the emergency response guidelines. In
4 the planning for the accident management program and also in
5 the process by which we came up with these 20 strategies, at
6 the time that we came up with the 20 strategies, we had a group
7 of five people. One of them was Wayne Hodges who was the chief
8 of the Reactor Safety Branch. That's the branch in NRR that
9 has primary responsibility for the emergency procedure
10 guidelines.

11 MR. KERR: In your view, do you think you were
12 successful in avoiding this overlap?

13 MR. BARRETT: I think we have been successful to the
14 extent that we can be. I think that to a certain extent, there
15 is an overlap and it's somewhat unavoidable. I think that for
16 instance, we'll find that when all of this is implemented at
17 the utilities, some utilities will implement the given
18 procedure in the ALPs. Others will implement it as a separate
19 accident management procedure, depending on the way they do
20 business.

21 We're trying to give them a lot of latitude.

22 MR. LEWIS: Can I ask a question?

23 MR. SHEWMON: Is it on the topic?

24 MR. LEWIS: Yes, it's on the topic.

25 MR. SHEWMON: Otherwise, I'd like to continue.

1 MR. LEWIS: Oh, it's not exactly on those topics, so
2 maybe you should go first.

3 MR. SHEWMON: As I recall the regulations, there is a
4 time when somebody declares an emergency and presumably that
5 has some relationship to when the EOPs come into play.

6 MR. BARRETT: The entry into the EOPs --

7 MR. SHEWMON: Let me finish the question. I may be
8 wrong on that. You can do that but from what I got from your
9 answer to Kerr's question was that they sort of meld into each
10 other and you don't even try to distinguish between when you
11 have an emergency and when you have an accident.

12 I just wondered if there's anything else in the
13 regulations that requires somebody to declare an accident and
14 if they can be so co-mingled as you suggest -- or I understood
15 you to suggest.

16 MR. BARRETT: Again, I think the question of
17 declaring an accident, declaring so-called emergency action
18 levels, as to whether you have an "alert," a "site emergency"
19 or a "general emergency" is not completely coordinated. That
20 decision is not completely coordinated with the decisions that
21 are made. Those decisions are primarily regarding the off-site
22 response. Those decisions are not completely coordinated with
23 the decisions that are made as to how you respond to the
24 emergency within the plant, whether you're -- whether or not
25 you're in the emergency operating procedures, which emergency

1 operating procedure you're in.

2 So there is a fuzziness there but the question --
3 when we say "accident" as opposed to "emergency," we're not
4 making a distinction that some circumstances are emergencies
5 and some circumstances are accidents. That's just a
6 terminology.

7 MR. KERR: Then why do we need to have the two
8 separate terminologies if there's no distinction between them?

9 MR. BARRETT: I'm not saying there's no distinction.
10 There could be a very big distinction.

11 MR. KERR: I thought you just said you made no
12 distinction between them. Did I misunderstand you?

13 MR. BARRETT: We haven't clearly defined the limit
14 where one ends and the other begins because that limit can be
15 different.

16 MR. KERR: Then I misunderstood you. I thought you
17 said you made no distinction between them.

18 MR. BARRETT: No, I think there's a strong
19 distinction. Let me try and make that distinction.

20 The emergency operating procedure philosophy is to
21 have a set of procedures that are completely pre-planned based
22 on -- that a licensed operator can use -- based on his training
23 and the symptoms that he observes, to take prescribed actions
24 and I think that's the philosophy of the emergency operating
25 procedures with some exceptions.

1 I think that some of these procedures that we're
2 talking about, some of these strategies, may find their way
3 into that framework but accident management goes beyond that.

4 Accident management program is intended to address
5 the actions on the part of people who are not necessarily
6 licensed operators but perhaps engineering people, people who
7 have been trained in severe accidents, PRA, severe accident
8 phenomenology, people who are in a position to step back from
9 the emergency operating procedures and say that's fine.
10 Operators continue working on those emergency operating
11 procedures, but it is now time for us to begin to think about
12 what's really happening here and to begin to sift priorities as
13 to how the plant should respond. So accident management goes
14 beyond emergency operating procedures.

15 MR. CATTON: That's right, but there's some -- there
16 is a plant that has the accident management approach in place
17 and they have the one system that's much like the procedures
18 that we see today. Then they have a point that if they have to
19 make a decision, the procedures are not achieving their
20 intended function. They go down a different branch that's
21 called accident management, and it's well defined. It's clear.
22 You know when you achieve it, when you get to that decision
23 point, and you can track it.

24 There's no confusion, no controversy, no conflict. I
25 think that's what you've got to do.

1 MR. BARRETT: I don't know --

2 MR. CATTON: I would not want to be in a plant that
3 follows the rules that you're sort of laying down.

4 MR. BARRETT: I do not know which plant you're
5 referring to.

6 MR. CATTON: Well, it's Phillipsberg in Germany.

7 MR. CATTON: Oh, okay. I'm not familiar with that.

8 MR. BARRETT: I think that you ought to get familiar
9 with it. The first paper in the NURETH conference in Karlsruhe
10 describes some of this.

11 MR. CATTON: Well, we certainly will get familiar
12 with it.

13 MR. CARROLL: An added complication you have to deal
14 with, I guess, is that EOP's vary by vendor/owner group, also.
15 My impression is GEs tend to go farther than the rest of them
16 in terms of getting into the accident management area.

17 MR. BARRETT: Exactly.

18 MR. CARROLL: So you've got that whole tradition or
19 structure that's in place to be concerned about when you start
20 trying to draw lines.

21 MR. BARRETT: Yes. There's another important point,
22 too, that I'd like to make, and that is that we're not starting
23 from scratch on accident management. Accident management
24 exists in every plant in this country to a greater or a lesser
25 degree. Every plant has a tech support center; it has more --

1 some have very extensive sets of procedures and guidance for
2 the tech support center for severe accident type conditions,
3 others less so. What we're trying to do with this program is
4 to get a set of guidelines to bring everybody up to a uniformly
5 good set of accident management capabilities.

6 MR. WARD: You know, it sounds to me like you have
7 made a pretty clear distinction between EOPs and accident
8 management procedures. What I heard you say is that the EOPs
9 are traditional procedures for the shift staff to use and to
10 follow in the case of plant events. The accident management
11 procedures are not really for the shift staff, but they're pre-
12 thought-out guidelines for the plant management and technical
13 support staff to use in the event of the rare accident that
14 goes well beyond provisions that are detailed in the EOPs.

15 Now, the connection might be that as -- it seems to
16 me there are two connections possible with the EOPs. As the
17 accident management procedures or guidelines are developed,
18 people may say, "Hey, there are some things in the EOPs that
19 ought to be changed, or added to, or something."

20 The other thing is that as the accident is developing
21 or emergency is developing, the tech support staff and plant
22 management using these accident management guidelines will be
23 developing ad hoc EOPs for the shift staff to use. But that's
24 a pretty clear distinction to me, if that's what you mean.

25 MR. BARRETT: I think that is exactly the

1 distinction, but, as I pointed out, I could take a particular
2 strategy, and I'd say, "I think this is an accident management
3 strategy according to the definition you gave." But I know of
4 plants today that have that strategy in their EOPs. And we
5 don't want to say, "No, you've got to take that out of your
6 EOPs and put it in your tech support center." We want people
7 to work this problem within the structure of their own way of
8 doing business. But you're absolutely right. That's a good
9 definition.

10 MR. KERR: Mr. Lewis, you've been waiting. I started
11 to say "patiently," but I'm not sure you have been waiting
12 patiently.

13 MR. LEWIS: Oh, I have been waiting patiently. The
14 problem I have is that my friends are way ahead of me. They're
15 in the middle innings, and I'm still trying to buy a scorecard
16 so I know who's planning, and I wonder if I could just -- I
17 think it's on the same subject, as a matter of fact.

18 But as I read the front page of the handout, and read
19 where you come from -- I'm not picking on you -- and I read
20 from the bottom up, I find that you're from NRR, and I know
21 what NRR is. Then I find that it's the division of radiation
22 protection and emergency preparedness. I wonder if that means
23 that emergency preparedness and radiation protection are not
24 distinguished in NRR? I didn't previously realize that they
25 were the same division in NRR, but they are? They must be.

1 MR. BARRETT: They are the same division. There are
2 two separate branches.

3 MR. LEWIS: They're separate, but it's the same
4 division.

5 MR. BARRETT: It's the same division.

6 MR. LEWIS: Okay. So the division contains two
7 separate branches for emergency preparedness and radiation
8 protection, you are telling me?

9 MR. BARRETT: Yes.

10 MR. LEWIS: Okay. Fine.

11 MR. BARRETT: And a third branch, which is the risk
12 applications branch.

13 MR. LEWIS: Okay. Fine. But I just wanted to know
14 about these. Okay. So it's that these branches are combined.
15 I'm working my way up.

16 Then I find that within that division, there is a
17 branch called risk applications. I didn't know there were
18 applications of risk, but I'm willing to be educated. Could
19 you, in one sentence, say what risk applications means?

20 MR. BARRETT: Yes. After the reorganization of NRC a
21 few years back, the role of PRA was divided, and the
22 traditional role of reviewing the utility PRAs and doing
23 research on PRA methodologies went to the Office of Research.
24 What remained in the Office of NRR was a small group, the risk
25 applications branch, and the purpose of that group was to take

1 the results of past PRAs and try to apply them to NRR's
2 activities.

3 I think the most outstanding example, for instance,
4 is that we work a lot with inspectors in the regions to try to
5 help them to prioritize what they're looking at in the plant to
6 understand, you know, if you're going to, for instance, look at
7 a valve, we tell them, "Look at this valve. This is a risk
8 significant valve. This other one is a less significant
9 valve." That's an over-simplified, but that's the applications
10 of risk that we're talking about.

11 MR. LEWIS: Okay. Fine. It was seven sentences, but
12 I won't quibble. So risk applications doesn't mean risk
13 applications; it means applications of risk analysis.

14 MR. BARRETT: Exactly.

15 MR. LEWIS: Okay. Fine. I'm working my way up
16 there. And finally, it says that you're a senior reliability
17 and risk analysis. Is that because you have two separate
18 skills, one in reliability and one in risk analysis, or is that
19 the distinction is not clearly made within the branch? I'm not
20 picking on you; I just want to know.

21 MR. BARRETT: Okay. First of all, that's Mr. Palla
22 you're talking about. He'll be speaking next. I'm the branch
23 chief. And we -- reliability and risk -- well, I guess the
24 distinction there would be that we -- in the PRA business, as
25 you well know, there tend to be people who are very good at

1 doing the so-called front end, the reliability aspect of
2 equipment and human errors and that sort of thing, and we tend
3 to think of them as reliability experts and front-enders. We
4 also have people who are more adept at the phenomenology of
5 source terms, containments, and off-site consequences, and we
6 tend to think of them more as risk analysts.

7 MR. LEWIS: I see. And you are both?

8 MR. BARRETT: I'm the branch chief. I'm not sure I'm
9 either.

10 MR. LEWIS: Well, no, it says here that you're a
11 senior reliability --

12 MR. BARRETT: You have the wrong person. You have
13 the wrong person.

14 MR. LEWIS: Oh, I'm sorry. Forgive me.

15 MR. BARRETT: That's Robert Palla.

16 MR. LEWIS: I'm not picking on you. I really missed
17 that. Okay. I apologize for that. Okay. But there is a
18 title called "reliability of risk analyst," and it is somebody
19 who's expert in both --

20 MR. WARD: He's the next speaker.

21 MR. LEWIS: Forgive me. I lost the sequence of
22 events. Okay. Fine.

23 MR. CARROLL: He is a manager.

24 MR. LEWIS: He's a manager. I understand. Managers,
25 as you well know, have no expertise in anything. Okay. Fine.

1 I was just trying to find out who the players are because all
2 of the conversation has been about the separation of risk
3 management from other things, and I wanted to get it straight.

4 MR. BARRETT: Who's in charge of what. Okay. Very
5 good. Thank you.

6 MR. KERR: Any other questions? One additional
7 question. You commented early on that many of these examples
8 that are given had come out of PRAs, and presumably, therefore,
9 one has some indication from the PRAs as to the risk reduction
10 that might be associated with the strategies. The report,
11 however, does not mention this at all, and it would seem to me,
12 if that information existed, it would be useful to the people
13 who are planning to use these strategies to include it in the
14 report.

15 MR. BARRETT: That's a useful suggestion, yes. I
16 couldn't say off hand how much of an effort that would be to
17 pull that together.

18 MR. KERR: It's not a question; it's just a comment.

19 MR. BARRETT: Yes.

20 MR. KERR: And finally, it strikes me, from some of
21 the things I have read in other situations, that some of the
22 suggested strategies would be illegal under existing NRC rules.
23 Some of the cross connection, for example, would leave one in a
24 situation of violating single-failure criteria. What is a
25 licenses supposed to do about this? He does not receive any

1 guidance in the reports, as far as I can see, that says, "Wait.
2 This may be illegal, so don't do it unless you are prepared to
3 violate NRC rules, and if you do, you'll probably get cited for
4 it."

5 MR. BARRETT: You are absolutely right. Many of them
6 -- and that's primarily why we wanted to put together this
7 report, to point out the disadvantages -- many of them are not
8 only illegal, but they're illegal for good reason. They have
9 potentially major downside effects. However, in a situation
10 where you have gone beyond the design basis, and you're in a
11 serious accident, then you do reach a point where you are
12 authorized to say, "Well, I think I'm at the point now where I
13 can deviate from emergency operating procedures. I can do
14 extraordinary actions to try to save this plant."

15 MR. REMICK: There are provisions in the regulations
16 for violating procedures, or tech specs, I believe, in case of
17 emergency.

18 MR. PALLA: It's 50.54(x).

19 MR. CATTON: I believe that's why the Phillipsberg --
20 they have two stems on the procedure. When they reach the
21 decision point, they go down this one where they can do these
22 things.

23 MR. KERR: That's all well and good, but that says
24 that you can't make any plant changes that are permanent that
25 might be valuable in the case of an emergency. You have got to

1 wait until you or the NRC decides that an emergency exists
2 before you can do these things. IT strikes me that some of
3 these suggested strategies might profit from pre-connections
4 and rearrangements. I don't believe, in terms of the report, I
5 don't believe enough thought has been given to the possibility
6 that some of the regulations may need to be revised if we are
7 serious about accident management.

8 MR. BARRETT: I understand your point. We worried
9 about that a lot.

10 MR. KERR: Well, it seems to me something other than
11 worrying about it might be worthwhile.

12 MR. BARRETT: Let me give you an example. I think
13 there are some cases, for instance, where we talk about cross-
14 tying an electrical system. There's an obvious downside to
15 doing that because if you have a fault in one, you can create a
16 fault in the other.

17 So the wording has been changed in some of the
18 suggested strategies so that the wording says that you should
19 have available the capability to do so.

20 MR. KERR: That is precisely the point I was trying
21 to make.

22 Now, we now have available tools, which presumably
23 were in existence, but they were not well known when our
24 current regulations were formulated. Wouldn't it make some
25 sense, in those cases in which one is not sure about the operation

1 or downside, to do some risk analysis? And it may be that some
2 of these rules that we have are obsolete because they don't
3 take into account the risk reduction that might be achieved by
4 cross-connections which are now illegal.

5 MR. BARRETT: You may well be right. It may well be
6 a good time to start thinking about some of these things. But
7 I think, in the cases we're talking about here, there are good
reasons why these things are forbidden.

8 MR. KERR: And the good reasons are existing
9 regulations, and my point is that these regulations were
10 formulated without giving thought to risk analysis, and they
11 may therefore be obsolete.

12 MR. BARRETT: You are right, there may be a lot of
13 things like that that are obsolete. We'll take that as a
14 suggestion. Do I understand you to suggest that that's
15 something that should be done on a separate track?
16

17 MR. KERR: it seems to me that it ought to be done
18 when one gets serious about accident management. If one is not
19 serious about it, and is playing with it, then I suppose you
20 don't need to do it, but if you're really serious about
21 accident management strategies, it seems to me one ought to
22 take into account the only tool I know of that we have to
23 assess the risks associated with doing various things.

24 MR. BARRETT: Well, I guess I go back to another
25 example. There is good reason for having the MSIV to shut

1 under certain circumstances, and there's good reason under many
2 circumstances, perhaps most circumstances, to keep it shut.

3 The kind of circumstances we're talking about here
4 are very remote and unlikely. Compared to the circumstances
5 under which you would want to have it shut, the circumstances
6 under which you would want to reopen it are much less likely.

7 MR. KERR: I would like to see the risk analysis that
8 demonstrates this. Is there one?

9 MR. BARRETT: No. I don't know of a comparison risk
10 analysis of that.

11 MR. KERR: It might be interesting to do one.

12 MR. BARRETT: You're right.

13 MR. KERR: Mr. Lewis?

14 MR. LEWIS: On the same related point, I recall that
15 after Three Mile Island, there was an INE report -- I think it
16 was 0600 or something like that -- that made a great to-do
17 about the fact that the operators at TMI had not only done bad
18 things, but had also violated regulations at the time, and that
19 was never pressed very hard. But I remember, at the time,
20 saying that the situation in aviation is entirely different in
21 the sense that a pilot always has the authority to say, " I
22 declare an emergency," in which case he is guaranteed immunity
23 from any subsequent punishment for violating any rules. He may
24 be punished for bad judgement and things like that, but not for
25 violating rules.

1 I remember raising the question after TMI and being
2 told there was adequate provision in the regulations for the
3 operators to do that, but it was never clear to me that there
4 really was, and what I've heard this morning is that it is
5 clear.

6 MR. REMICK: They were added later than TMI.

7 MR. LEWIS: And they are quite clear, and --

8 MR. REMICK: Well, that's always questioned. I don't
9 know. I know they were added somewhere in the early '80s.

10 MR. LEWIS: I see. Okay. Fine.

11 MR. REMICK: Am I correct? Does the staff agree with
12 that?

13 MR. KERR: Where would one find this?

14 MR. REMICK: We were told 50.54(x).

15 MR. LEWIS: Okay. It would be very nice to see what
16 they say and learn whether operators are told during their
17 training that they have that option, because that's at least as
18 important.

19 MR. REMICK: Bill, going on with what you're talking
20 about, one thing that the staff might do in the generic letter,
21 you might encourage licensees, in developing the accident
22 management strategies, if they encounter cases where the
23 regulations are inhibiting them from an optimal solution and so
24 forth, that they identify those to the Commission, since
25 they're going to be developing their strategies, and if they

1 run across this type of thing, it would be good to identify it,
2 and then, perhaps, those regulations could be looked at.

3 MR. KERR: That's a good suggestion.

4 MR. BARRETT: Good suggestion. Thank you.

5 MR. LAUBEN: Norman Lauben, Office of Research.

6 Do you want me to address risk reduction implications
7 of what we're doing at this point, or should I wait until some
8 later point?

9 MR. BARRETT: We'll leave it up to you.

10 MR. KERR: If there is a point at which this is going
11 to be discussed, fine. I'm in no hurry.

12 MR. BARRETT: Is there a natural point at which to
13 discuss this?

14 MR. LAUBEN: No, there's not, because that's not
15 addressed in the document.

16 MR. KEPR: My point was simply not a question but a
17 suggestion that it might be useful to the people who would use
18 this report if they had that information.

19 MR. LAUBEN: Okay. Let me just address it, then,
20 briefly.

21 There is a Sandia report, the title of which is "The
22 Risk Management Implications of NUREG-1150", where they
23 attempted to address already-in-use action management schemes
24 and some proposed ones and put those into the PRAs to determine
25 what the risk reduction was, similar to, I think, what you're

1 talking about the Germans did.

2 Those kinds of things that they looked at in NUREG-
3 1150, principally because they are the kinds of things that
4 were being proposed by the plants after the 1150 work was done
5 were in the area of what we call preventive measures, in the
6 same way that the work that's going to be talked about today is
7 preventive, and not surprisingly, since it really only dealt
8 with preventive and not mitigative strategies, the risk
9 reduction numbers didn't look quite as large as what the
10 Germans have done.

11 The German program is pretty aggressive in terms of
12 what they require the plants to do, and they've made a very
13 aggressive move towards eliminating high-pressure risk and that
14 sort of thing, and they also have fewer types of plants that
15 they have to deal with, but our intention is -- in fact, we
16 have a program -- a joint program with the Risk Applications
17 branch in our division to look at mitigative strategies -- to
18 have Sandia look at mitigative strategy in the same way they
19 looked at preventive strategies for this previous report that I
20 spoke of.

21 We plan to do that. It will get underway this year,
22 but it hasn't started as of yet.

23 MR. CATTON: I kind of remember that the two orders
24 of magnitude were in stopping the accident before they got into
25 real trouble.

1 MR. LAUBEN: Well, some of it was their venting, as
2 well. They have extra-large feedwater addition. They had
3 aggressive depressurization and that sort of thing.

4 MR. CATTON: And aggressive ways of getting more
5 water into the system.

6 MR. LAUBEN: Right, but it was also they gained a lot
7 in time, too, to recover from the accident.

8 MR. LAUBEN: That's right.

9 MR. KERR: Mr. Carroll.

10 MR. CARROLL: Isn't this two orders of magnitude in
11 the beholder's eye inasmuch as it really depends on what you
12 define as accident management and what you define as emergency
13 operating procedures? The two orders of magnitude are with and
14 without "accident management".

15 MR. LAUBEN: I think that the two orders of magnitude
16 would be in areas that we would consider still accident
17 management, although we might consider them as much preventive
18 as mitigative, but there also is the point that a lot of these
19 -- and I think I implied it and maybe didn't state it directly.
20 There are significant hardware changes that were installed to
21 achieve this risk reduction.

22 MR. KERR: Mr. Lauben, I guess I would have to
23 interpret your comments, if they were in response to my
24 suggestion, to say that there really isn't much risk reduction
25 associated with these measures in this report and so, you

1 didn't put them in.

2 MR. LAUBEN: No. The kinds of risk reductions that
3 appear in this report are, indeed, the kind of risk reduction
4 measures that are being discussed and that will be discussed in
5 this report. Those are exactly the kind.

6 MR. KERR: I don't find them in the Brookhaven
7 report. Where are they?

8 MR. LAUBEN: You don't find the measures or you don't
9 find the numbers?

10 MR. KERR: I don't find the numbers.

11 MR. LAUBEN: Well, that's right. There was no
12 attempt to make numerical estimates of risk reduction simply
13 because, in a lot of cases, it's extremely plant-specific. In
14 fact, in most cases, it is. So, we did not ask Brookhaven or
15 PNL to attempt to quantify the risk reduction associated with
16 those measures. However, the Sandia report would indicate what
17 the approximately magnitude of those kinds of risk reduction
18 measures would be.

19 MR. KERR: My impression, from reading the background
20 material, is that Brookhaven did not do a lot of de novo work
21 here. They were asked to look at existing reports, including
22 the Sandia reports, and dig out this information from these
23 voluminous reports and put it in a smaller report, and I
24 applaud that. I'm simply saying that since the risk reduction
25 must have been in the same reports, it therefore seems to me it

1 might have been useful to include that -- maybe I'm wrong --
2 because in the implementing strategy, whether you decide to do
3 it or not, it seems to me, could depend on where you think it
4 is likely to reduce risk and how much.

5 MR. BARRETT: I'd like to make a point here about
6 that.

7 Remember, the process here is that we're putting out
8 this information to the industry to be used in the process of
9 performing their IPEs, which, based on the responses that we've
10 gotten back from the utilities so far, those will all be PRAs.
11 So, every utility will do a plant-specific PRA, and what our
12 generic letter is asking them to do is to evaluate these in the
13 context of their own PRAs. It's difficult to evaluate
14 generically what the risk reduction of adding another water
15 source is, unless you have a sense of how many water sources --

16 MR. KERR: Mr. Barrett, you refer to reports that
17 dealt with five plants, I think. There are numbers in these
18 reports, and I don't think anybody would necessarily think it
19 applied to his plants, but since those numbers exist and are
20 readily accessible, since you dug out all this other
21 information, it isn't clear to me why you didn't dig out the
22 numbers, as well, because I think the numbers are relevant.

23 MR. LAUBEN: That report is, I think, about 3 weeks
24 old now -- the Sandia report. I imagine, if we wanted to, we
25 include it by reference into the report and people could read

1 this and they could see what the risk reduction effect is for
2 those five specific plants where the risk reduction measures
3 were looked at.

4 I don't think, necessarily, that those risk reduction
5 options that were looked at in that report were necessarily as
6 comprehensive as what we're proposing our work. It can
7 certainly be incorporated by reference now, if that appears to
8 be a useful thing.

9 MR. KERR: I had understood, from Mr. Barrett's
10 earlier statement, that these things that you have in this
11 report were put there because they were PRA-based. That was, I
12 believe, the statement he made.

13 Now, to me, that means that they came out of analyses
14 that included the risk reduction associated with these. What
15 you're telling me now, apparently, is that only three weeks ago
16 was the risk reduction number available. To me, that doesn't
17 sound like that these things were PRA-based.

18 MR. LAUBEN: No. The report was, generally, though,
19 but the people who were familiar with that work that went into
20 the report were -- at least two or three of them were familiar
21 with that work in the guru group that we constituted to look at
22 this stuff. So, they knew of that work. The final report
23 wasn't necessarily available, but they were familiar with the
24 work.

25 MR. KERR: Good enough.

1 I simply made a suggestion, and it may be a bad one,
2 because it's sort of ad hoc.

3 MR. BARRETT: I think it would be useful for us to
4 try to reference some of the risk analyses that have been done,
5 including this Sandia effort to pull some of them together.
6 It's a useful one.

7 MR. KERR: Thank you.

8 MR. BARRETT: I'd like to make one more comment.
9 There was a discussion a little earlier about the
10 question of when you go from emergency operating procedures to
11 accident management and the difficulty that might cause for the
12 staff.

13 One of the elements that we are examining, as part of
14 the framework study that's the part of this accident management
15 that we're not talking about today, is to give guidance on this
16 very process of decisionmaking. Who is authorized to make
17 decisions at what point? Who within a utility, for instance,
18 is authorized to make a decision to vent the containment?

19 So, that is an element that is the program that we
20 believe is a very important part of an accident management
21 program, is to think in advance of how you're going to make
22 your decisions.

23 MR. KERR: By the way, having 50.54(x) and (y) in
24 front of me, I do not consider what is here to be very clear as
25 to when and what action needs to be taken, but that may be a

1 personal difficult and not a general one.

2 MR. CATTON: Is it the fine print?

3 MR. SIESS: The question is you darn well better be
4 able to justify it after it's all over if it didn't work and
5 maybe even if it did.

6 MR. CARROLL: Sure, but isn't that reasonable? How
7 else would you write the regulation?

8 MR. SIESS: Well, if the object is to write
9 regulations, this is the way to do it. If the object is to
10 help protect the health and safety of the public, there may be
11 a better way.

12 MR. REMICK: I assume we're on time, Mr. Chairman.

13 MR. KERR: I always make that assumption.

14 MR. REMICK: Good.

15 MR. KERR: Especially when I'm responsible for it.
16 Is your presentation complete?

17 MR. BARRETT: I'm finished, unless there are further
18 questions.

19 MR. KERR: Thank you, Mr. Barrett.

20 Who is next?

21 MR. BARRETT: This is Mr. Bob Paula, who will discuss
22 the generic letter 88-20 supplement.

23 [Slide.]

24 MR. PALLA: My name is Bob Palla. I'm with the Risk
25 Applications Branch of NRR and I'm going to give you a

1 condensed version of what I plan to talk about today.

2 I'm going to just briefly touch on a little bit of
3 background that has led up to the issuance of the strategies.
4 I'll discuss the nature of the strategies briefly. Tim Lee
5 will talk about them in more detail and Bill Luckas after that.

6 I'll briefly summarize what the generic letter does
7 and doesn't do, what it will require and what it won't require
8 of Licensees and then finally give you the summary of the
9 status on the letter.

10 [Slide.]

11 MR. PALLA: Accident management strategies, while not
12 the focus of previous documents related to IPE and severe
13 accidents have been brought up in several places. I just
14 wanted to flag a few places in which this was the case.

15 In Generic Letter 8820, which initiates the
16 Individual Plant Examination, it is pointed out that in the
17 course of doing an IPE Licensees may identify actions that can
18 reduce risk and Generic Letter 8820 encourages Licensees to
19 implement such measures in the form of EOPs.

20 In the IPE submittal guidance document, NUREG-1335,
21 Licensees were requested to report in their documentation on
22 the IPE study any strategies that they identified through the
23 IPE and took credit for in the analysis.

24 [Slide.]

25 MR. PALLA: In our Commission paper on accident

1 management, SECY-89-012, which we presented in January of this
2 year, we described accident management procedures as one
3 element of five in an accident management framework and we
4 stated that NRC would be providing to Licensees a set of
5 accident management strategies for them to consider in their
6 IPE.

7 Finally, in response to our meeting with the
8 Commission in a Staff requirements memorandum the Commission
9 directed the Staff to provide Licensees such strategies on a
10 schedule consistent with the IPE so that the Licensees could
11 consider these and implement them if appropriate in concert
12 with doing that analysis.

13 They asked that the Staff look at potential drawbacks
14 of the strategies that could result in a reduction in safety
15 and they pointed out that, well, the Licensees are to be
16 cautioned on the implementation of strategies that could be
17 misapplied.

18 [Slide.]

19 MR. PALLA: In SECY-89-012 we provided a list of 20
20 or so accident management strategies. These could be
21 categorized into three general categories, such as conserving
22 or replenishing limited resources -- for example, load shedding
23 to extend battery life or throttling of containment sprays to
24 extend UST inventory.

25 The second category -- using existing systems for

1 innovative applications. For example, the use of fire pumps
2 for core injection in BWRs.

3 Finally, the feeding interlocks or overriding trips
4 in emergency situations, and I have provided an example there.
5 This is a potentially hazardous situation and we recognize it
6 but reopening MSIVs is a good example of the kinds of things
7 that we're thinking in that area.

8 We have performed some work at Brookhaven and Pacific
9 Northwest Labs have evaluated these strategies further and with
10 the primary emphasis to further articulate what the strategies
11 are and to highlight some potential drawbacks that utilities
12 should be aware of when they look at the strategies.

13 We plan to provide this new NUREG/CR as an attachment
14 to the generic letter supplement and that's really all I want
15 to say about that.

16 [Slide.]

17 MR. PALLA: It is important to know what the letter
18 is doing, what it is going to ask Licensees for and more
19 importantly what it doesn't require of Licensees.

20 The letter will provide the list of strategies, the
21 same list that was in SECY-89-012 and it will provide a
22 NUREG/CR attachment with the description of the strategies.

23 It will be provided in the context that it is
24 information for licensees to consider. Now we encourage them
25 but we do not require them to consider this in conjunction with

1 their IPE. We recognize that the timing is -- there may be a
2 mismatch there. We would encourage it to the extent possible.

3 [Sounding of alarm system.]

4 MR. ILLA: We do not require any reporting of what
5 they do with these strategies beyond what was already stated in
6 Generic Letter 8820, namely if you do an IPE, find a strategy
7 that you would like to take credit for and do so, then we
8 should hear about it in the documentation but there is nothing
9 new in this generic letter supplement.

10 We have made a concerted effort to not imply that
11 these things should be implemented so it's strictly a situation
12 where we're providing it for Licensee's to consider
13 information.

14 MR. REMICK: A question: Nowhere could I find in
15 this Supplement 2 any reference to training as appropriate of
16 personnel if you do develop new strategies. Is that because it
17 is covered in the 88-20 letter or Supplement 1? But I don't
18 find the words "accident management training" anywhere in the
19 document.

20 MR. PALLA: It is silent on training. Our thinking
21 is we're mainly trying to put these strategies on the table for
22 Licensees to consider. If they find one that they think is
23 suitable for their plant and choose to implement it, I believe
24 that training should be a part of the implementation of any of
25 those but we didn't try to speak to that here. The purpose

1 here is just to inform them of the strategy and not to set, not
2 to prescribe or to say anything about training that should go
3 along with them if implemented.

4 MR. REMICK: But am I correct that the Generic Letter
5 88-20 or the Supplement 1 does talk about training?

6 MR. PALLA: 88-20 does discuss training, in a
7 general sense I believe.

8 I am saying Generic Letter 88-20 on the IPE does
9 include some discussion of the value, the need for training as
10 part of procedures and yes, next year, when we -- really the
11 main task of the accident management effort -- when we develop
12 an accident management framework, this is a key element of that
13 framework.

14 We will devote a lot of attention to training at that
15 point but in this generic letter supplement, just strategies.

16 MR. REMICK: Thank you.

17 MR. KERR: Please continue.

18 [Slide.]

19 MR. PALLA: Okay, let me give you a brief status of
20 where the letter stands right now.

21 NRR and RES staff has looked at the NUREG/CR in an
22 earlier state and provided numerous comments on it. These
23 comments were incorporated into the October '89 draft which has
24 just been distributed back to the reviewers and we expect some
25 additional comments but I'd characterize them as -- we are

1 expecting minimum comments.

2 We have had the Office of General Counsel look at the
3 letter. They have completed their review. They have
4 recommended and we haven't seen them yet but they are going to
5 be recommending some minor changes to the language. The
6 essence of their comments are of a cautionary nature. They are
7 pointing out to us that this letter does not provide any
8 regulatory basis for requiring anything. If we should go down
9 the road a year from now and come to a plant that doesn't have
10 one of these strategies we can't point back to this letter and
11 say why didn't you have it? We told you about it in 88-20,
12 Supplement 2. OGC is going to make a point to tell us that.

13 With regard to CRGR, I know when we talked with you
14 last time we were planning to go to CRGR and have them review
15 and approve this document before we issue it. The character of
16 the letter has changed somewhat from the form it was in at that
17 point. It is now much more clear that the information in there
18 is to be provided for Licensees' information, no new
19 requirements, and as a result, because it has no new
20 requirements, we don't view CRGR approval as a requirement for
21 issuing a letter.

22 We are providing it to them for their information
23 with the request that if they feel it appropriate or if they
24 feel additional action is needed to let us know and we'll
25 discuss that further with them.







1 Finally, as recommended by ACRS in our previous
2 meeting, I think ACRS was puzzled by the fact that we didn't
3 have industry, direct industry input into this process. Now
4 what I think what we didn't say at that time was that we do
5 have industry input into the strategies in an indirect way
6 because these many of them have been extracted from industry
7 sponsored PRAs there was indirect input to it but beyond that,
8 in follow-up to the ACRS comment, we have sent the document,
9 the draft NUREG/CR to the NUMARC people with the request that
10 they coordinate a review of the document with the owners'
11 groups.

12 They have distributed to the owners' groups already
13 and we have received some preliminary comments, feedback,
14 verbal feedback from NUMARC and the indication is that the
15 owners' group representatives don't have any problems with it.
16 They think it looks pretty reasonable. They will be formally
17 transmitting us a response on that by the end of November is
18 their target, so we are trying to -- the point I want to make
19 here also is that we want them mainly to look at the question
20 of technical accuracy and inconsistencies with EPGs and EOPs,
21 recognizing that these things might have come from people with
22 different experience.

23 We don't want to take a strategy that maybe came out
24 of a Westinghouse plant and give this thing out and then have
25 it create a problem for someone with a CE plant so there is, I








1

IMAGE EVALUATION TEST TARGET (MT-3)









1

IMAGE EVALUATION TEST TARGET (MT-3)










1

IMAGE EVALUATION TEST TARGET (MT-3)



1

IMAGE EVALUATION TEST TARGET (MT-3)



1 think it's beneficial to have them take a look at it and see if
2 there is any rough edges on it.

3 [Slide.]

4 MR. PALLA: Just finally, the only point to show in
5 the schedule here is to point out that we do still intend to go
6 forward with this supplement to the generic letter in the
7 December time frame. Again, it's subject to CRGR agreeing that
8 this is not something that they need to look at very closely.

9 That's really all I wanted to tell you about the
10 letter itself.

11 MR. REMICK: Question. If I recall -- and maybe I am
12 getting mixed up on which IPE letter and supplement and so
13 forth, but at one stage, and that I guess would be about a year
14 ago, we had a presentation on this and if I recall, the Staff
15 was proposing some immediate actions for Licensees, some kind
16 of what they observed as good ideas and this is the proper
17 letter that that was associated with and I assume that you have
18 taken those out now, is that right?

19 There is nothing here that says we think you should
20 immediately do this --

21 MR. PALLA: Yes. The original -- in our SECY paper,
22 SECY-89-012, we had attached as an enclosure a draft of a
23 generic letter and it did take a rather aggressive approach. I
24 think it was before its time, in fact.

25 We have now taken a two-step approach. This

1 supplement that I am talking about will disseminate strategies.

2 MR. REMICK: Right.

3 MR. PALLA: The letter that will actually talk to the
4 question of framework and accident management capabilities in a
5 broader sense is the one that we're scheduling for next year
6 and this will be after we have had a chance to review the
7 NUMARC guidelines.

8 MR. KERR: Thank you.

9 MR. SHERON: Mr. Remick, let me just interject if I
10 could. Brian Sheron from the Staff.

11 The Generic Letter 88-20 told the industry that, to
12 use my boss, Denny Ross's phrase, "watch this space" in terms
13 of accident management.

14 We did not provide them with any specific guidance
15 other than to say that we did consider it part of the closure
16 process. We did put in that letter a statement that said if
17 you do come across as part of your IPE some strategy, some way,
18 accident management that was very beneficial, please do not
19 wait, hesitate to implement that at your plant in order for
20 this, more structured -- do it now, don't wait.

21 The second thing which just may not have been pointed
22 out here, keep in mind the NRC is in the unique position -- we
23 are basically a clearinghouse for all PRA and risk assessment
24 type of documents that are generated by the industry.

25 We get to see what all the industry does in the way

1 of PRAs and the like.

2 One of the concerns that the EDU had back when was
3 that we were the repository and we were not disseminating the
4 insights from these PRAs back to the industry. He was very
5 concerned that we could be accused of sitting on information
6 that would be of value of the industry.

7 One of the things he instructed the Staff to do was
8 to gather these insights and particularly in the area of
9 accident management. In other words, go back, look at the
10 PRAs, find out the kind of things that the industry themselves
11 had discovered and done, okay, to improve their plant as a
12 result of their PRAs. Try and put them together into a general
13 form, okay, and send them back out to the industry so that they
14 had them and they could factor these in and that's what this
15 letter tries to do. It tries to just codify all those insights
16 that we got from the IPEs and put them in one place so that the
17 industry can take advantage of them.

18 We were a little cautious because we didn't want to
19 just put out everything so we devised what we call the A and B
20 strategies.

21 The A strategies are the ones we're very comfortable
22 with, that everybody says yes, we think these are a net benefit
23 and that maybe the answer to Dr. Kerr's question -- a lot of it
24 may not have had a big risk reduction but the risk reduction
25 was balanced by the costs you might say. In other words, it

1 was not an expensive fix and they did see some reduction in
2 risk.

3 These are the things that are in that letter and it's
4 merely to inform the industry and get them up to speed with
5 what we know.

6 MR. REMICK: I think that's good, and I think that
7 and I believe I remember our comments from back then. It's
8 easy to get these things mixed up from time to time. One is
9 that in the original draft we say, apparently with the SECY
10 document, it says develop accident management programs.
11 Incidentally, here are some things that you should do now.

12 Our argument was, well, you ought to provide that
13 information to them, but don't prejudge whether they should do
14 it now. I think that's what you're doing. You're providing
15 them with the insights, but you're not mandating date that at
16 this time -- one of the things, I think, was the BWR owner --
17 the Rev. 4 of their -- I forget what those are -- guidance,
18 EPGs. There are some things like that.

19 Our feeling at the time was, why are you telling
20 people to do these things at this point, rather than giving
21 them the information and allowing them to incorporate that into
22 the development of their accident management plan. I think
23 you're saying that that's the process or the procedure you're
24 following now?

25 MR. SHERON: Yes, sir.

1 MR. WARD: Brian, I was interested in your comment
2 about the NRC being the repository or the center of
3 information on PRAs. I thought there were some PRAs that have
4 been held by the industry and haven't been released to the NRC;
5 is that right?

6 MR. SHERON: Yes, there are some that the industry
7 has done which they haven't submitted to the staff, but I'm
8 saying that when Utility X sends in a PRA and we see also the
9 PRA from Utility Y and Utility Z and we look them, we're the
10 only ones that can see whether, for example, Utility X missed a
11 vulnerability that Utility Y found for their plant.

12 MR. WARD: And there is no comparable activity
13 sponsored by the industry going on in this process?

14 MR. SHERON: I'm not aware of any. We actually --

15 MR. WARD: That's interesting.

16 MR. SHERON: We were a little bit concerned about
17 that when we were developing the IPE letter. One of the things
18 we told the Commission in the IPE Commission paper, was that we
19 would perform this function when we reviewed the IPEs.

20 We were very afraid, -- let's, for example, take a
21 generic -- like a plant with a Mark I containment. Suppose
22 that we received 17 IPEs from owners with Mark 1 containments
23 and the 18th one that came in uncovered some vulnerability that
24 the other 17 forgot about or didn't catch?

25 We felt that that would be a function of the NRC to

1 go back to those other 17 utilities and advise them of what
2 this 18th utility found. We're the only one that can do that
3 right now.

4 MR. REMICK: Dr. Kerr, we're scheduled for a break at
5 10:00. Should we take it at this time?

6 MR. KERR: Let's do.

7 MR. REMICK: Okay, let's take a break and return at
8 10:15.

9 [Brief recess.]

10 MR. REMICK: Dr. Kerr, do you want to pick up where
11 we left off?

12 MR. KERR: Yes. Dr. Lee, are you ready?

13 MR. LEE: Yes.

14 [Slide.]

15 MR. LEE: My name is Tim Lee, and I'm a staff
16 engineer with the Office of Research, which is responsible for
17 the NRC program to assess the Candidate Accident Management
18 Strategies. We will just make a brief introduction of the
19 program and then turn it over to Bill Luckas from Brookhaven to
20 discuss in detail the results of their assessment work.

21 [Slide.]

22 MR. LEE: As has already been indicated, the purpose
23 of this program is to point out the positive and negative
24 aspects of features of strategies and disseminate the insight
25 for possible use by the licensees in their conduct of IPES.

1 We started with this document and identified
2 strategies which were later reviewed by the group of NRC PRA
3 experts and they selected about 20 strategies for further
4 assessment. I would like to point out, in particular, that
5 included in those surveys are the industry documents.

6 They include not only those from Seabrook, Vermont
7 Yankee, and a publication by EPRI. The task of assessing the
8 strategies are divided between the Brookhaven and PNL because
9 of the time constraints. Brookhaven is responsible for putting
10 together results from the two laboratories and to draft a
11 final report.

12 The initial draft of the report was extensively
13 reviewed by the staff, including instructors from the technical
14 training center who has broad experience in the nuclear plant
15 operations. The revised draft was issued in mid-October. That
16 included all the comments that we received from this review.

17 This is a copy that we have submitted to you for your
18 review and comment or approval and this is the subject that
19 Bill Luckas will be discussing.

20 MR. KERR: What is an NRC expert group?

21 MR. LEE: Okay, just to name those; we have Matt
22 Taylor from EDO, Cunningham from the Research Office, William
23 Hodges, Bob Jones and Rich Barrett from NRR. We have people
24 from AEOD, -- from the CTC later on.

25 MR. KERR: Thank you.

1 MR. LEE: We still plan to publish the final report
2 by the end of this year.

3 MR. MICHELSON: Just to get some idea of how you do a
4 PRA for some of these severe accident situations, for instance,
5 in the case of post-accident response, you may wish to
6 manipulate some air operated valves in the plant, particularly
7 on PWRs.

8 Does your analysis go to the depth of taking into
9 consideration whether or not there are accumulators on the
10 valves so that they could be operated? Whether the check
11 valves on the accumulators would expect to work after sitting
12 in the plant for forty years? Do you include considerations of
13 whether the air system is even lost to begin with, what it's
14 probability of failure for the particular severe accident
15 situation that exists?

16 This would be very important in the case of relief
17 valves, for instance, that are often air operated and which you
18 might want to maneuver during a severe accident. Do you know
19 you've got air with which to maneuver them?

20 MR. LEE: Yes, we considered those situations, and
21 actually, one of the strategies which you will see later,
22 addresses that aspect.

23 MR. MICHELSON: All right, so if I go to a PRA, I can
24 expect to see how those events were analyzed in terms of
25 likelihood of happening and so forth?

1 MR. LEE: I cannot assure that you can find a number,
2 but when these strategies are implemented, what will be the
3 change in the resources of the plant.

4 MR. MICHELSON: At least they're being thought about
5 and discussed in the procedures?

6 MR. LEE: Yes, we have considered those.

7 MR. MICHELSON: Thank you.

8 [Slide.]

9 MR. LEE: One of their recommendation we received
10 form their expert groups during their review of the initial
11 draft, -- maybe you should add -- I apologize for putting up
12 this busy slide to cause eye strain, but one of the
13 recommendations that we received from the expert groups is that
14 maybe we should ask for some kind of a road map which can
15 provide a clearer picture of the safety objectives of each
16 individual strategy.

17 In response to this request, we have developed this
18 logic diagram which, I believe, shows in a better perspective,
19 the relationship between the safety functions to be preserved
20 and applicable strategies under various accident conditions.

21 This diagram also shows the interrelations among the
22 different strategies. The report you have is structured in
23 accordance with this logical diagram. The numbers listed here
24 are the Section Numbers in the report you have received.

25 With that, I will turn this over to Bill Luckas and

1 discuss each of the strategy in more detail, unless you have
2 any general question beforehand.

3 MR. KERR: Thank you, Mr. Lee.

4 MR. CARROLL: What was your screening strategy to
5 eliminate a number of candidate strategies? You indicated --

6 MR. LEE: A lot of the strategies were eliminated
7 because they are largely uncertainties as to its usefulness or
8 there is a potential for advanced defect. I didn't mention it,
9 but we divided the strategies identified initially into two
10 categories, A strategies and B strategies.

11 The A strategies are the strategies we believe are
12 better understood and we can present to licensees'
13 consideration immediately. The B strategies are those
14 strategies with more questions which we will require more
15 research to determine the uncertainties.

16 MR. CARROLL: So you may add to your list of 20
17 candidate strategies at some time in the future after you
18 evaluate these?

19 MR. LEE: Yes, that was our intention. As a matter
20 of fact, as Mr. Palla indicated earlier, we are planning a
21 workshop on accident management and we hope to add some more
22 strategies to the list.

23 MR. MICHELSON: Thank you.

24 MR. CATTON: Is the steam to bleed steam generators
25 during secondary side bleed and feed so far down on the list

1 that it only deserves an asterisk or is it somewhere else?

2 MR. LEE: Mr. Luckas will discuss this.

3 [Slide.]

4 MR. CATTON: I see it down in the corner with an
5 asterisk.

6 MR. LUCKAS: The strategies that Brookhaven and
7 Pacific Northwest Lab are involved with are the ones that you
8 see here. This was just to complete the idea of looking loss
9 of a function; in this case, heat sink. That's already there.
10 That's not a strategy to be looked at. That's there. It's in
11 the plants right now.

12 So we're not looking at it. That's not anything
13 additional. That's one that definitely is in the emergency
14 procedures.

15 MR. CATTON: But there are strategies to make sure
16 that you can maintain the secondary side feed and bleed when
17 things happen.

18 MR. KERR: Ivan, I think his point is that he
19 believes that this is already covered in the emergency
20 operating procedures, so they didn't cover it here. Isn't that
21 correct?

22 MR. LUCKAS: That's correct. It's already covered.
23 We were just completing a process so if someone would have
24 asked that question. In fact, by trying to explain it, we've
25 made it more complicated. But now let me make it very --

1 MR. CATTON: I was told to refer to Section 3, and I
2 looked at Section 3 and I didn't see anything.

3 MR. LUCKAS: This is a simplified diagram of what you
4 just saw in this logic. My name is Bill Luckas, I'm a
5 technical advisor, Brookhaven National Laboratories. My forte
6 is an operational background, the same as the people from the
7 TTC.

8 Our role in this was to assess whether any of these
9 things really could be done. What I mean by really could be
10 done is that they were feasible, within some sort of constraint
11 as to being relative, that they weren't off the wall in terms
12 of what it would cost to do.

13 I think, as Dr. Remick had mentioned earlier, one of
14 the things that is implicit behind there is if they ever choose
15 to implement any of these things, there's going to be a long
16 hard look as far as what's required for the trading and the
17 people, because in most cases this is a minimal impact on
18 hardware and some great impact, or not so great impact on the
19 personnel involved.

20 MR. KERR: Mr. Luckas, you said you had an
21 operational background.

22 MR. LUCKAS: Yes.

23 MR. KERR: What does that mean?

24 MR. LUCKAS: I held, it's now expired, an SRO license
25 on boiler water reactor, and also certified as an operator on a

1 pressurized water reactor.

2 MR. KERR: Thank you.

3 MR. LUCKAS: And the plants, as it if didn't matter,
4 were Millstone & Zion.

5 [Slide.]

6 MR. LUCKAS: Now, what I would like to do -- bear
7 with me, because there are 20 of these. We have one half hour
8 to roam, if you will, through them. This is the first
9 challenge.

10 MR. KERR: As a matter of fact, I would say that I
11 don't think you should try to roam through all of them, but try
12 to pick some representative ones.

13 MR. LUCKAS: No. I didn't mean that. I mean in the
14 sense that I'm going to pick some. I'm going to take the
15 strategies within a given challenge. These are those five
16 boxes that I just showed you. We'll go down part way and then
17 hopefully stop, unless there's one you want to see, but then
18 that will jeopardize whether I'll get through any of the other
19 ones.

20 We started this with the Subcommittee and we got so
21 far. Anyway, this was the first one, this first challenge,
22 having to do with insufficient coolant. There are a number of
23 strategies that are implied, this idea of reducing sprays and
24 interfacing system LOCA and so forth. You can read, as I was
25 told last time.

1 In any event, let's go on and take a quick look at
2 some of these.

3 [Slide.]

4 MR. LUCKAS: One of the things that they do in a
5 plant -- now we're talking about -- and we have to look at
6 these things and keep them separated between the two.

7 What we're talking about here is containment spray,
8 really in a PWR, because what we're concerned about is keeping
9 enough water for the injections of the core. Some would say
10 that you -- I hold everything to the core and then I'd go worry
11 about the containment. But the way our plants are set up right
12 now, our Westinghouse, CE and B&W, there's a set point at
13 which, at certain pressure in the containment, at which these
14 things are going to fire off.

15 And if you look at what's being done right now, some
16 of them address that if the pressure comes down, then you could
17 cut down the spray; therefore, providing more water to the
18 core. This is an example of what I was saying before. This is
19 something that's actually being done and, therefore, when you
20 look at this as an overall strategy, it certainly, at least in
21 the context of some generic PWR, can be handled.

22 There are some concerns, if I had gotten to a point
23 where I already core damage, where I'd be losing the ability
24 for fission scrubbing, fission product scrubbing. There are
25 other concerns. All of these have to be looked at from the

1 standpoint of the benefits and the downsides.

2 Again, as Tim Lee had mentioned, what we did was to
3 identify the strategy, decide whether we've seen it's done or
4 we think it can be done, looking through procedures, plant
5 PNIDs, any number of things, look at whether the -- in this
6 case it says it does, and then what else some of the concerns
7 that may be associated.

8 Some of those may be extraordinary. They may be such
9 that the utility decides I'm not going to try that, I really
10 don't want to try to take advantage of that; in this case,
11 providing water to the core in difference of taking some away
12 because of some other concerns; namely, the containment itself.

13 So that's just one. I would like to just introduce
14 you to a bunch of these.

15 MR. MICHELSON: Let me just ask a question, just to
16 get a feel for the level at which these are explored. You say
17 you're going to throttle the core spray discharge valves. I
18 assume that in a particular plant, you check to see if you can
19 even throttle the core spray discharge.

20 MR. LUCKAS: That's up to the plant. They've got the
21 option to look at -- we're suggesting that they might -- they
22 may decrease the flow. They may have the ability to do it this
23 way, this way, this way, or they may say I can't do it all.

24 MR. MICHELSON: But these are just kind of guidelines
25 of things to look at.

1 MR. LUCKAS: These are ways that we think that it's
2 possible, and we've seen being done. I wouldn't suggest that
3 somebody takes a gate valve, like we see, and start throttling
4 with the thing.

5 MR. MICHELSON: You may not even be able to throttle
6 a gate because the control system generally is full-open full-
7 close and not intermediate throttling. So it's not even
8 possible.

9 MR. LUCKAS: That may be so, but it also -- the other
10 part of it is you may be getting yourself to a point in an
11 accident where you don't care whether you can throttle it very
12 well or not. You want to be able to perform that function
13 that's necessary to be performed under those extraordinary
14 circumstances.

15 MR. MICHELSON: The only caution, of course, is don't
16 start misusing equipment that you might have to later adjust as
17 well.

18 MR. LUCKAS: That's correct.

19 MR. MICHELSON: You might have to later close that
20 valve, and if it won't close anymore, you may have done more
21 harm than good.

22 MR. LUCKAS: That's correct. Again, from the
23 standpoint of addressing the IPE, these are suggestions which
24 they might consider based upon what we've seen done. If you
25 take, for instance, as a -- we don't -- the intention was never

1 to identify this plant does this or that, but if you take a
2 class most of the B&W plants do, in fact, throttle down. They
3 maintain as the pressure comes down in the -- as the pressure
4 comes down, they'll throttle back on these systems and hold a
5 certain flow. They won't hold a certain -- they just won't let
6 these things run out.

7 MR. MICHELSON: They were designed for maneuvering
8 PWRs or not necessarily designed for maneuvering. They had
9 different reasons on the BWR.

10 MR. LUCKAS: I said B&W.

11 MR. MICHELSON: Well, that's a PWF.

12 MR. LUCKAS: Yes. It's a PWR.

13 [Slide.]

14 MR. LUCKAS: Here is the one that we're all -- this
15 is the one that I don't really enjoy talking about very much,
16 because this is really -- I can remember when we -- let me just
17 give you -- when we were up looking at -- it was an assessment
18 a few years back of whether Seabrook could handle an
19 interfacing system LOCA. We went through the details of the
20 plant and we found certain things they could do and they
21 couldn't do, and they would demonstrate that they had done it.
22 They could demonstrate it on a simulator or they couldn't.

23 This is, again, just simply what would almost be -- I
24 don't mean to say intuitively obvious, but there are some
25 things which are not being done -- maybe not being done in

1 certain plants. They are or they're not. Which we found have
2 been done in other plants by virtue of several research studies
3 that might be of interest to help out.

4 Of course, this is the situation -- really, in the
5 interfacing system LOCA we're really concerned about just
6 bypassing the containment so we don't get any water back on the
7 blowdown on the primary system.

8 Again, I'm not going to go through the level of
9 detail, but there are real concerns about it. You've got to
10 remember; you start playing some of these games. The best
11 example of changing something and it almost got worse is what
12 happened at Davis-Besse. There was a situation where they
13 installed some new -- they installed this new logic and it got
14 them into more trouble than it wound up being worth, at least
15 from an operational standpoint.

16 [Slide.]

17 MR. LUCKAS: There are two parallel ones. Refilling
18 the condensate storage tank in a BWR, and the next one is a --
19 you fill in the refueling water storage tank in a PWR. Again,
20 there are many --

21 MR. KERR: From your operational experience, do you
22 think this sort of thing would be almost intuitively obvious to
23 the typical operator or is he likely not to have thought of it?

24 MR. LUCKAS: Dr. Kerr, I think I said when I
25 mentioned -- I'm going to answer this. When we -- and I had

1 never experienced this before in all -- whatever operational
2 background. I'd never been part of an emergency response drill
3 in terms of watching it.

4 I just came back from one on the west coast and one
5 on the east coast. We'll just leave the plants out of it for
6 the time being. What it finally came down to, they challenged
7 the operators to the point that they can get beyond the control
8 room and they get their release and so forth.

9 Well, to do that is really extraordinary as far as
10 humans are trained to mitigate and to prevent the consequences.
11 They finally, in both cases, gave up and told them you're going
12 to have to accept this as life. This is the way it is. I
13 failed this, this, this and this, and there's nothing you can
14 do about it.

15 Because what they do is right on the spot, sit down
16 -- in the case of this one utility, I'll give them credit
17 because the credit is due. It was Peach Bottom. They sat
18 right down there and they wrote their change in the technical
19 support center and it was a violation of the existing
20 procedures, but their procedures call for them to write a
21 change on the spot which then was not a violation of the
22 procedure.

23 They did all of this. Having gone through this whole
24 operator training in the 1970s as opposed to now, I was unaware
25 of what support that the technical support center and the

1 emergency operating facility and all the rest of these could
2 bring to bear to a situation to help the operator so he could
3 just safely shut down the plant, and that was the whole idea of
4 these organizations.

5 MR. REMICK: That is not the first case I've heard
6 recently. The same thing. It's very difficult to outsmart the
7 operators in the tech support, so eventually you have to tell
8 them, look, you can't fix it so we can proceed with the
9 emergency --

10 MR. LUCKAS: When it's a full blown accident and gets
11 FEMA and the NRC off-site, it frustrates the operators because
12 they really would like -- because -- well, of course, there's
13 no consequence to this, but they're going to show what they can
14 do, and they do it very well.

15 [Slide.]

16 MR. LUCKAS: This one is a little -- I didn't even
17 really talk about the last one, per se. Both of them are the
18 same. The idea is I want to get water back into the core, in a
19 condensate storage tank in a BWR, or the refueling water
20 storage tank in a PWR. The issue here is, though, I can always
21 get condensate water back. I can get some water. It may not
22 even be the greatest water, but I can get it back in the tank
23 by gravity, by pumping it, whatever.

24 But when you want to put a little boron in this
25 stuff, like to the tune of about 2,000 parts per million, this

1 gets a little bit more complicated. The normal makeup for the
2 plants are such that they don't even bother worrying about it.
3 However, the normal procedures say if the level gets low, make
4 up at 100 to 150 gallons a minute, but when the accident goes,
5 they say it's gone.

6 Now, it's very interesting that the 1150 analyzed
7 plants made the changes so that they could take advantage of
8 whatever they had at the plant at the time very comfortably.
9 In other words, they said during an accident, they had somebody
10 start to refill it. Even it would be inadequate, it was
11 something.

12 So at least it shows that when you address it with a
13 level at a given point and they want to take advantage of it,
14 they put it right in the procedures, and there they were in the
15 1988 and 1989 versions of their procedures. Whatever they
16 could do. I'm not saying that you can put mega thousands of
17 gallons a minute back into this tank. I'm not saying that.

18 What I'm saying is there is some limited capability,
19 but maybe that will help them. They have to look at that.
20 Again, a concern is if I don't have borated water and I just
21 put pure water in, well, then it could be a reactivity problem
22 if I start shoving that into the core.

23 MR. LEWIS: I wonder if I could just raise a
24 procedural question. I understand that these are just things
25 for the plants to think about, but as I read the 50.54

1 paragraphs that allow a licensee to depart from tech specs and
2 such things, they say a licensee may take reasonable action
3 that departs from a license condition.

4 Now, reasonable is in the eye of the beholder. I
5 wonder if by supplying this list, you're providing a definition
6 of what is reasonable that will hold up in later post-accident
7 reviews.

8 MR. CATTON: After an accident?

9 MR. LEWIS: That is inevitable after an accident.

10 MR. KERR: I think that needs to be addressed in the
11 Staff, because he is Brookhaven.

12 MR. LEWIS: I see. Okay. Fine. I will address it.

13 MR. LUCKAS: Again, not having been that route, and
14 the question being asked earlier, and it was asked at a
15 subcommittee meeting, I would think that one of the ways that
16 the utility deals with this is exactly what I said. They have
17 their own internal procedures, which allows them to make
18 changes with a quorum of people, engineering, operation or
19 whatever, on the spot, and will do so. I am talking about
20 paper, even if it is handwritten. Because in many cases,
21 setting up for these types of changes is not something that can
22 be done instantaneously, anyway. So they get five minutes and
23 they all decide, they get a quorum.

24 I'm in there in the simulated control room, which
25 happened to be the simulator room. And the word came down,

1 yes, they agreed with the operation staff, and they were going
2 to go ahead and they were going to jury-rig one high pressure
3 service water pump to another. And off they went. And I'm
4 sure that was not in any procedure, the way it existed then.
5 But more than likely, I suspect if I went up to TSC, I would
6 have seen it, if I were concerned about that.

7 MR. PALLA: I would like to just take a second to say
8 that no, that is not the intention, that this list of 20 is not
9 meant to mean these are the reasonable ones, and anything else
10 is not reasonable. And also, for many plants, these would not
11 be reasonable ones. So that was not the intent.

12 [Slide.]

13 MR. LUCKAS: This is one which is almost intuitively
14 obvious, and is in fact probably being done. And I fail to, I
15 personally fail to understand what the concern is, except maybe
16 it is the manual intervention. If it actually does not work
17 from the control room, you need this source of water on the
18 switchover when the water gets into the containment sump in the
19 PWR. And maybe you ought to think ahead of time, as Dr. Kerr
20 was mentioning before, what it is that you should need, such
21 that you will be able to go into that area and manually open
22 those valves, if that as all possible. But think about these
23 things ahead of time, not at a time when all of a sudden it
24 fails, and you say, oh-oh. Because we are beyond the space of
25 allowing these single failures. We're beyond that.

1 So all of a sudden you've got all this water sitting
2 in the base of the containment, you are almost out of this
3 refueling water storage tank, or you can't make up to it --
4 that was one of the other strategies was how well you could
5 make up to it -- and you need it, badly.

6 So a little bit of taking advantage of that. In this
7 case, they do it. But this came out of the concern, out of I
8 think in the Zion 1150. They kept saying the probability that
9 it wouldn't work, that the switchover wouldn't. Well, you
10 don't have just what is in the control room to make that
11 happen, on either manual or automatic. You do have the
12 ability, as big as those valves are, you do have the ability to
13 think about whether you can or cannot get them open in the
14 sump.

15 [Slide.]

16 MR. LUCKAS: This is the last of that group of
17 insufficient coolant.

18 Now, this, when it was presented to us, and if you
19 looked in some of the past records, was actually like two
20 substrategies. And this really should be the last one that
21 anyone should ever want to see, because if it has been
22 portrayed as the way we understand it here, it says this is the
23 ultimate cooling source. Some plants actually have lock-closed
24 valves, keylock-closed valves, that could in fact take
25 saltwater and put it right into a reactor. Obviously, that

1 means it is on the sea and it also a boiling water reactor.

2 If we are talking about a PWR, the same type of
3 thing, only going to a steam generator. But if I can't get it
4 any other way, that is the way I am going to get it.

5 But this is something that is coming out as a real
6 possibility. Sure, there are tremendous downsides to this.
7 But when you are out of water, as I say, that is why some
8 plants have it actually, either there are spool pieces and
9 there is nothing between the two, and all they do, it is all
10 made up, though, and all you have to do is pull the blank and
11 put a spool piece in place, and you can cross-connect seawater
12 to the reactor in a boiler.

13 Others actually have the lock-closed valve. And
14 others haven't thought about it. Is that important? It may
15 well be. It is just a matter of the plant-specific design.
16 Some may be physically very difficult to do, because of where
17 these lines are.

18 What is very interesting, when we went back to the
19 plants and asked them, the ones who were gracious enough to
20 talk to us, they said oh, yes. You get somebody who is there a
21 long time. Well, they have this cross-connection that was set
22 up originally from the startup of the plant, back in 1973. And
23 yes, they can do it. They showed me, and they were proud as
24 heck to show me they could show me how you could do this thing.
25 And no one else ever knew anything about it, except in that

1 case, usually what they were smart enough to do was to have
2 between the two valves a tell-tale drain so that you could
3 never let the one go back into the other and so forth and so
4 on.

5 MR. MICHELSON: Has the Staff ever looked into the
6 long-term post-accident consequences of using saltwater in the
7 reactor and so forth? Is that worse than doing nothing at all?
8 I don't know. I just wondered. Before I would push it as
9 being a good idea, I would certainly at least make sure that
10 you don't foresee problems. You are keeping in mind, I assume,
11 post-accident means tens of days or maybe 100 days of
12 operation. And I'm not sure I'd ever want to put saltwater in.
13 But I hadn't really thought about it, and I was hoping somebody
14 had.

15 MR. LUCKAS: But isn't it interesting, Mr. Michelson,
16 that there are in fact plants that physically do? I can tell
17 you by name

18 MR. MICHELSON: There are plants that do it, but have
19 the plants analyzed whether or not it is a good idea to do it,
20 or have they just said oh, I can get water that way if I need
21 it?

22 MR. LUCKAS: I think that is all part of this IPE
23 process. Do they need it? If they don't, I think the downside
24 is for them to decide.

25 MR. MICHELSON: Has the Staff ever addressed this

1 question? Because if it is a bad idea, the Staff ought to
2 bring it to the attention of the licensees.

3 MR. KERR: You are addressing that question to the
4 Staff, I presume?

5 MR. MICHELSON: Yes.

6 MR. KERR: Is there somebody on the Staff who can
7 respond to that? Mr. Barrett or Mr. Palla?

8 MR. SHOTKIN: This is Lou Shotkin, the Office of
9 Research.

10 The question of saltwater, maybe you have in mind an
11 economic question.

12 MR. MICHELSON: I can't hear you too well.

13 MR. SHOTKIN: The Staff will not look, does not look
14 at the question of the economics of doing something.

15 MR. MICHELSON: It is only the safety that I was
16 concerned with, not the economics.

17 MR. SHOTKIN: Yes. We do have, as part of our
18 accident management program, looking into the effectiveness of
19 long-term cooling after an accident. And this has not been
20 addressed up until now. But we do plan to address it.

21 MR. MICHELSON: So you will look at whether saltwater
22 is a good idea or a bad idea?

23 MR. SHOTKIN: Yes.

24 MR. MICHELSON: From the safety viewpoint, of course?

25 MR. SHOTKIN: Just from the safety viewpoint.

1 MR. MICHELSON: Yes. That's the only one I was
2 concerned about.

3 MR. LUCKAS: Actually, with a smile on my face, in
4 1972, in September, when they blew the tubes at the Millstone-1
5 plant, and we put saltwater into the reactor. So I mean, it
6 has been done.

7 MR. MICHELSON: Oh, yes. But that was not a
8 wholesale usage of saltwater, which I think you are proposing
9 in this case. They didn't keep it there for 100 days, either.

10 MR. LUCKAS: Agreed. Absolutely.

11 MR. MICHELSON: They worked real fast at getting it
12 out again.

13 MR. LUCKAS: Absolutely.

14 MR. MICHELSON: I just, I'm not quarrelling with it,
15 but I sure hope the Staff looks carefully before we encourage
16 it.

17 MR. LUCKAS: Again, from my perspective, if I were to
18 do this in the order which I wanted, this would be the last
19 thing I would have put down just in terms of try this one.

20 [Slide.]

21 MR. LUCKAS: Okay. That was insufficient coolant.
22 And this is do I have the injection system unavailable.

23 And again, for each of these strategies, and the way
24 it is in the document, there really is a sort of a priority
25 associated with this. And what we are trying to do is make

1 better what is already there and then if it doesn't work, the
2 alternate. So that is sort of, if you will, a prevention and
3 mitigation if you will, or an alternate. And so that the order
4 in which you see these things, they get more and more difficult
5 to think about. Such as the last one that you just saw, from
6 an operational perspective.

7 MR. REMICK: I have to remind you, Mr. Luckas, we
8 have about ten more minutes on this agenda item. So you'll
9 have to keep that in mind.

10 MR. LUCKAS: Okay. Fine.

11 So these are the types of things here. I think what
12 I will do right now is just simply to pick out one out of this
13 group, because there are some others that I do wish to address.

14 [Slide.]

15 MR. LUCKAS: This one here on protective trips, which
16 would be, I guess if you bear with me, if you go through one,
17 two, it says provide emergency bypass for injection pump.

18 Again, this again has the aspects of, I need this
19 thing so bad that I don't want it to trip. But if it doesn't
20 trip, I want it to keep going. Because if it doesn't, it is
21 going to fail. That is what the trip was probably there for.

22 So this is again a challenge. We have this again
23 later on the diesel generators, the same type of thing. There
24 are right now on the diesel generators trips which are bypassed
25 on an emergency start. There is the low-boil temperature and

1 the pressure in the crankcase, and also that's bypassed,
2 because it is an emergency start. They want this thing to
3 start. They don't want it to be taken out by something which,
4 if you had the time, it was nice, and you wanted to protect
5 everything and you wanted to make sure everything was hunky-
6 dory like during the test, like a regular load test on it, you
7 let it run. But there are things that are already done this
8 way. I'm not proposing anything or leaving it to them. If
9 there is something that they would want to pull off of theirs,
10 that they would like to think about, if it is a matter of I'm
11 going to lose it, or I'm going to lose it anyway, but I want to
12 at least have it available during that time.

13 [Slide.]

14 MR. LUCKAS: Then if I go, and I am going to go all
15 the way back a little ways to the next group, if you don't
16 mind. And this is if I've lost, power loss. And this is sort
17 of an arbitrary lumping, because we are talking about
18 conserving power, non-essential loads. We are talking about
19 resupplying with portable battery chargers and replenishing
20 pneumatic supplies. And here is the one I was talking about,
21 bypassing or changing the diesel trips.

22 Okay. And then there is a whole series of crossties.
23 And these came out at a very specific analysis in 1150 where
24 there were individual plants that just happened to have, for
25 instance, a gas turbine, on top of a plant, the Surry plant,

1 which is the one that has two gas turbines. They are there.
2 Does anybody think ahead of time whether you might be able to
3 use them? We're not talking about qualifying them like they
4 are safety-related. But they're there. But finding out that
5 you just needed one little piece of something or other when you
6 have the blackout and you need a source of power is not the
7 time to start looking for it. And that what that means.

8 So again, when they do the individual IP, they can
9 say, can I think advantage of that and what is the downside.

10 There is none in here that I would like. I would
11 like to go to the -- and again, my apologies for jumping -- but
12 we are going to go down to what is called "Challenges, Heat
13 Sink Lost."

14 [Slide.]

15 MR. LUCKAS: And this is the next to last category of
16 challenges.

17 The one that we have here, this is already done.
18 This is already here. It is to re-establish the main
19 condenser. And that is the only one that is really in that
20 category that we have out of the 20. But it is important to
21 note. And in having with Bob Palla just yesterday, that it
22 looks like part of this is to be able to, the idea is, if the
23 main steam isolation valves go closed, in some plants they will
24 say it takes 50 to 100 pounds or 200 pounds pressure DP across
25 the valves to get the valves open, depending on the plant. I

1 wouldn't even try. It is in violation. The valves shut for a
2 good reason.

3 Now, can we go around the valves on the bypasses,
4 which are on the order of decay heat capability? As long as we
5 have the main condenser, as long as we have power to the
6 circulating water pump -- this won't work in a station blackout
7 -- then let's go ahead and suggest it to them, see if they want
8 to take advantage of that. Or, try to open those valves again.

9 But the big thing is you have to get the condenser
10 vacuum back again, or you will literally take the main
11 condenser and a few pounds of pressure and blow it apart.

12 MR. MICHELSON: No you won't.

13 MR. CATTON: Rupture discs.

14 MR. MICHELSON: Sure. That's what I was going to
15 ask.

16 MR. LUCKAS: I'm sorry to sound dramatic. But the
17 fact of the matter is what you are going to do is blow the
18 steam into the turbine.

19 MR. MICHELSON: That you will do.

20 MR. LUCKAS: Okay. And the idea is not to do that.

21 MR. MICHELSON: Well, in this dire emergency which
22 has led you to all these dire things, what is wrong with
23 blowing the condenser diaphragm?

24 MR. LUCKAS: That is up to them to see what the
25 consequences of that might be, if they thought so.

1 MR. MICHELSON: What I was going to ask is, is there
2 an emergency procedure analysis that is gone through and
3 decided under what circumstances it would be all right to use
4 the main condenser even without vacuum?

5 MR. LUCKAS: Right.

6 Right now we are not proposing that. You will not
7 get the bypass valves open right now, because they went shut.

8 MR. MICHELSON: Like a lot of other bypasses, you've
9 got a fix for a lot of your other procedures, too, that you
10 didn't even mention. Now you've got to go in and jerry-rig
11 stuff to get this things open. But is that considered viable,
12 then, to use the main condenser, even if you've got cooling
13 water, but you just don't have your hogging pumps?

14 MR. LUCKAS: Is it viable? Sure, we could add that.
15 I mean we could add it in the sense of do they want to try it.
16 But they are going to have to analyze what the consequence of
17 that is. That's what I meant by the fact that your -- the
18 condenser will no longer be intact.

19 MR. MICHELSON: I assume they wouldn't try it if it
20 isn't a part of their emergency procedure. If they don't have
21 a procedure to do it, they probably won't try it.

22 MR. LUCKAS: No, there was no emergency procedure to
23 do that.

24 MR. MICHELSON: Is it all right, though, to try
25 things that aren't covered by an emergency procedure? Or is

1 that against regulation?

2 MR. LUCKAS: I think, at least from my neophyte
3 perspective, that's what we're doing in many of these cases.

4 MR. MICHELSON: Well, you are leaving out a few
5 things that you might be able to do. This is not ever thought
6 to be a comprehensive list of every possibility, I'm sure.
7 It's not so plant-specific, to begin with.

8 MR. LUCKAS: That's correct.

9 MR. MICHELSON: So I just wondered on the question,
10 though, do the operators understand that they can try other
11 things, even if they don't have an emergency procedure for it?

12 MR. LUCKAS: They can't do that now.

13 MR. MICHELSON: So you can only do things covered by
14 your emergency procedures?

15 MR. LUCKAS: Emergency procedures, changes to those
16 procedures, as determined by the plant staff and the technical
17 staff supporting them during the emergency.

18 MR. MICHELSON: So they can conjure up a procedure,
19 in other words, during an emergency?

20 MR. LUCKAS: I would suspect on the spur of the
21 moment, with not having thought of this ahead of time, I don't
22 think anybody would do that. The chance --

23 MR. MICHELSON: I thought you convinced me a little
24 earlier that these guys would sit right down and write one if
25 they --

1 MR. LUCKAS: I didn't say they would write one for
2 anything and everything. I told you what they did write it
3 for.

4 MR. KERR: We're running out of time.

5 MR. SHOTKIN: Mr. Luckas, could we interrupt? We
6 would like Brian Sheron to wrap this up with what the staff is
7 expecting or would like to ask from the ACRS. If you can spend
8 the last five minutes on that.

9 MR. KERR: You won't feel hurt, will you, Mr. Luckas?

10 MR. LUCKAS: Excuse me?

11 MR. KERR: You won't feel hurt if we --

12 MR. LUCKAS: Not at all.

13 MR. KERR: Thank you very much.

14 Mr. Sheron?

15 MR. SHERON: I am Brian Sheron with the staff. Let
16 me just wrap up quickly, if I could.

17 One is what you have heard, I hope, is that we have
18 produced a document on strategies which were derived from the
19 various spectrum of sources, which we believe is consistent
20 with and in accordance with the direction we got from both the
21 EDO and the Commission.

22 We think it is a pretty good document. It was
23 developed and evaluated by PRA experts. It drew its
24 information from just a wide spectrum of sources, both from
25 within the staff as well as the industry. Basically we think

1 it is a pretty valuable technical document that the industry
2 should get right away, and at least so they have it and can
3 start using it to whatever degree they would like.

4 Also I would just point out, it is going out for
5 comment from the industry. I think this is good. It's going
6 to force them to read it. When you ask them to comment on
7 something, it means they have to read it and provide you with
8 comments as opposed to just putting it on a shelf. So I think
9 we will get some good feedback from the industry on that.

10 Remember, it is just information, it is not a
11 requirement to the industry at all. I think that the overall
12 accident management framework development is still ongoing, so
13 in other words, this is not the final word on accident
14 management.

15 We are doing a lot more work on this. There is
16 another generic letter, as you saw, that is planned for next
17 year, and I am sure you will be seeing much more of what's down
18 here, telling you about that.

19 I want to say I think we got some good comments from
20 the committee today. For example, the statement that utilities
21 should identify any regulations that they think are hampering
22 them from optimally implementing the strategies I think is a
23 good one. Because we are worried about that, too.

24 With regard to identifying the actual risk reduction
25 of some of these strategies, I think what we are going to try

1 and do is see how best we can do that, whether it is by
2 referencing documents from which the strategies were derived,
3 or the like, and so the utilities can go back and look up
4 exactly what the risk reduction was for that particular plant.
5 I think we can handle that one,

6 I guess the real question is with regard to a letter,
7 I guess I always have an opinion that if it's a good letter, we
8 can always use it, we'll take all the help we can get. I guess
9 we don't feel that it is absolutely mandatory, since this is a
10 letter that's going out for just information purposes to the
11 industry, and it's certainly not something we are asking for
12 Commission approval on.

13 But, nevertheless, I think that if the committee
14 feels that we are approaching this in a responsible manner,
15 consistent with the guidance we have gotten, and if you
16 basically concur in our approach, like I said, we would
17 certainly appreciate a letter. It would always help us with
18 regard to dealing with the Commission.

19 Likewise, I haven't heard any basic objections, but
20 again, if there are any that the committee has, we certainly
21 would need to know that before we went out with such a letter.
22 And if there are any additional suggestions or so forth, again
23 we would like to hear about those, to see if we can incorporate
24 them.

25 So with that, that's the end of our presentation.

1 MR. CARROLL: Is there any intention, Brian, of
2 asking industry to look at the ten or so strategies that you
3 have put in the other pile and maybe argue that this one ought
4 to be included, or that one ought to be included? Do they know
5 what those ten are?

6 MR. SHERON: Lou, can you answer that?

7 MR. SHOTKIN: The B strategies are ones that involve
8 a lot of uncertainty and phenomenology, might have some
9 questions of cost effectiveness, and right now the staff is
10 concentrating their efforts on looking at the B strategies.

11 If we come up with a B strategy that looks like it is
12 worthwhile to give to the industry for their use, we certainly
13 will.

14 MR. CARROLL: My question was, though, have you
15 provided that list to NUMARC?

16 MR. SHOTKIN: Yes, I believe they have informally
17 that list.

18 MR. KERR: Other questions of Mr. Sherpon?

19 Thank you, Brian.

20 One additional comment. There is in the publication
21 from the office -- well, I guess this is a weekly news item,
22 but this is from the Office of Nuclear Reactor Regulation for
23 the week ending October 27th, and it has to do with an audit of
24 the Turkey Point and St. Lucie Station blackout responses, and
25 in their blackout response, they have devised an alternate AC

1 source existing diesel generators which will be available
2 within 10 minutes for each plant. They have done this by a
3 tie, this is a single tie between units. This tie is subject
4 to a single failure and was rejected by the NRC staff as not
5 meeting the single failure criteria.

6 Now I don't know any details other than that, but it
7 occurs to me that it might be well for the group that is
8 developing these procedures to keep in touch with NRR
9 enforcement people to get some idea of what is the boundary
10 between those things that can be done and those things that
11 can't be done under existing rules.

12 Any further comments or questions?

13 MR. REMICK: Does the subcommittee have a
14 recommendation about a letter?

15 MR. KERR: My own recommendation would be that we
16 write a letter. I think the document is a worthwhile document.
17 It would propose to say so. I have some comments, and if there
18 are other comments that you would like me to add to a draft
19 letter, I would welcome them; in writing, preferably, but I
20 will take them orally.

21 MR. REMICK: Okay, any further comments?

22 MR. CARROLL: Just one other point that always has
23 intrigued me in thinking about accident management. One
24 resource all utilities have, or most utilities have, are either
25 their own gas department or a local gas department, and these

1 guys have some amazing tools that I don't think many of us ever
2 thought about in the nuclear industry. When a high pressure
3 gas line breaks, they know how to come out with a magic
4 hydraulic machine and crimp that sucker off and stop flow
5 immediately. I think that is a resource that ought to be
6 considered in your accident management strategies.

7 MR. KERR: Any further comments?

8 I turn it back to you, Mr. Chairman.

9 MR. REMICK: Thank you, and I thank the staff and
10 their consultants for the presentation. We will go to our next
11 topic, which is a discussion of adequate protection. Once
12 again, attempting to understand the staff views and the ACRS
13 views on adequate protection. Mr. Ward is our subcommittee
14 chairman in this case, so, Dave, are the staff people here?

15 MR. WARD: Yes. We haven't asked for a presentation
16 from the staff. We have some written material that we want to
17 look at, and I will try to describe what it is we need to do.

18 If you look in tab 3, there is a letter to Mr.
19 Fraley, beginning on page 6, but then the document that we want
20 to consider is a draft document from the EDO prepared, I think,
21 by Mr. Houston from the EDO to the Commissioners. It begins on
22 page 7, and there are some aspects of exactly what this
23 memorandum or SECY paper, whatever it would be, says that we
24 want to consider.

25 I think we have got a little bit of a tricky problem

1 today in dealing with this, and let me provide a little bit of
2 background.

3 You recall, of course, that the ACRS has commented
4 fairly extensively on the staff plan to implement the safety
5 goal policy. We have written several fairly lengthy,
6 comprehensive letters, and I think we have influenced the staff
7 to make a number of changes in the plan over the course of the
8 last probably two years or so. The plan now is quite a bit
9 different than the original proposal.

10 But we have not quite reached closure. There are
11 still some points in the letter, some issues -- I mean in the
12 plan, where we have -- there are some disagreements.

13 Our final letter, what I will call our final letter,
14 at least our last major letter on the topic, was in February of
15 this year, February 16th, and it described these several points
16 in which we have not yet come together, and we were in essence
17 -- the staff didn't offer any further reaction to that, and so
18 in essence it was up to the Commission to decide which position
19 it wanted to take where there was a disagreement.

20 The Commission has not yet done that. They haven't
21 moved to the point where they would be doing that, but they
22 have asked for clarification on one of the points of
23 disagreement.

24 Apparently they understand all of the points of
25 disagreement except for this one particular one which concerns

1 what the term "adequate protection" means, or at least how that
2 term or that concept relates to the safety goal and concepts in
3 the safety goal policy.

4 So they asked the ACRS and the staff to get together
5 and for the staff to issue a paper that made the ACRS staff
6 difference on adequate protection understandable to the
7 Commission.

8 Now the ACRS, I believe, doesn't think this
9 particular issue, the definition of adequate protection, is the
10 most important of the several differences that remain, but it
11 is the one which the Commission has requested this
12 clarification on.

13 As an aside, I am personally concerned that the
14 emphasis on this, worrying about the definition of "adequate
15 protection" may be obscuring some more important problems with
16 the safety goal policy implementation, some of which, I think,
17 are really quite substantive.

18 We have some indication from the Commission staff
19 that the Commission, or the Commission staff, at least, is
20 aware of the differences and before doing whatever it is
21 they're going to do with these differences, they want to have a
22 better understanding of this particular one on adequate
23 protection.

24 Okay, the staff has a way of trying to reach closure
25 on this, at least clarifying what our differences are on this

1 one particular issue. The staff, Mr. Houston, I believe, has
2 prepared this draft paper which begins on page 7 in tab 3,
3 which attempts to explain the ACRS staff differences, I think
4 without prejudice, so that the Commission can understand and
5 make a choice between the two or pick a third choice or
6 something.

7 I think the draft is quite good but in two or three
8 places, it doesn't quite accurately represent the ACRS
9 thinking. At least, I don't think it does, and I'll go over
10 that in a minute.

11 The somewhat tricky part here is how we are to reach
12 closure with the staff on what their paper is to say about what
13 we mean.

14 MR. SIESS: Say that again?

15 MR. WARD: The Commission has asked the staff and
16 we're expecting the staff to say in this paper what the ACRS
17 means by something the ACRS already, you know, discoursed
18 lucidly in its letter and obviously it wasn't understood.

19 MR. SIESS: Perhaps the letter is supposed to tell
20 the staff what they thought the ACRS means. That's different.

21 MR. WARD: Perhaps, but I guess I'd like it to say
22 what we really mean, if we could --

23 MR. LEWIS: We shouldn't say it through a staff
24 letter to the Commission.

25 MR. WARD: Okay, well that's the point I want to

1 raise.

2 MR. SIESS: I think it would be nice if we could say
3 what we mean.

4 MR. WARD: We thought we did but it wasn't clear.

5 MR. LEWIS: Really, there's a serious point here. We
6 can't be in a position of essentially certifying a staff letter
7 as saying what we mean.

8 MR. WARD: That's the tricky point I'm raising. How
9 do you want to do this? We could for example, write a letter
10 at this meeting which quotes the pertinent paragraphs in this
11 draft staff paper and then says, that's not quite right. This
12 is what we really mean. Or, we could today tell the staff what
13 we really mean and ask them to get the appropriate words in
14 their paper and give us a chance to review it before it goes on
15 to the Commission. I don't know.

16 MR. REMICK: Dave, could I suggest a possibility?

17 MR. WARD: Sure.

18 MR. REMICK: I think you've covered it but I think
19 you know, I differ with how the staff is characterizing what we
20 wrote but maybe we could convince the staff to change their
21 interpretation to something that's acceptable and then we could
22 write a letter saying we agree with the staff assuming that we
23 do, but then go on and remind the Commission that there are
24 other things that we differed with and draw their attention to
25 those without going into considerable detail, but just remind

1 them that we had other differences that we viewed as being more
2 important.

3 So we would be writing a letter and hopefully might
4 be in a position of saying we agree with the staff's
5 characterization.

6 MR. WARD: Okay. That might be a good way to do it.

7 MR. LEWIS: I have a problem with that, Forrest.

8 It might work this time, but it's a bad habit to get
9 into because meaning is conveyed not by isolated paragraphs but
10 by context and take in this particular case in the staff draft
11 thing, they've taken a paragraph that we wrote about our
12 adequate protection and quoted it to the Commission and omitted
13 the previous paragraph from our letter which provided the entre
14 to the paragraph that they then quoted.

15 It's easy to do that and to lose the thread of an
16 argument. The meaning of words have to be construed in the
17 whole document. So I'm a little unhappy about our essentially
18 providing approval of any staff interpretation of our views. I
19 think they have a right to send it to the Commission and in
20 general, we won't disagree if they've got it about right but I
21 hate to give them a sort of gold star stamp of approval.

22 MR. SIESS: Maybe I'm just confused but it seems to
23 me there are two different areas of agreement-disagreement.

24 MR. WARD: Could we get to that a little later?

25 MR. SIESS: No, I'm not -- I don't know what you

1 don't want me to say.

2 MR. WARD: Well, go ahead and say it. I'll turn off
3 your microphone.

4 MR. SIESS: The Commission and staff requirements'
5 memo presumably assumed that there is a difference between the
6 staff's concept and our concept and they asked us to clearly
7 identify the differing positions.

8 MR. WARD: Yeah.

9 MR. SIESS: They didn't ask us to agree with anybody
10 -- just to identify the different positions.

11 MR. WARD: That's right.

12 MR. SIESS: Now one thing we can talk about is
13 agreeing with the staff on a position. We may do that. That
14 would be nice. Then we wouldn't have a differing position. We
15 might convince the staff we're right. The other thing though
16 is agreeing that the staff has properly identified our
17 position.

18 MR. WARD: That's right. That's what we're talking
19 about.

20 MR. SIESS: Now, why can't the staff state their
21 position and we state our position and the Commission read the
22 two statements and understand the differences?

23 MR. WARD: We've already done that.

24 MR. SIESS: Is there something that they're not doing
25 it right or we're not doing it right?

1 MR. WARD: No, we've already done that and we did
2 that in February. There were, you know, a number of issues
3 covered in which there are differences. On this one, the
4 Commission thought --

5 MR. SIESS: Adequate protection is all I'm talking
6 about.

7 MR. WARD: Oh, okay.

8 MR. SIESS: The Commission cannot --

9 MR. WARD: They didn't understand from the two pieces
10 of paper how this business works. It's all right. I don't
11 understand it either.

12 MR. SIESS: So we're trying to explain the difference
13 between the staff's position and ours.

14 MR. WARD: Yeah.

15 MR. SIESS: Somebody's trying to explain it.

16 MR. WARD: Actually the staff is trying to explain
17 it.

18 MR. SIESS: And to explain it, first they have to
19 know what their position is and second, they've got to know
20 what our position is. Now presumably they know what their
21 position is although I don't think I do and we don't think they
22 know what our position is, assuming that we know what it is.

23 MR. LEWIS: I don't know what the issue is.

24 [Laughter.]

25 MR. SIESS: And I'm not sure how adequate protection

1 got into this thing in the first place because it wasn't in our
2 letter.

3 MR. WARD: Yeah it was. It sure was.

4 MR. SIESS: It was very peripheral. The words were
5 in there but the concept was secondary to everything else.

6 MR. WARD: No, that's right. We didn't see it as a
7 major issue in the implementation plan for the safety goal but
8 the staff did. It's their plan.

9 MR. KERR: One way of dealing with this is to say
10 that we don't have a position on adequate protection because I
11 don't have a position on adequate protection as it is legally
12 used by the NRC. I'm not even sure I know what it means.

13 MR. LEWIS: In fact, I would go a little further than
14 you. I wish I cared, because it's only a legal issue.

15 MR. WARD: I'm not sure it's quite that -- it's
16 tempting to just wash our hands of it and say dismiss it and
17 let the staff worry about it but I'm not sure that's --

18 MR. KERR: The issue is not adequate; the issue is
19 backfit.

20 MR. LEWIS: You will tell us why we should care.

21 MR. SIESS: The staff's issue is backfit. That's
22 always a staff concern and the backfit issue is where the
23 adequate protection comes in.

24 MR. LEWIS: But that's through the legal issues.

25 MR. SIESS: I know.

1 MR. KERR: Dave, I don't think it's washing one's
2 hands of something to say that one does not have a position on
3 it if one does not.

4 MR. REMICK: But we do and I think we stated our
5 position.

6 MR. LEWIS: Not for the legal issue. It comes in in
7 the backfit rule because the courts rejected the backfit rule
8 at the beginning because they said it's not legal to take into
9 account costs and benefits if you're doing something that
10 brings the plants up to an adequate protection standard but it
11 is legal to consider costs and benefits for improvements that
12 go beyond the adequate protection standard. The court
13 established the words "adequate protection" as the line between
14 which you have to do cost-benefit analysis or you don't have to
15 do cost-benefit analysis.

16 I find I don't give a damn where the courts drew that
17 line.

18 MR. WARD: You might not, but the Commission staff
19 have to worry about it.

20 MR. KERR: I think the Commission made a mistake in
21 not challenging that because to say that cost doesn't enter is
22 absolute nonsense. Of course it enters. If you want to
23 reduce the risk to zero, you shut down all the plants but the
24 cost right now is too great so we don't do that.

25 Cost does enter into determining -- and indeed in

1 existing regulation, cost enters in Appendix I of 10 CFR 50.
2 It enters very specifically and that's not a backfit, far as I
3 know.

4 MR. REMICK: What we did in our previous letter
5 indicate how we thought the safety goal should or should not be
6 used with relation to adequate protection. We've made that
7 statement. They've asked the staff to try to find out where do
8 you and the ACRS differ on that point.

9 MR. KERR: If you're referring to the paragraph on
10 page 2 of the staff's -- it certainly doesn't seem to me that
11 defines what we mean by adequate protection. It simply says we
12 believe that safety goals should play an important but indirect
13 role.

14 MR. REMICK: Right. It's a relationship between
15 safety goal and adequate protection.

16 MR. WARD: Go back to page 14, at the bottom right
17 corner.

18 MR. SIESS: I think maybe they're misleading.

19 MR. LEWIS: The previous paragraph says that the term
20 "adequate protection" is important in the legal areas. It's
21 used with precision in legal instruments.

22 MR. KERR: If that's opposition, it seems to me
23 that's clear, that first sentence.

24 MR. LEWIS: That's the only reason --

25 MR. REMICK: I spoke on how the safety goals should

1 be used in defining adequate protection.

2 MR. KERR: No, we did not. Where?

3 MR. REMICK: Let me read you the sentence. "We
4 believe that the safety goals should play an important but
5 indirect role in defining adequate protection." We addressed
6 the question of how the safety goals should be used.

7 MR. LEWIS: That's in the context of the previous
8 paragraph.

9 MR. REMICK: Of course. I'm aware of that.

10 MR. LEWIS: Which the staff omitted.

11 MR. KERR: But Forrest, to say it is an important but
12 indirect role is so ambiguous as to be meaningless.

13 MR. REMICK: But then read the rest of the paragraph.

14 MR. KERR: I did.

15 MR. SIESS: Now read the third paragraph. That's the
16 one that brings in the backfit rule.

17 MR. LEWIS: We're acting like scholars here.

18 MR. SIESS: That's where the staff came back and said
19 we don't agree with it. That's where we said we don't agree
20 with the staff.

21 MR. KERR: Well, again, to me that doesn't establish
22 a position on our part. It says some of the things we don't
23 believe, but it doesn't say what we do.

24 MR. SIESS: You have to get to the next page for
25 that.

1 MR. WARD: That's cutting it pretty thin. I guess
2 I'm a little puzzled by -- we wrote rather extensively on that
3 in February.

4 MR. LEWIS: My memory is that we came very, very
5 close to omitting those paragraphs about adequate protection
6 because it was a legal issue, and we really weren't writing
7 about legal issues, and we put it in, and it may have been a
8 mistake.

9 MR. REMICK: We were commenting on the staff's
10 implementation plan. They took up adequate protection in
11 relation to the safety goal, and we felt compelled to respond
12 to that.

13 MR. LEWIS: I guess that's why we did it. But it's a
14 red herring.

15 MR. WARD: You would like it to be a red herring, I
16 guess, but I don't think it is. It's there.

17 MR. LEWIS: No, no, no, lots of hounds follow the
18 scent of red herrings, but that doesn't change their color.

19 MR. CARROLL: Well, what does the paragraph beginning
20 on page 4 say about adequate protection? I don't think it says
21 anything.

22 MR. REMICK: It's not defining adequate protection,
23 it's addressing whether the safety goals should be used to
24 define. We are addressing safety goal implementation plan, how
25 should the safety goals be used.

1 MR. KERR: They should be used indirectly.

2 MR. REMICK: Is that what it says?

3 MR. WARD: That's right.

4 MR. LEWIS: It doesn't really say it. It says the
5 safety goal should play an important but indirect role, and
6 then it doesn't say what that role is.

7 MR. WARD: Well, that's what the next paragraphs say.

8 MR. LEWIS: No. It doesn't.

9 MR. KERR: The next paragraph discusses adequate
10 safety.

11 MR. LEWIS: They are using the excluded middle.

12 MR. REMICK: Basically what we said in that paragraph
13 was that adequate protection, we believe, should be meeting the
14 Commission's regulations.

15 MR. KERR: Where is that, which paragraph?

16 MR. LEWIS: We say a suitable surrogate. That's a
17 really important distinction. And the staff has ignored those
18 distinctions.

19 MR. REMICK: "Ideally, compliance with the
20 Commission's regulations is a suitable surrogate for defining
21 adequate protection of the public. However, we believe that
22 the adequacy of the regulation should be judged from the
23 viewpoint of whether nuclear power plants, as a class, licensed
24 under those regulations meet the safety goals."

25 MR. LEWIS: That does not mean that we equate safety

1 goals with adequate protection.

2 MR. REMICK: Absolutely, that's right, but the staff
3 says we are, and that's where they're wrong.

4 MR. LEWIS: They are wrong, and we should say they're
5 wrong.

6 MR. REMICK: I agree. But they are trying to
7 understand. Wayne is here to try to understand what our
8 position is.

9 MR. LEWIS: Well, let's explain that it is a
10 syllogism.

11 MR. REMICK: And when they say "equates," I think
12 they are mischaracterizing what that paragraph says, but they
13 are here to hear that.

14 MR. LEWIS: Okay, but it is simply the laws of
15 syllogism. We have a syllogism here with three items, and it
16 doesn't equate the beginning or the end. That's trivial.

17 MR. REMICK: But maybe they are willing to
18 characterize their understanding of our position differently; I
19 don't know. I think they are wrong in how they have done it,
20 but that doesn't say we shouldn't address it. Or that it's a
21 legal issue.

22 MR. WARD: Wayne, do we have your figure anywhere?

23 MR. HOUSTON: It's at the back, the very last page.

24 MR. LEWIS: But the figure doesn't actually show any
25 difference between them.

1 MR. WARD: Oh, I think it does.

2 MR. LEWIS: It has differences below the point at
3 which adequate protection appears.

4 MR. WARD: Look at page 17. I think page 17 is an
5 accurate representation of --

6 MR. LEWIS: Oh, I'm sorry, I got the boxes mixed up.
7 There is a difference.

8 The staff simply doesn't understand what we said.

9 MR. WARD: Well, the staff drew this picture, and I
10 think the picture explains what we said.

11 MR. REMICK: I don't, because they say we are
12 equating safety goals with adequate protection, because he has
13 adequate protection right underneath safety goals there.

14 MR. WARD: Well, what we have said is that adequate
15 protection is a term which is applied to -- its usage is for
16 individual plants. And in that usage, the compliance, full
17 compliance with the Commission's regulations is a surrogate.

18 We have said that a test of the regulations, whether
19 the body of regulations is adequate, is whether it's providing
20 a population of plants that is in conformance with the safety
21 goal.

22 MR. LEWIS: But that has nothing to do with that.

23 MR. REMICK: Well, it is saying how we think the
24 safety goal should be used.

25 MR. LEWIS: But it has nothing to do with adequate

1 protection.

2 MR. WARD: I don't understand how you say it has
3 nothing to do with that. There is a linkage there; right?

4 MR. LEWIS: The linkage is between the safety of the
5 body of plants and the safety goals. That's a clear linkage.
6 We have made it many, many times, and you are absolutely right.
7 Adequate protection is an issue which applies with respect to
8 individual plants.

9 MR. WARD: Exactly.

10 MR. LEWIS: And we say the safety goals have nothing
11 to do with that.

12 MR. WARD: No, no, no, but the linkage is through the
13 regulations, because --

14 MR. SIESS: Is there any significance to the fact
15 that "safe enough" is below "adequate protection" on the right?
16 Are those intended to be at the same level?

17 MR. WARD: I am sorry, Chet, I didn't hear what you
18 said.

19 MR. SIESS: On the right hand side is "adequate
20 protection" underneath the hatched area, and then underneath
21 "adequate protection" is "safe enough." Is there any
22 significance to the fact that one is below the other, or are
23 those supposed to be all at the same level?

24 MR. WARD: I don't know. Wayne, do you make any
25 significance out of it?

1 MR. HOUSTON: Wayne Houston from the staff.

2 They are intended to represent the same level.

3 MR. SIESS: Okay. So the big difference is that you
4 put "adequate protection" well below, somewhere below "safe
5 enough," and you think we put it at the same level?

6 MR. REMICK: That's correct.

7 MR. SIESS: And where are the regulations?

8 MR. HOUSTON: Well, they are not reflected on this
9 pictorial.

10 MR. REMICK: Wayne, I have tried to understand that
11 pictorial. I don't think it helps, personally; I really don't.

12 MR. HOUSTON: Well, that's what we're here for.

13 I would like to add a comment, if I may. I believe
14 that the issue of adequate protection arose in the middle of
15 this process. There is no evidence to suggest that actually
16 either that the -- well, that the ACRS had in mind any kind of
17 an association of safety goals with what I will call the
18 statutory standard of adequate protection. It is in the
19 statutes, it's not just in a court decision. It goes back to
20 1954, in the Atomic Energy Act.

21 It is true that as a matter of historical fact, that
22 the findings that the Commission has made with the issuance of
23 license has been done on a case-by-case basis, and one can
24 judgmentally assert that adequate protection for one plant
25 doesn't necessarily mean it's the same precise level of safety

1 as it is for another plant.

2 Even if we had a way of measuring it, such
3 measurements probably would show that there would probably be
4 differences.

5 It is kind of a difficult thing to come to grips
6 with.

7 The conclusions that are represented in this draft
8 paper are inferences drawn from what the ACRS has said. Now we
9 have not excised particular paragraphs, but we did cite certain
10 paragraphs that seemed to me, at any rate, to shed some light
11 on the question that the Commission was asking, to try to be
12 clear in trying to explain differences between the staff's view
13 and the ACRS view.

14 I suppose it is possible that what the ACRS has in
15 mind maybe cannot be represented pictorially in the fashion
16 that I have tried here.

17 It could be, however, that given that the primary
18 emphasis of the ACRS was with the concept of how safe is safe
19 enough, which is not a term of art or usage in the regulatory
20 process, whereas the adequate protection term is a term of
21 usage in the regulatory process.

22 But it is conceivable that we could simply leave out
23 the issue of adequate protection as far as ACRS is concerned,
24 and simply represent it as you have, that it's your
25 determination of what the safety goals should be associated

1 with the concept of how safe is safe enough, and then let the
2 Commission ponder what that means in terms of the regulatory
3 process.

4 What we have tried to do here is to sort of bring it
5 into the process as it exists. Now maybe we can't do that.
6 Maybe you have something more grandiose in mind, or something
7 different in mind. But if you do have something different in
8 mind, then it does create a problem, I think, with respect to
9 trying to implement safety goals, although maybe I am mistaken
10 on that point.

11 It certainly would be possible to pursue an
12 implementation plan dealing with safety goals, perhaps find
13 areas in which the regulations should be modified, and not use
14 any cost or cost-benefit arguments in creating new regulations.

15 When new regulations are put on the books, however,
16 it is necessary for the Commission to address the question as
17 to whether they apply to existing plants or to future plants or
18 both.

19 And if the answer to the question, if the staff
20 believes and the Commission believes that they should apply to
21 present plants, then we have to invoke the backfit rule. And
22 by the backfit rule, if we do, we have to invoke cost-benefit
23 arguments.

24 So we reach an impasse at that point. And what the
25 staff is trying to do is interpret what we think the ACRS is

1 saying in such a way as to sort of make it more compatible with
2 the regulatory process as it exists.

3 MR. KERR: When you say you have to invoke the
4 backfit rule, that is not statute, but rather NRC regulation,
5 isn't it?

6 MR. HOUSTON: I'm sorry, I didn't hear that.

7 MR. KERR: When you say that we have to invoke the
8 backfit rule if we use it for existing plants, that's not a
9 statutory requirement, is it?

10 MR. HOUSTON: That is correct, it's a rule.

11 MR. KERR: Thank you.

12 MR. CARROLL: Let me ask this question:

13 Does Wayne's picture, in terms of the "staff"
14 position, represent what we also believe? Does that --

15 MR. WARD: I am not sure what the committee believes.
16 It's not what I believe.

17 MR. SIESS: It's for the staff side, I think, only.

18 MR. WARD: Oh, is that what you mean? I guess I
19 don't know whether -- I guess I'm not sure whether there's
20 another indication of what they believe. So I don't know what
21 to compare this with.

22 MR. SIESS: The staff has got a definition of "safe
23 enough" in terms of the backfit rule, and I get lost on that,
24 for some reason.

25 MR. CARROLL: Now they have got a definition, as I'm

1 reading this, that the safety goals define what is safe enough.
2 Is that what you intended?

3 MR. SIESS: I am reading the bottom of page 8. "With
4 respect to the concept of safe enough, the staff interprets
5 this to mean a level of safety such that no further
6 improvements in safety would be justifiable on cost benefit
7 grounds for regulatory action."

8 MR. HOUSTON: That's correct.

9 MR. CARROLL: That's what this says.

10 MR. KERR: This stops at "safe enough," but
11 indicating that it's a fixed position. A cost-benefit basis is
12 not a fixed position necessarily.

13 MR. SIESS: But, you see --

14 MR. KERR: The cost-benefit region is between "safe
15 enough" and "adequate protection."

16 MR. SIESS: "Safe enough" is keep making it safer
17 until you can't afford it, and now the staff equates that to
18 the safety goal. And I don't see how you can do that.

19 MR. WARD: See, in a sense, I think we said the
20 regulations aren't shown on here. But in a sense, they are,
21 because if we accept this what we call a surrogate definition
22 of "adequate protection" as being in compliance with the safety
23 goal, if we just reverse that, then that would seem to say that
24 the line or the shaded line labeled "adequate protection"
25 represents the level of safety achieved with the body of

1 regulations. And what the staff seems to be -- no?

2 MR. SIESS: Go ahead.

3 MR. WARD: Well, why not? I mean I'm showing where
4 the logic is wrong. And what the staff is saying is that the
5 safety goal represents a level of safety which is beyond what
6 the regulations provide, and you used cost-benefit arguments in
7 pushing plants to get to that level. That's what the staff is
8 saying.

9 MR. HOUSTON: No. I think there is another problem
10 here which the ACRS has represented the intent that, if I can
11 say it properly, of creating a body of regulations which
12 presumably does not now exist as such, that acts as a surrogate
13 -- and I will modify that by saying apparently a total
14 surrogate for adequate protection.

15 Am I correct so far?

16 MR. CARROLL: No. I don't think so.

17 MR. HOUSTON: As a surrogate. You have used the word
18 surrogate and that is what I want to focus on.

19 MR. CARROLL: But I think what we were saying was the
20 existing regulations are quite adequate.

21 MR. HOUSTON: I understand.

22 MR. WARD: I think that's our position now, for what
23 we know now, the existing regulations are doing the job.

24 MR. HOUSTON: Now reading between the lines, I
25 understand that one can draw that inference. I think not so

1 much from what you have written, but from conversations which
2 we have had.

3 The difference that I would like to point to, which
4 may be considered to be subtle, is that the staff refers to the
5 regulations with respect to the concept of adequate protection
6 in the following fashion:

7 That is, if the regulations are met by a licensee
8 that presumptively assures what I will call a state of
9 adequate protection for that licensee.

10 Now that is a different statement than calling them a
11 surrogate for it, and one reason that I say that is that some
12 of the regulations we now have on the books could not legally
13 be used as part or as a surrogate for a definition of adequate
14 protection.

15 Professor Kerr has pointed out one Appendix I, there
16 are a couple of others, the ATWS rule, the station blackout
17 rule. They have all been put on the books taking into
18 consideration cost. So they cannot legally be part of a
19 surrogate for adequation protection because costs have been
20 considering in putting them on the books.

21 MR. WARD: You're turning it upside down.

22 MR. HOUSTON: I don't believe so.

23 MR. WARD: It seems to me the process for rulemaking
24 uses whatever information is appropriate and it's always used
25 costs and benefits. Once a rule is on the books, that

1 contributes to -- and a plant is complying with the rule, the
2 regulation, then that is providing some of this presumptive
3 evidence that the plant is meeting the standards of adequate
4 protection.

5 I agree. That way of expressing a presumptive
6 evidence of adequate protection is probably better than the
7 surrogate term, but, to me, there isn't any real difference in
8 the mean.

9 MR. KERR: But, Dave, I think what he's saying is the
10 Courts have ruled that one cannot use cost considerations in
11 determining adequate protection. Therefore, the Courts have
12 made it illegal for these regulations that include
13 consideration of cost to be used in determining adequate
14 protection.

15 MR. HOUSTON: That's correct.

16 MR. CARROLL: What did the Courts say about the
17 timing, though? If Appendix I existed before the Courts ruled
18 --

19 MR. HOUSTON: We'd have to have somebody from OGC
20 here, I think, to really get into that detail. My perception
21 is that prospectively we need to pay attention to this. If you
22 look back through the statements of considerations for existing
23 rules, you'll find that for the most part there is no reference
24 made to cost considerations for most of the rules that have
25 gone on the books.

1 For example, the general design criteria. Now,
2 arguably, there may have been somewhere in the whole judgmental
3 process that created them some though given to costs associated
4 with them.

5 MR. WARD: Absolutely. In fact, you can't --

6 MR. HOUSTON: The question is what the record shows.

7 MR. WARD: When there's a single failure criteria in
8 the GDC, that's an important part of it, that could have been
9 made a double failure criterion or a triple failure criterion.
10 Why wasn't it?

11 MR. HOUSTON: I agree. A lot of these were written
12 by people who are engineers and, by the very nature of the
13 profession, cost tends to be a factor. I'm talking about what
14 the record shows.

15 MR. WARD: So to differentiate a rule where cost was
16 explicitly considered and one where it's only implicitly
17 considered, which is all of the others, I think is specious.

18 MR. HOUSTON: It would be very difficult to
19 establish, if one were to ask the question with regard to
20 existing regulations, which ones are on the books that were put
21 there without any consideration of cost and shown by the
22 record, and the record is not clear on that. You need to look
23 at this prospectively rather than retrospectively.

24 MR. SIESS: That's what I'm trying to understand now.
25 50.109 originally did not have this cost benefit thing, did it?

1 MR. HOUSTON: That's correct.

2 MR. SIESS: So by your reasoning, any new rules that
3 were established by the Commission before the current version
4 of 50.109 was enacted could be considered as raising the level
5 of adequate protection. Presumably, we change the rules to
6 increase safety, but since 50.109 has been put in, any new rule
7 that had a cost benefit basis, you would say, did not raise the
8 level of adequate protection because if it had raised the level
9 of adequate protection, it wouldn't have needed the cost
10 benefit basis. Right?

11 MR. HOUSTON: It could not have been justified on a
12 cost benefit basis is what I said.

13 MR. SIESS: But it wouldn't have needed it. If it
14 was required for adequate protection, you don't need cost
15 benefit if somebody makes that ruling.

16 MR. HOUSTON: That's correct.

17 MR. SIESS: And I don't know how you do that, but I
18 think the Committee is saying that if a rule change is required
19 in order to make this whole body of plants meet the safety
20 goal, the rule change ought to be done. Right? Who decides
21 whether something meets the requirement for adequate
22 protection?

23 MR. HOUSTON: Up to this point in time, there is no
24 definition of the term as a standard in any quantitative sense,
25 or even anything more than the words themselves. I've often

1 referred to as a --

2 MR. SIESS: So if somebody comes in and wants to
3 change the rule, say to require something on accident
4 management, first there has to be a decision made as to whether
5 the rule change is required in order to provide adequate
6 protection. If that decision is made, then it doesn't have to
7 be justified on cost benefit. If that decision is not made, it
8 does have to be justified on cost benefit. Right?

9 MR. HOUSTON: I believe that's a fair
10 characterization.

11 MR. SIESS: But who is empowered under the law to
12 decide whether a rule change is needed to provide adequate
13 protection?

14 MR. HOUSTON: The Commission.

15 MR. SIESS: The Commission can just say that.

16 MR. HOUSTON: Yes.

17 MR. SIESS: And we're saying that they should use the
18 safety goal as a guide to do that.

19 MR. WARD: Right. That's what we've said.

20 MR. HOUSTON: That's what I thought I had
21 characterized on this pictorial.

22 MR. MICHELSON: Then the picture is correct.

23 MR. WARD: But in your picture, you can go above
24 adequate protection --

25 MR. HOUSTON: In safety, yes. More safe.

1 MR. SIESS: If you can justify it by cost benefit.

2 MR. HOUSTON: Correct. The staff has no intention,
3 at this point --

4 MR. SIESS: Up to the safety goal.

5 MR. HOUSTON: That's correct.

6 MR. SIESS: But the safety goal may not be up there.
7 It may be down below.

8 MR. REMICK: Could be.

9 MR. HOUSTON: It could be, yes.

10 MR. SIESS: I think should condition your argument by
11 showing adequate protection different than the safety goal and
12 below it.

13 MR. HOUSTON: The staff has not made any
14 recommendation to the Commission with regard to a proposed
15 definition of what adequate protection means. It seems to us
16 that the ACRS is doing that.

17 MR. SIESS: That's exactly what we've tried to do,
18 because it seems to me somebody needs that definition if every
19 time there's a rule change the Commission has got to decide
20 whether it's needed to provide adequate protection.

21 MR. WARD: I know some of the members want to avoid
22 this, but I think that's really at the heart of what the ACRS
23 has been proposing as the central idea of the safety goal.

24 MR. REMICK: Dave, this is just my own personal view
25 of what the staff had characterized our viewpoint, how I think

1 I could have agreed with it if you had characterized it this
2 way.

3 I believe Hal had a good point that you probably
4 should put that first paragraph in, as well as the paragraph
5 you have quoted, because it sets the stage. But then if you
6 had said something like the ACRS only indirectly relates,
7 rather than equates, how safe is safe enough with adequate
8 protection, they indicate that the safety goals are to be used
9 to judge the adequacy of the regulations in producing a
10 population of plants that meet the safety goals.

11 However, they indicate that the safety goals should
12 not be used to determine whether an individual plant provides
13 adequate protection to the public. Adequate protection does
14 relate to individual plant determinations, I believe.

15 MR. HOUSTON: In effect, yes.

16 MR. REMICK: In my mind, you would have been
17 characterizing our position, as I understand it, if you had
18 words like that. I don't think a diagram helps. I really
19 don't. I think it's impossible to put our position in a
20 diagram.

21 MR. HOUSTON: That may be.

22 MR. CARROLL: Or yours.

23 MR. HOUSTON: I think ours can be, but I can't --

24 MR. SIESS: If I move these two boxes, put this one
25 down here and that one up there, you can't make this work.

1 MR. HOUSTON: That wouldn't represent what we're
2 saying, so I wouldn't do that.

3 MR. SIESS: Are you saying that adequate protection
4 is always less safe than the safety goal?

5 MR. HOUSTON: It's what we would think of as a basic
6 or minimum level of protection, yes.

7 MR. MICHELSON: That's a different definition.

8 MR. CARROLL: The problem you get into, Wayne, is if
9 some issue comes along that says we're no longer meeting
10 adequate protection and we're no longer meeting the safety
11 goal, you could have a situation where your two boxes are
12 reversed.

13 MR. HOUSTON: Conceptually, yes, that's possible.
14 That's not --

15 MR. CARROLL: There isn't a cost benefit region for
16 that situation.

17 MR. HOUSTON: Again, on an individual plant basis,
18 the term adequate protection tends to mean the following. If a
19 circumstance is found where the staff of the Commission may
20 judge that there is a real question as to whether or not the
21 level of protection currently being provided at a plant, for
22 whatever reason, a change from something or a situation that
23 had previously existed, the real question would arise as to
24 whether the plant should be shut down or not.

25 So in principle, it's a level which really raises a

1 serious question for the plant, whereas the staff's perception
2 of the safety goal level is not of that nature. It's one that
3 one is striving for, but not one which, if it failed to be met,
4 would trigger the question of whether or not the plant should
5 be shut down.

6 MR. KERR: Wayne, if 1150, I believe, finds that
7 practically -- I think all of the plants are better than the
8 safety goal?

9 MR. HOUSTON: All six of the ones that we've seen, by
10 a substantial margin, yes.

11 MR. KERR: Why would the staff then conclude that the
12 safety goal is considerably less in risk than adequate
13 protection?

14 MR. HOUSTON: That's what this is representing.

15 MR. WARD: No, I don't think so, Wayne.

16 MR. SIESS: How do you define adequate protection?

17 MR. HOUSTON: We don't.

18 MR. SIESS: How would you recommend --

19 MR. HOUSTON: But it's a minimum level. It's a
20 minimal level of safety.

21 MR. SIESS: I know, but somebody has got to go out
22 there and decide whether a plant is providing adequate
23 protection or, if not, they should shut them down.

24 MR. SHEWMON: Wouldn't compliance with the
25 regulations be taken as evidence that there is adequate

1 protection?

2 MR. SIESS: No, because they shut down --

3 MR. WARD: That provides evidence that the plant
4 meets at least the standard of adequate protection, but it
5 might be much better than that. That's Wayne's point. That's
6 the difference. That's why he didn't like us using the term
7 surrogate, because he's just saying it's a boundary with which
8 the plant is within, but not necessarily at it.

9 MR. SHEWMON: Conservatism.

10 MR. WARD: To me, just in plain English, and I know
11 this can be deceptive, but engineering English, I guess, the
12 terms safe enough, adequately protected, and no undue risks can
13 very easily be taken to all mean the same thing. I guess they
14 --

15 MR. HOUSTON: I would agree with that preamble, yes.

16 MR. WARD: They do, to me. I guess the problem is
17 that the particular term -- and that's what we're trying to see
18 with the safety goal, is that the level -- the standard
19 established by the safety goal should be defined as to what all
20 of those three things are.

21 The problem, I guess, is that the particular term
22 adequate protection with capital letters, let's say, has a
23 specialized meaning in the law and in Court cases, anyway. So
24 that's the problem we're faced with.

25 MR. HOUSTON: A year ago, when some of the initial

1 drafts of the staff's plan or further plans or revised plans,
2 if you will, for implementing safety goals; there was no
3 mention of adequate protection. That, however, was a
4 contributing factor of a delay of quite a number of months,
5 about year ago, because of a concern being expressed by
6 attorneys in the OGC, which in turn, related to the court case
7 on the backfit rule, because one of the points that was being
8 made by the Union of Concerned Scientists was that they wanted
9 the court to require the NRC to define what it meant by
10 adequate protection, because it was a term of used in the
11 backfit rules.

12 They properly pointed out that there is no
13 definition, so how can the Commission use a rule containing a
14 term which has no definition? The court chose not to address
15 that particular issue, and the court did not order the NRC to
16 define it.

17 MR. SIESS: I don't know why we should step in where
18 the courts wouldn't, but let me point out --

19 MR. HOUSTON: That's our position.

20 MR. SIESS: Let me point out something that's giving
21 me difficulty here and maybe giving others difficulty. The
22 term, "adequate protection," appears in 50.109 and it's been
23 used here with respect to particular plants -- shall I shut
24 down this plant because it doesn't provide adequate protection.

25 Now, that's a plant-specific thing. We've also

1 talked about adequate protection as being reflected by some
2 kind of a level, but if it's regulations, that again applies to
3 specific plants. You can measure a plant against the
4 regulations.

5 The other thing is that we talk about some of these
6 other terms we use are the aggregate, right? As whole, plants
7 meet the safety goals. So, when I asked the question about a
8 backfit, when the backfit had to be applied, they said somebody
9 has to make a ruling that it's required for adequate
10 protection.

11 Now, for the ATWS rule, that was decided for all
12 plants; wasn't it? It was not just for one. It's a change in
13 the rule.

14 MR. HOUSTON: There were classes which were treated
15 differently, yes, but, in toto, it applies to all plants.

16 MR. SIESS: So what you are saying is then it was
17 decided that those plants should be shut down if they didn't
18 fix this?

19 MR. HOUSTON: Not at all. Cost was a consideration
20 in the ATWS rulemaking process.

21 MR. SIESS: Oh, that's right, they already provided
22 adequate protection and we were going beyond it?

23 MR. HOUSTON: That's correct.

24 MR. SIESS: Okay. Now, anybody who meets those new
25 rules is beyond adequate protection?

1 MR. HOUSTON: Correct.

2 MR. CARROLL: For ATWS?

3 MR. HOUSTON: Station blackouts, the same situation.

4 MR. SIESS: So you now have no measure of adequate
5 protection?

6 MR. HOUSTON: We never have had, and we do not now
7 have a measure of it in risk space, yes.

8 MR. SIESS: Presumably you could find some point at
9 which the rules represented adequate protection and every
10 change in the rules since that time go above adequate
11 protection.

12 MR. KERR: It seems to me that the letter is easy
13 then. We say that the staff has no position on adequate
14 protection. We don't have any position on adequate protection
15 and there is no disagreement.

16 MR. HOUSTON: There is a certain grain of truth in
17 that.

18 MR. SIESS: The point is that we brought in another
19 term about safe was safe enough that you have equated to
20 adequate protection, orally.

21 MR. WARD: Yes.

22 MR. SIESS: But nowhere else.

23 MR. HOUSTON: Actually, we do have a position. We
24 don't have a definition of adequate protection.

25 MR. KERR: Our position is the same. Neither of us

1 has a definition.

2 MR. SIESS: Well, it's a definition of how safe is
3 safe enough. Anywhere in our letter, do we equate how safe is
4 safe enough to adequate protection, or no undue risk? Not in
5 our letter, I don't think. Dave did it a few minutes ago.

6 MR. WARD: I am saying that to me, those terms -- it
7 makes sense to equate them. I don't think we've really taken a
8 position.

9 MR. KERR: But the term, as it is used by the courts,
10 Dave, is just -- it has, I think, no particular meaning as far
11 as we're concerned.

12 MR. REMICK: We say the safety goals should be used
13 to judge the adequacy of the regulations. Now, we do offer
14 that the regulations are an adequate surrogate for adequate
15 protection, or a surrogate, but we don't say the safety goals
16 are.

17 MR. SIESS: We did say that, but now Wayne has got an
18 argument that that's not true. The regulations are a surrogate
19 for adequate protection. We could show that by logic and by
20 law.

21 MR. REMICK: We might be wrong and he might be right,
22 but what he's trying to do is to understand our position.

23 MR. KERR: We don't have to be bound by the court
24 decision.

25 MR. HOUSTON: That's true, but what the --

1 MR. KERR: We can be wrong and the Commission could
2 ignore advice because OGC gives them better advice.

3 MR. HOUSTON: What you have said, however, and this
4 was part of the inference that the staff drew, is that when the
5 regulations are modified for the purpose of complying with
6 safety goals, cost/benefit should not be used.

7 MR. REMICK: Yes, we've said that.

8 MR. HOUSTON: You've said that in a letter.

9 MR. REMICK: That's right.

10 MR. HOUSTON: That was part of our trying to piece it
11 together to see how it fits the process or how it relates to
12 the process.

13 MR. REMICK: It is possible that we might have been
14 inconsistent? To me, it is inconsistent.

15 MR. HOUSTON: Actually, the problem is that you
16 didn't start out, as we didn't start out, recognizing that
17 adequate protection had anything to do with safety goals; that
18 is, the statutory standard, the legal standard -- had anything
19 to do with safety goals.

20 I think we've both been drawn into it.

21 MR. WARD: We haven't brought -- is anyone from OGC
22 here?

23 [No response.]

24 MR. WARD: I guess not.

25 MR. SHEWMON: So we can say anything we want.

1 MR. WARD: No, but the problem is, in the past, we
2 could say that's legal and we'll let the lawyers worry about
3 the term, "adequate protection," but in the past when we've
4 discussed it with them and they've said, well, what do you
5 mean by "adequate protection?" They say, that's up to you
6 technical people to define what that means.

7 MR. REMICK: Right, they have said that.

8 MR. FRALEY: But when they're pressed -- and this may
9 not be absolutely correct in all cases, they say, as I have
10 said before, adequate protection is whatever regulation is
11 applied to that plant when it was licensed.

12 MR. SIESS: But that is not true anymore.

13 MR. HOUSTON: That's not a correct characterization.

14 MR. SIESS: We've got regulations that were invoked
15 to go beyond adequate protection.

16 MR. FRALEY: Since TMI, the regulations have been
17 changed because adequate protection was redefined. Basically,
18 it is those regulations that apply to that plant. That is what
19 is adequate.

20 MR. MICHELSON: Wayne shakes his head. Why do you
21 shake your head?

22 MR. HOUSTON: What they said, and I said it a little
23 while ago, and I'll say it again, compliance with the
24 regulations on the part of a particular plant, presumptively
25 assures adequate protection. That's not the same thing as you

1 just said.

2 It bypasses the question as to whether all of the
3 regulations needed to be complied with, because it's not
4 uncommon in the issuance of a license that some exemptions are
5 granted, for instance, on a plant-specific basis.

6 MR. FRALEY: When an exemption is granted, then that
7 regulation does not apply to that plant, and that is part of
8 the regulations that apply to that plant and that one doesn't.

9 MR. HOUSTON: That's true, and then the issue becomes
10 whether they might have been exempted from other regulations
11 and still meet adequate protection.

12 MR. SIESS: It's the body of regulations as applied
13 and interpreted by the Staff. Obviously, the body of
14 regulations, in themselves, don't do anything for anybody, but
15 once the staff applies them to a plant then it's presumptive
16 that that plant, designed and accepted by the staff according
17 to their interpretation of the regulations, does provide
18 adequate protection, or it wouldn't have been given a license.

19 That's the legal presumption. It might be better
20 than adequate.

21 MR. WARD: Then you might question what business the
22 staff had requiring it to be?

23 MR. SIESS: Well, they did it on a cost/benefit basis
24 under a rule, 50.109. It told them that if they wanted more
25 than adequate protection, they had to justify it on a

1 cost/benefit basis and they did.

2 But the question is, where do you stop? When it is
3 it safe enough?

4 MR. WARD: That is the whole idea of the safety goal,
5 and that we agree on. This is where you stop.

6 MR. REMICK: I'm sure Dr. Houston completely
7 understands our position now and you have adequate guidance on
8 what we are supposed to do; is that correct, since it is now
9 12:00?

10 MR. KERR: If the Commission asks us to prepare a
11 joint letter, have we deserted that possibility or abandoned
12 that possibility?

13 MR. REMICK: Dave raised several alternatives at the
14 beginning of different ways to approach it.

15 MR. WARD: We did start a little bit late. Could we
16 have an extra five minutes for the procedural part.

17 MR. SIESS: The equating of adequate protection to
18 safe enough on Wayne's diagram; where do we say that?

19 MR. WARD: I don't think we do, or that we ever
20 have.

21 MR. WARD: Maybe that's just my interpretation and
22 the Committee really hasn't taken a position on that.

23 MR. HOUSTON: That's an inference. You don't say
24 that; that's correct.

25 MR. WARD: It's very logical to me.

1 MR. SIESS: That's where I have the problem. We
2 equated safety goal to safe enough; that's clear. But then
3 sticking adequate protection in there is a red herring.

4 MR. WARD: Maybe so, but without this legal
5 definition, if someone asks you, does that mean the plants are
6 adequately safe; that the public is adequately protected? I
7 mean, would you -- could these have meant some different
8 things, or do they all mean the same thing?

9 MR. SIESS: I'd want to look at the PRA for that
10 plant.

11 MR. REMICK: Can we discuss the procedural aspects of
12 how we're going to handle this?

13 MR. WARD: I guess it's probably -- I'd suggest
14 thing, probably the most appropriate thing to do is for us to
15 take this draft as writ in stone for the moment and to comment
16 on the draft, so there's something fixed to compare and say,
17 you know, we're in agreement with the draft of such and such a
18 date, except for this paragraph which, what we really mean is
19 loddy, blah, blah.

20 MR. HOUSTON: That would be very helpful if you could
21 do that.

22 MR. CARROLL: Who are you commenting to now?

23 MR. WARD: The Commissioners.

24 MR. HOUSTON: You would comment to the Commission?

25 MR. WARD: Yes.

1 MR. HOUSTON: The Commission hasn't seen this.

2 MR. WARD: Yes, but you could make it available to
3 them. This is your position.

4 MR. REMICK: Are you saying that if we did that, you
5 might consider your -- reconsider your characterization?

6 MR. HOUSTON: Yes. That's what I thought you were
7 implying. My next question was going to be; how soon can you
8 do that?

9 MR. CARROLL: What we've been asked to do is jointly
10 prepare a position. Now, have we decided?

11 MR. HOUSTON: I think procedurally that is probably a
12 little difficult to do.

13 MR. CARROLL: I think we decided that a couple of
14 months ago that we couldn't really do that.

15 MR. WARD: One way to make it effectively the same
16 thing would be to quote their paragraph and the paragraph as we
17 would revise it.

18 But if you're going to make another version in the
19 meantime, that kind of gets into another --

20 MR. HOUSTON: I wouldn't. In the meantime, before
21 the week is out, if you could have something -- and it could
22 take the form of a memorandum to the EDO or to Mr. Beckjord,
23 since he requested it, with like a marked up copy or something
24 of that nature.

25 Maybe you might want to supplement that with another

1 full memorandum to the EDO, for example. The other alternative
2 we have is that that we would proceed with -- I think that on
3 the basis of our discussion today, I would modify some things
4 that are currently in this draft, and I'd simply send it to the
5 Commission and this is what we think the ACRS is saying.

6 Then you have a subsequent opportunity to write a
7 letter on it and say, no, it isn't, and this is what we meant.
8 I'm not sure that's as helpful to the Commission.

9 MR. WARD: I think that's the option. I'm sure the
10 letter would get to EDO, or instead of air inspector or
11 something, instead of the Commission.

12 MR. MICHELSON: And then write another letter after
13 they send their formal statement to the Commission.

14 MR. WARD: Then they would say, by god, they haven't
15 gotten it right yet.

16 MR. SIESS: This thing is not complete. This refers
17 back to SECY 89-102 and I guess I'd have to get a copy of that
18 to understand this last round. It seems to me, if it's going
19 to take three pages, they could make it four pages and be
20 complete.

21 MR. REMICK: All right.

22 MR. SIESS: I'd also suggest -- the staff is trying
23 to interpret what the Commission said, and is there anything
24 wrong with anybody asking the Commission what they meant? I
25 mean, they're asking us what we meant.

1 MR. WARD: No, you don't get to ask them anything.

2 MR. SIESS: I could do it nicely.

3 MR. REMICK: Not those high levels, Chet. Gentlemen,
4 I suggest we take a recess for lunch, returning at 1:00 p.m.

5 [Whereupon, at 12:10 p.m., the workshop was recessed,
6 to reconvene this same date at 1:00 p.m.]

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

AFTERNOON SESSION

[1:04 p.m.]

1
2
3 MR. REMICK: Maybe we should get started. Jay can
4 offer any background he wishes when he arrives. I refer the
5 committee members to handout No. 4 which is a background paper
6 for the discussion. Charles Miller from the staff is going to
7 lead us through a status report on standardized pressurized
8 water reactors. So, I'll turn it over to you, Mr. Miller.

9 MR. MILLER: Thank you, Mr. Chairman.

10 What I'd like to do today is give the committee a
11 brief overview of where we are on the review of the pressurized
12 water reactors that we're pursuing in our standard plant
13 program.

14 [Slide.]

15 MR. MILLER: I guess I'd like to mention to the
16 committee first off that I think you have in your package a
17 copy of SECY-89-334 which is a paper that's before the
18 Commission right now for a vote. In that paper, the staff as
19 requested by the Commission forwarded our review priorities or
20 at least the priorities as we saw them as how we would like to
21 proceed from this point.

22 The Chairman has been asking the staff to do that and
23 the Commission has been trying to come to grips with where we
24 are with the programs and with the resource constraints in
25 trying to establish some overall priorities at how we are going

1 to proceed.

2 The information that's in there at this point is pre-
3 decisional and I wanted to just remind everyone that at this
4 point in time, we're awaiting Commission vote on the subject.
5 Some of the information that's presented in my presentation
6 today should be taken within that context. It's the staff's
7 best estimates at this point in time as to how we're going to
8 proceed.

9 With that, I'd like to go into a little about how all
10 the programs with regard to pressurized water reactors fit
11 together. In the various subcommittees, we've been addressing
12 this.

13 We're currently working on a PDA type review for the
14 Westinghouse SP-90. Westinghouse has recently informed both
15 the staff and the ACRS subcommittee, that at this point in
16 time, they are not going to seek an FDA until such a time as
17 they have a customer. So what we're trying to do is to
18 basically wrap up the review that's been in house here for
19 several years and in doing that, we're going to recognize that
20 there may be some open items that we're going to have to defer
21 to such a time that we proceed with an FDA application.

22 I wanted to say a little bit about the EPRI review
23 because the other reviews fit within the EPRI context.

24 MR. REMICK: Excuse me. Before we leave the SP-90,
25 could you remind me what power level is that? What power level

1 is the SP-90?

2 MR. MILLER: It's a large evolution area plant.

3 MR. REMICK: It's the standard evolution, okay.

4 MR. DONATELL: It's 1,300 electrical.

5 MR. MILLER: The EPRI requirements document which is
6 also under active review has basically two phases to it --
7 those for the large evolutionary plants and those for the
8 passive plants and I've tried to put our estimates as to how
9 we're going to proceed and to try to wrap those up.

10 I think the dates that I've tried to portray here
11 include the times that we try to hit our milestones for
12 completing the reviews of those projects. The Combustion
13 Engineering system, 80 plus -- I'll be going into each of these
14 in more detail -- I think our nearest term milestone is to try
15 to get a licensing review document issued to Combustion
16 Engineering.

17 At this point in time, we really haven't established
18 any formal dealings with the subcommittee on the Combustion
19 Engineering project but we're going to be asking for ACRS input
20 in the coming months on this project. So it's something we're
21 going to have to be visiting very soon.

22 The Westinghouse AP-600 is the smaller, passive
23 plant, that we're going to be seeing coming before us.
24 Westinghouse is one of the successful bidders in the
25 development contract with the Department of Energy. They

1 inform us that they would like to submit an LRB in about the
2 middle of 1990 but it's still going to be a couple of years
3 before we get into the actual active review of that but we're
4 going to be doing some preliminary assessments which I'll get
5 into in a little bit and we're going to be asking for the
6 committee's input in that regard.

7 [Slide.]

8 MR. MILLER: I'd like to go into a little bit more
9 detail on each of these now. Basically, this is a little bit
10 of history with what's gone on with the System 80 Plus. In
11 1987, Combustion Engineering started a process on their System
12 80 Plus by issuing a series of amendments to the System 80
13 application. We issued an FDA on the System 80 several years
14 ago and they started the process out by actually submitting
15 amendments to that which incorporate some of the features of
16 the System 80 Plus.

17 They actually made their formal application in March
18 of this year at which point they asked for design
19 certification. The initial step in the process, the licensing
20 review basis, was something that was done for the General
21 Electric ABWR a couple of years ago. This has got a lot of
22 attention recently with the committee and the Commission and
23 I'm anticipating that the Commission is going to ask to be
24 formally involved in the issuance of this document in the
25 future and I'm anticipating that they're going to ask the ACRS

1 to get involved formally in commenting on it before it proceeds
2 with the Commission.

3 So with that in mind, this is anticipated based upon
4 discussions that I have been involved in. It has not been
5 formally decided yet, but in the context of that, the staff
6 review of a draft document on a licensing review basis with
7 combustion is in process and I think in about February of this
8 year, we're going to be seeking the ACRS's active review and
9 input on that with Commission review following that and
10 hopefully by the spring of this year, we'll be able to issue
11 it. This will get us on the formal process of trying to
12 proceed actively with the Combustion System 80 Plus application
13 in a more formal manner with the goal of trying to issue a
14 final design approval approximately 2 years after the issuance
15 of the LRB.

16 MR. REMICK: Was their formal application that you
17 show in March of '89 complete -- fairly complete?

18 MR. MILLER: The information, no, is not yet
19 complete. What we saw in the application, the idea was to
20 completely resubmit what they had in the System 80
21 documentation and put it in what they call their CESSAR-DC
22 application.

23 So they're going to resubmit the documentation. A
24 lot of it has been received but there's still quite a bit to
25 come. I can show you a little bit here. I don't want to go

1 into this in detail but I thought I put these bullets down so
2 you would have some information regarding the kinds of
3 information that we received over the last couple of years.

4 In my next slide, I can show some of the near-term
5 things that they still have to submit.

6 [Slide.]

7 MR. MILLER: To answer your question more directly,
8 Mr. Chairman, what we got was pretty much a letter committing
9 to submit detailed information for an essentially complete
10 plant in the detail. At the time they submitted their
11 application, it was a month or two before 10 CFR 52 got
12 promulgated but it was close enough to the promulgation that
13 they -- we pretty much had complete information as to what was
14 going to be in the rule. The draft rule had been out for
15 comment and the comment period had expired in the back and the
16 Commission had had its formal meeting.

17 What combustion did was at that point in time asked
18 for design certification anticipating that 10 CFR 52 would get
19 promulgated. So they have committed to essentially complete
20 information under Part 52 and that information is required by
21 the regulation in order to proceed.

22 In the near term, this shows how the information will
23 be received. It has not yet been received. We're anticipating
24 in December of this year to getting a proposed resolution to
25 USIs and GSIs and getting more on the PRA methodology. Right

1 down through the coming year, you can see some of the
2 information that they have yet to submit.

3 Just in summary, over the course of the time, we have
4 been trying to get input back to them with regard to questions
5 and requests for more information and to date, the staff has
6 issued about 277 questions. We have received responses to 186
7 questions and we have 92 questions which CE is working on. Now
8 this is by no means a complete list. I'm sure there's going to
9 be a lot more to come.

10 [Slide.]

11 MR. MILLER: With regard to the SP-90 review, this
12 has been under fairly active review lately by both the staff
13 and the ACRS subcommittee and a quick history here. Between
14 '88 and '89, we've had a fair amount of activity with the front
15 end of the PRA draft safety evaluation having been issued.

16 There's been a series of subcommittee meetings over
17 the last year with two very recently in September and earlier
18 this month. We've recently received the -- what we call Module
19 II from Westinghouse which is the amended USIs and GSIs and
20 this is under active staff review now.

21 One of the things that we're going to have to do in
22 order to get this done in the time frame that we talked about
23 was to try to really nail down a near term schedule. In order
24 to be able to keep the schedule that I've put up here on the
25 board, the staff is going to have to break from some of our

1 traditional question and answers and Westinghouse has asked us
2 and we've agreed to try to just sit down and resolve a lot of
3 these issues in a more expeditious manner.

4 In order to reach the end, it's going to require a
5 fair amount of input from the committee to get your views,
6 since you can reach to such a point that you would be able to
7 write a letter on the subject. We are trying to wrap up this
8 review by the middle of 1990. I think it's incumbent on all
9 parties that we have a fairly rigorous schedule here and it's
10 going to require a fairly active commitment. Westinghouse is
11 anxious to wrap up the review and so is the staff, especially
12 knowing at this time they're not going to pursue an FDA.

13 We really would like to get this one off the table
14 for a while and kind of wrap a ribbon around it and put it on
15 the shelf til such a time that they want to proceed.

16 MR. WARD: Charlie, what you seem to be doing is
17 asking the committee to not worry about every little point in
18 this --

19 MR. MILLER: Yes, that's a good point. Maybe I
20 should mention that. Yes.

21 MR. WARD: Because we're going to get a crack at it
22 again.

23 MR. MILLER: Right.

24 MR. WARD: And kind of get on with our review of it.

25 MR. MILLER: Yes. I guess I should make clear that

1 it's the staff's intention that whenever we issue the PDA, we
2 want to make it clear that all parties will have another crack
3 at it at the FDA stage and we don't want to nail it down in
4 such a manner that decisions have been made that are
5 irreversible. It's really a snapshot in time of our thinking
6 at this point.

7 Westinghouse is agreeable to that so they can
8 basically get the benefit of the staff's thinking at this point
9 in time and the agency's thinking when it's actually issued.
10 The point is that when we get to the FDA stage, everything will
11 get revisited in full scale. So, it will not be a case that we
12 won't be able to go back and -- if new information is
13 available, we get more detailed information on the design,
14 we're obviously going to be pursuing it.

15 [Slide.]

16 MR. MILLER: Just a little bit of summary about where
17 we are in the review of the SP/90. We have issued three draft
18 safety evaluations thus far, and currently, with the draft
19 safety evaluations that have been issued, we have broken down
20 the items into basically three categories: those which we feel
21 need to be resolved before a PDA is issued; those which we feel
22 that can be deferred to the FDA, and we have the 99 issues that
23 need to be resolved before the FDA is issued or may need to
24 wait for plant specific application to come in.

25 I should mention that the resolution of many of these

1 issues may not be an actual technical resolution, but may
2 require deferral of decisions until a later date.

3 We anticipate that we'll probably issue two more
4 additional draft safety evaluations before a final integrated
5 safety evaluation is put together, and we'll have to reflect on
6 what we're going to do to actually resolve the USIs and GSIs at
7 this stage.

8 We're going to have, I think, a couple rounds of ACRS
9 meetings, I think, before we finally reach the end of the
10 process, of course which is to issue a final safety evaluation
11 and convert that to a preliminary design approval.

12 MR. CARROLL: Just a comment. The 107 open items
13 before PDA that you mentioned, I got the sense earlier this
14 month that although you hadn't formally resolved them paperwork
15 wise, many of them were --

16 MR. MILLER: Yeah. I think there are many of them.
17 Let me ask the project manager to comment on those. You know,
18 some of these issues are what I would call relatively minor
19 issues, and for things that are minor issues, we like to get
20 them nailed down rather than just leave them open. In some
21 cases, we actually have examined what's been presented to us,
22 and I think that list will drop dramatically over the coming
23 month if we were to put it into a documented format.

24 MR. DONATELL: As the project manager, I probably
25 received draft forms from our reviewers related to the

1 responses, and the numbers are about 70 to 80 at this point in
2 time. The majority of those, probably 60 percent of those, are
3 acceptable on the responses. The majority of the remainder
4 should just take some minor clarification.

5 There will be a handful, and I'm not sure what that
6 number is yet, that are going to be hard spots where a decision
7 will have to be made as to what we do with it at this point in
8 time.

9 [Slide.]

10 MR. MILLER: I'd like to shift gears and talk a
11 little bit about what we call the early review of the passive
12 plants.

13 One of the things that Dr. Murley wants to achieve in
14 NRR is the ability to be able to give the designers as much
15 early information as to what our thinking is concerning, if you
16 will, the design philosophy that's being used.

17 What we are going to try to do is take the
18 information that we have at hand -- we have an early conceptual
19 design document from Westinghouse on the AP-600, and we're
20 going to be receiving some briefings from General Electric on
21 their what they call SPWR, and EPRI is in the process of
22 developing a requirements document for the passive plants which
23 we are going to be receiving over the course of 1990.

24 What we'd like to do is be able to do an early
25 conceptual -- it's not going to be a detailed review, but

1 basically try to do an overview review of the information that
2 we have at haydn concerning how the designers are proceeding so
3 that we can get early input back to the designers should there
4 be any show-stoppers out there, or if they're proceeding with
5 some philosophy that the agency as a whole just is not willing
6 to accept. And if I can use some examples.

7 If, for example, a designer wanted to remove the
8 emergency diesels because they feel that with gravity driven
9 systems, etcetera, that they were not needed anymore, we
10 consider that to be a major, if you will, philosophical type
11 decision. I'm not saying that they are; I'm just using that as
12 an example. But if they were to do such a thing, I think we'd
13 have to search our souls as to whether the agency really wanted
14 to proceed on that line.

15 There's a myriad of issues that we need to look at
16 with regard to passive plants, because with some of the systems
17 that will be included in those plants, they may not fall within
18 the current GDCs, the regulations, the SRPs. If there's
19 something that I think that the agency will philosophically be
20 against, one train versus train of certain types of systems,
21 we'd like to get that information out to them as early as
22 possible so that they don't go through and do a complete
23 design, present an application, and it would just be totally
24 unacceptable to what the agency's thinking is.

25 So in that regard, we're trying to take the

1 information that we have in hand, and try to get some early
2 input back to them.

3 MR. CARROLL: Do you see an ACRS role in this phase?

4 MR. MILLER: Yes, sir. I'll get to that.

5 MR. CARROLL: Okay.

6 MR. MILLER: Very definitely. I not only see an ACRS
7 role, but I'm anticipating that the Commission is going to want
8 to be involved, and that the Commission is going to want to ask
9 the ACRS to be involved.

10 MR. PALLA: In the document, you said that before the
11 Commission there is a discussion of PIUS. Is there an actual
12 request to review PIUS?

13 MR. MILLER: Yes. ABB has submitted a request asking
14 the staff to do what they would call a license-ability review.

15 MR. SHEWMON: Who is asking the staff?

16 MR. MILLER: ABB. The vendors for PIUS. In that
17 request, they ask that once the license-ability review is
18 complete, they do plan on proceeding towards an FDA and design
19 certification of the PIUS design.

20 At this time, I think the license-ability review will
21 probably be performed, but I think it's being determined as to
22 who actually will perform that review, and if the review will
23 be somewhat like the review that was done for the MHTGR and the
24 LMRs at the first stage, versus an actual staff review in NRR.
25 But the paper itself, I think, addresses what the staff's

1 thinking at this point in time is concerning how to proceed in
2 the immediate future with PIUS.

3 MR. SHEWMON: Thank you.

4 [Slide.]

5 MR. MILLER: Mr. Carroll, a request you had was, was
6 ACRS going to be involved, and I think I can address that in
7 the next slide.

8 Here's kind of the near-term review schedule. What
9 we're trying to do is put together a work plan, and then try to
10 stick to it, which requires a series of activities in order to
11 be able to try to commit some kind of early information back to
12 the vendors in the early guidance.

13 Westinghouse gave the staff a presentation on their
14 AP-600 in August. In December, General Electric is going to
15 come in and brief the staff on the SBWR design. We also
16 anticipate having a meeting with EPRI regarding their
17 requirements document on the passive plants. We have not
18 received any of that yet, and we've asked EPRI to try to get
19 together and find a mutually agreeable date where they can come
20 in and make a presentation to the staff.

21 With that information, as we've built on it over
22 time, between February and 1990, the staff is going to try to
23 do an evaluation to try to come up with what, you know, we call
24 the show-stoppers, if there are any, or some basic questions
25 that we need to proceed and possibly get policy guidance on how

1 to proceed.

2 I anticipate that in about April of this year, we're
3 going to be asking the ACRS to get actively involved. At that
4 point in time, I think the staff will have put together some
5 kind of report based upon our findings. I'm going to ask the
6 committee to look at that and basically comment on our
7 findings.

8 I also anticipate that the Commission is going to
9 want to get actively involved, so although this hasn't been
10 arranged yet, I would imagine, at some time after we've had an
11 opportunity meet with the ACRS and the ACRS has had an
12 opportunity to pass judgment, we will meet with the Commission
13 concerning our findings. And after the whole process is
14 completed, we anticipate trying to get the guidance out to the
15 designers some time next summer, probably in about July.

16 I think that completes the general overview I had
17 planned on giving today. I'd like to open the floor to any
18 further questions.

19 MR. SHEWMON: Let me ask one which may be too
20 detailed, but what's this plant down in Arizona that ships his
21 power off to the West Coast?

22 MR. CARROLL: Palo Verde.

23 MR. SHEWMON: When Palo Verde came up, it seems to me
24 they cheerfully said that the radiation in their core belt line
25 vended life would be something like four times ten to the 19th

1 fast neutrons, which is getting to be less and less
2 satisfactory with time. Could you tell me whether CESSAR 90
3 has a different diameter vessel than Palo Verde, or whether
4 they've --

5 MR. MILLER: It's a slightly larger plant.

6 MR. SHEWMON: More power.

7 MR. MILLER: Yes, more power. I don't have the
8 dimensions. Bobby, do you know, off the top of your head?

9 MR. SHEWMON: And you haven't heard anything about
10 what they expect to have --

11 MR. MILLER: I haven't personally really focused on
12 any types of fluids calculations or anything like that.

13 MR. SINGH: We do not have that information right
14 now, but the vessel is larger than the Palo Verde is.

15 MR. SHEWMON: Do you know whether they've increased
16 the core to fill all that space?

17 MR. SINGH: I do not know that.

18 MR. MILLER: Let us go back and see what we can find
19 out.

20 MR. CARROLL: The SP-90, Paul, looks pretty good in
21 that regard. Westinghouse has done some things to cut fluence
22 down.

23 MR. SHEWMON: GE has their ABWR apparently way down
24 on that regard, too.

25 MR. MICHELSON: Did they tell us how they got the

1 fluence down? Was that some outboard reflectors, or something,
2 wasn't it? Is that correct?

3 MR. DONATELL: That's the scheme that Westinghouse
4 uses. They've got a reflector region; the core is larger; it's
5 a little bit different fuel management scheme and load pattern.
6 I forget what the fluence level is at this point in time.

7 MR. MICHELSON: Are those reflectors showing up the
8 first time on the APWR, or have they been used on other plants?

9 MR. DONATELL: Reflector regions, to my knowledge,
10 have not been used in commercial plants before.

11 MR. MICHELSON: Well, maybe that's one of the ways
12 they're getting it down.

13 MR. DONATELL: Absolutely.

14 MR. MICHELSON: Okay.

15 MR. DONATELL: Absolutely. I think the design is up
16 to, I think a 60-year life, if I recall, with no fluence
17 problems.

18 MR. MILLER: Most of the designers have indicated
19 that they'd like to have the plants reviewed for a 60-year
20 life, and off the top of my head, I would guess, if that's
21 their indication, they're going to have to get it down because
22 if they get the kinds of numbers that you talked about at a 40-
23 year life, they're certainly not going to make it to 60 years.

24 MR. SHEWMON: Yes. And Reg. Guide 1.99 REV 2 has
25 tended to move more people into trouble than were there before.

1 So if they're smart, they will have done it. But one of the
2 frustrations, I guess, on some of these things is they say, you
3 know, "Well, we'll put it inside of a pressure vessel. Trust
4 us," in effect.

5 MR. MICHELSON: The APRR, as I recall, is only being
6 proposed presently for 40-year, and that 20-year is something
7 that'll come later at the FSAR stage.

8 MR. MILLER: Right. When they get to the FDA stage,
9 they may change.

10 MR. CARROLL: Legally, today, there's no way the
11 Commission can issue a license for more than 40 years.

12 MR. MILLER: Yes. And that's an issue -- I mean,
13 that's an issue where our hands are tied: The Commission can't
14 issue a license for more than 40 years. We're bound by
15 legislation.

16 MR. DONATELL: There are two issues related to the
17 time frame. One is the license-ability term, and the other one
18 would be a design lifetime, and, as I said, I believe the
19 design lifetime is the 60-year period.

20 MR. MICHELSON: That part I misunderstand. I thought
21 they were only designing for at this PDA stage. When I asked
22 the question, I thought that was the answer.

23 MR. CARROLL: You're talking SP-90, Carl?

24 MR. MICHELSON: Yes.

25 MR. CARROLL: I got the clear impression that they

1 felt they had a vessel that would be okay for 60 years.

2 MR. MICHELSON: But they were only proposing it for
3 40.

4 MR. CARROLL: That's all they could get approval for
5 at this time.

6 MR. MICHELSON: They didn't say that was the reason,
7 but that's all they said they were planning on at this stage.
8 If they go FDA, then they would have to extend it or would
9 extend it to 60.

10 MR. CARROLL: Not unless the Commission gets a change
11 in their regulations.

12 MR. SHEWMON: I'd like to have him tell me what he
13 told me again. As I understood it, you said that one can carry
14 out the design for 60 years and you can review that, but that
15 the Commission can't license for more than 40 years. Is that
16 right?

17 MR. DONATELL: That's my understanding.

18 MR. MILLER: That's correct.

19 MR. SHEWMON: So when you write your SER or
20 something, you say, yes, we think this design is good for 60
21 years?

22 MR. DONATELL: Well, we haven't gotten to that stage
23 yet, and I won't commit to whether we would write it that way
24 or not. My guess is it would be written around the term that
25 is currently licensable. Whether it would extend that to a 60

1 year lifetime, I can't answer that.

2 MR. MILLER: I think for those who have specifically
3 asked for review for a 60 year lifetime, we probably would
4 address those aspects of the review where we feel that the
5 design is adequate for that.

6 MR. MICHELSON: The ABWR is a 60 year proposed design
7 and the DSER talks about 60 years.

8 MR. MILLER: That's correct, and we'll address that.
9 Now, that doesn't necessarily mean that every component in the
10 plant is going to last for 60 years, because I think as part of
11 the -- obviously, components like the reactor vessel have to,
12 but I think when they say 60 years, some of them have even
13 planned for when the lifetime of a particular component would
14 end and when it would have to be changed out and they're
15 designing that into the plant so that that's a feasible thing
16 to do.

17 So it doesn't necessarily mean that every component
18 has to last for 60 years.

19 MR. REMICK: Any comments from the Subcommittee?

20 MR. CARROLL: No. I guess one procedural matter. I
21 assume the same subcommittees would work with the staff on the
22 passive plants that are working with them on the present things
23 that are being reviewed.

24 MR. REMICK: If you're talking about BWR and PWR when
25 it comes to things like PIUS, I think we certainly might want

1 to consider that.

2 MR. MICHELSON: We have an Advanced Reactor
3 Subcommittee which deals with PIUS and the others. Is that
4 right?

5 MR. REMICK: Whether PIUS is in that --

6 MR. WARD: I'm not sure it's clear.

7 MR. MICHELSON: APWR is another one of those that I
8 thought was going to be Advanced Reactor versus Improved or
9 Enhanced. I thought it was. That's my own opinion only.

10 MR. WARD: We can make it whatever we want.

11 MR. MICHELSON: Right. That's why I think Jay was
12 asking the question.

13 MR. MILLER: Mr. Chairman, if I could bring up a
14 procedural point.

15 MR. REMICK: Sure.

16 MR. MILLER: From the System 80-plus, especially in
17 the near term, over the coming months, we're going to be asking
18 the Committee to review the licensing review basis. There is
19 no, to my understanding, correct me if I'm wrong, but we have
20 had no activity since I've been involved here. I don't think
21 there is a standing subcommittee for the System 80-plus.

22 We do. It's the same one as for the SP-90, so we
23 will deal with that one. That will help us with regard to
24 getting information.

25 MR. WARD: It seems to me that 600 megawatt plants

1 ought to go with the same subcommittee. That would be my
2 suggestion.

3 MR. CARROLL: If they can handle it. If they get the
4 load too great.

5 MR. REMICK: Anything further?

6 [No response.]

7 MR. REMICK: If not, we thank you very much, Mr.
8 Miller. Mr. Fraley, ACS future activities. Off the record.

9 [Discussion off the record.]

10 MR. REMICK: Back on the record.

11 And Ivan, if you would give us the subject, please.

12 MR. CATTON: While I was at the meeting in Karlsruhe,
13 I went to visit the Siemens MOV test site, where they are
14 testing a series of, NRC is testing a series of valves through
15 a contract with EG&G and Siemens. The valve that I was there
16 to see tested was a six-inch valve, and they tried to close it
17 against a full head of steam.

18 The valve closed. But to close it, it required that
19 the force be 50 percent above the design specifications for the
20 valve. It was an Anchor Darling valve. And the conclusion is
21 that the valve would not have closed if called upon to do so in
22 the plant configuration, because of the excess load that was
23 required.

24 What happens is that under full load, the valve disc
25 tilts, and the edge of it starts to gouge into the seat. And

1 it just takes one hell of a force to shove it shut.

2 MR. KERR: They tried to close it under what
3 circumstances?

4 MR. CATTON: Full steam flow.

5 MR. KERR: What does "full steam flow" mean?

6 MR. CATTON: I don't recollect what the pressure is.
7 But whatever you would expect in a nuclear power station.

8 Carl, do you know what the pressure was they tested
9 that at?

10 MR. MICHELSON: I'm sorry?

11 MR. CATTON: Do you know what the pressure was they
12 tested that against?

13 MR. MICHELSON: Which tests? The Wylie tests?

14 MR. CATTON: The six-inch valve at Siemens.

15 MR. MICHELSON: No, I don't know.

16 MR. CARROLL: I think it was simulating that HPCI
17 steam-line isolation valve.

18 MR. MICHELSON: I would guess it was a thousand
19 pounds.

20 MR. CATTON: A thousand pounds.

21 MR. MICHELSON: Gas only.

22 MR. CATTON: Okay.

23 MR. WARD: Pressure. You were talking about flow,
24 though.

25 MR. CATTON: Well, it is whatever the design

1 conditions were. So I don't recollect, I don't know what the
2 flow rate is.

3 MR. SHEWMON: Is most of the problem pulling it shut
4 against the flow?

5 MR. CATTON: Yes.

6 MR. SHEWMON: Or holding it against the pressure that
7 is there when the flow -

8 MR. CATTON: No, no, no. The problem is getting it
9 shut

10 MR. CARROLL: Fully shut.

11 MR. CATTON: Fully shut.

12 MR. KERR: So it is a differential pressure of about
13 1,000?

14 MR. CATTON: Right.

15 MR. KERR: Is that right?

16 MR. CATTON: Right. And the problem is, it tilts and
17 gouges. So the friction factor gets kind of high.

18 And once they had it closed -- Actually, I missed the
19 excitement, because the day I was supposed to go there, the
20 local radio station signals were being picked up in the
21 instrumentation. So they cancelled the test.

22 But the day that I was there, they opened the valve.
23 And it turned out it took almost as much force to open it as it
24 did to close it. So whatever happens, it really gets wedged
25 in.

1 MR. MICHELSON: That was after being damaged on
2 closure, though, wasn't it?

3 MR. CATTON: Yes. Yes. It was the following day.
4 And the valve was cold, and they couldn't get it open, until
5 they had reached about the same force pulling it as they did
6 pushing it.

7 MR. CARROLL: Now, in this test, the valve had an
8 oversized operator on it, I gather.

9 MR. CATTON: Yes. They wanted to be sure that they
10 closed it, and then they would look at whatever the load was
11 that it took to do that.

12 MR. CARROLL: And had it followed the pattern in
13 previous tests, the load was okay until you got very close to
14 closed, and galling started to occur?

15 MR. CATTON: All the data wasn't reduced when I was
16 there, but the valve was not fully closed when the galling
17 started. Now, I don't know if it started at the same place
18 that the other valves did or not. But I looked at the other
19 valves that they had tested, and they all had damaged seats as
20 well. And there was even one, I don't recollect the name of
21 it, that looked like it behaved reasonably well, but the seat
22 was still damaged.

23 MR. SHEWMON: What kind of a valve was it?

24 MR. CATTON: This was an Anchor Darling. I'm not
25 sure I know one valve from another. These are massive devices.

1 MR. SHEWMON: I'm almost sure it was a butterfly ball
2 valve.

3 MR. CATTON: This was a wedge gate valve. Right.

4 While I was there, it was interesting that both
5 Westinghouse and a small company that is a spinoff from Glen
6 Reed's place were there testing valve diagnostics, and the --
7 I'm not sure which one -- oh, the fellow from Westinghouse,
8 they actually have a sensing device that they put on the valve
9 stem. And they measure its change in diameter. And they
10 relate the change in diameter of the stem to the load.

11 I would have thought that that is an awful small
12 amount of motion. But they were able to correlate their
13 results very well with the results that were obtained by NRC.

14 The NRC test was extremely well-instrumented. They
15 had Pitot tubes upstream, downstream. They had strain gauges
16 all over the thing, temperatures. They even measured pressures
17 inside the bonnet of the valve to make sure that everything was
18 recorded.

19 And this simple instrument of Westinghouse was able
20 to hit right on the load, almost as well as the more exotic
21 instrumentation that NRC has.

22 MR. MICHELSON: Was it actually able to measure load
23 or just tell you when the loading was significantly increased?

24 MR. CATTON: It measured the load.

25 MR. MICHELSON: Somehow the conversion factor between

1 stem diameter and thrust?

2 MR. CATTON: That is correct. That is correct.

3 Now, the other people had a little different
4 approach. What they did was they prestressed the bolts that
5 hold the top of this thing down, and then when the valve is
6 opened you unload those bolts. So they essentially measured
7 the unloading of these bolts and related that to the load.

8 MR. MICHELSON: Those are load washers, I assume.

9 MR. CATTON: Yes.

10 MR. MICHELSON: The load washers on the bolts.

11 MR. CATTON: Yes. Now, the Westinghouse system would
12 be put on the valve and left on the valve, and would record
13 anytime that valve was used.

14 The other system was only when they had the valve down
15 for maintenance or were doing maintenance-type testing.

16 Yes.

17 MR. SHEWMON: Change in diameter is on the order of a
18 tenth of a percent, depending on how big it is. So it is ten
19 to the minus three strain.

20 MR. CATTON: That is do-able?

21 MR. SHEWMON: It is do-able, that magnitude.

22 MR. CATTON: I guess I know it is do-able, because I
23 saw it.

24 MR. CARROLL: What do they do about stem deflection
25 and so forth that is occurring which might affect the diameter

1 and ovality of the stem?

2 MR. CATTON: I think this mounts directly on the stem
3 itself, so if there is a little bit of deflection side to side
4 it doesn't matter.

5 MR. CARROLL: No. But if you have a long stem, and
6 the thrust is out at the end, it bows a wee bit and that
7 affects the ovality.

8 MR. CATTON: But they are measuring the diameter of
9 the stem.

10 MR. CARROLL: What is the diameter now that they are
11 measuring?

12 MR. CATTON: I guess I don't know what happens to the
13 diameter when you bow. I guess if you bowed far enough to
14 affect the measurements, they would be in trouble.

15 MR. SHEWMON: Maybe they measure it twice and measure
16 it.

17 MR. MICHELSON: That may be what they do. You would
18 have to do something.

19 MR. CATTON: It looked like a very nice system.

20 MR. IGNE: They could balance that strain out by when
21 it bowed you could have positive and compression on the other
22 side, that could be balanced out, in the bridge.

23 MR. CATTON: He told me what they measured is actual
24 change in diameter across the stem.

25 MR. MICHELSON: But in an ellipse, that is different

1 than on a circle.

2 MR. CATTON: That's true. That's true.

3 MR. MICHELSON: So you would have to know which
4 diameter you are measuring.

5 MR. CATTON: I think if you start bending the stem
6 that much, you are in trouble.

7 MR. REMICK: Is that the end of your subcommittee
8 report, or your visit report? Any questions?

9 MR. CATTON: If you want to hear about the rest of
10 the visit, I'd be delighted to tell you.

11 MR. MICHELSON: Before you go to the rest of the
12 visit, could you tell us what else they are planning on doing?

13 MR. CATTON: There was one more valve there that they
14 were going to test. And I believe it was a ten-inch valve of
15 the same type. Not the same manufacturer. But it was a wedge
16 gate valve.

17 MR. MICHELSON: Okay.

18 MR. CATTON: It was a massive piece of steel.

19 MR. SIESS: They were testing U.S.-made valves?

20 MR. CATTON: Yes. It was interesting, too.

21 MR. SIESS: Are they doing it for us?

22 MR. CATTON: Yes. NRC contracted EG&G who in turn
23 contracted Kraffwerke Union to do the test.

24 MR. SIESS: We were told that when KWU started
25 building nuclear plants, they decided the valves weren't good

1 enough and they went out and designed their own. Are there any
2 tests like this on their own valves that we could use for
3 comparison?

4 MR. CATTON: I think this test facility was there to
5 test Kraffwerke Union valves.

6 MR. MICHELSON: Not gate valves.

7 MR. CATTON: Whatever kinds -- I don't know.

8 MR. SIESS: You don't think they designed new gate
9 valves, Carl? You don't think KWU designed new gate valves?

10 MR. MICHELSON: No, the facility was designed, we
11 visited, Charlie and I visited the facility a couple of years
12 ago. And that is when we told the Staff, the Staff said there
13 was nothing in the world where they could do the testing.

14 MR. SIESS: The question is that KWU, we were told,
15 had developed their own valves as an improvement.

16 MR. MICHELSON: I'm leading to the answer to that.

17 The facility was built to test two types of valves,
18 originally. And that was, they designed a very special main
19 steam isolation valve with a relief valve capability on it, and
20 it was originally designed to test that, because it was a very
21 large valve, 20-some inch diameter.

22 We were over there two years ago, we asked them, and
23 no, they hadn't tested any small gate valves, for instance, but
24 the fellow from out here at Bechtel Alliance told us they had.
25 I asked Charlie again and we agree. They never told us they'd

1 done that kind of testing. I think he was perhaps mixing it up
2 with something else.

3 MR. CATTON: But there are other tests at the
4 Kraftwerke Union arena, too.

5 MR. MICHELSON: Right, but not at that facility.
6 That was our understanding, at least.

7 MR. CATTON: It was interesting that the finding
8 valves to test was a bit of a problem. The manufacturers were
9 very cooperative. So what they had to do was find one in a bone
10 yard somewhere and they would take it to people who were in the
11 business of refurbishing them. So, they would have the valve
12 refurbished and then they took the refurbished valves to
13 Germany, but they couldn't get the manufacturers to cooperate.

14 MR. SHEWMON: They could go down to a couple of the
15 abandoned TVA plants?

16 MR. CATTON: Well, that's essentially what they did.
17 There's a bone yard and you can go to the bone yard and find
18 your own bones and refurbish them.

19 MR. CARROLL: I think the refurbishing part is that
20 Roy Woods has taken this over, is very sensitive to the
21 criticism of the earlier tests that they really didn't know
22 what kind of shape the valves were in when they started.

23 MR. SIESS: Are we going to know a lot more if they
24 don't test them; is that the argument? If you don't test them,
25 you won't know how bad they are.

1 MR. CATTON: Well, one thing is sure. It takes a lot
2 more force than the manufacturer said to close those valves.

3 MR. CARROLL: Not necessarily, because the earlier
4 tests, the water tests were done over there, duplicated
5 the tests that Idaho had done with respect to the Anchor
6 Darling valve. It apparently bowed and galled in the seat.
7 The Walworth valve that was tested in Germany performed
8 beautifully -- no problems.

9 MR. MICHELSON: But the friction factor was about t.5
10 and not .3 and I think that's what Ivan's talking about.
11 That's the considerably bigger load.

12 MR. CARROLL: Except some of them specify .5.

13 MR. MICHELSON: Yes, but the manufacturer
14 traditionally in this country has been using .3.

15 MR. CARROLL: I don't think that's necessarily true.
16 It depends on the manufacturer and the application.

17 MR. MICHELSON: At any rate, that's what I thought
18 Ivan was referring to.

19 MR. CATTON: I looked at the other valves that had
20 been tested there and the seats on those other valves are not
21 nice after the test. They may have closed with the right load,
22 but I would refurbish the valve if I had the responsibility for
23 it. The seats were damaged.

24 MR. REMICK: Ivan, thank you. I would like to use
25 the additional 20 minutes we have for the reading of a draft

1 letter here.

2 [Discussion off the record.]

3 MR. REMICK: Back on the record. Let's move to Item
4 No. 6 then. Let's move to Item No. 6. Staff here, I believe?

5 A little bit of history on this item -- several
6 months ago, I was out at Idaho National Engineering Lab and had
7 a briefing on the latest information that the people out there
8 had looking at the bottom head of the TMI 2 reactor and they
9 had recorded two four-inch cracks in the head. It was not
10 clear exactly at that time, or not clear how deeply they were.

11 I reported that back and we did have showing at
12 noontime one day a couple of months ago that video of their
13 observation of the cracks but we thought it would probably be
14 timely to ask the staff to come in and fill us in on recent
15 findings that they might have with the explorations of the TMI
16 2 reactor.

17 So that's the purpose of this discussion. It's just
18 background information. I'm not sure who is here from the
19 staff; do we know?

20 [Pause.]

21 MR. STOLZ: My name is John Stolz. I'm project
22 director, one four, and I wanted to provide a few introductions
23 before we talk about the status of TMI 2 this afternoon.

24 In early '88, the TMI program office was abolished at
25 the site and the responsibilities for that were assigned to

1 NRR. We were fortunate enough to have still with us in that
2 transfer project manager Mike Masnik and Lee Thonus who is the
3 project manager assigned to residents at the site.

4 Lee will be talking about the history of the accident
5 briefly and concentrate on the current activities including the
6 cracking in the bottom of the vessel. He'll have a videotape
7 to show that. I think it's very instructive.

8 We also have Bob Van Houten from research this
9 afternoon, and he is responsible for managing the research and
10 the sampling program -- the sampling in the bottom of the head.
11 That should take place in about a month and a half. Mike
12 Masnik will finish up with describing our future plans for
13 completing the cleanup and placing the facility in a monitored
14 storage condition.

15 So if there are no questions, we'll start out with
16 Lee Thonus.

17 MR. REMICK: Just a suggestion. We've had a number
18 of briefings, of course, on the accident. I don't want to
19 belabor that too much. It is the more recent findings and
20 where you stand that we'd like to have emphasized.

21 [Slide.]

22 MR. THONUS: My name is Lee Thonus. I'm the on-site
23 project manager. The first slide we have here is basically
24 what the reactor looked like several hours after the accident.
25 Of course, it took us about eight years to gather this

1 information.

2 This was basically put together by DOE and you can
3 see at the top of the -- you all have a copy of this color
4 slide in your hand out -- at the top, you can see there's a
5 void that was roughly five feet deep when they first got a TV
6 camera in there in 1982. That was the first thing that they
7 found, below that, loose material, consolidated material, which
8 was once molten, below that some partially intact assemblies
9 which had shown some thermal damage and then you can see where
10 the molten areas were.

11 It started out on the side where it melted through
12 the baffle plates and made its way to the lower head. Next
13 slide.

14 [Slide.]

15 MR. THONUS: I'm just going to very, very quickly run
16 over where we've come from, not to belabor it, but just to give
17 you, when I talk about where we are now, what got us there.

18 '79 was the accident. Initially looked at things
19 like plant stabilization. People were putting in extra decay
20 heat removal systems one of which was called the auxiliary
21 decay removal systems. It never got all the way hooked up.
22 There was one called long-term B. It started water processing
23 through EPICOR II. It was a system that processed the water
24 that was mainly in the auxiliary building.

25 That water is now called AGW, accident generated

1 water. There is 2 million gallons of it. At that time, in
2 late 1979, we had what was called the City of Lancaster
3 agreement. Accident generated water was defined as having
4 greater than 0.25 microcuries per milliliter of tritium and
5 there's a little bit more extent to it than that but that's
6 very briefly what it was.

7 The deal was a three-way deal struck between the NRC,
8 the Intervenors, the City of Lancaster, and the utility, that
9 they would be allowed to use the process, clean up the water,
10 but the ultimate disposition would be decided some time off in
11 the future and it would go through some sort of a licensing
12 process.

13 Anyway, 1980, the krypton was vented from the
14 building. That allowed manned entries into the building.
15 There was some early data gathering. '81, some dose reduction,
16 decontamination activities. We're a couple of years into the
17 accident. The last thing, SDS operational -- that's the system
18 that cleaned up the radioactive water that was in the basement.
19 There was about 600,000 gallons of water in the basement and it
20 was roughly 150 microcuries per milliliter. Next slide.

21 [Slide.]

22 MR. THONUS: '82, they removed the lead screw at the
23 H-8 location, lowered TV camera, got that first picture that I
24 mentioned before. More decontamination, data gathering. '83,
25 lot of '83 was taken up with polar crane. Some of you may or

1 may not remember, there were a lot of allegations about how the
2 polar crane refurbishment was done, was it done safely, were
3 things treated as ITS, not ITS and basically that set the clean
4 up back about a year until all those issues were resolved.

5 Come into '84, the head was removed. The internal
6 indexing fixture was installed on top of the reactor vessel
7 flange, allowed it to be flooded up another five feet. The
8 canal -- the end of the canal by the fuel transfer tubes was
9 also flooded. The rest of the canal was kept dry by a dam.
10 You see, we've gone five years post-accident before they get
11 the head off and get a look inside. Next slide.

12 [Slide.]

13 MR. THONUS: '85, a video was taken of the lower
14 head. There are holes that are used -- exercise holes -- for
15 the internal vent valves. They lowered a camera down through
16 the internal vent valves exercise holes, went down along the
17 outer annulus of the reactor vessel, got a camera, looked at
18 what was in the lower head. It looked like a pile of coal.
19 There was also some shots of where dripping candle effect
20 coming through the elliptical flow distributor of a lower core
21 support assembly.

22 The plenum was removed in '85 and actually in late
23 '85, I think it was October 31st, they actually started what
24 was called defueling. That was preliminary moving things
25 around -- not actually taking anything out. 1986, the rubble

1 bed, the loose stuff was defueled.

2 The core bore samples where they used an oil drilling
3 rig to drill through the core and get vertical samples just
4 like any geologist would take samples of the earth. Those
5 samples were taken in '86. '86 was where they had the
6 visibility problems. Bacteria and other organisms got in the
7 reactor coolant system. It was an ideal growth medium.
8 Temperatures around 80 degrees.

9 The hydraulic fluid, which was carbon-based, served
10 as a source of nutrients. The lights they used for observing
11 what was going on served as a source of heat and energy and at
12 one point in time, the visibility was about that far.

13 The first fuel shipment went out in '86. 1987, they
14 actually got down to where they were taking -- if you look at
15 the color slide of the reactor vessel -- the assembly remnants.
16 They got down to where they got underneath the lower end of the
17 assemblies and popped the assemblies loose. That basically
18 meant the core area was defueled.

19 There was sludge in the reactor building. At one
20 point, everybody, oh gee, how deep is this sludge. It looked
21 like a lot. It turned out to not be very much of anything. A
22 lot of radioactivity associated with it compared to a normal
23 plant. It was mainly probably a layer of silt only a quarter
24 inch thick but looking at it initially, it looked like a big
25 layer of mud, but it varied. The floor wasn't even and in a

1 couple of spots, it may have been a couple of inches deep and
2 they said, oh, my God. Two inches deep over an entire
3 containment building. There's going to be tons of this. There
4 wasn't.

5 Decontaminated the reactor building walls, that was
6 basically a mechanical abrasion process. There's a lot been
7 written about this. The reactor building walls, you know, the
8 water flooded 200 microcuries per milliliter. The activity
9 leached in and again I'm trying to gloss over this very
10 quickly. It tended to stay in the outer centimeter of the core
11 concrete wall. It was also a hollow block wall, if we hit the
12 next slide.

13 [Slide.]

14 MR. THONUS: Talking about defueling the lower core
15 support assembly, that's somewhat we've got in the model here.
16 Deconning the reactor building walls, same thing, a mechanical
17 thing. The block wall flush. There was also hollow blocks,
18 like cinder blocks. They poured water in the center but the
19 water flowed out. It leached. It was about 35 percent
20 successful in leaching radioactivity out.

21 The hollow walls absorbed radioactivity much more
22 efficiently or to a much larger extent than the solid poured
23 walls that were the 5,000 p.s.i. and 3,000 p.s.i. walls.

24 Yes, sir.

25 MR. SHEWMON: Is that because their one block that

1 had holes in the center was also more porous in its
2 construction or aggregate or something?

3 MR. THONUS: The hollow wall was very much more
4 porous.

5 MR. SHEWMON: Okay. Cinder block or concrete?

6 MR. THONUS: It's concrete -- as far as I know, but
7 it's a concrete block but they were hollow.

8 If you want, I'll tilt up the model. I'll catch that
9 in a second. We also had the evaporator hearings. Earlier, I
10 alluded to the fact that there was water in the auxiliary
11 building. There was also water in the reactor building. When
12 you added up all the water that was here, there and then there
13 was continuous makeup every time there was a little bit of
14 leakage, they used fresh batches of DI water, added boron,
15 added to the system, and it's continually adding to the total
16 inventory but any more of the additions are very, very slow and
17 when they leak water out, they reprocess it and they reuse it.

18 We're up to around 2.3 million gallons right now at
19 the site.

20 There were public hearings on how that water was to
21 be disposed of. Those hearings were held in late 1988,
22 October-November, 1988.

23 Various alternatives were considered. We put out an
24 addendum to the Environmental Impact Statement that dealt with
25 the water processing possible alternatives. The alternatives

1 selected by GPU Nuclear was to evaporate the water.

2 At first I thought that took some people by surprise
3 but there was -- everyone was expecting there to be a water
4 discharge and the Intervenors would oppose that and when it was
5 in evaporation the Intervenors also opposed that. The hearings
6 were concluded in 1988-1989. The evaporator decision was
7 rendered by the ASLB in favor of the utility. It went through
8 the appeal process. There was a stay denied, appeal denied.

9 Right now they are in the phase of testing the
10 evaporator. I expect that the evaporator testing will be
11 complete and the first gallon of water will be evaporated
12 probably sometime in January of 1990.

13 Defueling-wise, 1989 defueling lower core support
14 assembly, which was quite a difficult job, the lower head which
15 they are still doing a little bit of now and the area behind
16 the core baffle plates.

17 Remember the first slide, the first color slide we
18 had showed that a hole was melted in the baffle plate. You'll
19 get to see that on the videotape and a lot of fuel was
20 distributed behind the baffle plate. The last thing to happen
21 this year, when they are finished with the fueling probably the
22 first part of next month, we have an international research
23 program -- Bob Van Houten's here and he'll be able to answer
24 any detailed questions -- we'll hit that a little bit more but
25 to obtain samples from the reactor vessel head, especially in

1 the areas where we have observed cracks.

2 Let's see what we've got for the next slide.

3 [Slide.]

4 MR. THONUS: This is probably a good point for me to
5 tilt this up.

6 The various components of the lower core support
7 assembly when they are cut apart, this obviously the forging is
8 14 inches thick. It is pretty tough to cut with anything. It
9 was all cut under 40 feet of water with a plasma arc torch and
10 every time just because of the way the torch head was, now this
11 side was cut just as much as that one but the way the model is,
12 one-half the model shows how it originally was and one-half
13 shows after cutting.

14 You'll notice it is kind of a step defect. Every
15 time you go down one layer, just because of the size of the
16 head, you have to step in a little bit narrower, so by the time
17 you got access through the final layer which we couldn't fit in
18 the car -- we have a piece, the piece that was cut out -- this
19 would fit underneath here like that [indicating].

20 MR. SIESS: None of this was melted?

21 MR. THONUS: Pardon me?

22 MR. SIESS: None of this was melted?

23 MR. THONUS: No, none of the -- there was very little
24 damage, essentially no damage to the various layers of the
25 lower core support assembly. There was a little bit of damage

1 and you will see some of it. It alludes to it slightly on the
2 first color picture, that there was some damage noticed on the
3 guide tubes. There was some damage to the guide tubes and when
4 you see the in-core entry penetrations, you'll see it in the
5 video, there was extensive damage done to those.

6 A lot of metal flowed through here but apparently it
7 went through fast enough not to do any damage.

8 There are holes in the core formers that started out
9 being three-quarters of an inch in diameter.

10 MR. CATTON: What is a core former?

11 MR. THONUS: Do we have that on a slide? Yes.

12 [Slide.]

13 MR. THONUS: This unfortunately is the wrong
14 dimension for what I want to show you but the core former, if
15 you have a round core barrel and then your actual -- the core
16 is kind of a stepped, rectangular --

17 MR. CATTON: Okay, I understand.

18 MR. THONUS: -- so you have the baffle plate and the
19 core former is the -- are these [indicating]. They are round
20 on one side and flat on the other and a real odd shape, as best
21 I could describe it. I'm not sure now to, but the core formers
22 are oriented horizontally -- pardon me?

23 MR. CATTON: There are spacers?

24 MR. THONUS: There are spacers. There are spacers
25 between the baffle plate and the core barrel and they have

1 these three-quarter inch diameter holes in them that as the
2 melt went through there apparently it had a long enough stay
3 time or enough heat was -- and some of those holes are about
4 this big now, about three inches or so.

5 MR. CATTON: Was the core barrel damaged?

6 MR. THONUS: Not to -- there's a couple of spots
7 where it is kind of hard to say. It's been discolored from
8 heat or material adhering to it. It wasn't melted through
9 anyplace. It may have had small areas of ablation but it's
10 kind of hard to call it, looking at it -- you know, you're
11 looking through a camera that's under forty feet of water and
12 maybe it's just kind of a shadow and maybe it's just something
13 adhered and maybe there really is a little bit.

14 Most people tend to think that there was just a
15 little bit of slight ablation in a couple areas on the core
16 barrel.

17 [Slide.]

18 MR. THONUS: This shows -- while I've got this slide
19 out here -- this was a couple of months back, what the status
20 of everything was. This shows that the five layers of the core
21 support assembly and how as you go down, the final one being
22 the elliptical flow distributor, a hole through the center of
23 the core gets a little smaller. Now this area here was all
24 filled with fuel at one point in time and right now you also
25 see that as you get down this far there's remaining fuel

1 material out here and out here [indicating]. When you flush it,
2 it tends to fall downhill and wind up in the lower head, which
3 is a convenient spot to pick it up.

4 MR. CATTON: Right in the center there is a spike in
5 the downward direction. Have you looked at that? Was that the
6 -- did the melt penetrate like that?

7 MR. THONUS: Yes, there was -- some of the melt that
8 got pretty close to the lower end fitting near the center of
9 the core but it wasn't -- you know, when you looked at the end
10 fittings it didn't go through. There wasn't significant damage
11 at the very, very bottom.

12 It went almost all the way.

13 MR. CATTON: So the crust failed and it spilled out.

14 MR. THONUS: The crust failed and it spilled out and
15 it spilled out and went through the baffle plate. It kind of,
16 like I said, enlarged those holes in the core formers as it
17 went through.

18 It also expanded radially. It melted a hole -- and
19 you will get to see that very, very dramatically when I show
20 you the video.

21 MR. SHEWMON: This stuff that came around on the far
22 side you think came out of the crucible there and ran around
23 differentially?

24 Yes, that. How did that get from the left side to
25 the right side?

1 MR. THONUS: Oh, it's 360 degrees around. When it
2 spread it went all the way around.

3 MR. SHEWMON: But the source was only that one place
4 on the left?

5 MR. THONUS: Yes. There was only one principal hole
6 through the baffle plates. When they took apart the baffle
7 plates -- and you'll get to see that hole -- it's a big hole.
8 You could crawl through it with no problem without touching.

9 MR. CATTON: You show a crust up there on the right.
10 High up above --

11 MR. THONUS: Yes, this is a three dimensional
12 picture.

13 MR. CATTON: High up.

14 MR. THONUS: This crust?

15 MR. CATTON: Run your finger up a little bit.

16 MR. THONUS: Okay.

17 MR. CATTON: Is that crust material or is that a
18 mistake?

19 MR. SHEWMON: That was filled with molten material
20 before there was this opening up and it fell out.

21 MR. CATTON: That high?

22 MR. SHEWMON: Well, there's a lot of stuff on the
23 bottom that was on top of what's still remaining there.

24 MR. THONUS: I don't -- I'd have to measure that.
25 That crust that you are talking about on the top right looks a

1 little higher than my recollection of being any crust.

2 MR. CATTON: So the crust failure on the side won out
3 over the penetration in the dominant direction?

4 MR. THONUS: Yes, the crust failure on the side won
5 out over what was going down the center.

6 MR. CATTON: But it looks like it was a close race.

7 MR. THONUS: Yes. It looks like it was a close race.
8 I certainly couldn't dispute that.

9 MR. REMICK: We are going to have to move ahead as
10 fast as we can.

11 MR. THONUS: Okay, one more slide. We'll keep going
12 forward.

13 [Slide.]

14 MR. THONUS: This gives you a rough idea of progress
15 versus time. You find that they get something that they could
16 dig out and they'd get something that would represent a new
17 challenge, then they'd figure out how to attack it and then you
18 would have a rate of progress, then a flat zone, a rate of
19 progress and a flattened out area.

20 The big flat area here is trying to drill and cut and
21 get through the lower core support assembly which is stainless
22 steel and isn't a very easy material to cut. It smears rather
23 than chipping nicely like carbon steel.

24 Next slide.

25 [Slide.]

1 MR. THONUS: I'll go through these real quick.

2 This is just some of the melting points. I'm sure
3 that most of you probably know more about metallurgy than I do
4 but anyway these are just some of the melting points of some of
5 the material that was in the core. Stainless steel control
6 rods, one of the first things to melt, spacer grids, Inconel.
7 We'll see the spacer grids, also the in-core instrument
8 penetrations are Inconel -- the UO2 5000 -- the Eutectic, if
9 you melted zirc, you could actually sort of either form a
10 Eutectic or you could actually dissolve a certain amount of
11 uranium dioxide. It appears you also have some of that other
12 Eutectics, other than zirc uranium. You could have a Eutectic
13 of stainless steel dissolving zirc -- but not much of that
14 happened.

15 MR. PEMICK: We are particularly interested in what
16 you have recently found on the bottom head, the cracks, the
17 depth of those cracks, and those type of things. You are going
18 over a lot of information we've had in the past.

19 MR. THONUS: Just this little bit of background
20 information for the video. These in-core instrument
21 penetrations started out as one inch penetrations I think on
22 the start-up of Oconee or one of those plants. There was a
23 problem. They weren't large enough in diameter and there was
24 flow induced vibration and damage to them so this was then
25 ground out. There was a weld put in with a backing sleeve and

1 then the larger two inch diameter in-core instrument
2 penetrations were put in.

3 Just to give you a history of what these things are,
4 why they are two inch and why you have so much weld zone here
5 at the base, you've got 3/16ths nominal stainless steel clad on
6 a typical mg/mo carbon steel vessel.

7 Next we have -- what? Oh, next is the video. Okay.

8 MR. CARROLL: Relate that to this.

9 MR. THONUS: Oh, this is above the head. This is
10 this [indicating] and this is this [indicating]. These are the
11 guide tubes and these dowels are simulating the in-core
12 instrument penetrations themselves. Then I'd have the lower
13 head is what fits onto here that wouldn't fit in the car.

14 [Video presentation follows:]

15 MR. MICHELSON: One of the cracks, G-6, this is the
16 smaller crack.

17 Go ahead, roll it.

18 [Slide.]

19 MR. SHEWMON: Is it always from top to bottom so
20 there's apparently a white line as the fluid came around?

21 MR. MICHELSON: No, this is just purely a -- it's
22 fuel dust somewhat obscuring a crack. Now, there is a crack
23 looking vertically down. That also looks like G-6.

24 MR. SHEWMON: Which ways did the material flow when
25 it came down --

1 MR. MICHELSON: The material flowed from top to
2 bottom in the picture.

3 MR. SHEWMON: My question, did it flow top down, and
4 it did.

5 MR. MICHELSON: It came more from a 45 degree angle.
6 It's following the curvature of the head rather than
7 vertically, okay. You know, there should be a hole in the
8 center of this for the instrument tube and you can see that's
9 filled.

10 MR. SHEWMON: What sort of dimension are we looking
11 at here?

12 MR. MICHELSON: That's two inches roughly in
13 diameter. Now, what this picture shows is they're trying to
14 measure the diameter. It's two inches are built. When they
15 measured it, it was actually off -- it was slightly smaller
16 than two inches.

17 Go ahead, roll it.

18 [Slide.]

19 MR. REMICK: Still only two cracks found?

20 MR. MICHELSON: Well, more than two. This shows the
21 better crack. This is E-7, and what you've got on here is what
22 I call a little stinger. If you notice it's black and white
23 striped so that you could tell the depth how many stripes went
24 in. This little stinger is going to try and do like this,
25 they're going to try and stick it in the hole.

1 MR. SHEWMON: How long is that crack?

2 MR. MICHELSON: That's probably around six inches
3 from here to here.

4 MR. SHEWMON: Okay.

5 MR. MICHELSON: This is two inches in diameter, so
6 figure that's about six. They brushed it to see whether or not
7 the crack was a crack or whether the crack was a crack in some
8 fuel deposits, you know, just some crusty material on top of
9 it. But the crack after they brushed it the crack was a crack.
10 Okay. In the metal. Now, there's some dispute over whether
11 that's just in the clotting or whether that goes down into the
12 base metal of the reactor vessel.

13 This thing is cut so that it'll fit the curvature of
14 the head and right now it's backwards to the head and the
15 stinger should be side toward you but it's on the side away
16 from you and this thing was also the diameter, the diameter of
17 it was sized so it would fit over one of the penetrations and
18 it would fit the curvature of the head and the stinger would go
19 in the hole. Well, as it turns out they got the stinger in the
20 hole only with it turned free floating, not being aligned, and
21 turned backwards, but such is the life of an engineer.

22 Okay, roll it.

23 [Slide.]

24 MR. MICHELSON: As you can see, the stinger right now
25 is in the hole and it's moving back and forth about that much

1 freedom in that hole. The stinger is 3/32nds -- or, in
2 diameter.

3 MR. SHEWMON: So, you couldn't see how deep it was?

4 MR. MICHELSON: There are people who, with calibrated
5 eyeballs, have said how deep it went. I can't, but someone who
6 is more familiar with it than I am declared a depth.

7 Go ahead, roll it.

8 [Slide.]

9 MR. MICHELSON: I could tell roughly, you know, it
10 went from here to here back and forth if you're watching all
11 the back and forth. You could tell how deep it went by looking
12 at the number of black and white stripes that disappeared on
13 you. Of course, with it facing the wrong direction I have a
14 hard time and I didn't get to see it that well.

15 This is the center of the core looking out toward the
16 outer periphery. You know, you're in the hole that's been cut
17 through the center of the LCSA and you're looking out and you
18 can see how there's a lot of junk out here on the outside.
19 You're looking out and between the layers there's a lot of
20 stuff that falls down there that's very hard to remove.

21 Keep rolling.

22 [Slides.]

23 MR. SIESS: What's that on the left?

24 MR. MICHELSON: It's just a post, a support post to
25 align tools.

1 In the background there this is the hole. Of course,
2 every time we freeze it we lose the picture quality. This is
3 the hole that was melted through the baffle plate and we'll get
4 a little bit better near the bottom of it. We get a little bit
5 better look at it there and if you've got this kind of affect
6 where you've got a step defect toward you you're looking at
7 something like this and it's -- now, if you orient this
8 vertically and this wall extends up and down for some distance,
9 the hole is melted through on two bases that are 90 degrees to
10 one another, and you'll see that and it goes in and out of both
11 sides of this.

12 Go ahead and roll it.

13 [Slide.]

14 MR. MICHELSON: This striped affect on here is
15 artifact of a high-pressure water flush. A super high water
16 flush that they used to try and clean it off and it actually --
17 some of the metal was probably partially oxidized and
18 embrittled and it actually blew away some metal, okay.

19 You can see the hole through there now. Back here
20 somebody asked before about was the core barrel damaged and if
21 you look at this shadow here and here and someone says, well,
22 gee, the direction of the light was such that's not a shadow,
23 that's a damage area, and there are other pictures that show
24 that better than this one. But there is the holes through the
25 baffle plate.

1 Dimensionally, how big are you looking at? These
2 bolt holes here are roughly four inches apart and an assembly
3 -- or, one of the steps is roughly eight inches.

4 Go ahead, keep rolling.

5 This is near the upper part of that -- we're getting
6 a little bit higher. This is again the baffle plate, that's
7 the hole melted through, you can see one of the core formers.
8 There is where you see it's got two surfaces. There's a step
9 here -- I should get my hand out of the way and let you guys
10 look. This is the top of a little bit of a spire. You've got
11 a dimension and then you've got another that goes in and out
12 and you can see where it went in this way, came -- it went in
13 this one, came around and out that one, sort of like almost
14 like a spire staircase.

15 MR. SIESS: Have you made mark-ups of models of what
16 you see?

17 MR. MICHELSON: To my knowledge no one has. There
18 are drawings of it but there's no.

19 MR. SHEWMON: In the bottom can you -- how much
20 strength does it have now? Does it easily fall apart or is it
21 crystallized into something which is solid or firm?

22 MR. MICHELSON: The former core material with all the
23 things that it dissolved in would have generally proven to be
24 relatively friable; it broke up, except the layer that was on
25 the very bottom of the lower head. The rest of it broke up

1 fairly readily. There was that -- the stuff that was behind
2 the baffle plats. In other words, if this is the bottom of the
3 core, which is this here, I've got -- was 156 inches or so long
4 assemblies. This was loose up in here. Relatively loose.
5 They just fall down. Some of this was solidified but broke up
6 easily and as you got to the very bottom it became more
7 difficult to break up. It was also --

8 MR. SHEWMON: What I'm trying to get at, I guess, is
9 that if there was indeed a crust there and it tended to freeze
10 and break up and particulate as it came down then -- the
11 question is usually how molten is that material when it gets
12 down to the bottom of the core and if --

13 MR. MICHELSON: All the indications are that the
14 relocation occurred very very quickly and it didn't stop and
15 freeze and thaw on the way, it just went bang once.

16 MR. SHEWMON: But it did go around a lot of obstacles
17 which meant it had to break up and expose fresh surface to
18 what.

19 MR. MICHELSON: Yes, and that's what I think the
20 loose stuff is and you're finding that on the upper layers that
21 the stuff was that was freshly exposed may have solidified as
22 particles this big and settled out but the main melt that made
23 its way down tended to stay intact to a certain extent. Yes,
24 that's -- when we saw the lower head we saw the free coal pile,
25 the chunks that looked like, if you didn't know you were

1 looking at an old core, you'd look like it was some kind of old
2 coal mining heap. And then the stuff at the very very bottom
3 that, you know, the stuff that got broken into pieces kind of
4 fell off onto the side on the way down and the stuff that went
5 out the very very bottom, there was a solid mask, maybe 18, 20
6 inches deep, five feet across, and that was also tougher than
7 most to break up.

8 I want to stop that there.

9 All you're seeing here, that bent piece is when they
10 were doing some defueling they hooked a tool on the bottom of
11 one of the baffle plates and they bent it some, so you got.
12 Now, what you're seeing here, these arrows are some cracks that
13 appear to be out in the middle of no man's land not necessarily
14 associated with any in-core instrument penetration, but the
15 arrows are pointing at additional cracks. You see the cracks
16 here? And I have seen other pictures, I mean, I sat through
17 about six hours of looking at these tapes and I've seen some
18 other cracks and if you follow them long enough sometimes you
19 can lead them to a in-core instrument penetration so it's kind
20 of up in the air.

21 Are they all associated with in-core instrument
22 penetrations as a good starting point for the crack, or are
23 they not? Two theories. I believe that -- yes, sir?

24 MR. SIESS: Why do you say a starting point? Usually
25 cracks end at a hole.

1 MR. MICHELSON: But there's a lot of residual stress
2 from the extra welding that had to go on to change those one-
3 inch penetrations in the tube. So, there's probably more
4 residual stress and more strange metallurgy in that particular
5 area than the area where you had a very controlled process to
6 lay down -- there was, you know, automatic welding machines I
7 think that had four or five fingers on it that laid down this
8 stainless steel cloud and just went around and around the head.

9 Okay, next, roll it. I think that's it. Do you want
10 to go back and look at any particular one of those again? The
11 crack or anything?

12 MR. REMICK: Are any of the additional ones they
13 found of the same length as the first two? The four to six
14 inch links?

15 MR. MICHELSON: The first -- the sixth one, the one
16 at E-7 that's six inches or so long, that's certainly the most
17 dramatic crack. There are a couple that I've -- you know,
18 they're just, they're kind of shadowy looking because there's a
19 layer of dust on the lower head. You really can't see it very
20 well and there may be some of those other ones that were shown
21 by the arrows that are as long but they're certainly -- those
22 E-7 you can actually see separation and you saw the stinger go
23 in the hole. The other ones, you know, you could have just
24 drawn a pencil line on there. You know, it's a crack without
25 any physical -- you can't see any separation from side to side.

1 MR. CARROLL: What was the diameter of the stinger,
2 again? 3/32nds?

3 MR. MICHELSON: 3/32nds.

4 MR. CARROLL: You can't use something smaller in
5 diameter than that?

6 MR. MICHELSON: Oh, they could have, but it just
7 would have been a research process in the point where they're
8 just trying to get the fuel out of the core. They took several
9 days out of the fueling to get what information they did.

10 MR. CARROLL: The comment was these went in and cut
11 in the order of an inch or so?

12 MR. MICHELSON: No. They went in -- the person who
13 made that call -- I couldn't make that call. The guy who made
14 the call I think called them in the same thing, 3/32nds of an
15 inch.

16 MR. CARROLL: And the clouding thicknesses?

17 MR. MICHELSON: It's 3/16ths.

18 MR. CARROLL: Half-way through the clouding thickness
19 if you believe that the probe got to the bottom of the hole --

20 MR. MICHELSON: Yes, I would tend to think looking at
21 the crack, and again, there's no facts behind it, that that
22 crack is more than 3/16ths deep, if you looked at that crack.

23 MR. REMICK: Any further questions?

24 MR. CARROLL: Is there any plan to try to get a
25 better definition of --

1 MR. MICHELSON: Yes, next slide.

2 MR. CARROLL: All right. One other question. Just
3 out of curiosity, how are TV cameras holding up down there with
4 respect to lens browning or any other problems?

5 MR. MICHELSON: The colored TV cameras don't hold up
6 very well, but the black and whites seem to hold up quite well.
7 Right now the radiation feels that -- they aren't that intense
8 anymore. Most of the fuel has gone, you're out of the area
9 where there's very much neutron activation. You're down in the
10 lower head.

11 What this is a slide of is a metal disintegration
12 machine head and this is depicting the lower head of the
13 reactor vessel and how this head is going to come in from one
14 side and then the other and take out a triangular cross-section
15 chunk out of the reactor vessel head. This is Bob Van Houten's
16 program and this is what it looks like -- that's what it sort
17 of looks like when it's backwards, that's correct, after it's
18 done its job.

19 You can do two things. One is you can just take a
20 piece out of the head and you can see the triangular cross-
21 section and if we pull this down just slightly you can see the
22 dimensions of this wedge, it's about this big and triangular in
23 cross-section. You can also use the machine to take out a
24 piece that includes one of the in-core instruments
25 penetrations.

1 The first thing you have to do is cut off the in-core
2 instrument penetration two to four inches above the reactor
3 vessel wall and then there's an expanding plug that's put in
4 the lower portion because the reactor coolant pressure boundary
5 is right in here when that's in here. This, the reactor
6 coolant pressure boundaries is there.

7 [Slide.]

8 MR. MICHELSON: We have this slide. Right here is
9 the reactor coolant pressure boundary. So, when you take that
10 out they have an expanding mandrel that then expands the tube
11 against the hole in the reactor vessel head. It will hold over
12 a 1,000 PSI and there's only, you know, whatever the static
13 head of 40 feet of water and then you get this piece out that
14 looks the same as this one except it has the in-core in it
15 including what I'm sure Bob Van Houten hopes is the ones with
16 the cracks.

17 MR. WARD: What is that called? I guess I would call
18 it like an electron discharge device, very, very slow -- not
19 inexpensive. You wouldn't want to do much production work with
20 it, given the environment that they're working in. It will get
21 the job done.

22 MR. THONUS: A metal disintegration machine.

23 MR. WARD: What is that? It's not electrolytic then.
24 It's a spark discharge.

25 MR. THONUS: Yes, it's very high temperature. I

1 forget what it takes -- maybe an hour or so to cut one of the
2 suckers out. They have plans for taking 20 samples and
3 hopefully they're going to get these guys that include the
4 cracks.

5 Bob tells me it will be about two years. You know,
6 the data will flow back from the labs gradually, piecemeal.
7 Samples will be taken, in-core instrument guide tubes will be
8 sent out to the OECD countries in Japan and then as they go
9 through their program, their results will come in.

10 It will be two years before the results will come in.

11 MR. STOLZ: Is there anything further from the staff?

12 [No response.]

13 MR. STOLZ: Mr. Masnik will talk about future plans.

14 [Slide]

15 MR. MASNIK: In 1987, the licensee formally submitted
16 to the NRC, plans for long term storage of the facility after
17 defueling. The licensee felt that further decontamination of
18 the facility, once it had achieved a safe, stable, and defueled
19 condition, would incur additional man-rem exposure without a
20 significant increase in safety.

21 This first slide talks about the licensee's plans for
22 the TMI 2 facility. The licensee intends to complete defueling
23 by removing greater than 99 percent of the fuel. The fuel
24 remaining in the facility will be in a condition that precludes
25 criticality.

1 This will be assured by a variety of methods such as
2 defueling below a critical mass amount, preventing the movement
3 of fuel and removing the potential for a moderator. All
4 contamination that has been removed from the facility will be
5 packaged and shipped offsite, and all liquid rad waste will be
6 disposed of.

7 Lee mentioned that the licensee will shortly begin
8 the evaporation of the accident generator water. The next
9 slide, please?

10 [Slide.]

11 MR. MASNIK: Some additional decontamination will be
12 performed after defueling, but only that necessary to place and
13 maintain the facility in long term storage. The licensee's
14 term for this storage period is post-defueling monitored
15 storage, or PDMS and in recent correspondence, the licensee has
16 indicated that storage would likely be until Unit 1 ceases
17 operation, at which time both Unit 1 and Unit 2 would be
18 decommissioned simultaneously.

19 This would be approximately 23 years from now. There
20 would be limited access to the facility during this storage
21 period, and at first, there would be inspections to verify that
22 the internal conditions of the facility are not changing and
23 these may change or the frequency may change, if warranted.

24 The licensee is making no attempt to preserve the
25 facility. The licensee's energy plans for the future do not

1 reflect the return to service of TMI 2. The next slide,
2 please?

3 [Slide.]

4 MR. MASNIK: This next slide provides a schedule for
5 the major remaining activities associated with the current
6 defueling effort. Defueling will be done by the end of this
7 month, early next month. The lower head sampling will begin,
8 hopefully, in December and run for approximately 30 days.

9 The accident-generated water evaporation will begin
10 in January and will take approximately a year to 18 months.
11 The fuel shipping will be completed by March, 1990. The last
12 fuel will be shipped offsite to Idaho. The decon of the
13 facility necessary to place the facility in long term storage
14 will be completed in March of 1991 and the licensee hopes to
15 enter PDMS in April, 1991.

16 A license amendment is required to place the facility
17 in long term storage, and if a hearing is required, this date
18 may slip as much as a year or so. Waste shipments will be done
19 in June of '91. The last six months or so will be principally
20 evaporator bottoms associated with the evaporation of the
21 evaporation-generated water.

22 The next slide, please?

23 [Slide.]

24 MR. SHEWMON: What are the main isotopes in the
25 accident-generated water?

1 MR. MASNIK: Principally tritium which, of course,
2 will be evaporated, but there is some strontium and some
3 cesium -- less than a Curie each.

4 MR. REMICK: What is the licensee doing with the
5 turbine generator. You indicated no interest in the capital
6 preservation. Are they selling that, or is it just going to
7 sit there?

8 MR. MASNIK: There have been some parts --

9 MR. THONUS: The turbine generator, at one point, was
10 kept under nitrogen to preserve it. That's no longer being
11 done. I'm sure if anybody wanted to buy it, the guy back there
12 would take any bids, but if either Unit 1 or some other
13 facility has a use for any parts in their current condition, I
14 think GPU would be glad to sell them, and a few have been sold,
15 but there's no effort being made right now to maintain those
16 parts.

17 [Slide.]

18 MR. MASNIK: This last slide lists the principal
19 remaining NRC staff actions associated with the cleanup. But
20 first, and probably the most important is the defueling
21 completion report. This is the licensee's submittal to the
22 staff that establishes the end of the defueling.

23 It must demonstrate that the licensee has defueled
24 the facility to the extent practicable and that the probability
25 of a criticality is precluded. Next, is the staff's review of

1 the post-defueling fuel survey reports.

2 These are a series of fuel surveys of the various
3 locations throughout the facility where fuel will remain after
4 the facility is placed in storage. The purpose of these
5 surveys is to form a basis for S&M accountability.

6 The staff also plans to fund an independent fuel
7 measurements program that will hopefully verify the licensee's
8 measurements and form the basis for a Commission policy
9 statement on the completion of the cleanup, and the safe,
10 stable, condition of the facility.

11 Next is the review of the long term storage option,
12 PDMS. The staff has had the licensee's proposal under review
13 since 1987 and this past August, we published a supplement to
14 the impact statement that addressed specifically the issue of
15 long term storage of the facility.

16 This Spring, we plan to issue the SER and PDMS and
17 then the staff will likely have to go through the hearing
18 process before an amendment will be issued. Finally, oversight
19 of the evaporation of the accident-generated water, due to the
20 significant public interest in this activity, the NRC on-site
21 staff plans to closely monitor this activity, especially in the
22 early months of operation.

23 We also plan to review and approve the detailed
24 operating procedures of this activity, prior to operation.
25 That's it. Are there any questions?

1 MR. SHEWMON: On the fuel quantification, is this for
2 ALARA, or to avoid re-criticality, or what level of fuel
3 quantification?

4 MR. MASNIK: This is a study we plan to fund, just to
5 verify that the numbers that are reported to us by the licensee
6 are correct and that we can say that the facility is in a safe,
7 stable condition, principally for criticality.

8 MR. SHEWMON: Thank you.

9 MR. REMICK: Further questions?

10 [No response.]

11 MR. REMICK: Is that it for the staff?

12 MR. STOLZ: Yes.

13 MR. REMICK: Thank you very much for an interesting
14 presentation, with all the color viewgraphs and models.

15 [Whereupon, at 3:30 p.m., the hearing was adjourned.]

16

17

18

19

20

21

22

23

24

25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: ACRS 355th General Meeting

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Marilynn Nations

Marilynn Nations

Official Reporter
Ann Riley & Associates, Ltd.

T-2

NRR STAFF PRESENTATION TO THE ACRS

R. Barred

SUBJECT: Generic Letter Supplement on Accident Management Strategies

DATE: November 16, 1989

PRESENTER: Robert L. Palla, Jr.

PRESENTER'S TITLE/BRANCH/DIV: Senior Reliability and Risk Analyst
Risk Applications Branch
Division of Radiation Protection and
Emergency Preparedness
Office of Nuclear Reactor Regulation

PRESENTER'S NRC TEL. NO.: 492-1076

SUBCOMMITTEE: Severe Accidents

OUTLINE OF PRESENTATION

1. PURPOSE OF PRESENTATION
2. BACKGROUND
 - MEETING CHRONOLOGY
 - A/M PROGRAM ELEMENTS
 - A/M STRATEGY IMPLICATIONS IN RELATED DOCUMENTS
3. ACCIDENT MANAGEMENT STRATEGIES
4. GENERIC LETTER SUPPLEMENT
5. STATUS OF SUPPLEMENT AND NUREG/CR
6. SCHEDULE OF ACTIVITIES

PURPOSE OF PRESENTATION

1. TO DESCRIBE BACKGROUND AND APPROACH FOR THE PROPOSED GENERIC LETTER SUPPLEMENT
2. TO SOLICIT ACRS VIEWS/COMMENTS ON PROPOSED SUPPLEMENT

ACCIDENT MANAGEMENT MEETING CHRONOLOGY

T-2

<u>MEETING</u>	<u>TOPIC</u>
SEPT 9, 1988 - ACRS FULL COMMITTEE	PRELIMINARY CONCEPTS REGARDING A/M
JAN 13, 1989 - ACRS FULL COMMITTEE	STAFF PLANS FOR A/M REGULATORY AND RESEARCH PROGRAMS
JAN 23, 1989 - COMMISSION	STAFF PLANS FOR A/M REGULATORY AND RESEARCH PROGRAMS (SECY-89-12)
MARCH 2, 1989 - INDUSTRY (IPE WORKSHOP)	OVERVIEW OF A/M PLANS AND APPROACH
SEPT 20, 1989 - ACRS SUBCOMMITTEE	1. GENERIC LETTER SUPPLEMENT 2. A/M RESEARCH PROGRAM PLAN 3. NUMARC A/M GUIDELINES

A/M PROGRAM ELEMENTS

T-2

1. ACCIDENT MANAGEMENT FRAMEWORK
 - REVIEW NUMARC/EPRI GUIDELINES FOR A/M NOV 1989
 - DEMONSTRATE GUIDELINES (INDUSTRY) 1989 - 1990
 - PRESENT IMPLEMENTATION PLAN TO COMMISSION SUMMER 1990
 - ISSUE GENERIC LETTER ON ACCIDENT MANAGEMENT FALL 1990

2. ACCIDENT MANAGEMENT STRATEGIES
 - IDENTIFY AND EVALUATE "LESSONS-LEARNED" FALL 1989
 - ISSUE SUPPLEMENT TO IPE GL 88-20 FALL 1989
 - EVALUATE ADDITIONAL STRATEGIES (RES) ONGOING
 - ISSUE ADDITIONAL STRATEGY GUIDANCE AS NEEDED

T-6

A/M STRATEGY IMPLICATIONS IN RELATED DOCUMENTS

- IPE GENERIC LETTER 88-20
 - STATES THAT ACTIONS WHICH CAN SUBSTANTIALLY REDUCE RISK MAY BE IDENTIFIED DURING CONDUCT OF IPE
 - ENCOURAGES LICENSEES TO IMPLEMENT SUCH ACTIONS IN FORM OF EOPS OR SIMILAR GUIDANCE
 - DEFERS REQUIREMENT FOR LICENSEES TO DEVELOP A/M PLANS CITING WORK WITH NUMARC TO
 - (1) DEFINE SCOPE AND CONTENT OF A UTILITY A/M PLAN
 - (2) DEVELOP AN APPROACH FOR INCORPORATING IPE RESULTS INTO A/M PLANS

- IPE SUBMITTAL GUIDANCE DOCUMENT (NUREG-1335)
 - REQUESTS LICENSEES TO DOCUMENT STRATEGIES TO PREVENT/MITIGATE EFFECTS OF SEVERE ACCIDENTS
 - DEVELOPED AS PART OF IPE PROCESS
 - CREDITED IN THE ANALYSIS

RELATED DOCUMENTS - CONTINUED

- ° COMMISSION PAPER ON A/M (SECY-89-012)
 - DESCRIBES ACCIDENT MANAGEMENT PROCEDURES AS A MAJOR ELEMENT OF AN A/M PLAN
 - STATES THAT NRC WILL PROVIDE A/M STRATEGIES TO LICENSEES FOR THEIR EVALUATION

- ° STAFF REQUIREMENTS MEMORANDUM REGARDING SECY-89-012
 - DIRECTS STAFF TO PROVIDE LICENSEES A/M STRATEGIES WHICH MAY BE APPROPRIATE, ON SCHEDULE SO LICENSEES CAN CONSIDER THEM DURING IPE
 - ° ENSURE STRATEGIES ARE NOT LIKELY TO DETRACT FROM SAFETY
 - ° CAUTION LICENSEES ON IMPLEMENTATION OF STRATEGIES

ACCIDENT MANAGEMENT STRATEGIES

- EXAMPLE STRATEGIES FOR FURTHER ENHANCING EMERGENCY OPERATING PROCEDURES ARE IDENTIFIED IN SECY-89-012
 - STRATEGIES FALL INTO 3 GLOBAL CATEGORIES
 1. CONSERVING OR REPLENISHING LIMITED RESOURCES
 2. USING EXISTING SYSTEMS FOR INNOVATIVE APPLICATIONS
 3. DEFEATING INTERLOCKS OR OVERRIDING TRIPS IN EMERGENCY SITUATIONS (E.G., REOPENING MSIV'S IN ATWS)
- THESE STRATEGIES AND THEIR POTENTIAL DRAWBACKS HAVE BEEN FURTHER EVALUATED (RES)
- EVALUATION WILL BE PUBLISHED AS A NUREG/CR
- GENERIC LETTER SUPPLEMENT WILL PROVIDE STRATEGIES AND NUREG/CR TO UTILITIES FOR THEIR CONSIDERATION DURING THE PERIOD WHEN THE IPE IS BEING PERFORMED

GENERIC LETTER SUPPLEMENT

° THIS LETTER DOES:

- DESCRIBE ACCIDENT MANAGEMENT STRATEGIES, AND THEIR BENEFITS AND POTENTIAL ADVERSE EFFECTS (NUREG/CR)
- PROVIDE THE STRATEGIES TO LICENSEES FOR INFORMATION
- ENCOURAGE LICENSEES TO EVALUATE THESE A/M STRATEGIES IN CONJUNCTION WITH THEIR IPE

° THIS LETTER DOES NOT:

- REQUEST ANY INFORMATION ABOUT CURRENT OR PROPOSED ACCIDENT MANAGEMENT PROCEDURES (BEYOND WHAT GENERIC LETTER 88-20 REQUESTS)
- IMPLY A REQUIREMENT TO IMPLEMENT ANY OF THE STRATEGIES

STATUS OF GENERIC LETTER SUPPLEMENT AND NUREG/CR

- ° NRR/RES
 - REVIEW OF DRAFT NUREG/CR COMPLETED
 - COMMENTS INCORPORATED IN OCTOBER 1989 REDRAFT
 - ADDITIONAL COMMENTS EXPECTED TO BE MINOR

- ° OGC
 - REVIEW OF GENERIC LETTER SUPPLEMENT COMPLETED
 - MINOR CHANGES TO LANGUAGE
 - CAUTION THAT SUPPLEMENT PROVIDES NO BASIS FOR REQUIRING IMPROVEMENTS

- ° CRGR
 - APPROVAL NOT VIEWED AS REQUIREMENT FOR ISSUANCE
 - SUPPLEMENT AND NUREG/CR BEING PROVIDED TO CRGR FOR INFORMATION

- ° NUMARC/OWNERS GROUPS
 - DRAFT NUREG/CR PROVIDED FOR COMMENT ON TECHNICAL ACCURACY
 - PRELIMINARY FEEDBACK: NO MAJOR COMMENTS OR PROBLEMS
 - FORMAL RESPONSE EXPECTED BY END OF NOVEMBER


November 15, 1989

ACCIDENT MANAGEMENT GENERIC LETTER SUPPLEMENT SCHEDULE

- 4/21 - First meeting with contractors regarding A/M strategies
- 6/15 - Request to brief CRGR into concurrence
- 6/19 - Draft strategy evaluations to key reviewers
- 6/28&29 - Meeting with contractors and key reviewers
- 7/21 - Revised evaluations for initial strategies
- 8/14 - Revised evaluations for remaining strategies
- 8/28 - Draft NUREG/CR to PRA Review Committee
- 9/7 - TTC staff review meeting
- 9/11 - PRA Review Committee Meeting
- 9/20 - ACRS Subcommittee Meeting
- 10/20 - Revised NUREG/CR to ACRS
- 10/24 - CRGR Package into concurrence (for CRGR information)
- 10/27 - Request for NUMARC/Owners Groups comments
- 11/16 - ACRS meeting
- 12/1 - Camera-ready copy
- 12/15 - Publish NUREG/CR
- 12/29 - Issue Generic Letter (SUBJECT TO CRGR ACTION)

Table 2 Logic Structure of Accident Management Strategies

17/8



CHALLENGES

COOLANT INSUFFICIENT

STRATEGIES

- Conserve Coolant
 - Reduce Ctmt. Spray Flow (PWR)
 - Isolate Interfacing Systems LOCA

- Resupply Injection
 - Emergency Storage Tank Makeup
 - Refill CST (BWR)
 - Refill RWST (PWR)
 - Ensure Ctmt. Sump Recirc. Switchover (PWR)

- Use Alternate Source
 - Firewater

- Use Ultimate Source
 - Provide Emergency Connections

REDUCE CONTAINMENT SPRAY (CS) FLOW RATE TO
CONSERVE WATER FOR CORE INJECTION (PWR)

- MAY BE ACCOMPLISHED BY:
 - THROTTLING CS DISCHARGE VALVES.
 - SECURING ONE OR MORE REDUNDANT SPRAY TRAINS.
 - RECIRCULATING PORTION OF DISCHARGE FLOW BACK TO RWST VIA TEST LINE.

- MAY HELP FOR SEQUENCES WHERE RWST INVENTORY SHOULD BE CONSERVED (SUMP RECIRCULATION IS UNAVAILABLE).

- MANY EOPs CALL FOR STARTING AND STOPPING ONE OR MORE CS PUMPS USING CONTAINMENT PRESSURE AS GUIDE, AS WELL AS MAXIMUM USE OF FAN-COOLERS.

- CONCERNS: INADEQUATE SPRAY COVERAGE, LACK OF ATOMIZATION.

ENABLE EARLY DETECTION, ISOLATION, AND OTHERWISE
MITIGATION OF THE EFFECTS OF AN INTERFACING SYSTEMS
LOCA (ISL) (BWR AND PWR)

- MAY BE ACCOMPLISHED BY:
 - PRIMARY INDICATORS: ABNORMAL PRESSURE, TEMPERATURE AND RADIATION LEVELS OUTSIDE CONTAINMENT.
 - INFORMATION CORRELATION OF VALVE POSITION INDICATORS, LINE FLOW RATES, PRESSURES, TEMPERATURES, INVENTORY LEVELS.
 - ISOLATION USING EXISTING VALVES IN AFFECTED SYSTEM.
 - MITIGATION THROUGH DEPRESSURIZATION.
- ALL EOPs ADDRESS VARIOUS ISL ISSUES, SUCH AS CHECKING OF MAJOR CONTAINMENT ISOLATION VALVES AND RECOGNIZING STEAM GENERATOR TUBE RUPTURE EVENTS.
- CONCERNS: CLOSING WRONG VALVES THUS SHUTTING DOWN VITAL SYSTEMS, FLOODING SPRAYS MAY CAUSE ELECTRICAL FAILURES.

REFILL. CONDENSATE STORAGE TANK (CST) (BWR)

- MAY BE ACCOMPLISHED BY:
 - OBTAINING TREATED WATER VIA PUMPS OR GRAVITY DRAIN FROM DEMINERALIZED WATER STORAGE TANK (NORMAL SOURCE), CONDENSER HOT WELL, BWR REFUELING WATER STORAGE TANK, UNAFFECTED UNIT'S TANKS.
 - UNTREATED WATER FROM PLANT FIREWATER, COMMUNITY FIRE PUMPER TRUCK, MUNICIPAL WATER SUPPLY.
- MAY HELP TO MAINTAIN HPCI/HPCS AND/OR RCIC INJECTION LONGER IF SUPPRESSION POOL IS UNAVAILABLE.
- SOME CST MAKEUP PROCEDURES FOUND IN EOPs OF ALL PLANTS EXAMINED.
- CONCERNS: PLUGGING OF INJECTION LINES BY UNTREATED WATER.

REFILL REFUELING WATER STORAGE TANK (RWST) (PWR)

- MAY BE ACCOMPLISHED BY:
 - OBTAINING BORATED WATER FROM NORMAL RWST MAKEUP (LIMITED), BORATED WATER HOLDUP TANK, SPENT FUEL POOL, UNAFFECTED UNIT'S RWST.
 - UNBORATED SOURCES ALSO POSSIBLE.
- MAY BE HELPFUL FOR MAINTAINING ECCS INJECTION LONGER FOR INTERMEDIATE SIZE BREAKS IF CONTAINMENT SUMP RECIRC. WATER IS NOT AVAILABLE.
- SOME RWST MAKEUP PROCEDURES FOUND IN EOPs OF ALL PLANTS EXAMINED.
- CONCERNS: USE OF UNBORATED WATER COULD LEAD TO RECRITICALITY PROBLEMS, FUEL IN SPENT FUEL POOL.

T-15

STANDARDIZED PRESSURIZED WATER REACTORS

A PRESENTATION TO THE
ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS

November 16, 1989

CHARLES L. MILLER, PROJECT DIRECTOR
STANDARDIZATION AND LIFE EXTENSION
PROJECT DIRECTORATE

T-15

STANDARDIZED PWR PLANT REVIEW GOALS

WESTINGHOUSE RESAR SP/90

- o PDA ISSUANCE JUNE 1990

EPRI REQUIREMENTS DOCUMENT

- o EVOLUTIONARY DESIGN SER ISSUANCE MARCH 1991
- o PASSIVE DESIGN SER ISSUANCE FEBRUARY 1992

COMBUSTION ENGINEERING SYSTEM 80 +

- o LRB APRIL 1990
- o FDA ISSUANCE APRIL 1992

WESTINGHOUSE AP - 600

- o LRB SUBMITTAL JUNE 1990
- o DESIGN SUBMITTAL JULY 1992
- o FDA ISSUANCE DECEMBER 1993

T-15

CE SYSTEM 80 + DESIGN CERTIFICATION MILESTONES

FIRST CESSAR-DC SUBMITTAL NOVEMBER 1987

FORMAL APPLICATION FOR CERTIFICATION MARCH 1989

LICENSING REVIEW BASIS (LRB) DOCUMENT

o STAFF REVIEW IN PROGRESS

o ACRS REVIEW FEBRUARY 1990

o COMMISSION REVIEW MARCH 1990

o ISSUE APRIL 1990

FDA (TWO YEARS AFTER LRB) APRIL 1992

INITIAL CESSAR-DC SUBMITTALS RECEIVED

NOVEMBER 1987

- o GENERAL DESCRIPTION
- o POWER CONVERSION SYSTEM

APRIL 1988

- o REACTOR CORE & COOLANT SYSTEM
- o CHEMICAL & VOLUME CONTROL SYSTEM
- o PROCESS SAMPLING SYSTEM

JUNE 1988

- o SHUTDOWN COOLING SYSTEM
- o SAFETY INJECTION SYSTEM
- o EMERGENCY FEEDWATER

SEPTEMBER 1988

- o SITE ENVELOPE
- o SAFETY DEPRESSURIZATION SYSTEM
- o I&C SYSTEMS
- o HUMAN FACTORS ENGINEERING

MARCH 1989

- o LEAK-BEFORE-BREAK ANALYSIS
- o BALANCE-OF-PLANT DESCRIPTIONS
- o ELECTRICAL POWER DISTRIBUTION
- o REACTOR PROTECTION SYSTEM
- o FUEL HANDLING SYSTEM
- o RADWASTE SYSTEM
- o BUILDING AND SITE ARRANGEMENTS
- o CONTAINMENT SYSTEMS
- o SABOTAGE PROTECTION

INITIAL CESSAR-DC SUBMITTALS EXPECTED

DECEMBER 1989

- o RESOLUTIONS TO USIs/GSIs
- o PRA METHODOLOGY

MARCH 1990

- o REMAINING USI/GSI RESOLUTIONS
- o EQUIPMENT QUALIFICATION ENVELOPES
- o ADDITIONAL SYSTEM INFORMATION

JUNE 1990

- o SAFETY ANALYSIS
- o PRA & SEVERE ACCIDENT RESULTS
- o SEISMIC METHODS
- o BUILDING LAYOUTS

SEPTEMBER 1990

- o SEISMIC RESULTS
- o TECHNICAL SPECIFICATIONS
- o INSPECTIONS, TESTS, MAINTENANCE & RELIABILITY GUIDELINES

T-15

CESSAR-DC REVIEW STATUS

- o STAFF ISSUED 277 QUESTIONS
- o CE RESPONDED TO 186 QUESTIONS
- o CE WORKING ON 91 QUESTIONS

CURRENT RESAR SP/90 REVIEW STATUS

Accomplishments to November 1989

DSER PRA "FRONTEND"	MARCH 1988
ACRS SUBCOMMITTEE	APRIL 1988
DSER - SRP	JUNE 1988
DSER - SRP	MARCH 1989
WESTINGHOUSE RESPONDED TO OPEN ITEMS	JUNE-SEPTEMBER 1989
ACRS SUBCOMMITTEE	SEPTEMBER 1989
WESTINGHOUSE SUBMITTED AMENDED USIs/GSIs	OCTOBER 1989
ACRS SUBCOMMITTEE	NOVEMBER 1989

SCHEDULE TO COMPLETE RESAR SP/90 PDA REVIEW

Items to be Accomplished

STAFF COMPLETES DSER PRA "BACKEND"	NOVEMBER 1989
NRC REVIEWS USIs/GSIs AND PROVIDES INPUT TO WESTINGHOUSE	NOVEMBER - DECEMBER 1989
ACRS SUBCOMMITTEE Re: DSER CHAPTERS	JANUARY 1990
WESTINGHOUSE RESPONDS TO USI/GSI INPUT	JANUARY 1990
ACRS SUBCOMMITTEE Re: USIs/GSIs	FEBRUARY 1990
NRC ISSUES DSER ON USIs/GSIs AND SEVERE ACCIDENTS	FEBRUARY 1990
ACRS SUBCOMMITTEE Re: DRAFT FINAL SER	MARCH 1990
ACRS FULL COMMITTEE Re: DRAFT FINAL SER AND REQUEST LETTER	APRIL 1990
NRC ISSUES FINAL SER	MAY 1990
PDA DECISION AND SSER	JUNE 1990

T-16

RESAR SP/90 SUMMARY

- o ESTABLISH COMMISSION - APPROVED PRIORITY FOR SP/90 PDA

- o 3 DSERS ISSUED

- o OPEN ITEMS
 - o 107 BEFORE PDA IS ISSUED
 - o 53 BEFORE FDA IS ISSUED
 - o 99 BEFORE FDA IS ISSUED AND/OR PLANT SPECIFIC APPLICATION

- o RESOLVE USI/GSI AND SEVERE ACCIDENT ISSUES

- o 2 ADDITIONAL DSERS NEEDED BEFORE PDA DECISION

- o ROUND OF ACRS MEETINGS

- o ISSUE FINAL SER

- o ISSUE PDA AND SSER

EARLY REVIEW OF ALWRs WITH PASSIVE SAFETY SYSTEMS

o STAFF TO CONSIDER POTENTIAL SAFETY ISSUES ASSOCIATED WITH
CONCEPTUAL DESIGNS OF ALWRs WITH PASSIVE SAFETY SYSTEMS

o PURPOSE:

1. TO PROVIDE EARLY GUIDANCE TO THE DESIGNERS TO ENSURE THAT
DESIGNS ARE COMPATIBLE WITH NRC SAFETY PHILOSOPHY.
2. TO DETERMINE WHETHER OR NOT EPRI AND THE VENDORS ARE
TAKING ACCEPTABLE APPROACHES TO IDENTIFYING AND RESOLVING
MAJOR DESIGN BASES AND SEVERE ACCIDENT APPROACHES.
3. TO IDENTIFY ANY "SHOW STOPPERS" REGARDING PASSIVE DESIGN APPROACHES.

71
ENSURE APPROPRIATE RECIRCULATION SWITCHOVER (PWR)

- ACCOMPLISHED BY ASSURING AUTOMATIC OR MANUAL SWITCHOVER AND USING MANUAL INTERVENTION IF AN AUTOMATIC SWITCHOVER RECIRCULATION FAILS TO OCCUR.
- EOPs OF THOSE PLANTS EXAMINED INCLUDE STEPS DIRECTING OPERATOR TO ASSURE SWITCHOVER INCLUDING MANUAL BACKUP TO AUTOMATIC FAILURE.
- CONCERNS: FOR MANUAL SWITCHOVER MAY NEED TO ACCESS POSSIBLE HIGH RADIATION AREAS.

T-9

ADEQUATE PLANT HEAT REMOVAL CAPABILITY BY
EMERGENCY CONNECTION(S) OF EXISTING OR
ALTERNATE WATER SOURCES (BWR AND PWR)

- MAY BE ACCOMPLISHED BY:
 - WATER SUPPLY TO SW FROM SOURCES SUCH AS RIVERS, RESERVIORS, MUNICIPAL WATER SYSTEMS, OCEAN, ETC.
 - SW SUPPLY DIRECTLY TO FW OR CONDENSATE SYSTEM
- SEVERAL PLANTS REVIEWED HAVE HARDWARE AND/OR PROCEDURES IN PLACE TO ACCOMPLISH THIS ULTIMATE CORE COOLING
- CONCERN:
 - WATER NOT ADEQUATELY FILTERED FOR BWR CORE OR PWR STEAM GENERATOR INJECTION
 - WATER SOURCE USED MAY BE OPENED TO RADIONUCLIDE CONTAMINATION

9

CHALLENGES

**INJECTION SYSTEM
UNAVAILABLE**

STRATEGIES

- **Improve System Availability**
 - **Extend ECCS Avail. by Pump Suction Switch (BWR)**
 - **Protective Trips Bypassed**
 - **Bypass or Change Pump Trips**
 - **Bypass or Change RCIC Pump Trips (BWR)**

- **Use Alternate Injection**
 - **Core Injection Non-Safety Pump**
 - **Provide CRD Pump (BWR)**
 - **Provide Charging Pump (PWR)**
 - **Provide RCP Seal Cooling (PWR)**
 - **Provide Condensate or Startup FW Pump to SG (PWR)**
 - **Firewater**

**EXTEND ECCS AVAILABILITY BY SWITCHING
PUMP SUCTION (BWR)**

- **MAY BE ACCOMPLISHED BY SWITCHING TO THESE OTHER POSSIBLE SOURCES:**
 - **CONDENSATE STORAGE TANK.**
 - **MAIN CONDENSER HOTWELL.**
 - **OTHER LARGE QUANTITY OF CONDENSATE VIA TEMPORARY HOOK-UPS.**
- **MAY HELP IN SEQUENCES WHERE LOCA BLOWDOWN ALONG WITH HPCI AND RCIC TURBINE EXHAUST RAISE SUPPRESSION POOL (SP) TEMPERATURE ENOUGH TO CAUSE ECCS PUMP FAILURE DUE TO CAVITATION (NPSH LOSS) OR EXCESSIVE WEAR.**
- **NO STEPS FOUND IN EOPs EXAMINED RELATED TO SWITCHING ECCS SUCTION SYSTEMS BACK TO CONDENSATE FROM SP.**
- **CONCERNS: RISING SP WATER LEVEL AFFECTING CONTAINMENT PERFORMANCE; POSSIBLE BACKFLOW CONTAMINATION.**

7.9

PROVIDE EMERGENCY BYPASS OR CHANGE OF PROTECTIVE TRIPS FOR INJECTION PUMPS (BWR AND PWR)

- MAY BE ACCOMPLISHED BY CAREFUL CONSIDERATION OF WHAT TRIPS CAN BE BYPASSED OR CHANGED IN AN EMERGENCY TO KEEP EQUIPMENT FUNCTIONING LONGER WITHOUT CAUSING FAILURE.
- MAY BE HELPFUL FOR SPECIFIC ACCIDENT SCENARIOS WHERE CONTINUED OPERATION OF EMERGENCY EQUIPMENT, EVEN IF ONLY FOR MINUTES, CAN PREVENT OR MITIGATE CORE DAMAGE.
- AT SOME PLANTS BYPASSES WERE NOTED ON CERTAIN INTERLOCKS AND TRIPS OF THE INJECTION PUMPS.
- CONCERN: INCREASED RISK OF DAMAGE TO VITAL EQUIPMENT.

**EXTEND RCIC AVAILABILITY BY PUMP TRIP BYPASS
OR CHANGE (BWR)**

- MAY BE ACCOMPLISHED BY BYPASSING OR CHANGING ONE OR MORE TRIP SETPOINT(S).
- MAY BE HELPFUL FOR SITUATIONS WHERE NO OTHER SOURCE OF CORE INJECTION IS IMMEDIATELY AVAILABLE AND CORE DAMAGE CANNOT BE PRECLUDED, i.e., WHERE RISK OF DAMAGING RCIC PUMP IS PREFERABLE TO STOPPING ALL INJECTION.
- NO STEPS FOUND IN EOPs EXAMINED.
- CONCERN: FAILURE OF RCIC SYSTEM.

USE CONTROL ROD DRIVE (CRD) PUMPS FOR CORE
INJECTION (BWR)

- MAY BE CONSIDERED:
 - BACKUP TO OTHER EMERGENCY INJECTION.
 - REACTOR LIQUID LEVEL/POWER CONTROL DURING ATWS.
 - LIMITING REACTOR POWER AFTER CORE UNCOVERY WHILE BORON IS BEING INJECTED.
- SOME PLANT EOPs CONTAIN STEPS FOR USING CRD PUMPS.
- CONCERNS: EXACERBATE CORE DAMAGE BY INJECTING TOO MUCH OR TOO LITTLE.

USE OF NON-SAFETY RELATED CHARGING PUMPS FOR
CORE INJECTION (PWR)

FOR THOSE FEW PLANTS WHICH HAVE AT LEAST ONE NON-SAFETY CHARGING PUMP:

- MAY BE ACCOMPLISHED BY:
ASSURING THE PUMP(S) HAVE A RELIABLE SOURCE OF POWER FROM ITS NORMAL BUS OR A MORE RELIABLE ALTERNATE.
- MAY BE USED FOR CORE INJECTION IN SEQUENCES WHERE RCS PRESSURE REMAINS HIGH, e.g., LOSS OF FEEDWATER TO SG, ATWS, OR SMALL BREAK LOCA.
- CONCERN: RELIABILITY OF NON-SAFETY RELATED BACKUP.

**ALTERNATE SEAL INJECTION WHEN RCP SEAL COOLING
IS LOST (PWR)**

- **MAY BE ACCOMPLISHED BY:**
 - **USING AN INSTALLED HYDROTEST PUMP.**
 - **USING A NON-SAFETY RELATED CHARGING PUMP.**

- **MAY BE USEFUL FOR SITUATIONS WHERE THE SAFETY RELATED CHARGING PUMPS AND THE CCW FLOW TO THE RCP THERMAL BARRIER HEAT EXCHANGERS ARE NOT ADEQUATELY COOLING THE RCP SEALS.**

- **AT LEAST TWO NON-U.S. PLANTS HAVE PROCEDURES IN PLACE TO USE HYDROTEST PUMP FOR ALTERNATE SEAL INJECTION.**

- **CONCERN: RELIABILITY OF NON-SAFETY RELATED BACKUP.**

**USE OF CONDENSATE OR STARTUP FEEDWATER PUMPS FOR
STEAM GENERATOR INJECTION (PWR)**

- **MAY BE ACCOMPLISHED BY REDUCING STEAM GENERATOR (SG) PRESSURE, OPENING ISOLATION VALVES, AND STARTING THE PUMP(S).**
- **MAY HELP IN SITUATIONS WHERE MAIN AND AUXILIARY FEEDWATER PUMPS ARE UNAVAILABLE, BUT NORMAL AC POWER IS STILL AVAILABLE.**
- **THESE MAY BE LOW HEAD OR LOW VOLUME PUMPS.**
- **SEVERAL OF THE PLANT PROCEDURES EXAMINED CONTAINED STEPS FOR SG INJECTION VIA CONDENSATE PUMPS.**
- **CONCERNS: REESTABLISHING FEEDWATER TO A HOT, DRY SG MAY RESULT IN EXCESSIVE THERMAL STRESSES AND REPRESSURIZE THE SG ABOVE THE SHUTOFF HEAD OF THE PUMP.**

CHALLENGES

POWER LOST

STRATEGIES

- **Conserve Power**
 - Shed Non-Essential DC Loads

- **Resupply Source**
 - Recharge DC With Portable Battery Charger
 - Replenish Pneumatic Supply

- **Improve Power Availability**
 - Bypass or Change Diesel Gen. (DG) Protective Trips

- **Use Alternate Source**
 - Provide Emergency Crosstie of AC Power
 - Provide DG or Gas Turbine Gen. for AC Loads (BWR)
 - Provide Diesel-Driven Firewater Pump for Feedwater Injection or Ctmt. Spray

CONSERVE BATTERY CAPACITY BY SHEDDING NON-
ESSENTIAL LOADS (BWR AND PWR)

- MAY BE ACCOMPLISHED BY SHEDDING LOADS NOT NEEDED TO ACHIEVE AND MAINTAIN THE PLANT IN A SAFE SHUTDOWN STATE.
- HELPFUL DURING AN SBO WHEN NORMAL STATION BATTERY CHARGERS ARE UNAVAILABLE.
- ALL PLANTS EXAMINED HAD SOME PROVISIONS FOR LOAD SHEDDING.
- CONCERN: POSSIBILITY OF SHEDDING WRONG LOADS.

**USE OF PORTABLE BATTERY CHARGERS TO RECHARGE
STATION BATTERIES (BWR AND PWR)**

- MAY BE ACCOMPLISHED BY USING A RELIABLE POWER SOURCE SUCH AS A SUITABLY SIZED PORTABLE GASOLINE DRIVEN BATTERY CHARGER.
- HELPFUL FOR PROLONGED SBO.
- NOT FOUND IN PLANT EOPs REVIEWED.
- CONCERN: USE OF NON-SAFETY RELATED EQUIPMENT ON A SAFETY RELATED SYSTEM.

**ENABLE EMERGENCY REPLENISHMENT OF PNEUMATIC SUPPLY
FOR SAFETY RELATED AIR OPERATED COMPONENTS (BWR AND
PWR)**

- **MAY BE ACCOMPLISHED BY CROSS CONNECTION OPTIONS SUCH AS INSTRUMENT AND SERVICE AIR SUPPLY SYSTEMS, USE OF DIESEL AIR COMPRESSORS AND BOTTLED AIR.**
- **HELPFUL FOR SITUATIONS WHERE A PROLONGED SBO OR OTHER CONDITIONS MAKE ADDITIONAL AIR SUPPLY NECESSARY.**
- **MOST PLANTS EXAMINED HAD MADE MODIFICATIONS TO PROVIDE BACKUP AIR SYSTEMS.**

PROVIDE EMERGENCY BYPASS OR CHANGE OF PROTECTIVE TRIPS FOR DIESEL GENERATORS (BWR AND PWR)

- **MAY BE ACCOMPLISHED BY CAREFUL CONSIDERATION OF WHAT TRIPS CAN BE BYPASSED OR CHANGED IN AN EMERGENCY TO KEEP EQUIPMENT FUNCTIONING LONGER WITHOUT CAUSING FAILURE.**
- **MAY BE HELPFUL FOR SPECIFIC ACCIDENT SCENARIOS WHERE CONTINUED OPERATION OF EMERGENCY EQUIPMENT, EVEN IF ONLY FOR MINUTES, CAN PREVENT OR MITIGATE CORE DAMAGE.**
- **ALL PLANTS REVIEWED BYPASS SOME TRIPS ON THE DIESEL GENERATORS DURING EMERGENCY STARTUP AND OPERATION.**
- **CONCERN: INCREASED RISK OF DAMAGE TO VITAL EQUIPMENT.**

ENABLE EMERGENCY CROSSTIE OF AC POWER BETWEEN TWO UNITS OR TO ONSITE GAS TURBINE GENERATOR (BWR AND PWR)

- **MAY BE ACCOMPLISHED BY ESTABLISHING EMERGENCY CROSSTIE WITH AN EQUIVALENT AC POWER SYSTEM BETWEEN TWO UNITS AT A MULTI-UNIT SITE, OR CONNECTING AN AVAILABLE ONSITE GAS TURBINE GENERATOR TO THE AC SYSTEM.**
- **HELPFUL WHEN BOTH NORMAL AND EMERGENCY AC POWER SOURCES FAIL.**
- **MOST MULTIPLE UNIT SITES HAVE CROSSTIE EQUIPMENT.**
- **CONCERN: POSSIBLE COMPROMISE OF AC POWER RELIABILITY.**

**USE OF DIESEL GENERATOR OR GAS TURBINE GENERATOR
TO DRIVE APPROPRIATE PUMPS (BWR)**

- **MAY BE ACCOMPLISHED BY MAINTAINING A MOBILE DIESEL GENERATOR OR ONSITE GAS TURBINE GENERATOR TO PROVIDE AC POWER TO THE CRD OR OTHER APPROPRIATE PUMPS (e.g., RHR, CONDENSATE/FEEDWATER).**
- **MAY BE HELPFUL IN SBO SITUATIONS.**
- **PROCEDURAL STEPS HAVE NOT BEEN FOUND FOR THE PLANTS EXAMINED.**

USE OF DIESEL-DRIVEN FIREWATER PUMP FOR BWR CORE INJECTION, PWR STEAM GENERATOR INJECTION OR CONTAINMENT SPRAYS

- MAY BE ACCOMPLISHED BY USING AN APPROPRIATE SPOOL-PIECE OR TEMPORARY HOSE CONNECTION ARRANGEMENT TO LINK THE PLANT FIRE MAIN, SUPPLIED BY A DIESEL-DRIVEN PUMP, WITH THE INDICATED PLANT SYSTEMS.
- MAY HELP IN SEQUENCES INVOLVING A LOSS OF ALL FEED-WATER OR A LOSS OF CONTAINMENT SPRAY. COULD BE USED DURING STATION BLACKOUT.
- SOME EOPs EXAMINED CALL FOR USE OF DIESEL-DRIVEN FIRE PUMPS AS SOURCE OF BWR CORE INJECTION OR PWR SG INJECTION; NO USE FOR CONTAINMENT SPRAY FOUND
- CONCERNS:
 - REDUCTION IN FLOW AVAILABLE FOR FIRE SUPPRESSION.
 - CLOGGING OF SPRAY NOZZLES.
 - UNBORATED WATER TO CONTAINMENT SUMP IN PWRs.

T-9

CHALLENGES

HEAT SINK LOST

STRATEGIES

- Reestablish Main Condenser
 - Reopen MSIVs and TBVs

- Use Alternate Sink
 - Open Atmospheric Steam Dumps (PWR)
 - Blowdown to Suppression Pool (BWR)

9

REOPEN MSIVs AND TURBINE BYPASS VALVES TO RE-GAIN MAIN CONDENSER AS HEAT SINK (BWR AND PWR)

- MAY BE ACCOMPLISHED BY MAINTAINING CONDENSER VACUUM, AND EQUALIZING PRESSURE ON BOTH SIDES OF MSIVs, WHILE DRAINING AND WARMING MSLs AND CLEARING AND RESETTING ISOLATION SIGNAL. AN ALTERNATE MIGHT BE TO JUST OPEN THE MSIV BYPASS (DRAIN HEADER).
- MAY BE HELPFUL FOR THOSE SITUATIONS WHERE THE MAIN CONDENSER IS AVAILABLE (i.e., CIRCULATING WATER AND VACUUM PUMPS ARE AVAILABLE), AND THE CIRCUMSTANCES WHICH CAUSED ISOLATION ARE CORRECTED OR CAN BE TOLERATED
- SEVERAL OF THE BWR AND PWR EOPs EXAMINED CONTAINED PROCEDURAL STEPS FOR REOPENING MSIVs and TBVs
- CONCERNS:
 - AUTOMATIC ISOLATION CAPABILITY LOST.
 - POSSIBLE CONDENSER FAILURE.

CHALLENGES

REACTOR FAILS TO SHUTDOWN

STRATEGIES

- Manual Rod Insertion

- Emergency Boration
 - Ensure Long-Term Supply of Borated Water

 - Inject Borated Water if Potential Core Damage

**ENSURE ABUNDANT SUPPLY OF BORATED MAKEUP FOR
LONG-TERM ACCIDENT CONTROL (BWR AND PWR)**

- **MAY BE ACCOMPLISHED BY CONSIDERING THE RANGE OF WORST CASE ACCIDENT SCENARIOS AND ENSURING THAT AN ADEQUATE SUPPLY OF BORON IS AVAILABLE FOR ALL CONTINGENCIES.**
- **MAY BE HELPFUL FOR SEQUENCES WHERE NORMAL SOURCES OF BORATED WATER WOULD BE INADEQUATE.**
- **CURRENT METHODS AND PRACTICES AT PWRs PROVIDE BORATED WATER TO THE RWST AT A VERY LIMITED RATE. AC POWER IS NEEDED FOR INJECTION. IN BWRs BORON SUPPLIES AND INJECTION ARE IN CONFORMANCE WITH THE ATWS RULE. MAY BE INSUFFICIENT FOR SOME SEVERE ACCIDENT SCENARIOS.**

INJECT BORATED WATER IN CASE OF POTENTIAL CORE DAMAGE AND GUARD AGAINST BORON DILUTION (BWR)

- **MAY BE ACCOMPLISHED BY:**
 - **APPROPRIATE USE OF SLCS, OR**
 - **ALTERNATE INJECTION METHOD (e.g., CONTROL ROD DRIVE OR REACTOR WATER CLEANUP).**


- **NEED TO GUARD AGAINST BORON DILUTION TO PREVENT POSSIBLE RECRITICALITY WHEN RECOVERING FROM ATWS OR A CORE DAMAGE EVENT WHERE CONTROL RODS WERE LOST.**

- **THE EOPs EXAMINED GIVE SEVERAL METHODS OF INJECTING BORATED WATER.**

t-19

**STATUS OF THE CLEANUP AT
THREE MILE ISLAND UNIT 2**

TMI-2 Core End-State Configuration



CHRONOLOGY OF THE CLEANUP

1979 ACCIDENT

PLANT STABILIZATION

WATER PROCESSING — EPICOR II

1980 KRYPTON VENTED

FIRST ENTRIES

DATA GATHERING

1981 DOSE REDUCTION/DECONTAMINATION

RADWASTE ACTIVITIES

SDS OPERATIONAL

1982 QUICK LOOK TV PICTURES

DECONTAMINATION

DATA GATHERING

1983 POLAR CRANE REFURBISHMENT

POLAR CRANE ALLEGATIONS

BASEMENT WATER FINISHED

1984 HEAD REMOVAL

IIF INSTALLED

IIF/CANAL FLOODED

**1985 VIDEO OF LOWER HEAD
PLENUM REMOVAL
BEGIN DEFUELING**

**1986 DEFUELING RUBBLE BED
CORE BORE SAMPLES
VISIBILITY PROBLEMS
FIRST FUEL SHIPMENT**

**1987 DEFUELING ASSEMBLIES
SEDIMENT REMOVAL IN RB
DECON RB WALLS**

1988 DEFUELING LCSA

DECON RB WALLS

BLOCK WALL FLUSH

EVAPORATOR HEARINGS

1989 DEFUEL LCSA/LOWER HEAD/BAFFLE

EVAPORATOR APPEALS/TESTING


RV METALLURGICAL SAMPLES


P05

NRC TLR TMI UNIT 1

NOV 09 '89 13:47

TMI-2 DEFUELING PLAN






JL Fricke
8/16/92

TMI-2 MATERIAL REMAINING IN THE REACTOR VESSEL


TMI-2 DEFUELING PROGRESS




T

MAJOR CORE MATERIAL PARAMETERS

MATERIAL	WEIGHT	MELTING POINT
Fuel	104 Tons	5080F
Cladding(Zr)	23 Tons	3362F
Control Rods(Ag,In,Cd)	3 Tons	1472F
Spacer Grids(Inconel)	1.5 Tons	2300F
Burnable Poisons	0.5 Tons	2300F
Eutectic(Zr,UO ₂)	-	4700F
Lower Core Internals(Stainless Steel)	8 Tons	2550F




INCORE INSTRUMENT GUIDE TUBE / NOZZLE INTERFACE




Approximately 11"

T-21


Approximately 13"




MDM HEAD
GENERAL ARRANGEMENT



TYPICAL SAMPLE REMOVED AT INCORE NOZZLE LOCATION



TYPICAL SAMPLE REMOVED AT OPEN AREA AWAY FROM INCORE LOCATIONS



SAMPLES BEING REMOVED FROM BOTTOM OF REACTOR VESSEL

T-10

LICENSEE'S PLANS FOR THE TMI-2 FACILITY

- Remove greater than 99% of the fuel.
- Maintain the facility in a configuration that precludes a criticality.
- Remove all radwaste from the facility.
- Dispose of all liquid radwaste.

LICENSEE'S PLANS FOR THE TMI-2 FACILITY

- Place the facility in long term monitored storage, called Post Defueling Monitored Storage(PDMS), until TMI-1 is ready for decommissioning(about 23 years) and decommission both units simultaneously.**
- Limited access to facility during storage for monitoring.**
- No attempt to preserve capital investment.**

REMAINING LICENSEE ACTIVITIES

ACTIVITY	SCHEDULED COMPLETION
Complete Defueling	Nov 88
Lower Head Sampling	Dec 88
Begin AGW Evaporation	Jan 90
Complete Fuel Shipping	Mar 90
Complete Decon of Facility	Mar 91
Enter Long Term Storage(PDMS)	Apr 91
Complete Waste Shipments	Jun 91

REMAINING NRC STAFF ACTIONS

Review of the Defueling Completion Report


Review of Post Defueling Fuel Survey Reports

Independent Fuel Quantification Program

Review of Long Term Storage(PDMS)

Oversight of AGW Evaporation

TMI-2 Core End-State Configuration



LOWER CORE SUPPORT ASSEMBLY

FLOW DISTRIBUTOR PLATE


LOWER GRID FORGING

SPIDER CASTING

LOWER GRID SUPPORT POST

LOWER GRID RIB SECTION

LOWER CORNER BATTLE PLATE



REFLECTIVE INSULATION

IN-CORE INSTRUMENT NOZZLE

IN-CORE INSTRUMENT GUIDE TUBE

FLOW DISTRIBUTOR HEAD

IN-CORE GUIDE SUPPORT PLATE