

NOV 15 1989

Docket/License: 50-334/DPR-66  
50-412/NPF-73

Duquesne Light Company  
ATTN: Mr. J. D. Sieber  
Vice President, Nuclear Group  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Gentlemen:

SUBJECT: Combined Inspection Report Nos. 50-334/89-18 and 50-412/89-18

This refers to the routine resident safety inspection by Messrs. J. Beall and P. Wilson at the Beaver Valley Power Station in Shippingport, Pennsylvania. The reporting period covers the time from September 1 - October 13, 1989. The inspection consisted of document reviews, interviews and observation of activities. The findings were summarized and discussed with you and members of your staff at the conclusion of the inspection.

Based on the results of this inspection, it appears that in two instances, activities were not conducted in compliance with NRC requirements with respect to overtime and communications. In addition, a weakness was identified in oversight by senior management in the control of overtime during the Unit 2 first refueling outage. In responding to violation A, please include your plans for correcting this weakness.

The response directed by this letter and the accompanying Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1989, PL 96-511.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By: *Curtis J. Cougill*

*for* Edward C. Wenzinger, Chief  
Projects Branch No. 4  
Division of Reactor Projects

Enclosures:

1. Appendix A, Notice of Violation
2. NRC Region I Combined Inspection Report Nos.  
50-334/89-18 and 50-412/89-18

OFFICIAL RECORD COPY

IN89-18 - 0001.0.0  
10/27/89

8911280492 891115  
PDR ADOCK 05000334  
Q FDC

1401  
11

NOV 15 1989

cc w/encls:

J. J. Carey, Executive Vice President, Operations  
J. D. Crockett, General Manager, Corporate Nuclear Services  
W. S. Lacey, General Manager, Nuclear Operations  
N. R. Tonet, Manager, Nuclear Engineering  
T. P. Noonan, Plant Manager  
S. C. Fenner, Manager, Quality Assurance  
K. D. Grada, Manager, Nuclear Safety  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
Commonwealth of Pennsylvania

bcc:

Region I Docket Room (with concurrences)  
Management Assistant, DRMA (w/o enclosures)  
C.J. Cowgill, DRP  
N.F. Dudley, DRP  
P. S. Tam, LPM, NRR  
R. J. Bores, DRSS

DRP:RI *ck*  
CCowgill/pj  
11/14/89

DRP:RI *Wenzinger*  
EWenzinger  
11/16/89

OFFICIAL RECORD COPY

IN89-18 - 0002.0.0  
11/09/89