



Westinghouse Energy Systems



8911300295 891122
PJR ADOCK 03000304
P PDC

WCAP-12396

ANALYSIS OF CAPSULE Y FROM THE
COMMONWEALTH EDISON COMPANY
ZION UNIT 2 REACTOR VESSEL
RADIATION SURVEILLANCE PROGRAM

E. Terek
S. L. Anderson
L. Albertin

September 1989

Work performed under Shop Order No. CUAP-106

APPROVED:

T. A. Meyer

T. A. Meyer, Manager

Structural Materials and Reliability Technology

Prepared by Westinghouse for the Commonwealth Edison Company

WESTINGHOUSE ELECTRIC CORPORATION
Nuclear and Advanced Technology Division
P.O. Box 2728
Pittsburgh, Pennsylvania 14230-2728

PREFACE

This report has been technically reviewed and verified.

Reviewer

Sections 1 through 5 and 7, 8

S. E. Yanichko

S. E. Yanichko

Section 6

E. P. Lippincott

E. P. Lippincott

TABLE OF CONTENTS

| Section | Title | Page |
|---------|--|------|
| 1 | SUMMARY OF RESULTS | 1-1 |
| 2 | INTRODUCTION | 2-1 |
| 3 | BACKGROUND | 3-1 |
| 4 | DESCRIPTION OF PROGRAM | 4-1 |
| 5 | TESTING OF SPECIMENS FROM CAPSULE Y | 5-1 |
| | 5-1. Overview | 5-1 |
| | 5-2. Charpy V-Notch Impact Test Results | 5-3 |
| | 5-3. Tension Test Results | 5-5 |
| | 5-4. Wedge Opening Loading Tests | 5-5 |
| 6 | RADIATION ANALYSIS AND NEUTRON DOSIMETRY | 6-1 |
| | 6-1. Introduction | 6-1 |
| | 6-2. Discrete Ordinates Analysis | 6-2 |
| | 6-3. Neutron Dosimetry | 6-7 |
| 7 | SURVEILLANCE CAPSULE REMOVAL SCHEDULE | 7-1 |
| 8 | REFERENCES | 8-1 |

LIST OF ILLUSTRATIONS

| Figure | Title | Page |
|--------|--|------|
| 4-1 | Arrangement of Surveillance Capsules in the Zion Unit 2 Reactor Vessel | 4-8 |
| 4-2 | Capsule Y Diagram Showing Location of Specimens, Thermal Monitors, and Dosimeters | 4-9 |
| 5-1 | Charpy V-Notch Impact Data for Zion Unit 2 Reactor Vessel Shell Plate C4007-1 (Transverse Orientation) | 5-15 |
| 5-2 | Charpy V-Notch Impact Data for Zion Unit 2 Reactor Vessel Shell Plate C4007-1 (Longitudinal Orientation) | 5-16 |
| 5-3 | Charpy V-Notch Impact Data for Zion Unit 2 Reactor Vessel Weld Metal | 5-17 |
| 5-4 | Charpy V-Notch Impact Data for Zion Unit 2 Reactor Vessel Weld Heat Affected Zone Metal | 5-18 |
| 5-5 | Charpy V-Notch Impact Data for Zion Unit 2 A533 Grade B Class 1 Correlation Monitor Material (HSST Plate 02) | 5-19 |
| 5-6 | Charpy Impact Specimen Fracture Surfaces for Zion Unit 2 Reactor Vessel Shell Plate C4007-1 (Longitudinal Orientation) | 5-20 |
| 5-7 | Charpy Impact Specimen Fracture Surfaces for Zion Unit 2 Reactor Vessel Shell Plate C4007-1 (Transverse Orientation) | 5-21 |
| 5-8 | Charpy Impact Specimen Fracture Surfaces for Zion Unit 2 Reactor Vessel Weld Metal | 5-22 |

LIST OF ILLUSTRATIONS (Cont)

| Figure | Title | Page |
|--------|---|------|
| 5-9 | Charpy Impact Specimen Fracture Surfaces for Zion Unit 2 Reactor Vessel HAZ Metal | 5-23 |
| 5-10 | Charpy Impact Specimen Fracture Surfaces for Zion Unit 2 ASTM Correlation Monitor Material | 5-24 |
| 5-11 | Tensile Properties for Zion Unit 2 Reactor Vessel Shell Plate C4007-1 (Longitudinal Orientation) | 5-25 |
| 5-12 | Tensile Properties for Zion Unit 2 Reactor Vessel Weld Metal | 5-26 |
| 5-13 | Fractured Tensile Specimens for Zion Unit 2 Reactor Vessel Shell Plate C4007-1 (Longitudinal Orientation) | 5-27 |
| 5-14 | Fractured Tensile Specimens for Zion Unit 2 Reactor Vessel Weld Metal | 5-28 |
| 5-15 | Typical Stress-Strain Curve for Tension Specimens | 5-29 |
| 6-1 | Plan View of a Reactor Vessel Surveillance Capsule | 6-12 |
| 6-2 | Fast Neutron ($E > 1.0$ MeV) Fluence at the 40 Degree Surveillance Capsule Location as a Function of Full Power Operating Time | 6-13 |

LIST OF TABLES

| Table | Title | Page |
|-------|---|------|
| 4-1 | Chemical Composition of the Zion Unit 2 Reactor Vessel Surveillance Materials | 4-3 |
| 4-2 | Chemical Composition for Zion Unit 2 Capsule Y Irradiated Charpy Impact Specimens | 4-4 |
| 4-3 | Chemistry Results from the NBS Certified Reference Standards | 4-5 |
| 4-4 | Zion Unit 2 Reactor Vessel Toughness Data (Unirradiated) | 4-6 |
| 4-5 | Heat Treatment of the Zion Unit 2 Reactor Vessel Surveillance Materials | 4-7 |
| 5-1 | Charpy V-Notch Impact Data for the Zion Unit 2 Reactor Vessel Shell Plate C4007-1 Irradiated at 550°F, fluence 1.48×10^{19} n/cm ² (E > 1.0 MeV) | 5-6 |
| 5-2 | Charpy V-Notch Impact Data for the Zion Unit 2 Reactor Vessel Weld Metal and HAZ Metal Irradiated at 550°F, Fluence 1.48×10^{19} n/cm ² (E > 1.0 MeV) | 5-7 |
| 5-3 | Charpy V-Notch Impact Data for the Zion Unit 2 ASTM Correlation Monitor Material (HSST Plate 02) Irradiated at 550°F, Fluence 1.48×10^{19} n/cm ² (E > 1.0 MeV) | 5-8 |
| 5-4 | Instrumented Charpy Impact Test Results for Zion Unit 2 Reactor Vessel Shell Plate C4007-1 Irradiated at 550°F, Fluence 1.48×10^{19} n/cm ² (E > 1.0 MeV) | 5-9 |
| 5-5 | Instrumented Charpy Impact Test Results for Zion Unit 2 Reactor Vessel Weld Metal and HAZ Metal Irradiated at 550°F, Fluence 1.48×10^{19} n/cm ² (E > 1.0 MeV) | 5-10 |

LIST OF TABLES (Cont)

| Table | Title | Page |
|-------|---|------|
| 5-6 | Instrumented Charpy Impact Test Results for Zion Unit 2 ASTM Correlation Monitor Material (HSST Plate 02) Irradiated at 550°F, Fluence 1.48×10^{19} n/cm ² (E > 1.0 MeV) | 5-11 |
| 5-7 | The Effect of 550°F Irradiation at 1.48×10^{19} n/cm ² (E > 1.0 MeV) on the Notch Toughness Properties of the Zion Unit 2 Reactor Vessel Materials | 5-12 |
| 5-8 | Comparison of Zion Unit 2 Reactor Vessel Surveillance Capsule Charpy Impact Test Results with Regulatory Guide 1.99 Revision 2 Predictions | 5-13 |
| 5-9 | Tensile Properties for Zion Unit 2 Reactor Vessel Material Irradiated to 1.48×10^{19} n/cm ² (E > 1.0 MeV) | 5-14 |
| 6-1 | Calculated Fast Neutron Exposure Parameters at the Surveillance Capsule Center | 6-14 |
| 6-2 | Calculated Fast Neutron Exposure Parameters at the Pressure Vessel Clad/Base Metal Interface | 6-15 |
| 6-3 | Relative Radial Distributions of Neutron Flux (E>1.0 MeV) Within the Pressure Vessel Wall | 6-16 |
| 6-4 | Relative Radial Distributions of Neutron Flux (E>0.1 MeV) Within the Pressure Vessel Wall | 6-17 |
| 6-5 | Relative Radial Distribution of Iron Displacement Rate (dpa) Within the Pressure Vessel Wall | 6-18 |

LIST OF TABLES (Cont)

| Table | Title | Page |
|-------|---|------|
| 6-6 | Nuclear Parameters for Neutron Flux Monitors | 6-19 |
| 6-7 | Irradiation History of Neutron Sensors Contained in Capsule Y | 6-20 |
| 6-8 | Measured Sensor Activities and Reaction Rates | 6-25 |
| 6-9 | Summary of Neutron Dosimetry Results | 6-27 |
| 6-10 | Comparison of Measured and FERRET Calculated Reaction Rates at the Surveillance Capsule Center | 6-28 |
| 6-11 | Adjusted Neutron Energy Spectrum at the Surveillance Capsule Center | 6-29 |
| 6-12 | Comparison of Calculated and Measured Exposure Levels for Capsules | 6-30 |
| 6-13 | Neutron Exposure Projections at Key Locations on the Pressure Vessel Clad/Base Metal Interface | 6-31 |
| 6-14 | Neutron Exposure Values for Use in the Generation of Heatup/Cooldown Curves | 6-32 |
| 6-15 | Updated Lead Factors for Zion Unit 2 Surveillance Capsules | 6-33 |

SECTION 1
SUMMARY OF RESULTS

The analysis of the reactor vessel material contained in Capsule Y, the third surveillance capsule to be removed from the Commonwealth Edison Company Zion Unit 2 reactor pressure vessel, resulted in the following conclusions:

- o The capsule received an average fast neutron fluence ($E > 1.0$ MeV) of 1.48×10^{19} n/cm².
- o Irradiation of the reactor vessel lower shell Plate C4007-1, to 1.48×10^{19} n/cm², resulted in 30 and 50 ft-lb transition temperature increases of 121 and 130°F, respectively, for specimens oriented normal to the major working direction (transverse orientation) and temperature increases of 88 and 103°F, respectively, for specimens oriented parallel to the major working direction (longitudinal orientation).
- o Weld metal irradiated to 1.48×10^{19} n/cm² experienced increases in the 30 and 50 ft-lb transition temperatures of 220 and 255°F, respectively. This results in a 30 ft-lb transition temperature of 210°F and a 50 ft-lb transition temperature of 300°F.
- o Irradiation to 1.48×10^{19} n/cm² resulted in no decrease in the average upper shelf energy of Plate C4007-1 (transverse orientation) and a decrease of 18 ft-lb for the weld metal. This results in a weld metal average upper shelf energy of 51 ft-lb.
- o Comparison of the 30 ft-lb transition temperature increases for the Zion Unit 2 surveillance material with predicted increases using the methods of NRC Regulatory Guide 1.99, Revision 2, demonstrated that the Plate C4007-1 material and weld metal transition temperature increases were 31° and 22°F, respectively, greater than predicted. NRC Regulatory Guide 1.99, Revision 2 requires a 2 sigma allowance, of 34°F for base metal and 56°F for weld metal, be added to the predicted

reference transition temperature to obtain a conservative upper bound value. Thus, the reference transition temperature increases for Plate C4007-1 material and the weld metal are bounded by the 2 sigma allowance for shift prediction.

SECTION 2 INTRODUCTION

This report presents the results of the examination of Capsule Y, the third capsule to be removed from the reactor in the continuing surveillance program which monitors the effects of neutron irradiation on the Commonwealth Edison Company Zion Unit 2 reactor pressure vessel materials under actual operating conditions.

The surveillance program for the Commonwealth Edison Company Zion Unit 2 reactor pressure vessel materials was designed and recommended by the Westinghouse Electric Corporation. A description of the surveillance program and the preirradiation mechanical properties of the reactor vessel materials are presented by Yanichko and Lege.^[1] The surveillance program was planned to cover the 40-year design life of the reactor pressure vessel and was based on ASTM E-185-70, "Recommended Practice for Surveillance Tests in Nuclear Reactors". Westinghouse Electric Corporation personnel performed the postirradiation mechanical testing of the Charpy V-notch impact and tensile surveillance specimens.

This report summarizes testing and the postirradiation data obtained from surveillance Capsule Y removed from the Commonwealth Edison Company Zion Unit 2 reactor vessel and discusses the analysis of the data. The data are also compared to results of the previously removed Zion Unit 2 Capsule U^[2] and Capsule T^[3].

SECTION 3 BACKGROUND

The ability of the large steel pressure vessel, which contains the reactor core and its primary coolant to resist fracture constitutes an important factor in ensuring safety in the nuclear industry. The beltline region of the reactor pressure vessel is the most critical region of the vessel because it is subjected to significant fast neutron bombardment. The overall effects of fast neutron irradiation on the mechanical properties of low alloy ferritic pressure vessel steels such as SA533 Grade B Class 1 (base material of the Zion Unit 2 reactor pressure vessel beltline) are well documented in industry literature. Generally, low alloy ferritic materials demonstrate an increase in hardness and tensile properties and a decrease in ductility and toughness under certain conditions of irradiation.

A method for performing analyses to guard against fast fracture in reactor pressure vessels has been presented in "Protection Against Non-ductile Failure," Appendix G to Section III of the ASME Boiler and Pressure Vessel Code. The method utilizes fracture mechanics concepts and is based on the reference nil-ductility temperature (RT_{NDT}).

RT_{NDT} is defined as the greater of either the drop weight nil-ductility transition temperature (NDTT per ASTM E-208) or the temperature 60°F less than the 50 ft lb (and 35-mil lateral expansion) temperature as determined from Charpy specimens oriented normal (transverse) to the major working direction of the material. The RT_{NDT} of a given material is used to index that material to a reference stress intensity factor curve (K_{IR} curve) which appears in Appendix G of the ASME Code. The K_{IR} curve is a lower bound of dynamic, crack arrest, and static fracture toughness results obtained from several heats of pressure vessel steel. When a given material is indexed to the K_{IR} curve, allowable stress intensity factors can be obtained for this material as a function of temperature. Allowable operating limits can then be determined utilizing these allowable stress intensity factors.

RT_{NDT} and the operating limits of nuclear power plants can be adjusted to account for the effects of radiation on the reactor vessel material properties. The radiation embrittlement or changes in mechanical properties of a given reactor pressure vessel steel can be monitored by a reactor surveillance program such as the Commonwealth Edison Company Zion Unit 2 Reactor Vessel Radiation Surveillance Program.^[1] A surveillance capsule is periodically removed from the operating nuclear reactor and the encapsulated specimens are tested. The increase in the average Charpy V-notch 30 ft lb temperature (ΔRT_{NDT}) due to irradiation is added to the original RT_{NDT} to adjust the RT_{NDT} for radiation embrittlement. This adjusted RT_{NDT} ($RT_{NDT \text{ initial}} + \Delta RT_{NDT}$) is used to index the material to the K_{IR} curve and to set operating limits for the nuclear power plant which reflect the effects of irradiation on the reactor vessel materials.

SECTION 4 DESCRIPTION OF PROGRAM

Eight surveillance capsules for monitoring the effects of neutron exposure on the Zion Unit 2 reactor pressure vessel core region material were inserted in the reactor vessel prior to initial plant startup. The capsules were positioned in the reactor vessel between the thermal shield and the vessel wall at locations shown in Figure 4-1. The vertical center of the capsules is opposite the vertical center of the core.

Capsule Y (Figure 4-2) was removed after 9.18 effective full power years of plant operation. This capsule contained Charpy V-notch impact and tensile specimens from the reactor vessel lower shell Plate C4007-1, and submerged arc weld metal representative of that used for the beltline region intermediate shell longitudinal weld seams of the reactor vessel and Charpy V-notch specimens from weld heat-affected zone (HAZ) material. All heat-affected zone specimens were obtained from within the HAZ of Plate C4007-1 of the representative weld. In addition, the capsule also contained Charpy V-notch specimens of an ASTM correlation monitor material (HSST Plate 02).

The chemical composition, toughness data and heat treatment of the surveillance material are presented in Tables 4-1 through Table 4-5. The chemical analyses reported in Table 4-1 were obtained from unirradiated material used in the surveillance program. In addition, a chemical analysis using Inductively Coupled Plasma Spectrometry (ICPS) was performed on irradiated Charpy specimens from the lower shell Plate C4007-1 and weld metal and is reported in Table 4-2. The chemistry results from the NBS certified reference standards are reported in table 4-3.

All test specimens were machined from the 1/4 thickness location of the plate. Test specimens represent material taken at least one plate thickness from the quenched end of the plate. All base metal Charpy V-notch impact and tensile specimens were oriented with the longitudinal axis of the specimen both normal to (transverse orientation) and parallel to (longitudinal orientation) the principal working direction of the plate. Charpy V-notch specimens from the

weld metal were oriented with the longitudinal axis of the specimens transverse to the weld direction. Tensile specimens were oriented with the longitudinal axis of the specimens normal to the welding direction. Weld metal IT Wedge Opening Loading test specimens in Capsule Y were machined such that the simulated crack in the specimen would propagate parallel to the weld direction for weld specimens. All specimens were fatigue precracked per ASTM E399-70T.

Capsule Y contained dosimeter wires of pure iron, copper, nickel, and unshielded aluminum-cobalt. In addition, cadmium-shielded dosimeters of Neptunium (Np^{237}) and Uranium (U^{238}) were contained in the capsule.

Thermal monitors made from two low-melting eutectic alloys and sealed in Pyrex tubes were included in the capsule and were located as shown in Figure 4-2. The two eutectic alloys and their melting points are:

| | |
|------------------------------|-----------------------------|
| 2.5% Ag, 97.5% Pb | Melting Point 579°F (304°C) |
| 1.75% Ag, 0.75% Sn, 97.5% Pb | Melting Point 590°F (310°C) |

The arrangement of the various mechanical test specimens, dosimeters and thermal monitors contained in Capsule Y are shown in Figure 4-2.

TABLE 4-1

CHEMICAL COMPOSITION OF
THE ZION UNIT 2 REACTOR VESSEL
SURVEILLANCE MATERIALS

| <u>Element</u> | Plate C4007-1 ^[c] <u>(Wt. %)</u> | Weld Metal ^{[b][c]} <u>(Wt. %)</u> | ASTM Correlation <u>Monitor Material</u> |
|----------------|--|--|--|
| C | 0.23 | 0.077 | 0.22 |
| S | 0.016 | 0.013 | 0.018 |
| N ₂ | 0.006 | 0.014 | - |
| Co | 0.001 (a) | 0.001 (a) | - |
| Cu | 0.12 | 0.28 | 0.14 |
| Si | 0.22 | 0.47 | 0.25 |
| Mo | 0.54 | 0.39 | 0.52 |
| Ni | 0.53 | 0.55 | 0.68 |
| Mn | 1.39 | 1.51 | 1.48 |
| Cr | 0.065 | 0.064 | - |
| V | 0.001 | 0.003 | - |
| P | 0.010 | 0.017 | 0.012 |
| Sn | 0.011 | 0.004 | - |
| Al | 0.033 | 0.030 | - |
| Ti | 0.001 (a) | 0.001 (a) | - |
| Sb | 0.001 | 0.001 | - |
| Zr | 0.001 (a) | 0.001 (a) | - |
| As | 0.008 | 0.003 | - |
| B | 0.003 (a) | 0.003 (a) | - |
| Zn | 0.001 (a) | 0.003 | - |

(a) Not detected. The number indicates the minimum limit of detection.

(b) Surveillance weld specimens were made from same weld wire as the intermediate shell longitudinal weld seams (Wire Heat 72105) and Linde 80 Flux Lot 8773.

(c) Chemical composition data from WCAP-8132.

Table 4-2

CHEMICAL COMPOSITION FOR ZION UNIT 2 CAPSULE Y IRRADIATED CHARPY IMPACT SPECIMENS

| Weld Metal Specimen No. | Chemical Composition (wt.%) ^(a) | | | | | | | | | | |
|----------------------------|--|-----------|----------|-----------|----------|----------|-----------|-----------|-----------|----------|-----------|
| | <u>Cu</u> | <u>Ni</u> | <u>C</u> | <u>Mn</u> | <u>P</u> | <u>S</u> | <u>Si</u> | <u>Cr</u> | <u>Mo</u> | <u>V</u> | <u>Co</u> |
| W-50 | 0.26 | 0.57 | 0.09 | 1.68 | 0.016 | 0.008 | 0.49 | 0.08 | 0.34 | <0.010 | 0.016 |
| W-55 | 0.27 | 0.60 | 0.09 | 1.57 | 0.021 | 0.007 | 0.45 | 0.07 | 0.41 | <0.010 | 0.015 |
| W-49 | 0.26 | 0.59 | - | 1.59 | 0.015 | - | - | 0.08 | 0.42 | <0.010 | 0.015 |
| W-51 | 0.28 | 0.60 | - | 1.58 | 0.020 | - | - | 0.08 | 0.40 | <0.010 | 0.016 |
| W-52 | 0.26 | 0.60 | - | 1.66 | 0.019 | - | - | 0.08 | 0.40 | <0.010 | 0.015 |
| W-53 | 0.27 | 0.60 | - | 1.67 | 0.018 | - | - | 0.08 | 0.39 | <0.010 | 0.016 |
| W-54 | 0.26 | 0.56 | - | 1.50 | 0.020 | - | - | 0.08 | 0.35 | <0.010 | 0.015 |
| W-56 | 0.23 | 0.59 | - | 1.60 | 0.020 | - | - | 0.08 | 0.40 | <0.010 | 0.013 |
| Plate C4007-1 | | | | | | | | | | | |
| Specimen No. | <u>Cu</u> | <u>Ni</u> | <u>C</u> | <u>Mn</u> | <u>P</u> | <u>S</u> | <u>Si</u> | <u>Cr</u> | <u>Mo</u> | <u>V</u> | <u>Co</u> |
| E-70 | 0.10 | 0.48 | 0.26 | 1.24 | 0.007 | 0.011 | 0.25 | 0.064 | 0.45 | <0.010 | 0.010 |

(a) Method of analysis -- Inductively Coupled Plasma Spectrometry (ICPS) for all elements except C, S and Si.

TABLE 4-3
 CHEMISTRY RESULTS FROM THE NBS
 CERTIFIED REFERENCE STANDARDS

| Material ID | Low Alloy Steel: NBS Certified Reference Standards | | | |
|---------------|--|--------------|-----------|--------------|
| | NBS 361 | | NBS 362 | |
| | Certified | Measured (a) | Certified | Measured (a) |
| Metals | | | | |
| | Concentration in Weight Percent | | | |
| Fe * | 95.6 | (matrix) | 95.3 | (matrix) |
| Mn | 0.66 | 0.678 | 1.04 | 1.053 |
| Cr | 0.694 | 0.732 | 0.30 | 0.307 |
| Ni | 2.00 | above calib | 0.59 | 0.602 |
| Mo | 0.19 | 0.211 | 0.068 | 0.056 |
| Co | 0.032 | 0.031 | 0.30 | 0.321 |
| Cu | 0.042 | 0.043 | 0.50 | 0.513 |
| P | 0.014 | 0.0147 | 0.041 | 0.0485 |
| V | 0.011 | 0.011 | 0.040 | 0.036 |
| C | 0.383 | 0.383 | 0.160 | 0.157 |
| S | 0.014 | NA | 0.036 | 0.0351 |

| Material ID | Low Alloy Steel: NBS Certified Reference Standards | | | |
|---------------|--|--------------|-----------|--------------|
| | NBS 363 | | NBS 364 | |
| | Certified | Measured (a) | Certified | Measured (b) |
| Metals | | | | |
| | Concentration in Weight Percent | | | |
| Fe * | 94.4 | (matrix) | 96.7 | (matrix) |
| Mn | 1.50 | 1.543 | 0.255 | 0.261 |
| Cr | 1.31 | 1.396 | 0.063 | 0.064 |
| Ni | 0.30 | 0.319 | 0.144 | 0.147 |
| Mo | 0.028 | 0.032 | 0.49 | 0.520 |
| Co | 0.048 | 0.047 | 0.15 | 0.158 |
| Cu | 0.010 | 0.102 | 0.249 | 0.263 |
| P | 0.029 | 0.0283 | 0.01 | 0.0129 |
| V | 0.31 | 0.316 | 0.105 | 0.143 |
| | 0.62 | NA | 0.87 | NA |
| S | 0.0068 | NA | 0.0250 | 0.0249 |

* Matrix element calculated as difference for material balance.
 Tentative value, certified \pm 100% of value.
 NA - Not analyzed; NR, Not Requested

(a) Method of analysis -- Inductively Coupled Plasma Spectrometry (ICPS) for all elements except C, S and Si.

TABLE 4-4
ZION UNIT 2 REACTOR VESSEL TOUGHNESS DATA (UNIRRADIATED)

| Component | Heat No. | Material Type | Cu (%) | Ni (%) | T _{NDT} (°F) | RT _{NDT} (°F) | NMWD ^(e) USE (FT-LB) |
|-------------------------------|------------|---------------|--------|--------|-----------------------|------------------------|---------------------------------|
| Closure Head Dome | B9094-1 | A5338, Cl. 1 | .14 | .55 | -20 | 11 | 72 |
| Closure Head Seg. | C4787-1A | " " | .13 | .62 | 0 | 0 | 88 |
| Closure Head Seg. | C5086-2 | " " | .09 | .54 | 30 | 30 | 88 |
| Closure Head Flange | 124W609 | A508, Cl. 2 | .08 | .70 | 12(a) | 12 | 105 |
| Vessel Flange | 2V-965 | " " | .12 | .74 | 60(a) | 60 | 79 |
| Inlet Nozzle | ZT4007-2 | " " | .11 | .70 | 48(a) | 48 | >78 |
| Inlet Nozzle | ZT3885-1 | " " | .11 | .58 | 60(a) | 60 | 82 |
| Inlet Nozzle | ZT3885 | " " | .11 | .56 | 43(a) | 43 | 78 |
| Inlet Nozzle | ZT3885 | " " | .11 | .56 | 60(a) | 60 | >84 |
| Outlet Nozzle | ZV3930 | " " | .12 | .66 | 58(a) | 58 | 93 |
| Outlet Nozzle | ZV3930 | " " | .11 | .65 | 48(a) | 48 | >80 |
| Outlet Nozzle | ZV3930 | " " | .12 | .67 | 55(a) | 55 | 84 |
| Outlet Nozzle | ZT3885-4 | " " | .11 | .57 | 60(a) | 60 | >61 |
| Upper Nozzle Shell | ZD3940 | A508, Cl. 2 | .07 | .62 | 10 | 10 | 106 |
| Lower Nozzle Shell | ZV3855 | " " | .09 | .66 | 10 | 10 | >80 |
| Lower Shell | B8029-1 | A533B, Cl. 1 | .12 | .51 | -10 | 22 | 81 |
| Lower Shell | C4007-1 | " " | .12 | .53 | 10 | 22 | 94 (Actual) |
| Inter. Shell | B8006-1 | " " | .12 | .54 | 10 | 10 | 89 |
| Inter. Shell | B8040-1 | " " | .14 | .52 | -10 | 2 | 92 |
| Bottom Head Trans. Ring | 3V-433 | A508, Cl. 2 | .09 | .76 | 0 | 0 | 87 |
| Bottom Head Dome | C4007-2 | A533B, Cl. 1 | .12 | .53 | -20 | 0 | 72 |
| Inter. to Lower Shell | | | | | | | |
| Girth Weld Seam | SA1769 (b) | SAW | .26 | .60 | 0(a) | 0 | - |
| Lower Shell Long. Weld Seams | WF29 (c) | SAW | .23 | .63 | 0(a) | 0 | - |
| Inter. Shell Long. Weld Seams | WF70 (d) | SAW | .32 | .56 | 0(a) | 0 | - |

(a) Estimated using method of U.S. NRC WUREG-0800 Branch Technical Position MTEB 5-2, July, 1981.

(b) Weld Wire Heat No. 71249 and Linde 80 Flux Lot No. 8738

(c) Weld Wire Heat No. 72102 and Linde 80 Flux Lot No. 8650

(d) Weld Wire Heat No. 72105 and Linde 80 Flux Lot No. 8669 (Chemical composition per WCAP-10962, December 1985)

(e) Normal to Major Working direction

TABLE 4-5

HEAT TREATMENT OF THE ZION UNIT 2
REACTOR VESSEL SURVEILLANCE MATERIALS

| <u>Material</u> | <u>Temperature (°F)</u> | <u>Time (hr)</u> | <u>Coolant</u> |
|--|-------------------------|------------------|----------------|
| Intermediate Shell Plate C4007-1 | 1600/1650 | 9 3/4 | Brine quenched |
| | 1200/1225 | 9 3/4 | Brine quenched |
| | 1100/1150 | 30 | Furnace cooled |
| Weld Metal | 1100/1150 | 30 | Furnace cooled |
| Correlation Monitor (HSST Plate 02) | 1625 ± 25 | 4 | Air cooled |
| | 1600 ± 25 | 4 | Water quenched |
| | 1225 ± 25 | 4 | Furnace cooled |
| | 1150 ± 25 | 10 | Furnace cooled |




Figure 4-1. Arrangement of Surveillance Capsules in the Zion Unit 2 Reactor Vessel




Figure 4-2 Capsule Y Diagram Showing Locations of Specimens, Thermal Monitors, and Dosimeters

SECTION 5 TESTING OF SPECIMENS FROM CAPSULE Y

5-1. OVERVIEW

The postirradiation mechanical testing of the Charpy V-notch and tensile specimens was performed at the Westinghouse Research and Development Laboratory with consultation by Westinghouse Nuclear Energy Systems personnel. Testing was performed in accordance with 10CFR50, Appendices G and H^[4], ASTM Specification E185-82 and Westinghouse Procedure MHL 8402, Revision 1 as modified by Westinghouse RMF Procedures 8102, Revision 1 and 8103, Revision 1.

Upon receipt of the capsule at the laboratory, the specimens and spacer blocks were carefully removed, inspected for identification number, and checked against the master list in WCAP-8132.^[1] No discrepancies were found.

Examination of the two low-melting 304°C (579°F) and 310°C (590°F) eutectic alloys indicated no melting of either type of thermal monitor. Based on this examination, the maximum temperature to which the test specimens were exposed was less than 304°C (579°F).

The Charpy impact tests were performed per ASTM Specification E23-82 and RMF Procedure 8103, Revision 1 on a Tinius-Olsen Model 74, 358J machine. The tup (striker) of the Charpy machine is instrumented with an Effects Technology model 500 instrumentation system. With this system, load-time and energy-time signals can be recorded in addition to the standard measurement of Charpy energy (E_D). From the load-time curve, the load of general yielding (P_{GY}), the time to general yielding (t_{GY}), the maximum load (P_M), and the time to maximum load (t_M) can be determined. Under some test conditions, a sharp drop in load indicative of fast fracture was observed. The load at which fast fracture was initiated is identified as the fast fracture load (P_F), and the load at which fast fracture terminated is identified as the arrest load (P_A). The Charpy machine is maintained and

calibrated in accordance with ASTM Specification E-23. The annual qualification of the Charpy machine is accomplished with the Standardized Watertown test specimens. The specimens and procedures used by Westinghouse are recommended by the Army Materials Technology Laboratory and is identical to the approach used to certify machines that generate data for government contracts.

The energy at maximum load (E_M) was determined by comparing the energy-time record and the load-time record. The energy at maximum load is approximately equivalent to the energy required to initiate a crack in the specimen. Therefore, the propagation energy for the crack (E_p) is the difference between the total energy to fracture (E_D) and the energy at maximum load.

The yield stress (σ_y) is calculated from the three point bend formula. The flow stress is calculated from the average of the yield and maximum loads, also using the three point bend formula.

Percentage shear was determined from postfracture photographs using the ratio-of-areas methods in compliance with ASTM Specification A370-77. The lateral expansion was measured using a dial gage rig similar to that shown in the same specification.

Tension tests were performed on a 20,000-pound Instron, split-console test machine (Model 1115) per ASTM Specifications E8-83 and E21-79, and RMF Procedure 8102, Revision 1. All pull rods, grips, and pins were made of Inconel 718 hardened to Rc45. The upper pull rod was connected through a universal joint to improve axially of loading. The tests were conducted at a constant crosshead speed of 0.05 inch per minute throughout the test.

Deflection measurements were made with a linear variable displacement transducer (LVDT) extensometer. The extensometer knife edges were spring-loaded to the specimen and operated through specimen failure. The extensometer gage length is 1.00 inch. The extensometer is rated as Class B-2 per ASTM E83-67.

Elevated test temperatures were obtained with a three-zone electric resistance split-tube furnace with a 9-inch hot zone. All tests were conducted in air.

Because of the difficulty in remotely attaching a thermocouple directly to the specimen, the following procedure was used to monitor specimen temperature. Chromel-alumel thermocouples were inserted in shallow holes in the center and each end of the gage section of a dummy specimen and in each grip. In test configuration, with a slight load on the specimen, a plot of specimen temperature versus upper and lower grip and controller temperatures was developed over the range room temperature to 550°F (288°C). The upper grip was used to control the furnace temperature. During the actual testing the grip temperatures were used to obtain desired specimen temperatures. Experiments indicated that this method is accurate to plus or minus 2°F.

The yield load, ultimate load, fracture load, total elongation, and uniform elongation were determined directly from the load-extension curve. The yield strength, ultimate strength, and fracture strength were calculated using the original cross-sectional area. The final diameter and final gage length were determined from postfracture photographs. The fracture area used to calculate the fracture stress (true stress at fracture) and percent reduction in area was computed using the final diameter measurement.

5.2. CHARPY V-NOTCH IMPACT TEST RESULTS

The results of Charpy V-notch impact tests performed on the various materials contained in Capsule Y irradiated to approximately 1.48×10^{19} n/cm² at 550°F are presented in Tables 5-1 through 5-6 and Figures 5-1 through 5-5. The transition temperature increases and upper shelf energy decreases for the Capsule Y material are shown in Table 5-7.

Irradiation of the vessel lower shell Plate C4007-1 material (transverse orientation) specimens to 1.48×10^{19} n/cm² (Figure 5-1) resulted in a 30 and 50 ft-lb transition temperature increases of 121°F and 130°F, respectively, and an upper shelf energy increase of 4 ft-lb when compared to the unirradiated data.^[1] It is probable that the increase in upper shelf energy is due to a random scatter in the data and it is more likely that the upper shelf energy is not changed.

Irradiation of the vessel lower shell Plate C4007-1 material (longitudinal orientation) specimens to $1.48 \times 10^{19} \text{ n/cm}^2$ (Figure 5-2) resulted in 30 and 50 ft-lb transition temperature increases of 88°F and 103°F, respectively, and an upper shelf energy decrease of 17 ft-lb when compared to the unirradiated data.

Weld material irradiated to $1.48 \times 10^{19} \text{ n/cm}^2$ (Figure 5-3) resulted in a 30 ft-lb transition temperature increase of 220°F (from -10°F to 210°F) and a 50 ft-lb transition temperature increase of 255°F (from 45°F to 300°F). Weld metal irradiated to $1.48 \times 10^{19} \text{ n/cm}^2$ resulted in an upper shelf energy decrease of 18 ft-lb (from 69 ft-lb to 51 ft-lb).

Weld HAZ metal irradiated to $1.48 \times 10^{19} \text{ n/cm}^2$ (Figure 5-4) resulted in 30 and 50 ft-lb transition temperature increases of 97°F and 99°F, respectively, and an upper shelf energy decrease of 24 ft-lb.

A533 Grade B Class 1 correlation monitor material (HSST Plate 02) irradiated to $1.48 \times 10^{19} \text{ n/cm}^2$ (Figure 5-5) resulted in 30 and 50 ft-lb transition temperature increases of 135°F and 137°F, respectively, and an upper shelf energy decrease of 14 ft-lb. The 30 ft-lb transition temperature increase is 23°F greater than predicted. The 23°F increase is bounded by the 2 sigma allowance of 34°F for shift prediction.

The fracture appearance of each irradiated Charpy specimen from the various materials is shown in Figures 5-6 through 5-10 and show an increasing ductile or tougher appearance with increasing test temperature.

Table 5-8 shows a comparison of the 30 ft-lb transition temperature (ΔRT_{NDT}) increases for the various Zion Unit 2 surveillance materials with predicted increases using the methods of NRC Regulatory Guide 1.99, Revision 2.^[5] This comparison shows that the transition temperature increase resulting from irradiation to $1.48 \times 10^{19} \text{ n/cm}^2$ is greater than predicted by the Guide for Plate C4007-1. The weld metal transition temperature increase resulting from $1.48 \times 10^{19} \text{ n/cm}^2$ is also greater than the Regulatory Guide prediction.

5-3. TENSION TEST RESULTS

The results of tension tests performed on Plate C4007-1 (longitudinal orientation) and weld metal irradiated to 1.48×10^{19} n/cm² are shown in Table 5-5 and Figures 5-11 and 5-12, respectively. These results show that irradiation produced a 0.2 percent yield strength increase of approximately 20 ksi for Plate C4007-1 and the weld metal. Fractured tension specimens for each of the materials are shown in Figures 5-13 and 5-14. A typical stress-strain curve for the tension specimens is shown in Figure 5-15.

5-4. WEDGE OPENING LOADING

It is common practice to store 1T - Wedge Opening Loading (WOL) fracture mechanics specimens at the Westinghouse Science and Technology Center Hot Cell.

TABLE 5-1.

CHARPY V-NOTCH IMPACT DATA FOR THE ZION UNIT 2
 REACTOR VESSEL SHELL PLATE C4007-1
 IRRADIATED AT 550°F, FLUENCE 1.48×10^{19} n/cm² (E > 1.0 MeV)

| <u>Sample No.</u> | <u>Temperature</u> (°F) | (°C) | <u>Impact Energy</u> (ft-lb) | (J) | <u>Lateral Expansion</u> (mils) | (mm) | <u>Shear</u> (%) |
|---------------------------------|----------------------------|-------|---------------------------------|---------|------------------------------------|--------|---------------------|
| <u>Longitudinal Orientation</u> | | | | | | | |
| E62 | 75 | (24) | 12.0 | (16.5) | 10.0 | (0.25) | 10 |
| E61 | 125 | (52) | 32.0 | (43.5) | 27.0 | (0.69) | 20 |
| E70 | 125 | (52) | 31.0 | (42.0) | 22.0 | (0.56) | 20 |
| E63 | 150 | (66) | 47.0 | (63.5) | 35.0 | (0.89) | 35 |
| E66 | 150 | (66) | 44.0 | (59.5) | 34.0 | (0.86) | 35 |
| E67 | 175 | (79) | 53.0 | (72.0) | 41.0 | (1.05) | 45 |
| E65 | 200 | (93) | 69.0 | (93.5) | 45.0 | (1.14) | 70 |
| E69 | 275 | (135) | 113.0 | (153.0) | 60.0 | (1.52) | 100 |
| E64 | 350 | (177) | 108.0 | (146.5) | 73.0 | (1.85) | 100 |
| E68 | 450 | (232) | 112.0 | (152.0) | 73.0 | (1.85) | 100 |
| <u>Transverse Orientation</u> | | | | | | | |
| ET62 | 75 | (24) | 14.0 | (19.0) | 14.0 | (0.36) | 10 |
| ET61 | 150 | (66) | 23.0 | (31.0) | 22.0 | (0.56) | 20 |
| ET67 | 175 | (79) | 35.0 | (47.5) | 30.0 | (0.76) | 30 |
| ET66 | 175 | (79) | 35.0 | (47.5) | 32.0 | (0.81) | 25 |
| ET70 | 200 | (93) | 43.0 | (58.5) | 35.0 | (0.89) | 45 |
| ET65 | 210 | (99) | 94.0 | (127.5) | 68.0 | (1.73) | 100 |
| ET68 | 240 | (116) | 83.0 | (112.5) | 60.0 | (1.52) | 80 |
| ET64 | 275 | (135) | 78.0 | (106.0) | 59.0 | (1.50) | 80 |
| ET69 | 350 | (177) | 102.0 | (138.5) | 67.0 | (1.70) | 100 |
| ET6. | 450 | (232) | 98.0 | (133.0) | 66.0 | (1.68) | 100 |

TABLE 5-2

CHARPY V-NOTCH IMPACT DATA FOR THE ZION UNIT 2
 REACTOR VESSEL WELD METAL AND HAZ METAL IRRADIATED AT 550°F
 FLUENCE 1.48×10^{19} n/cm² (E > 1.0 MeV)

| <u>Sample No.</u> | <u>Temperature</u> | | <u>Impact Energy</u> | | <u>Lateral Expansion</u> | <u>Shear</u> | |
|-------------------|--------------------|-------------|----------------------|------------|--------------------------|--------------|-----|
| | <u>(°F)</u> | <u>(°C)</u> | <u>(ft-lb)</u> | <u>(J)</u> | <u>(mils)</u> | <u>(mm)</u> | |
| | | | <u>Weld Metal</u> | | | | |
| W56 | 74 | (23) | 15.0 | (20.5) | 10.0 | | |
| W55 | 150 | (66) | 19.0 | (26.0) | 15.0 | | |
| W50 | 200 | (93) | 20.0 | (27.0) | 0 | | |
| W53 | 225 | (107) | 39.0 | (53.0) | 0 | | |
| W54 | 225 | (107) | 33.0 | (44.5) | 0 | | |
| W52 | 250 | (121) | 44.0 | (59.5) | 0 | (1.5) | |
| W49 | 350 | (177) | 50.0 | (68.0) | 0 | (1.07) | |
| W51 | 450 | (232) | 52.0 | (70.5) | 0 | (1.5) | |
| | | | <u>HAZ Metal</u> | | | | |
| H54 | -50 | (-46) | 23.0 | (31.0) | 19.0 | (0.48) | 10 |
| H55 | -10 | (-23) | 10.0 | (13.5) | 14.0 | (0.36) | 10 |
| H56 | 0 | (-18) | 38.0 | (51.5) | 27.0 | (0.69) | 30 |
| H49 | 25 | (-4) | 49.0 | (66.5) | 33.0 | (0.84) | 45 |
| H51 | 75 | (24) | 48.0 | (65.0) | 29.0 | (0.74) | 40 |
| H52 | 150 | (66) | 95.0 | (129.0) | 70.0 | (1.78) | 100 |
| H50 | 250 | (121) | 118.0 | (160.0) | 76.0 | (1.93) | 100 |
| H53 | 350 | (177) | 83.0 | (112.5) | 53.0 | (1.35) | 100 |

TABLE 5-3

CHARPY V-NOTCH IMPACT DATA FOR THE ZION UNIT 2
 ASTM CORRELATION MONITOR MATERIAL (HSST PLATE 02)
 IRRADIATED AT 550°F, FLUENCE 1.48×10^{19} n/cm² (E > 1.0 MeV)

| <u>Sample No.</u> | <u>Temperature</u> | | <u>Impact Energy</u> | | <u>Lateral Expansion</u> | | <u>Shear</u> <u>(%)</u> |
|-------------------|--------------------|-------------|----------------------|------------|--------------------------|-------------|----------------------------|
| | <u>(°F)</u> | <u>(°C)</u> | <u>(ft-lb)</u> | <u>(J)</u> | <u>(mils)</u> | <u>(mm)</u> | |
| R55 | 74 | (23) | 14.0 | (19.0) | 11.0 | (0.28) | 10 |
| R51 | 150 | (66) | 18.0 | (24.5) | 15.0 | (0.38) | 15 |
| R54 | 175 | (79) | 23.0 | (31.0) | 21.0 | (0.53) | 20 |
| R49 | 200 | (93) | 43.0 | (58.5) | 31.0 | (0.79) | 35 |
| R50 | 200 | (93) | 39.0 | (53.0) | 29.0 | (0.74) | 35 |
| R56 | 250 | (121) | 75.0 | (101.5) | 53.0 | (1.35) | 65 |
| R56 | 350 | (177) | 113.0 | (153.0) | 74.0 | (1.88) | 100 |
| R52 | 450 | (232) | 108.0 | (146.0) | 70.0 | (1.78) | 100 |

TABLE 5-4
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR ZION UNIT 2
 REACTOR VESSEL SHELL PLATE C4007-1
 IRRADIATED AT 550°F, FLUENCE 1.48×10^{19} n/cm² (E > 1.0 MeV)

| Sample Number | Test Temp (°F) | Charpy Energy (ft-lb) | Normalized Energies | | | Yield Load (kips) | Time to Yield (μsec) | Maximum Load (kips) | Time to Maximum (μsec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|---------------------------------|----------------|-----------------------|--------------------------------------|---------------------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A (ft-lb/in ²) | Maximum Em/A ² | Trop Et/A | | | | | | | | |
| <u>Longitudinal Orientation</u> | | | | | | | | | | | | | |
| E62 | 75 | 12.0 | 97 | 39 | 58 | 2.75 | 80 | 3.60 | 135 | 3.45 | 0.45 | 92 | 105 |
| E70 | 125 | 31.0 | 250 | 151 | 99 | 2.95 | 85 | 4.25 | 360 | 4.25 | 0.65 | 98 | 119 |
| E61 | 125 | 32.0 | 258 | 169 | 88 | 2.25 | 95 | 3.90 | 445 | 3.90 | 1.05 | 74 | 102 |
| E66 | 150 | 44.0 | 354 | 217 | 138 | 2.70 | 85 | 4.20 | 510 | 4.10 | 1.15 | 90 | 115 |
| E63 | 150 | 47.0 | 378 | 206 | 173 | 2.60 | 90 | 4.00 | 510 | 3.95 | 1.45 | 86 | 109 |
| E67 | 175 | 53.0 | 427 | 253 | 174 | 3.00 | 60 | 3.85 | 610 | 3.85 | 1.45 | 100 | 114 |
| E65 | 200 | 69.0 | 556 | 266 | 290 | 2.55 | 60 | 4.40 | 575 | 4.15 | 2.05 | 84 | 115 |
| E69 | 275 | 113.0 | 910 | 298 | 612 | 2.55 | 145 | 4.15 | 750 | - | - | 84 | 111 |
| E64 | 350 | 108.0 | 870 | 266 | 604 | 3.00 | 100 | 4.20 | 610 | - | - | 99 | 119 |
| E68 | 450 | 112.0 | 902 | 259 | 642 | 2.60 | 110 | 4.05 | 625 | - | - | 97 | 115 |
| <u>Transverse Orientation</u> | | | | | | | | | | | | | |
| ET62 | 75 | 14.0 | 113 | 55 | 58 | 3.45 | 45 | 3.95 | 130 | 3.95 | 0.15 | 114 | 122 |
| ET61 | 150 | 23.0 | 185 | 94 | 91 | 2.45 | 65 | 3.65 | 260 | 3.65 | 1.05 | 80 | 100 |
| ET66 | 175 | 35.0 | 282 | 142 | 139 | 2.30 | 80 | 3.80 | 375 | 3.75 | 1.55 | 76 | 101 |
| ET67 | 175 | 35.0 | 282 | 159 | 123 | 2.80 | 65 | 4.15 | 370 | 4.10 | 1.25 | 93 | 115 |
| ET70 | 200 | 43.0 | 346 | 176 | 171 | 3.30 | 95 | 4.20 | 410 | 4.15 | 1.95 | 109 | 124 |
| ET65 | 210 | 94.0 | 757 | 220 | 537 | 2.70 | 130 | 3.65 | 605 | - | - | 89 | 105 |
| ET68 | 240 | 83.0 | 668 | 239 | 429 | 2.45 | 110 | 4.15 | 575 | 3.80 | 2.90 | 81 | 109 |
| ET64 | 275 | 78.0 | 628 | 173 | 455 | 2.20 | 80 | 3.65 | 480 | - | - | 72 | 96 |
| ET69 | 350 | 102.0 | 821 | 258 | 563 | 2.90 | 105 | 4.15 | 605 | - | - | 96 | 117 |
| ET63 | 450 | 98.0 | 789 | 209 | 580 | 2.85 | 95 | 4.00 | 505 | - | - | 95 | 113 |

TABLE 5-5

INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR ZIRCO UNIT 2

REACTOR VESSEL WELD METAL AND HAZ METAL

IRRADIATED AT 550°F, FLUENCE 1.48×10^{19} n/cm² (E > 1.0 MeV)

| Sample Number | Test Temp (°F) | Charpy Energy (ft-lb) | Normalized Energies | | | Yield Load (kips) | Time to Yield (μsec) | Maximum Load (kips) | Time to Maximum (μsec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|-------------------|----------------|-----------------------|---------------------|--|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A ² (ft-lb/in ²) | Prop Bp/A | | | | | | | | |
| W56 | 74 | 15.0 | 121 | 72 | 49 | 2.95 | 85 | 4.35 | 185 | 4.35 | 0.15 | 98 | 121 |
| W55 | 150 | 19.0 | 153 | 99 | 54 | 3.40 | 95 | 3.80 | 255 | 3.80 | 0.20 | 113 | 119 |
| W50 | 200 | 20.0 | 161 | 95 | 66 | 3.70 | 95 | 4.10 | 230 | 4.10 | 1.70 | 123 | 129 |
| W54 | 225 | 33.0 | 236 | 126 | 140 | 2.75 | 90 | 3.75 | 335 | 3.75 | 2.85 | 90 | 107 |
| W53 | 225 | 39.0 | 314 | 130 | 184 | 2.65 | 115 | 3.65 | 370 | 3.65 | 3.30 | 87 | 104 |
| W52 | 250 | 44.0 | 354 | 152 | 202 | 3.60 | 90 | 4.35 | 355 | - | - | 119 | 131 |
| W49 | 350 | 50.0 | 403 | 170 | 233 | 3.50 | 60 | 4.25 | 360 | - | - | 116 | 128 |
| W51 | 450 | 52.0 | 419 | 159 | 260 | 3.30 | 95 | 3.85 | 380 | - | - | 109 | 118 |
| <u>Weld Metal</u> | | | | | | | | | | | | | |
| H54 | -50 | 23.0 | 185 | 111 | 75 | 3.00 | 100 | 4.15 | 285 | 4.15 | 0.30 | 98 | 118 |
| H55 | -10 | 10.0 | 81 | 45 | 36 | 2.35 | 40 | 3.05 | 125 | 3.05 | - | 78 | 89 |
| H56 | 0 | 38.0 | 306 | 177 | 129 | 2.09 | 80 | 4.10 | 410 | 4.10 | 1.15 | 95 | 116 |
| H49 | 25 | 49.0 | 395 | 216 | 178 | 2.55 | 75 | 4.80 | 470 | 4.55 | 1.50 | 84 | 122 |
| H51 | 75 | 48.0 | 387 | 235 | 152 | 2.75 | 70 | 4.50 | 500 | 4.35 | 1.00 | 91 | 120 |
| H52 | 150 | 95.0 | 765 | 220 | 545 | 3.30 | 90 | 4.15 | 505 | - | - | 109 | 123 |
| H50 | 250 | 118.0 | 950 | 303 | 647 | 3.30 | 90 | 4.30 | 655 | - | - | 109 | 126 |
| H53 | 350 | 83.0 | 668 | 221 | 448 | 2.75 | 85 | 4.15 | 520 | - | - | 91 | 114 |
| <u>HAZ Metal</u> | | | | | | | | | | | | | |

TABLE 5-6

INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR ZION UNIT 2
 ASTM CORRELATION MONITOR MATERIAL (HSST PLATE 02)
 IRRADIATED AT 550°F, FLUENCE 1.48×10^{19} n/cm² (E > 1.0 MeV)

| Sample Number | Test Temp (°F) | Charpy Energy (ft-lb) | Normalized Energies | | | Yield Load (kips) | Time to Yield (μsec) | Maximum Load (kips) | Time to Maximum (μsec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|---------------|----------------|-----------------------|---------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A | Prop Ep/A | | | | | | | | |
| R55 | 74 | 14.0 | 113 | 46 | 67 | 2.55 | 100 | 3.90 | 155 | 3.95 | 0.30 | 84 | 106 |
| R51 | 150 | 18.0 | 145 | 83 | 62 | 2.40 | 60 | 3.45 | 235 | 3.45 | 0.55 | 79 | 97 |
| R54 | 175 | 23.0 | 185 | 90 | 95 | 2.10 | 90 | 3.40 | 285 | 3.40 | 1.25 | 69 | 91 |
| R50 | 200 | 39.0 | 314 | 216 | 98 | 2.75 | 85 | 4.25 | 505 | 4.25 | 1.60 | 91 | 116 |
| R49 | 200 | 43.0 | 346 | 246 | 100 | 2.30 | 60 | 4.05 | 580 | 4.05 | 1.20 | 77 | 105 |
| R56 | 250 | 75.0 | 604 | 220 | 384 | 3.15 | 100 | 4.15 | 510 | - | - | 105 | 121 |
| R53 | 350 | 113.0 | 910 | 284 | 626 | 2.50 | 65 | 4.05 | 665 | - | - | 82 | 108 |
| R52 | 450 | 108.0 | 870 | 242 | 628 | 2.75 | 95 | 3.80 | 605 | - | - | 90 | 106 |

TABLE 5-7
 THE EFFECT OF 550°F IRRADIATION AT 1.48×10^{19} n/cm² (E > 1.0 MeV)
 ON THE NOTCH TOUGHNESS PROPERTIES OF THE
 ZION UNIT 2 REACTOR VESSEL MATERIALS

| Material | Average 30 ft-lb Temp (°C) | | Average 35 mil Lateral Expansion Temp (°F) | | Average 50 ft-lb Temp (°F) | | Average Energy Absorption at Full Strain (ft-lb) | | | | | |
|---------------------------------|----------------------------|-----------------------|--|-----------------------|----------------------------|-----------------------|--|-----------------------|-----|-----|-----|-----|
| | Unirradiated | Irradiated ΔT | Unirradiated | Irradiated ΔT | Unirradiated | Irradiated ΔT | Unirradiated | Irradiated ΔT | | | | |
| Plate C4007-1 (Longitudinal) | 37 | 125 | 88 | 50 | 160 | 110 | 62 | 165 | 103 | 128 | 111 | -17 |
| Plate C4007-1 (Transverse) | 49 | 170 | 121 | 65 | 190 | 125 | 80 | 210 | 130 | 94 | 98 | +4 |
| Weld Metal | -10 | 210 | 220 | 0 | 240 | 240 | 45 | 300 | 255 | 69 | 51 | -18 |
| HAZ Metal | -87 | 10 | 97 | -45 | 50 | 95 | -39 | 60 | 99 | 123 | 99 | -24 |
| Correlation Monitor | 50 | 185 | 135 | 62 | 212 | 150 | 78 | 215 | 137 | 124 | 110 | -14 |

TABLE 5-8

COMPARISON OF ZION UNIT 2
 REACTOR VESSEL SURVEILLANCE CAPSULE CHARPY IMPACT TEST RESULTS
 WITH REGULATORY GUIDE 1.99 REVISION 2 PREDICTIONS

| <u>Material</u> | <u>Capsule</u> | Fluence ^[a] <u>10^{19} n/cm²</u> | <u>ΔRT_{NDT} (°F)</u> | | <u>USE DECREASE (%)</u> | |
|---------------------------------|----------------|--|--|--------------|-------------------------|--------------|
| | | | <u>Meas.</u> | <u>Pred.</u> | <u>Meas.</u> | <u>Pred.</u> |
| Plate C4007-1 (Longitudinal) | U | 0.27 | 38 | 53.3 | 5.5 | 16 |
| | T | 0.78 | 75 | 76.3 | 18.8 | 19 |
| | Y | 1.48 | 88 | 91.0 | 13.3 | 22.5 |
| Plate C4007-1 (Transverse) | U | 0.27 | 49 | 53.3 | 0 | 16 |
| | T | 0.78 | 90 | 76.3 | 14.9 | 19 |
| | Y | 1.48 | 121 | 91.0 | 0 | 22.5 |
| Weld Metal | U | 0.27 | 128 | 117 | 27.5 | 32 |
| | T | 0.78 | 175 | 167 | 36.2 | 40 |
| | Y | 1.48 | 220 | 200 | 26.1 | 46 |
| Correlation Monitor | U | 0.27 | 50 | 66.3 | 10.5 | 17.5 |
| | T | 0.78 | 100 | 94.9 | 28.2 | 22 |
| | Y | 1.48 | 135 | 113 | 11.3 | 25.5 |

[a] These have been recalculated using the methods of Section 6.

TABLE 5-9
 TENSILE PROPERTIES FOR ZION UNIT 2
 REACTOR VESSEL MATERIAL IRRADIATED TO 1.48×10^{19} n/cm² (E > 1.0 MeV)

| <u>Material</u> | <u>Sample Number</u> | <u>Test Temp. (°F)</u> | <u>0.2% Yield Strength (ksi)</u> | <u>Ultimate Strength (ksi)</u> | <u>Fracture Load (kip)</u> | <u>Fracture Stress (ksi)</u> | <u>Fracture Strength (ksi)</u> | <u>Uniform Elongation (%)</u> | <u>Total Elongation (%)</u> | <u>Reduction in Area (%)</u> |
|--|----------------------|------------------------|----------------------------------|--------------------------------|----------------------------|------------------------------|--------------------------------|-------------------------------|-----------------------------|------------------------------|
| Plate C4007-1 (Long. Orient.) | E6 | 79 | 89.1 | 114.1 | 3.60 | 270.6 | 73.3 | 11.2 | 23.2 | 68 |
| | E5 | 550 | 75.4 | 99.8 | 3.40 | 189.1 | 69.3 | 9.6 | 20.3 | 63 |
| Weld | W14 | 79 | 91.7 | 114.1 | 4.27 | 254.1 | 86.9 | 9.1 | 19.5 | 66 |
| | W13 | 550 | 89.6 | 105.9 | 4.60 | 210.8 | 93.7 | 8.3 | 13.5 | 56 |

5-14




FIGURE 5-1 CHARPY V-NOTCH IMPACT DATA FOR ZION UNIT 2 REACTOR VESSEL SHELL PLATE C4007-1 (TRANSVERSE ORIENTATION)




FIGURE 5-2 CHARPY V-NOTCH IMPACT DATA FOR ZION UNIT 2 REACTOR VESSEL SHELL PLATE C4007-1 (LONGITUDINAL ORIENTATION)




FIGURE 5-3 CHARPY V-NOTCH IMPACT DATA FOR ZIRCONIUM UNIT 2 REACTOR VESSEL WELD METAL




FIGURE 5-4 CHARPY V-NOTCH IMPACT DATA FOR ZION UNIT 2 REACTOR VESSEL WELD HEAT AFFECTED ZONE METAL




FIGURE 5-5 CHARPY V-NOTCH IMPACT DATA FOR ZION UNIT 2 A533 GRADE B CLASS 1 CORRELATION; MONITOR MATERIAL (HSST PLATE 02)




FIGURE 5-6 CHARPY IMPACT SPECIMEN FRACTURE SURFACES FOR ZION UNIT 2 REACTOR VESSEL SHELL PLATE C4007-1 (LONGITUDINAL ORIENTATION)




FIGURE 5-7 CHARPY IMPACT SPECIMEN FRACTURE SURFACES FOR ZION UNIT 2 REACTOR VESSEL SHELL PLATE C4007-1 (TRANSVERSE ORIENTATION)




FIGURE 5.9 CHARPY IMPACT SPECIMEN FRACTURE SURFACES FOR ZION UNIT 2 REACTOR
VISCSEL WELD METAL




FIGURE 5-9 CHARPY IMPACT SPECIMEN FRACTURE SURFACES FOR ZION UNIT 2 REACTOR VESSEL WELD HAZ METAL










FIGURE 5-10 CHARPY IMPACT SPECIMEN FRACTURE SURFACES FOR ZION UNIT 2 ASTM CORRELATION MONITOR MATERIAL








1

IMAGE EVALUATION TEST TARGET (MT-3)









1

IMAGE EVALUATION TEST TARGET (MT-3)









1


IMAGE EVALUATION TEST TARGET (MT-3)



1

IMAGE EVALUATION TEST TARGET (MT-3)





Code:

Open Points - Unirradiated
 Closed Points - Irradiated at 1.48×10^{19} n/cm²





FIGURE 5-11 TENSILE PROPERTIES FOR ZION UNIT 2 REACTOR VESSEL SHELL PLATE C4007-1 (LONGITUDINAL ORIENTATION)



Code:

Open Points - Unirradiated
 Closed Points - Irradiated at $1.48 \times 10^{19} \text{ n/cm}^2$




FIGURE 5-12 TENSILE PROPERTIES FOR ZION UNIT 2 REACTOR VESSEL WELD METAL





FIGURE 5-13 FRACTURED TENSILE SPECIMENS FOR ZION UNIT 2 REACTOR VESSEL SHELL
PLATE C4007-1 (LONGITUDINAL ORIENTATION)





FIGURE 5-14 FRACTURED TENSILE SPECIMENS FOR ZION UNIT 2 REACTOR VESSEL WELD METAL




FIGURE 5-15 TYPICAL STRESS-STRAIN CURVE FOR TENSION SPECIMENS

6.0 RADIATION ANALYSIS AND NEUTRON DOSIMETRY

6.1 INTRODUCTION

Knowledge of the neutron environment within the reactor pressure vessel and surveillance capsule geometry is required as an integral part of LWR reactor pressure vessel surveillance programs for two reasons. First, in order to interpret the neutron radiation-induced material property changes observed in the test specimens, the neutron environment (energy spectrum, flux, fluence) to which the test specimens were exposed must be known. Second, in order to relate the changes observed in the test specimens to the present and future condition of the reactor vessel, a relationship must be established between the neutron environment at various positions within the reactor vessel and that experienced by the test specimens. The former requirement is normally met by employing a combination of rigorous analytical techniques and measurements obtained with passive neutron flux monitors contained in each of the surveillance capsules. The latter information is derived solely from analysis.

The use of fast neutron fluence ($E > 1.0$ MeV) to correlate measured materials properties changes to the neutron exposure of the material for light water reactor applications has traditionally been accepted for development of damage trend curves as well as for the implementation of trend curve data to assess vessel condition. In recent years, however, it has been suggested that an exposure model that accounts for differences in neutron energy spectra between surveillance capsule locations and positions within the vessel wall could lead to an improvement in the uncertainties associated with damage trend curves as well as to a more accurate evaluation of damage gradients through the pressure vessel wall.

Because of this potential shift away from a threshold fluence toward an energy dependent damage function for data correlation, ASTM Standard Practice E853, "Analysis and Interpretation of Light Water Reactor Surveillance Results," recommends reporting displacements per iron atom (dpa) along with fluence

($E > 1.0$ MeV) to provide a data base for future reference. The energy dependent dpa function to be used for this evaluation is specified in ASTM Standard Practice E693, "Characterizing Neutron Exposures in Ferritic Steels in Terms of Displacements per Atom." The application of the dpa parameter to the assessment of embrittlement gradients through the thickness of the pressure vessel wall has already been promulgated in Revision 2 to the Regulatory Guide 1.99, "Radiation Damage to Reactor Vessel Materials."

This section provides the results of the neutron dosimetry evaluations performed in conjunction with the analysis of test specimens contained in surveillance Capsule Y. Updated evaluations of dosimetry from prior surveillance capsule withdrawals are also presented to provide a complete data base for use in establishing the integrated exposure of the pressure vessel wall. These re-evaluations include data from Capsules U and T withdrawn at the conclusion of the first and fourth fuel cycles, respectively.

Fast neutron exposure parameters in terms of fast neutrons fluence ($E > 1.0$ Mev), fast neutron fluence ($E > 0.1$ Mev), and iron atom displacements (dpa) are established for the irradiation history. The analytical formalism relating the measured capsule exposures to the exposure of the vessel wall is described and used to project the integrated exposure of the vessel itself. Also, uncertainties associated with the derived exposure parameters are provided.

6.2 DISCRETE ORDINATES ANALYSIS

A plan view of the reactor geometry at the core midplane is shown in Figure 4-1. Eight irradiation capsules attached to the thermal shield are included in the reactor design to constitute the reactor vessel surveillance program. Four capsules are located symmetrically at azimuthal angles of 4° and 40° relative to the core cardinal axis as shown in Figure 4-1.

A plan view of a surveillance capsule holder attached to the thermal shield is shown in Figure 6-1. The stainless steel specimen containers are 1-inch square and approximately 38 inches in height. The containers are positioned

axially such that the specimens are centered on the core midplane, thus spanning the central 3 feet of the 12-foot high reactor core.

From a neutron transport standpoint, the surveillance capsule structures are significant. They have a marked effect on both the distribution of neutron flux and the neutron energy spectrum in the water annulus between the thermal shield and the reactor vessel. In order to properly determine the neutron environment at the test specimen locations, the capsules themselves must be included in the analytical model.

In performing the fast neutron exposure evaluations for the surveillance capsules and reactor vessel, two distinct sets of transport calculations were carried out. The first, a single computation in the conventional forward mode, was used primarily to obtain relative neutron energy distributions throughout the reactor geometry as well as to establish relative radial distributions of exposure parameters ($\phi(E > 1.0 \text{ MeV})$, $\phi(E > 0.1 \text{ MeV})$, and dpa) through the vessel wall. The neutron spectral information was required for the interpretation of neutron dosimetry withdrawn from the surveillance capsule as well as for the determination of exposure parameter ratios; i.e., $\text{dpa}/\phi(E > 1.0 \text{ MeV})$, within the pressure vessel geometry. The relative radial gradient information was required to permit the projection of measured exposure parameters to locations interior to the pressure vessel wall; i.e., the 1/4T, 1/2T, and 3/4T locations.

The second set of calculations consisted of a series of adjoint analyses relating the fast neutron flux ($E > 1.0 \text{ MeV}$) at surveillance capsule positions, and several azimuthal locations on the pressure vessel inner radius to neutron source distributions within the reactor core. The importance functions generated from these adjoint analyses provided the basis for all absolute exposure projections and comparison with measurement. These importance functions, when combined with cycle specific neutron source distributions, yielded absolute predictions of neutron exposure at the locations of interest for the first 10 cycles of irradiation; and established the means to perform similar predictions and dosimetry evaluations for all subsequent fuel cycles. It is important to note that the cycle specific neutron source distributions utilized in these analyses included not only

spatial variations of fission rates within the reactor core; but, also accounted for the effects of varying neutron yield per fission and fission spectrum introduced by the build-up of plutonium as the burnup of individual fuel assemblies increased.

The absolute cycle specific data from the adjoint evaluations together with relative neutron energy spectra and radial distribution information from the forward calculation provided the means to:

1. Evaluate neutron dosimetry obtained from surveillance capsule locations.
2. Extrapolate dosimetry results to key locations at the inner radius and through the thickness of the pressure vessel wall.
3. Enable a direct comparison of analytical prediction with measurement.
4. Establish a mechanism for projection of pressure vessel exposure as the design of each new fuel cycle evolves.

The forward transport calculation for the reactor model summarized in Figures 4-1 and 6-1 was carried out in R, θ geometry using the DOT two-dimensional discrete ordinates code [6] and the SAILOR cross-section library [7]. The SAILOR library is a 47 group ENDFB-IV based data set produced specifically for light water reactor applications. In these analyses anisotropic scattering was treated with a P_3 expansion of the cross-sections and the angular discretization was modeled with an S_8 order of angular quadrature.

The reference core power distribution utilized in the forward analysis was derived from statistical studies of long-term operation of Westinghouse 4-loop plants. Inherent in the development of this reference core power distribution is the use of an out-in fuel management strategy; i.e., fresh fuel on the core periphery. Furthermore, for the peripheral fuel assemblies, a 2σ uncertainty derived from the statistical evaluation of plant to plant and cycle to cycle variations in peripheral power was used. Since it is unlikely

that a single reactor would have a power distribution at the nominal +2 σ level for a large number of fuel cycles, the use of this reference distribution is expected to yield somewhat conservative results.

All adjoint analyses were also carried out using an S_8 order of angular quadrature and the P_3 cross-section approximation from the SAILOR library. Adjoint source locations were chosen at several azimuthal locations along the pressure vessel inner radius as well as the geometric center of each surveillance capsule. Again, these calculations were run in R, θ geometry to provide neutron source distribution importance functions for the exposure parameter of interest; in this case, $\phi (E > 1.0 \text{ MeV})$. Having the importance functions and appropriate core source distributions, the response of interest could be calculated as:

$$R(r, \theta) = \int_r \int_{\theta} \int_E I(r, \theta, E) S(r, \theta, E) r dr d\theta dE$$

- where: $R(r, \theta)$ = $\phi (E > 1.0 \text{ MeV})$ at radius r and azimuthal angle θ
- $I(r, \theta, E)$ = Adjoint importance function at radius, r , azimuthal angle θ , and neutron source energy E .
- $S(r, \theta, E)$ = Neutron source strength at core location r, θ and energy E .

Although the adjoint importance functions used in the Zion Unit 2 analysis were based on a response function defined by the threshold neutron flux ($E > 1.0 \text{ MeV}$), prior calculations have shown that, while the implementation of low leakage loading patterns significantly impact the magnitude and the spatial distribution of the neutron field, changes in the relative neutron energy spectrum are of second order. Thus, for a given location the ratio of $\text{dpa}/\phi (E > 1.0 \text{ MeV})$ is insensitive to changing core source distributions. In the application of these adjoint important functions to the Zion Unit 2 reactor, therefore, calculation of the iron displacement rates (dpa) and the neutron flux ($E > 0.1 \text{ MeV}$) were computed on a cycle specific basis by using $\text{dpa}/\phi (E > 1.0 \text{ MeV})$ and $\phi (E > 0.1 \text{ MeV})/\phi (E > 1.0 \text{ MeV})$ ratios from the forward analysis in conjunction with the cycle specific $\phi (E > 1.0 \text{ MeV})$ solutions from the individual adjoint evaluations.

The reactor core power distributions used in the plant specific adjoint calculations were taken from the fuel cycle design reports for the first ten operating cycles of Zion Unit 2 [8 thru 17].

Selected results from the neutron transport analyses performed for the Zion Unit 2 reactor are provided in Tables 6-1 through 6-5. The data listed in these tables establish the means for absolute comparisons of analysis and measurement for the capsule irradiation period and provide the means to correlate dosimetry results with the corresponding neutron exposure of the pressure vessel wall.

In Table 6-1, the calculated exposure parameters (ϕ ($E > 1.0$ MeV), ϕ ($E > 0.1$ MeV), and dpa) are given at the geometric center of the two surveillance capsule positions for both the design basis and the plant specific core power distributions. The plant specific data, based on the adjoint transport analysis, are meant to establish the absolute comparison of measurement with analysis. The design basis data derived from the forward calculation are provided as a point of reference against which plant specific fluence evaluations can be compared. Similar data is given in Table 6-2 for the pressure vessel inner radius. Again, the three pertinent exposure parameters are listed for both the design basis and the cycle 1 through 10 average plant specific power distributions. It is important to note that the data for the vessel inner radius were taken at the clad/base metal interface; and, thus, represent the maximum exposure levels of the vessel wall itself.

Radial gradient information for neutron flux ($E > 1.0$ MeV), neutron flux ($E > 0.1$ MeV), and iron atom displacement rate is given in Tables 6-3, 6-4, and 6-5, respectively. The data, obtained from the forward neutron transport calculation, are presented on a relative basis for each exposure parameter at several azimuthal locations. Exposure parameter distributions within the wall may be obtained by normalizing the calculated or projected exposure at the vessel inner radius to the gradient data given in Tables 6-3 through 6-5.

For example, the neutron flux ($E > 1.0$ MeV) at the 1/4T position on the 45° azimuth is given by:

$$\phi_{1/4T}(45^\circ) = \phi(220.27, 45^\circ) F(225.75, 45^\circ)$$

where $\phi_{1/4T}(45^\circ)$ = Projected neutron flux at the 1/4T position on the 45° azimuth

$\phi(220.27, 45^\circ)$ = Projected or calculated neutron flux at the vessel inner radius on the 45° azimuth.

$F(225.75, 45^\circ)$ = Relative radial distribution function from Table 6-3.

Similar expressions apply for exposure parameters in terms of $\phi(E > 0.1$ MeV) and dpa/sec.

6.3 NEUTRON DOSIMETRY

The passive neutron sensors included in the Zion Unit 2 surveillance program are listed in Table 6-6. Also given in Table 6-6 are the primary nuclear reactions and associated nuclear constants that were used in the evaluation of the neutron energy spectrum within the capsule and the subsequent determination of the various exposure parameters of interest ($\phi(E > 1.0$ MeV), $\phi(E > 0.1$ MeV), dpa).

The relative locations of the neutron sensors within the capsules are shown in Figure 4-2. The iron, nickel, copper, and cobalt-aluminum monitors, in wire form, were placed in holes drilled in spacers at several axial levels within the capsules. The cadmium-shielded neptunium and uranium fission monitors were accommodated within the dosimeter block located near the center of the capsule.

The use of passive monitors such as those listed in Table 6-6 does not yield a direct measure of the energy dependent flux level at the point of interest.

Rather, the activation or fission process is a measure of the integrated effect that the time- and energy-dependent neutron flux has on the target material over the course of the irradiation period. An accurate assessment of the average neutron flux level incident on the various monitors may be derived from the activation measurements only if the irradiation parameters are well known. In particular, the following variables are of interest:

- o The specific activity of each monitor.
- o The operating history of the reactor.
- o The energy response of the monitor.
- o The neutron energy spectrum at the monitor location.
- o The physical characteristics of the monitor.

The specific activity of each of the neutron monitors was determined using established ASTM procedures [18 through 31]. Following sample preparation and weighing, the activity of each monitor was determined by means of a lithium-drifted germanium, Ge(Li), gamma spectrometer. The irradiation history of the Zion Unit 2 reactor during cycles 1 through 10 was obtained from NUREG-0020, "Licensed Operating Reactors Status Summary Report" for the applicable period.

The irradiation history applicable to capsule Y is given in Table 6-7. Measured and saturated reaction product specific activities as well as measured full power reaction rates are listed in Table 6-8. Reaction rate values were derived using the pertinent data from Tables 6-6 and 6-7.

Values of key fast neutron exposure parameters were derived from the measured reaction rates using the FERRET least squares adjustment code [32]. The FERRET approach used the measured reaction rate data and the calculated neutron energy spectrum at the center of the surveillance capsule as input and proceeded to adjust a priori (calculated) group fluxes to produce a best fit (in a least squares sense) to the reaction rate data. The exposure parameters along with associated uncertainties were then obtained from the adjusted spectra.

In the FERRET evaluations, a log normal least-squares algorithm weights both the a priori values and the measured data in accordance with the assigned uncertainties and correlations. In general, the measured values f are linearly related to the flux ϕ by some response matrix A :

$$f_1(s, \alpha) = \sum_g A_{1g}(s) \phi_g^{(\alpha)}$$

where 1 indexes the measured values belonging to a single data set s , g designates the energy group and α delineates spectra that may be simultaneously adjusted. For example,

$$R_1 = \sum_g \sigma_{1g} \phi_g$$

relates a set of measured reaction rates R_1 to a single spectrum ϕ_g by the multigroup cross section σ_{1g} . (In this case, FERRET also adjusts the cross-sections.) The lognormal approach automatically accounts for the physical constraint of positive fluxes, even with the large assigned uncertainties.

In the FERRET analysis of the dosimetry data, the continuous quantities (i.e., fluxes and cross-sections) were approximated in 53 groups. The calculated fluxes from the discrete ordinates analysis were expanded into the FERRET group structure using the SAND-II code [33]. This procedure was carried out by first expanding the a priori spectrum into the SAND-II 620 group structure using a SPLINE interpolation procedure for interpolation in regions where group boundaries do not coincide. The 620-point spectrum was then easily collapsed to the group scheme used in FERRET.

The cross-sections were also collapsed into the 53 energy-group structure using SAND II with calculated spectra (as expanded to 620 groups) as weighting functions. The cross sections were taken from the ENDF/B-V dosimetry file. Uncertainty estimates and 53×53 covariance matrices were constructed for each cross section. Correlations between cross sections were neglected due to data and code limitations, but are expected to be unimportant.

For each set of data or a priori values, the inverse of the corresponding relative covariance matrix M is used as a statistical weight. In some cases, as for the cross sections, a multigroup covariance matrix is used. More often, a simple parameterized form is used:

$$M_{gg'} = R_N^2 + R_g R_{g'} P_{gg'}$$

where R_N specifies an overall fractional normalization uncertainty (i.e., complete correlation) for the corresponding set of values. The fractional uncertainties R_g specify additional random uncertainties for group g that are correlated with a correlation matrix:

$$P_{gg'} = (1 - \theta) \delta_{gg'} + \theta \exp \left[-\frac{(g-g')^2}{2\gamma^2} \right]$$

The first term specifies purely random uncertainties while the second term describes short-range correlations over a range γ (θ specifies the strength of the latter term.)

For the a priori calculated fluxes, a short-range correlation of $\gamma = 6$ groups was used. This choice implies that neighboring groups are strongly correlated when θ is close to 1. Strong long-range correlations (or anticorrelations) were justified based on information presented by R. E. Maerker [34]. Maerker's results are closely duplicated when $\gamma = 6$. For the integral reaction rate covariances, simple normalization and random uncertainties were combined as deduced from experimental uncertainties.

Results of the FERRET evaluation of the capsule γ dosimetry are given in Table 6-9. The data summarized in Table 6-9 indicated that the capsule received an integrated exposure of 1.48×10^{19} n/cm² ($E > 1.0$ MeV) with an associated uncertainty of $\pm 8\%$. Also reported are capsule exposures in terms of fluence ($E > 0.1$ MeV) and iron atom displacements (dpa). Summaries of the fit of the adjusted spectrum are provided in Table 6-10. In general, excellent results were achieved in the fits of the adjusted spectrum to the individual experimental reaction rates. The adjusted spectrum itself is tabulated in Table 6-11 for the FERRET 53 energy group structure.

A summary of the measured and calculated neutron exposure of capsule Y is presented in Table 6-12 along with the updated exposure evaluations for capsules T and U. This information is also shown graphically as a function of reactor full power operating time in Figure 6-2. The agreement between calculation and measurement is good for all exposure parameters in each of the capsules withdrawn to date. The measured data from the early capsules (T and U) exceed prediction by approximately 14%, whereas, the data from capsule Y falls roughly 7% below prediction. In general, the measured data tracks the predicted exposure at the capsule locations quite well and, therefore, the calculated values will be used in the assessment of the exposure of the vessel itself.

Neutron exposure projections at key locations on the pressure vessel inner radius are given in Table 6-13. Along with the current (9.18 EFPY) exposure projections are also provided for an exposure period of 20 EFPY and to end of vessel design life (32 EFPY). The time averaged exposure rates for low leakage fuel cycles were used to perform projections beyond the end of the cycle 1 through 10 exposure period.

In the calculation of exposure gradients for use in the development of heatup and cooldown curves for the Zion Unit 2 reactor coolant system, exposure projections to 20 EFPY and 32 EFPY were employed. Data based on both a fluence ($E > 1.0$ MeV) slope and a plant specific dpa slope through the vessel wall are provided in Table 6-14. In order to access RT_{NDT} vs. fluence trend curves, dpa equivalent fast neutron fluence levels for the 1/4T and 3/4T positions were defined by the relations

$$\Phi' (1/4T) = \Phi (\text{Surface}) \left\{ \frac{\text{dpa} (1/4T)}{\text{dpa} (\text{Surface})} \right\}$$

$$\Phi' (3/4T) = \Phi (\text{Surface}) \left\{ \frac{\text{dpa} (3/4T)}{\text{dpa} (\text{Surface})} \right\}$$

Using this approach results in the dpa equivalent fluence values listed in Table 6-14.

In Table 6-15 updated lead factors are listed for each of the Zion Unit 2 surveillance capsules. These data may be used as a guide in establishing future withdrawal schedules for the remaining capsules.

NOTE: ALL DIMENSIONS ARE IN CENTIMETERS




Figure 6-1 Plan View of a Reactor Vessel Surveillance Capsule.




Figure 6-2. Fast Neutron ($E > 1.0$ Mev) Fluence at the 40 Degree Surveillance Capsule Location as a Function of Full Power Operating Time

TABLE 6-1

CALCULATED FAST NEUTRON EXPOSURE PARAMETERS
AT THE SURVEILLANCE CAPSULE CENTER

| | ϕ (E > 1.0 Mev) | | ϕ (E > 0.1 Mev) | | dpa/sec | |
|-------------|-----------------------|-----------------------|-----------------------|-----------------------|------------------------|------------------------|
| | <u>Design Basis</u> | <u>Cycle 1-10</u> | <u>Design Basis</u> | <u>Cycle 1-10</u> | <u>Design Basis</u> | <u>Cycle 1-10</u> |
| 40° Capsule | 7.54×10^{10} | 5.45×10^{10} | 2.22×10^{11} | 1.63×10^{11} | 1.24×10^{-10} | 8.80×10^{-11} |
| 4° Capsule | 2.49×10^{10} | 1.86×10^{10} | 6.30×10^{10} | 4.71×10^{10} | 3.92×10^{-11} | 2.92×10^{-11} |

TABLE 6-2

CALCULATED FAST NEUTRON EXPOSURE PARAMETERS AT
THE PRESSURE VESSEL CLAD/BASE METAL INTERFACE

| | $\phi (E > 1.0 \text{ Mev})$ | | $\phi (E > 0.1 \text{ Mev})$ | | dpa/sec | |
|-----|------------------------------|-----------------------|------------------------------|-----------------------|------------------------|------------------------|
| | Design Basis | Cycle 1-10 | Design Basis | Cycle 1-10 | Design Basis | Cycle 1-10 |
| 45° | 2.49×10^{10} | 1.84×10^{10} | 6.64×10^{10} | 4.91×10^{10} | 4.06×10^{-11} | 3.00×10^{-11} |
| 30° | 1.61×10^{10} | 1.20×10^{10} | 4.13×10^{10} | 3.08×10^{10} | 2.60×10^{-11} | 1.94×10^{-11} |
| 15° | 1.30×10^{10} | 9.82×10^9 | 3.25×10^{10} | 2.46×10^{10} | 2.09×10^{-11} | 1.58×10^{-11} |
| 0° | 8.02×10^9 | 5.98×10^9 | 2.02×10^{10} | 1.51×10^{10} | 1.31×10^{-11} | 9.77×10^{-12} |

TABLE 6-3

RELATIVE RADIAL DISTRIBUTIONS OF NEUTRON FLUX ($E > 1.0$ MeV)
 WITHIN THE PRESSURE VESSEL WALL

| Radius (cm) | <u>0°</u> | <u>15°</u> | <u>30°</u> | <u>45°</u> |
|-----------------------|-----------|------------|------------|------------|
| 220.27 ⁽¹⁾ | 1.00 | 1.00 | 1.00 | 1.00 |
| 220.64 | 0.977 | 0.978 | 0.979 | 0.977 |
| 221.66 | 0.884 | 0.887 | 0.889 | 0.885 |
| 222.99 | 0.758 | 0.762 | 0.765 | 0.756 |
| 224.31 | 0.641 | 0.644 | 0.648 | 0.637 |
| 225.63 | 0.537 | 0.540 | 0.545 | 0.534 |
| 226.95 | 0.448 | 0.451 | 0.455 | 0.443 |
| 228.28 | 0.372 | 0.373 | 0.379 | 0.367 |
| 229.60 | 0.309 | 0.310 | 0.315 | 0.303 |
| 230.92 | 0.255 | 0.257 | 0.261 | 0.250 |
| 232.25 | 0.211 | 0.212 | 0.216 | 0.206 |
| 233.57 | 0.174 | 0.175 | 0.178 | 0.169 |
| 234.89 | 0.143 | 0.144 | 0.147 | 0.138 |
| 236.22 | 0.117 | 0.118 | 0.121 | 0.113 |
| 237.54 | 0.0961 | 0.0963 | 0.0989 | 0.0912 |
| 238.86 | 0.0783 | 0.0783 | 0.0807 | 0.0736 |
| 240.19 | 0.0635 | 0.0632 | 0.0656 | 0.0584 |
| 241.51 | 0.0511 | 0.0501 | 0.0519 | 0.0454 |
| 242.17 ⁽²⁾ | 0.0483 | 0.0469 | 0.0487 | 0.0422 |

NOTES: 1) Base Metal Inner Radius
 2) Base Metal Outer Radius

TABLE 6-4

RELATIVE RADIAL DISTRIBUTIONS OF NEUTRON FLUX ($E > 0.1$ MeV)
 WITHIN THE PRESSURE VESSEL WALL

| <u>Radius</u> <u>(cm)</u> | <u>0°</u> | <u>15°</u> | <u>30°</u> | <u>45°</u> |
|------------------------------|-----------|------------|------------|------------|
| 220.27 ⁽¹⁾ | 1.00 | 1.00 | 1.00 | 1.00 |
| 220.64 | 1.00 | 1.00 | 1.00 | 1.00 |
| 221.66 | 1.00 | 0.996 | 1.00 | 0.994 |
| 222.99 | 0.965 | 0.958 | 0.968 | 0.953 |
| 224.31 | 0.916 | 0.906 | 0.919 | 0.898 |
| 225.63 | 0.861 | 0.849 | 0.865 | 0.838 |
| 226.95 | 0.803 | 0.790 | 0.809 | 0.777 |
| 228.28 | 0.746 | 0.732 | 0.752 | 0.717 |
| 229.60 | 0.689 | 0.675 | 0.695 | 0.657 |
| 230.92 | 0.633 | 0.619 | 0.640 | 0.600 |
| 232.25 | 0.578 | 0.565 | 0.586 | 0.544 |
| 233.57 | 0.525 | 0.513 | 0.534 | 0.490 |
| 234.89 | 0.474 | 0.463 | 0.483 | 0.437 |
| 236.22 | 0.424 | 0.414 | 0.433 | 0.387 |
| 237.54 | 0.375 | 0.367 | 0.385 | 0.338 |
| 238.86 | 0.328 | 0.322 | 0.338 | 0.291 |
| 240.19 | 0.283 | 0.277 | 0.292 | 0.244 |
| 241.51 | 0.239 | 0.232 | 0.245 | 0.196 |
| 242.17 ⁽²⁾ | 0.229 | 0.220 | 0.232 | 0.183 |

NOTES: 1) Base Metal Inner Radius

2) Base Metal Outer Radius

TABLE 6-5

RELATIVE RADIAL DISTRIBUTIONS OF IRON DISPLACEMENT RATE (dpa)
WITHIN THE PRESSURE VESSEL WALL

| <u>Radius</u> <u>(cm)</u> | <u>0°</u> | <u>15°</u> | <u>30°</u> | <u>45°</u> |
|------------------------------|-----------|------------|------------|------------|
| 220.27 ⁽¹⁾ | 1.00 | 1.00 | 1.00 | 1.00 |
| 220.64 | 0.983 | 0.983 | 0.984 | 0.983 |
| 221.66 | 0.913 | 0.914 | 0.918 | 0.915 |
| 222.99 | 0.818 | 0.819 | 0.827 | 0.820 |
| 224.31 | 0.728 | 0.728 | 0.739 | 0.730 |
| 225.63 | 0.647 | 0.646 | 0.659 | 0.647 |
| 226.95 | 0.574 | 0.573 | 0.587 | 0.573 |
| 228.28 | 0.510 | 0.507 | 0.523 | 0.507 |
| 229.60 | 0.453 | 0.450 | 0.466 | 0.449 |
| 230.92 | 0.402 | 0.399 | 0.414 | 0.397 |
| 232.25 | 0.356 | 0.353 | 0.368 | 0.349 |
| 233.57 | 0.315 | 0.312 | 0.327 | 0.307 |
| 234.89 | 0.277 | 0.275 | 0.289 | 0.269 |
| 236.22 | 0.243 | 0.241 | 0.254 | 0.233 |
| 237.54 | 0.212 | 0.210 | 0.222 | 0.201 |
| 238.86 | 0.182 | 0.181 | 0.192 | 0.170 |
| 240.19 | 0.155 | 0.154 | 0.164 | 0.141 |
| 241.51 | 0.131 | 0.128 | 0.137 | 0.113 |
| 242.17 ⁽²⁾ | 0.125 | 0.122 | 0.130 | 0.106 |

NOTES: 1) Base Metal Inner Radius
2) Base Metal Outer Radius

TABLE 6-6

NUCLEAR PARAMETERS FOR NEUTRON FLUX MONITORS

| <u>Monitor Material</u> | <u>Reaction of Interest</u> | <u>Target Weight Fraction</u> | <u>Response Range</u> | <u>Product Half-Life</u> | <u>Fission Yield (%)</u> |
|-------------------------|---|-------------------------------|-----------------------|--------------------------|--------------------------|
| Copper | $^{63}\text{Cu} (n, \alpha) ^{60}\text{Co}$ | 0.6917 | E > 4.7 MeV | 5.272 yrs | |
| Iron | $^{54}\text{Fe} (n, p) ^{54}\text{Mn}$ | 0.0582 | E > 1.0 MeV | 312.2 days | |
| Nickel | $^{58}\text{Ni} (n, p) ^{58}\text{Co}$ | 0.6830 | E > 1.0 MeV | 70.90 days | |
| Uranium-238* | $^{238}\text{U} (n, f) ^{137}\text{Cs}$ | 1.0 | E > 0.4 MeV | 30.12 yrs | 5.99 |
| Neptunium-237* | $^{237}\text{Np} (n, f) ^{137}\text{Cs}$ | 1.0 | E > 0.08 MeV | 30.12 yrs | 6.50 |
| Cobalt-Aluminum* | $^{59}\text{Co} (n, \gamma) ^{60}\text{Co}$ | 0.0015 | 0.4ev < E < 0.015 MeV | 5.272 yrs | |
| Cobalt-Aluminum* | $^{59}\text{Co} (n, \gamma) ^{60}\text{Co}$ | 0.0015 | E < 0.015 MeV | 5.272 yrs | |

*Denotes that monitor is cadmium shielded.

TABLE 6-7

IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE Y

| <u>Month</u> | <u>Year</u> | <u>PJ (MWh)</u> | <u>PJ/PMAX</u> | <u>Irradiation Time (days)</u> | <u>Decay Time (days)</u> |
|--------------|-------------|---------------------|----------------|--|----------------------------------|
| 12 | 1973 | 305.5 | 0.0940 | 8 | 5616 |
| 1 | 1974 | 394.2 | 0.1213 | 31 | 5585 |
| 2 | 1974 | 436.4 | 0.1343 | 28 | 5557 |
| 3 | 1974 | 394.2 | 0.1213 | 31 | 5526 |
| 4 | 1974 | 219.0 | 0.0674 | 30 | 5496 |
| 5 | 1974 | 0.0 | 0.0000 | 31 | 5465 |
| 6 | 1974 | 0.0 | 0.0000 | 30 | 5435 |
| 7 | 1974 | 0.0 | 0.0000 | 31 | 5404 |
| 8 | 1974 | 76.9 | 0.0237 | 31 | 5373 |
| 9 | 1974 | 998.0 | 0.3071 | 30 | 5343 |
| 10 | 1974 | 849.6 | 0.2614 | 31 | 5312 |
| 11 | 1974 | 2243.2 | 0.6902 | 30 | 5282 |
| 12 | 1974 | 1073.5 | 0.3303 | 31 | 5251 |
| 1 | 1975 | 1637.2 | 0.5037 | 31 | 5220 |
| 2 | 1975 | 1765.6 | 0.5433 | 28 | 5192 |
| 3 | 1975 | 1776.8 | 0.5467 | 31 | 5161 |
| 4 | 1975 | 1550.6 | 0.4771 | 30 | 5131 |
| 5 | 1975 | 1950.6 | 0.6002 | 31 | 5100 |
| 6 | 1975 | 452.0 | 0.1391 | 30 | 5070 |
| 7 | 1975 | 2631.2 | 0.8096 | 31 | 5039 |
| 8 | 1975 | 2434.3 | 0.7490 | 31 | 5008 |
| 9 | 1975 | 635.6 | 0.1956 | 30 | 4978 |
| 10 | 1975 | 2366.4 | 0.7281 | 31 | 4947 |
| 11 | 1975 | 2499.3 | 0.7690 | 30 | 4917 |
| 12 | 1975 | 2321.1 | 0.7142 | 31 | 4886 |
| 1 | 1976 | 925.4 | 0.2847 | 31 | 4855 |
| 2 | 1976 | 1269.8 | 0.3907 | 29 | 4826 |
| 3 | 1976 | 2764.6 | 0.8506 | 31 | 4795 |
| 4 | 1976 | 31.4 | 0.0097 | 30 | 4765 |
| 5 | 1976 | 1754.8 | 0.5399 | 31 | 4734 |
| 6 | 1976 | 1612.0 | 0.4960 | 30 | 4704 |
| 7 | 1976 | 3093.1 | 0.9517 | 31 | 4673 |
| 8 | 1976 | 2351.3 | 0.7235 | 31 | 4642 |
| 9 | 1976 | 1510.4 | 0.4647 | 30 | 4612 |
| 10 | 1976 | 122.2 | 0.0376 | 31 | 4581 |
| 11 | 1976 | 3131.5 | 0.9635 | 30 | 4551 |
| 12 | 1976 | 2522.3 | 0.7761 | 31 | 4520 |

TABLE 6-7 - cont'd

IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE Y

| <u>Month</u> | <u>Year</u> | <u>PJ (MW)</u> | <u>PJ/PMAX</u> | <u>Irradiation Time (days)</u> | <u>Decay Time (days)</u> |
|--------------|-------------|--------------------|----------------|--|----------------------------------|
| 1 | 1977 | 524.3 | 0.1613 | 31 | 4489 |
| 2 | 1977 | 0.0 | 0.0000 | 28 | 4461 |
| 3 | 1977 | 162.8 | 0.0501 | 31 | 4430 |
| 4 | 1977 | 2645.5 | 0.8140 | 30 | 4400 |
| 5 | 1977 | 3153.0 | 0.9702 | 31 | 4369 |
| 6 | 1977 | 2882.8 | 0.8870 | 30 | 4339 |
| 7 | 1977 | 2762.2 | 0.8499 | 31 | 4308 |
| 8 | 1977 | 3190.4 | 0.9817 | 31 | 4277 |
| 9 | 1977 | 5227.7 | 0.9932 | 30 | 4247 |
| 10 | 1977 | 3084.2 | 0.9490 | 31 | 4216 |
| 11 | 1977 | 3062.7 | 0.9424 | 30 | 4186 |
| 12 | 1977 | 2848.2 | 0.8764 | 31 | 4155 |
| 1 | 1978 | 2635.6 | 0.8110 | 31 | 4124 |
| 2 | 1978 | 220.9 | 0.0680 | 28 | 4096 |
| 3 | 1978 | 0.0 | 0.0000 | 31 | 4065 |
| 4 | 1978 | 1248.9 | 0.3843 | 30 | 4035 |
| 5 | 1978 | 3180.9 | 0.9787 | 31 | 4004 |
| 6 | 1978 | 3127.9 | 0.9624 | 30 | 3974 |
| 7 | 1978 | 3122.1 | 0.9606 | 31 | 3943 |
| 8 | 1978 | 3234.1 | 0.9951 | 31 | 3912 |
| 9 | 1978 | 3147.3 | 0.9684 | 30 | 3882 |
| 10 | 1978 | 3090.1 | 0.9508 | 31 | 3851 |
| 11 | 1978 | 3239.6 | 0.9968 | 30 | 3821 |
| 12 | 1978 | 3158.3 | 0.9718 | 31 | 3790 |
| 1 | 1979 | 2785.2 | 0.8570 | 31 | 3759 |
| 2 | 1979 | 1362.4 | 0.4192 | 28 | 3731 |
| 3 | 1979 | 312.8 | 0.0962 | 31 | 3700 |
| 4 | 1979 | 947.9 | 0.2917 | 30 | 3670 |
| 5 | 1979 | 2725.3 | 0.8385 | 31 | 3639 |
| 6 | 1979 | 2731.8 | 0.8406 | 30 | 3609 |
| 7 | 1979 | 2780.2 | 0.8554 | 31 | 3578 |
| 8 | 1979 | 2786.3 | 0.8573 | 31 | 3547 |
| 9 | 1979 | 2843.1 | 0.8748 | 30 | 3517 |
| 10 | 1979 | 1798.7 | 0.5534 | 31 | 3486 |
| 11 | 1979 | 0.0 | 0.0000 | 30 | 3456 |
| 12 | 1979 | 0.0 | 0.0000 | 31 | 3425 |

TABLE 6-7 - cont'd

IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE Y

| <u>Month</u> | <u>Year</u> | <u>PJ (MH)</u> | <u>PJ/PMAX</u> | <u>Irradiation Time (days)</u> | <u>Decay Time (days)</u> |
|--------------|-------------|--------------------|----------------|--|----------------------------------|
| 1 | 1980 | 1069.0 | 0.3289 | 31 | 3394 |
| 2 | 1980 | 3131.4 | 0.9635 | 29 | 3365 |
| 3 | 1980 | 3175.6 | 0.9771 | 31 | 3334 |
| 4 | 1980 | 2745.4 | 0.8448 | 30 | 3304 |
| 5 | 1980 | 91.2 | 0.0281 | 31 | 3273 |
| 6 | 1980 | 0.0 | 0.0000 | 30 | 3243 |
| 7 | 1980 | 302.1 | 0.0929 | 31 | 3212 |
| 8 | 1980 | 2633.7 | 0.8104 | 31 | 3181 |
| 9 | 1980 | 2720.5 | 0.8371 | 30 | 3151 |
| 10 | 1980 | 2997.7 | 0.9224 | 31 | 3120 |
| 11 | 1980 | 2572.4 | 0.7915 | 30 | 3090 |
| 12 | 1980 | 2509.3 | 0.7721 | 31 | 3059 |
| 1 | 1981 | 2812.4 | 0.8653 | 31 | 3028 |
| 2 | 1981 | 2966.1 | 0.9126 | 28 | 3000 |
| 3 | 1981 | 2854.6 | 0.8783 | 31 | 2969 |
| 4 | 1981 | 2906.9 | 0.8944 | 30 | 2939 |
| 5 | 1981 | 2810.3 | 0.8647 | 31 | 2908 |
| 6 | 1981 | 2962.6 | 0.9116 | 30 | 2878 |
| 7 | 1981 | 2777.4 | 0.8546 | 31 | 2847 |
| 8 | 1981 | 2164.0 | 0.6658 | 31 | 2816 |
| 9 | 1981 | 566.5 | 0.1743 | 30 | 2786 |
| 10 | 1981 | 0.0 | 0.0000 | 31 | 2755 |
| 11 | 1981 | 6.3 | 0.0019 | 30 | 2725 |
| 12 | 1981 | 1485.9 | 0.4572 | 31 | 2694 |
| 1 | 1982 | 1533.6 | 0.4719 | 31 | 2663 |
| 2 | 1982 | 342.9 | 0.1055 | 28 | 2635 |
| 3 | 1982 | 543.7 | 0.1673 | 31 | 2604 |
| 4 | 1982 | 2120.3 | 0.6524 | 30 | 2574 |
| 5 | 1982 | 3098.8 | 0.9535 | 31 | 2543 |
| 6 | 1982 | 2071.6 | 0.6374 | 30 | 2513 |
| 7 | 1982 | 2730.2 | 0.8401 | 31 | 2482 |
| 8 | 1982 | 3122.9 | 0.9609 | 31 | 2451 |
| 9 | 1982 | 699.2 | 0.2151 | 30 | 2421 |
| 10 | 1982 | 795.4 | 0.2447 | 31 | 2390 |
| 11 | 1982 | 3229.7 | 0.9937 | 30 | 2360 |
| 12 | 1982 | 2945.8 | 0.9064 | 31 | 2329 |

TABLE 6-7 - cont'd

IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE Y

| <u>Month</u> | <u>Year</u> | <u>PJ (MW)</u> | <u>PJ/PMAX</u> | <u>Irradiation Time (days)</u> | <u>Decay Time (days)</u> |
|--------------|-------------|--------------------|----------------|--|----------------------------------|
| 1 | 1983 | 3080.4 | 0.9478 | 31 | 2298 |
| 2 | 1983 | 2557.5 | 0.7869 | 28 | 2270 |
| 3 | 1983 | 0.0 | 0.0000 | 31 | 2239 |
| 4 | 1983 | 0.0 | 0.0000 | 30 | 2209 |
| 5 | 1983 | 207.5 | 0.0638 | 31 | 2178 |
| 6 | 1983 | 3001.5 | 0.9235 | 30 | 2148 |
| 7 | 1983 | 3066.5 | 0.9435 | 31 | 2117 |
| 8 | 1983 | 3021.4 | 0.9297 | 31 | 2086 |
| 9 | 1983 | 3222.9 | 0.9917 | 30 | 2056 |
| 10 | 1983 | 3227.7 | 0.9932 | 31 | 2025 |
| 11 | 1983 | 2835.5 | 0.8725 | 30 | 1995 |
| 12 | 1983 | 3226.5 | 0.9928 | 31 | 1964 |
| 1 | 1984 | 2928.0 | 0.9009 | 31 | 1933 |
| 2 | 1984 | 3226.5 | 0.9928 | 29 | 1904 |
| 3 | 1984 | 2393.6 | 0.7365 | 31 | 1873 |
| 4 | 1984 | 0.0 | 0.0000 | 30 | 1843 |
| 5 | 1984 | 0.0 | 0.0000 | 31 | 1812 |
| 6 | 1984 | 0.0 | 0.0000 | 30 | 1782 |
| 7 | 1984 | 1793.9 | 0.5520 | 31 | 1751 |
| 8 | 1984 | 3080.5 | 0.9479 | 31 | 1720 |
| 9 | 1984 | 3165.4 | 0.9740 | 30 | 1690 |
| 10 | 1984 | 3214.7 | 0.9891 | 31 | 1659 |
| 11 | 1984 | 3218.7 | 0.9904 | 30 | 1629 |
| 12 | 1984 | 3174.1 | 0.9766 | 31 | 1598 |
| 1 | 1985 | 3163.2 | 0.9733 | 31 | 1567 |
| 2 | 1985 | 3194.7 | 0.9830 | 28 | 1539 |
| 3 | 1985 | 3055.3 | 0.9401 | 31 | 1508 |
| 4 | 1985 | 3206.3 | 0.9866 | 30 | 1478 |
| 5 | 1985 | 3065.5 | 0.9432 | 31 | 1447 |
| 6 | 1985 | 2983.3 | 0.9179 | 30 | 1417 |
| 7 | 1985 | 2300.5 | 0.7078 | 31 | 1386 |
| 8 | 1985 | 1637.9 | 0.5040 | 31 | 1355 |
| 9 | 1985 | 182.4 | 0.0561 | 30 | 1325 |
| 10 | 1985 | 0.0 | 0.0000 | 31 | 1294 |
| 11 | 1985 | 0.0 | 0.0000 | 30 | 1264 |
| 12 | 1985 | 0.0 | 0.0000 | 31 | 1233 |

TABLE 6-7 - cont'd

IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE Y

| <u>Month</u> | <u>Year</u> | <u>PJ (MH)</u> | <u>PJ/PMAX</u> | <u>Irradiation Time (days)</u> | <u>Decay Time (days)</u> |
|--------------|-------------|--------------------|----------------|--|----------------------------------|
| 1 | 1986 | 0.0 | 0.0000 | 31 | 1202 |
| 2 | 1986 | 2169.0 | 0.6674 | 28 | 1174 |
| 3 | 1986 | 2813.0 | 0.8655 | 31 | 1143 |
| 4 | 1986 | 3188.0 | 0.9809 | 30 | 1113 |
| 5 | 1986 | 3043.7 | 0.9365 | 31 | 1082 |
| 6 | 1986 | 2788.8 | 0.8581 | 30 | 1052 |
| 7 | 1986 | 1737.8 | 0.5347 | 31 | 1021 |
| 8 | 1986 | 3216.8 | 0.9898 | 31 | 990 |
| 9 | 1986 | 2838.3 | 0.8733 | 30 | 960 |
| 10 | 1986 | 3217.9 | 0.9901 | 31 | 929 |
| 11 | 1986 | 3227.3 | 0.9930 | 30 | 899 |
| 12 | 1986 | 3226.5 | 0.9928 | 31 | 868 |
| 1 | 1987 | 3226.7 | 0.9928 | 31 | 837 |
| 2 | 1987 | 2870.9 | 0.8833 | 28 | 809 |
| 3 | 1987 | 2007.2 | 0.6176 | 31 | 778 |
| 4 | 1987 | 0.0 | 0.0000 | 30 | 748 |
| 5 | 1987 | 0.0 | 0.0000 | 31 | 717 |
| 6 | 1987 | 0.0 | 0.0000 | 30 | 687 |
| 7 | 1987 | 0.0 | 0.0000 | 31 | 656 |
| 8 | 1987 | 1937.8 | 0.5962 | 31 | 625 |
| 9 | 1987 | 3168.4 | 0.9711 | 30 | 595 |
| 10 | 1987 | 2653.4 | 0.8164 | 31 | 564 |
| 11 | 1987 | 3151.4 | 0.9697 | 30 | 534 |
| 12 | 1987 | 3049.2 | 0.9382 | 31 | 503 |
| 1 | 1988 | 3142.8 | 0.9670 | 31 | 472 |
| 2 | 1988 | 3121.3 | 0.9604 | 29 | 443 |
| 3 | 1988 | 2920.1 | 0.8985 | 31 | 412 |
| 4 | 1988 | 2906.9 | 0.8944 | 30 | 382 |
| 5 | 1988 | 3082.5 | 0.9484 | 31 | 351 |
| 6 | 1988 | 3176.0 | 0.9772 | 30 | 321 |
| 7 | 1988 | 3214.1 | 0.9889 | 31 | 290 |
| 8 | 1988 | 2694.2 | 0.8290 | 31 | 259 |
| 9 | 1988 | 3166.3 | 0.9742 | 30 | 229 |
| 10 | 1988 | 1950.3 | 0.6001 | 13 | 216 |

TABLE 6-8

MEASURED SENSOR ACTIVITIES AND REACTION RATES

| <u>Monitor and Axial Location</u> | <u>Measured Activity (dis/sec-gm)</u> | <u>Adjusted Saturated Activity (dis/sec-gm)</u> | <u>Reaction Rate (RPS/NUCLEUS)</u> |
|-----------------------------------|---------------------------------------|---|------------------------------------|
| <u>Cu-63 (n,α) Co-60</u> | | | |
| Middle | 1.32×10^5 | 2.78×10^5 | 4.30×10^{-17} |
| Bottom-Middle | 1.36×10^5 | 2.86×10^5 | |
| Average | 1.34×10^5 | 2.82×10^5 | |
| <u>Fe-54(n,p) Mn-54</u> | | | |
| Top | 1.10×10^6 | 2.52×10^6 | 4.04×10^{-15} |
| Top-Middle | 1.12×10^6 | 2.56×10^6 | |
| Middle | 1.08×10^6 | 2.47×10^6 | |
| Bottom-Middle | 1.14×10^6 | 2.61×10^6 | |
| Bottom | 1.10×10^6 | 2.52×10^6 | |
| Average | 1.11×10^6 | 2.54×10^6 | |
| <u>Ni-58 (n,p) Co-58</u> | | | |
| Top-Middle | 4.22×10^6 | 3.94×10^7 | 5.65×10^{-15} |
| Middle | 4.21×10^6 | 3.93×10^7 | |
| Bottom-Middle | 4.31×10^6 | 4.02×10^7 | |
| Average | 4.25×10^6 | 3.96×10^7 | |
| <u>U-238 (n,f) Cs-137 (Cd)</u> | | | |
| Middle | 4.09×10^5 | 2.31×10^6 | 1.52×10^{-14} |

TABLE 6-8

MEASURED SENSOR ACTIVITIES AND REACTION RATES - cont'd

| <u>Monitor and Axial Location</u> | <u>Measured Activity (dis/sec-gm)</u> | <u>Saturated Activity (dis/sec-gm)</u> | <u>Reaction Rate (RPS/NUCLEUS)</u> |
|---|---|--|--|
| <u>Np-237(n,f) Cs-137 (Cd)</u> | | | |
| Middle | 3.88×10^6 | 2.19×10^7 | 1.33×10^{-13} |
| <u>Co-59 (n,γ) Co-60 (Cd)</u> | | | |
| Top | 1.23×10^7 | 2.47×10^7 | 1.61×10^{-12} |
| Average | 1.23×10^7 | 2.47×10^7 | |

TABLE 6-9

SUMMARY OF NEUTRON DOSIMETRY RESULTS

| | <u>TIME AVERAGED EXPOSURE RATES</u> | |
|---|-------------------------------------|------------|
| ϕ (E > 1.0 MeV) {n/cm ² -sec} | 5.10×10^{10} | $\pm 8\%$ |
| ϕ (E > 0.1 MeV) {n/cm ² -sec} | 1.64×10^{11} | $\pm 15\%$ |
| dpa/sec | 8.47×10^{-11} | $\pm 10\%$ |
| | <u>INTEGRATED CAPSULE EXPOSURE</u> | |
| ϕ (E > 1.0 MeV) {n/cm ² } | 1.48×10^{19} | $\pm 8\%$ |
| ϕ (E > 0.1 MeV) {n/cm ² } | 4.76×10^{19} | $\pm 15\%$ |
| dpa | 2.45×10^{-2} | $\pm 10\%$ |

NOTE: Total Irradiation Time = 9.18 EFPY

TABLE 6-10

COMPARISON OF MEASURED AND FERRET CALCULATED
REACTION RATES AT THE SURVEILLANCE CAPSULE CENTER

| <u>Reaction</u> | <u>Measured</u> | <u>Adjusted Calculation</u> | <u>C/M</u> |
|---------------------------------|------------------------|---------------------------------|------------|
| Cu-63 (n, α) Co-60 | 4.30×10^{-17} | 4.34×10^{-17} | 1.01 |
| Fe-54 (n,p) Mn-54 | 4.04×10^{-15} | 3.98×10^{-15} | 0.98 |
| Ni-58 (n,p) Co-58 | 5.65×10^{-15} | 5.49×10^{-15} | 0.97 |
| U-238 (n,f) Cs-137 (Cd) | 1.52×10^{-14} | 1.77×10^{-14} | 1.16 |
| Np-237 (n,f) Cs-137 (Cd) | 1.33×10^{-13} | 1.36×10^{-13} | 1.02 |
| Co-59 (n, γ) Co-60 (Cd) | 1.61×10^{-12} | 1.59×10^{-12} | 0.99 |

TABLE 6-11

ADJUSTED NEUTRON ENERGY SPECTRUM AT
THE SURVEILLANCE CAPSULE CENTER

| <u>Group</u> | <u>Energy (Mev)</u> | <u>Adjusted Flux (n/cm²-sec)</u> | <u>Group</u> | <u>Energy (Mev)</u> | <u>Adjusted Flux (n/cm²-sec)</u> |
|--------------|-----------------------|---|--------------|-----------------------|---|
| 1 | 1.73x10 ¹ | 6.45x10 ⁶ | 28 | 9.12x10 ⁻³ | 7.63x10 ⁹ |
| 2 | 1.49x10 ¹ | 1.49x10 ⁷ | 29 | 5.53x10 ⁻³ | 9.16x10 ⁹ |
| 3 | 1.35x10 ¹ | 5.49x10 ⁷ | 30 | 3.36x10 ⁻³ | 2.89x10 ⁹ |
| 4 | 1.16x10 ¹ | 1.23x10 ⁸ | 31 | 2.84x10 ⁻³ | 2.79x10 ⁹ |
| 5 | 1.00x10 ¹ | 2.71x10 ⁸ | 32 | 2.40x10 ⁻³ | 2.75x10 ⁹ |
| 6 | 8.61x10 ⁰ | 4.63x10 ⁸ | 33 | 2.04x10 ⁻³ | 8.24x10 ⁹ |
| 7 | 7.41x10 ⁰ | 1.07x10 ⁹ | 34 | 1.23x10 ⁻³ | 8.45x10 ⁹ |
| 8 | 6.07x10 ⁰ | 1.54x10 ⁹ | 35 | 7.49x10 ⁻⁴ | 8.71x10 ⁹ |
| 9 | 4.97x10 ⁰ | 3.10x10 ⁹ | 36 | 4.54x10 ⁻⁴ | 8.98x10 ⁹ |
| 10 | 3.68x10 ⁰ | 3.68x10 ⁹ | 37 | 2.75x10 ⁻⁴ | 9.70x10 ⁹ |
| 11 | 2.87x10 ⁰ | 6.92x10 ⁹ | 38 | 1.67x10 ⁻⁴ | 1.23x10 ¹⁰ |
| 12 | 2.23x10 ⁰ | 7.98x10 ⁹ | 39 | 1.01x10 ⁻⁴ | 1.03x10 ¹⁰ |
| 13 | 1.74x10 ⁰ | 9.78x10 ⁹ | 40 | 6.14x10 ⁻⁵ | 9.97x10 ⁹ |
| 14 | 1.35x10 ⁰ | 9.21x10 ⁹ | 41 | 3.73x10 ⁻⁵ | 9.50x10 ⁹ |
| 15 | 1.11x10 ⁰ | 1.49x10 ¹⁰ | 42 | 2.26x10 ⁻⁵ | 8.99x10 ⁹ |
| 16 | 8.21x10 ⁻¹ | 1.52x10 ¹⁰ | 43 | 1.37x10 ⁻⁵ | 8.54x10 ⁹ |
| 17 | 6.39x10 ⁻¹ | 1.47x10 ¹⁰ | 44 | 8.32x10 ⁻⁶ | 8.11x10 ⁹ |
| 18 | 4.98x10 ⁻¹ | 1.04x10 ¹⁰ | 45 | 5.04x10 ⁻⁶ | 7.67x10 ⁹ |
| 19 | 3.88x10 ⁻¹ | 1.27x10 ¹⁰ | 46 | 3.06x10 ⁻⁶ | 7.29x10 ⁹ |
| 20 | 3.02x10 ⁻¹ | 1.66x10 ¹⁰ | 47 | 1.86x10 ⁻⁶ | 6.85x10 ⁹ |
| 21 | 1.83x10 ⁻¹ | 1.51x10 ¹⁰ | 48 | 1.13x10 ⁻⁶ | 5.91x10 ⁹ |
| 22 | 1.11x10 ⁻¹ | 1.23x10 ¹⁰ | 49 | 6.83x10 ⁻⁷ | 5.73x10 ⁹ |
| 23 | 6.74x10 ⁻² | 9.58x10 ⁹ | 50 | 4.14x10 ⁻⁷ | 8.60x10 ⁹ |
| 24 | 4.09x10 ⁻² | 6.48x10 ⁹ | 51 | 2.51x10 ⁻⁷ | 9.47x10 ⁹ |
| 25 | 2.55x10 ⁻² | 6.21x10 ⁹ | 52 | 1.52x10 ⁻⁷ | 1.05x10 ¹⁰ |
| 26 | 1.99x10 ⁻² | 4.22x10 ⁹ | 53 | 9.24x10 ⁻⁸ | 3.20x10 ¹⁰ |
| 27 | 1.50x10 ⁻² | 6.32x10 ⁹ | | | |

NOTE: Tabulated energy levels represent the upper energy of each group.

TABLE 6-12

COMPARISON OF CALCULATED AND MEASURED
EXPOSURE LEVELS FOR SURVEILLANCE CAPSULE

| | <u>CAPSULE Y</u> | | |
|--|-----------------------|-----------------------|------------|
| | <u>Calculated</u> | <u>Measured</u> | <u>C/M</u> |
| $\Phi(E > 1.0 \text{ MeV}) \{n/cm^2\}$ | 1.58×10^{19} | 1.48×10^{19} | 1.07 |
| $\Phi(E > 0.1 \text{ MeV}) \{n/cm^2\}$ | 4.71×10^{19} | 4.76×10^{19} | 0.99 |
| dpa | 2.55×10^{-2} | 2.46×10^{-2} | 1.04 |
| | <u>CAPSULE T</u> | | |
| | <u>Calculated</u> | <u>Measured</u> | <u>C/M</u> |
| $\Phi(E > 1.0 \text{ MeV}) \{n/cm^2\}$ | 6.70×10^{18} | 7.81×10^{18} | 0.86 |
| $\Phi(E > 0.1 \text{ MeV}) \{n/cm^2\}$ | 2.00×10^{19} | 2.51×10^{19} | 0.80 |
| dpa | 1.08×10^{-2} | 1.29×10^{-2} | 0.84 |
| | <u>CAPSULE U</u> | | |
| | <u>Calculated</u> | <u>Measured</u> | <u>C/M</u> |
| $\Phi(E > 1.0 \text{ MeV}) \{n/cm^2\}$ | 2.34×10^{18} | 2.73×10^{18} | 0.86 |
| $\Phi(E > 0.1 \text{ MeV}) \{n/cm^2\}$ | 6.98×10^{18} | 8.56×10^{18} | 0.82 |
| dpa | 3.78×10^{-2} | 4.43×10^{-3} | 0.85 |

TABLE 6-13
 NEUTRON EXPOSURE PROJECTIONS AT KEY LOCATIONS
 ON THE PRESSURE VESSEL CLAD/BASE METAL INTERFACE

| | AZIMUTHAL ANGLE | | | |
|--|-------------------------|-------------------------|-------------------------|-------------------------|
| | <u>0°</u> | <u>15°</u> | <u>30°</u> | <u>45°</u> |
| <u>9.18 EFPY</u> | | | | |
| Φ(E > 1.0 MeV) (n/cm ²) | 1.73 x 10 ¹⁸ | 2.85 x 10 ¹⁸ | 3.48 x 10 ¹⁸ | 5.34 x 10 ¹⁸ |
| Φ(E > 0.1 MeV) (n/cm ²) | 4.38 x 10 ¹⁸ | 7.13 x 10 ¹⁸ | 8.93 x 10 ¹⁸ | 1.42 x 10 ¹⁹ |
| dpa | 2.83 x 10 ⁻³ | 4.58 x 10 ⁻³ | 5.63 x 10 ⁻³ | 8.70 x 10 ⁻³ |
| <u>20.0 EFPY</u> | | | | |
| Φ(E > 1.0 MeV) (n/cm ²) | 3.47 x 10 ¹⁸ | 5.85 x 10 ¹⁸ | 7.20 x 10 ¹⁸ | 1.11 x 10 ¹⁹ |
| Φ(E > 0.1 MeV) (n/cm ²) | 8.77 x 10 ¹⁸ | 1.47 x 10 ¹⁹ | 1.85 x 10 ¹⁹ | 2.97 x 10 ¹⁹ |
| dpa | 5.57 x 10 ⁻³ | 9.41 x 10 ⁻³ | 1.16 x 10 ⁻² | 1.81 x 10 ⁻² |
| <u>32.0 EFPY</u> | | | | |
| Φ(E > 1.0 MeV) (n/cm ²) | 5.41 x 10 ¹⁸ | 9.18 x 10 ¹⁸ | 1.13 x 10 ¹⁹ | 1.74 x 10 ¹⁹ |
| Φ(E > 0.1 MeV) (n/cm ²) | 1.36 x 10 ¹⁹ | 2.30 x 10 ¹⁹ | 2.91 x 10 ¹⁹ | 4.65 x 10 ¹⁹ |
| dpa | 8.83 x 10 ⁻³ | 1.47 x 10 ⁻² | 1.83 x 10 ⁻² | 2.84 x 10 ⁻² |

TABLE 6-14

NEUTRON EXPOSURE VALUES FOR USE IN THE GENERATION OF HEATUP/COOLDOWN CURVES

| | NEUTRON FLUENCE ($E > 1.0$ MeV) SLOPE (n/cm^2) | | | 20 EFPY dpa SLOPE (equivalent n/cm^2) | | |
|-----|--|-----------------------|-----------------------|--|-----------------------|-----------------------|
| | Surface | 1/4 T | 3/4 T | Surface | 1/4 T | 3/4 T |
| | 0° | 3.47×10^{18} | 1.83×10^{18} | 3.78×10^{17} | 3.47×10^{18} | 2.22×10^{18} |
| 15° | 5.85×10^{18} | 3.11×10^{18} | 6.44×10^{17} | 5.85×10^{18} | 3.74×10^{18} | 1.34×10^{18} |
| 30° | 7.20×10^{18} | 3.87×10^{18} | 8.13×10^{17} | 7.20×10^{18} | 4.70×10^{18} | 1.74×10^{18} |
| 45° | 1.11×10^{19} | 5.84×10^{18} | 1.16×10^{18} | 1.11×10^{19} | 7.10×10^{18} | 2.45×10^{18} |

| | NEUTRON FLUENCE ($E > 1.0$ MeV) SLOPE (n/cm^2) | | | 32 EFPY dpa SLOPE (equivalent n/cm^2) | | |
|-----|--|-----------------------|-----------------------|--|-----------------------|-----------------------|
| | Surface | 1/4 T | 3/4 T | Surface | 1/4 T | 3/4 T |
| | 0° | 5.41×10^{18} | 2.86×10^{18} | 5.89×10^{17} | 5.41×10^{18} | 3.46×10^{18} |
| 15° | 9.18×10^{18} | 4.88×10^{18} | 1.01×10^{18} | 9.18×10^{18} | 5.87×10^{18} | 2.11×10^{18} |
| 30° | 1.13×10^{19} | 6.07×10^{18} | 1.27×10^{18} | 1.13×10^{19} | 7.37×10^{18} | 2.73×10^{18} |
| 45° | 1.74×10^{19} | 9.15×10^{18} | 1.82×10^{18} | 1.74×10^{19} | 1.11×10^{19} | 3.84×10^{18} |

TABLE 6-15

UPDATED LEAD FACTORS FOR ZION
UNIT 2 SURVEILLANCE CAPSULES

| <u>Capsule</u> | <u>Lead Factor</u> |
|----------------|--------------------|
| U | Withdrawn |
| T | Withdrawn |
| Y | Withdrawn |
| X | 2.97 |
| W | 1.01 |
| V | 1.01 |
| Z | 1.01 |
| S | 1.01 |

SECTION 7.0
SURVEILLANCE CAPSULE REMOVAL SCHEDULE

The following removal schedule meets ASTM E185-82 and is recommended for future capsules to be removed from the Zion Unit 2 reactor vessel:

| Capsule | Location (deg.) | Capsule Lead Factor | Removal Time (a) | Estimated Fluence (n/cm ²) |
|---------|--------------------|---------------------------|------------------|--|
| U | 140 | 2.97 | 1.27 (Removed) | 2.73×10^{18} |
| T | 40 | 2.97 | 3.56 (Removed) | 7.81×10^{18} (b) |
| Y | 320 | 2.97 | 9.18 (Removed) | 1.48×10^{19} (c) |
| X | 220 | 2.97 | 15 | 2.42×10^{19} |
| W | 184 | 1.01 | Standby | - |
| V | 176 | 1.01 | Standby | - |
| Z | 356 | 1.01 | Standby | - |
| S | 4 | 1.01 | Standby | - |

(a) Effective full power years from plant startup.

(b) Approximate fluence at 1/4 thickness reactor vessel wall at end of life.

(c) Approximate fluence at reactor vessel inner wall at end of life.

8.0 REFERENCES

1. S. E. Yanichko and D. L. Lege, "Commonwealth Edison Co. Zion Unit No. 2 Reactor Vessel Radiation Surveillance Program", WCAP-8132, May 1973.
2. Perrin, Farmelo, Jung and Fromm, "Zion Nuclear Plant Reactor Pressure Vessel Surveillance Program: Unit No. 1 Capsule T, and Unit No. 2 Capsule U", BCL-585-4, March 1978.
3. E. B. Norris, "Reactor Vessel Material Surveillance Program For Zion Unit No. 2 Analysis of Capsule T", SwRI Project No. 06-6901-001, July 1983.
4. Code of Federal Regulations, 10CFR50, Appendix G, "Fracture Toughness Requirements," and Appendix H, "Reactor Vessel Material Surveillance Program Requirements," U.S. Nuclear Regulatory Commission, Washington, D.C.
5. Regulatory Guide 1.99, Proposed Revision 2, "Radiation Damage to Reactor Vessel Materials," U.S. Nuclear Regulatory Commission, February 1986.
6. R. G. Soltesz, R. K. Disney, J. Jedruch, and S. L. Ziegler, "Nuclear Rocket Shielding Methods, Modification, Updating and Input Data Preparation. Vol. 5--Two-Dimensional Discrete Ordinates Transport Technique", WANL-PR(LL)-034, Vol. 5, August 1970.
7. "ORNL RSCI Data Library Collection DLC-76, SAILOR Coupled Self-Shielded, 47 Neutron, 20 Gamma-Ray, P3, Cross Section Library for Light Water Reactors".
8. S. Altomare, et al., "Core Physics Characteristics of the Zion Station Nuclear Plants (Units 1 and 2, Cycle 1), WCAP-7675, November 1971. (Proprietary)

9. T. L. Wheeler, et al., "Core Physics Characteristics of the Zion Station Nuclear Plant (Unit 2, Cycle 2)," WCAP-8881, November 1976.
(Proprietary)
10. T. L. Wheeler, et al., "Core Physics Characteristics of the Zion Station Nuclear Plant Unit 2 (COM), Cycle 3," WCAP-9246, December 1977.
(Proprietary)
11. W. F. Staley, et al., "Core Physics Characteristics of the Zion Station Nuclear Plant Unit 2 (COM), Cycle 4," WCAP-9458, January 1979.
(Proprietary)
12. C. A. Grier, et al., "Core Physics Characteristics of the Zion Station Nuclear Plant Unit 2 (COM), Cycle 5," WCAP-9687, April 1980.
(Proprietary)
13. D. L. Maret, et al., "Core Physics Characteristics of the Zion Station Nuclear Plant (Unit 2, Cycle 6)," WCAP-9959, August 1981. (Proprietary)
14. D. J. Wanner, et al., "Core Physics Characteristics of the Zion Station Nuclear Plant (Unit 2, Cycle 7)," WCAP-10282, February 1983.
(Proprietary)
15. D. K. Lee, et. al., "Nuclear Design Report for Zion Unit 2, Cycle 8," NFSR-0024, May 1984. (CECo. Proprietary)
16. D. K. Lee, et al., "Nuclear Design Report for Zion Unit 2, Cycle 9," NFSR-0037, December 1985. (CECo. Proprietary)
17. D. K. Lee, et al., "Nuclear Design Report for Zion Unit 2, Cycle 10," NFSR-0052, December 1985. (CECo. Proprietary)
18. ASTM Designation E482-82, "Standard Guide for Application of Neutron Transport Methods for Reactor Vessel Surveillance", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.

19. ASTM Designation E560-77, "Standard Recommended Practice for Extrapolating Reactor Vessel Surveillance Dosimetry Results", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
20. ASTM Designation E693-79, "Standard Practice for Characterizing Neutron Exposures in Ferritic Steels in Terms of Displacements per Atom (dpa)", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
21. ASTM Designation E706-81a, "Standard Master Matrix for Light-Water Reactor Pressure Vessel Surveillance Standard", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
22. ASTM Designation E853-84, "Standard Practice for Analysis and Interpretation of Light-Water Reactor Surveillance Results", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
23. ASTM Designation E261-77, "Standard Method for Determining Neutron Flux, Fluence, and Spectra by Radioactivation Techniques", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
24. ASTM Designation E262-77, "Standard Method for Measuring Thermal Neutron Flux by Radioactivation Techniques", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
25. ASTM Designation E263-82, "Standard Method for Determining Fast-Neutron Flux Density by Radioactivation of Iron", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
26. ASTM Designation E264-82, "Standard Method for Determining Fast-Neutron Flux Density by Radioactivation of Nickel", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.

27. ASTM Designation E481-78, "Standard Method for Measuring Neutron-Flux Density by Radioactivation of Cobalt and Silver", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
28. ASTM Designation E523-82, "Standard Method for Determining Fast-Neutron Flux Density by Radioactivation of Copper", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
29. ASTM Designation E704-84, "Standard Method for Measuring Reaction Rates by Radioactivation of Uranium-238", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
30. ASTM Designation E705-79, "Standard Method for Measuring Fast-Neutron Flux Density by Radioactivation of Neptunium-237", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
31. ASTM Designation E1005-84, "Standard Method for Application and Analysis of Radiometric Monitors for Reactor Vessel Surveillance", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
32. F. A. Schmittroth, FERRET Data Analysis Core, HEDL-TME 79-40, Hanford Engineering Development Laboratory, Richland, WA, September 1979.
33. W. N. McElroy, S. Berg and T. Crocket, A Computer-Automated Iterative Method of Neutron Flux Spectra Determined by Foil Activation, AFWL-TR-67-41, Vol. I-IV, Air Force Weapons Laboratory, Kirkland AFB, NM, July 1967.
34. EPRI-NP-2188, "Development and Demonstration of an Advanced Methodology for LWR Dosimetry Applications", R. E. Maerker, et al., 1981.