

# OFFICIAL TRANSCRIPT OF PROCEEDINGS

**Agency:** Nuclear Regulatory Commission

**Title:** Public Workshop on Technical and  
Policy Considerations for Nuclear  
Power Plant License Renewal:  
Reactor Pressure Boundary

**Docket No.**

SESSION 2

**LOCATION:** Reston, Virginia

**DATE:** Monday, November 13, 1989 **PAGES:** 1 - 83

*WFOB  
0/1*

**ANN RILEY & ASSOCIATES, LTD.**

1612 K St. N.W., Suite 300  
Washington, D.C. 20006  
(202) 293-3950

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3

4

5

- - - - -

6

PUBLIC WORKSHOP ON

7

TECHNICAL AND POLICY CONSIDERATIONS

8

FOR

9

NUCLEAR POWER PLANT LICENSE RENEWAL

10

11

- - - - -

12

Session 2

13

Reactor Pressure Boundary

14

- - - - -

15

16

Sheraton Resort Hotel

17

11810 Sunrise Valley Drive

18

Reston, Virginia

19

Monday, November 13, 1989

20

1:15 p.m.

21

22

23

24

25

## 1       SESSION LEADERS:

2

3               J. Richardson

4               L. Shao

5

## 6       PARTICIPANTS:

7               James A. Norberg, NRC

8               Matthew F. Cinadr, NYS-DPS

9               Edgar I. Landerman, Consultant

10              Charles Z. Serpan, Jr., NRC

11              I. Manoly, NRC

12              Joseph McCumber, Yankee Atomic Electric Company

13              L. R. Katz, Westinghouse

14              Cedric L. Child, Yankee Atomic Electric Company

15              William D. Hinkle, Yankee Atomic Electric Company

16              Vik Shah, INEL

17              Peter Stancavage, GE

18              Jim Chardos, GPU-N

19              L. B. Marsh, NRC

20              R.E. Nickell, EPRI

21              Peter D. Hedgecock, Nutech Engineers

22              Jim Perrin, Public Service Electric &amp; Gas

23              Bill Corwin, Oak Ridge National Laboratory

24              Gilbert Zigler, SEA/ASME

25              John Nyquist, Detroit Edison - Fermi



## 1 PARTICIPANTS, Continued:

2

3

4

Charles W. Allison, National Board

5

Jim Higgins, MPR Associates

6

Johnnie B. Cannon, Oak Ridge National Laboratory

7

Terry R. Woods, TVA

8

Wayne Pavinich, TENERA

9

Paul Norman, NRC

10

Herb Massie, Westinghouse

11

Peter Bloch, NRC

12

John Bromgren, Commonwealth Edison

13

Rhonda Doney, Combustion Engineering

14

Ron Chrzanowski, Commonwealth Edison

15

Michael Mayfield, NRC

16

Joe Muscara, NRC

17

Art Deardoff, Structural Integrity Association

18

19

20

21

22

23

24

25



## P R O C E E D I N G S

1  
2 MR. SHAO: Good afternoon. Ladies and gentlemen, the  
3 microphones aren't working so I have to shout. Anyone who  
4 wants to speak will have to shout too. Anybody who wants to  
5 speak will have to identify themselves so that it can be  
6 recorded.

7 My name is Larry Shao. I'm the director of  
8 engineering, Office of Research. Today I'm the chairman of  
9 Section 2, Reactor Pressure Boundary. My co-chairman, James  
10 Richardson, is the director of engineering technology, Office  
11 of Nuclear Reactor Regulation.

12 Before we start questions, let me give you a short  
13 introduction related to the issues relating to primary pressure  
14 boundaries.

15 [Pause.]

16 MR. SHAO: As you all know, the primary system  
17 pressure boundary must have very high reliability for the  
18 operational life of a nuclear power plant. It is necessary for  
19 reactor core cooling during shutdown and serves as a barrier to  
20 the release of fission products during accidents.

21 The principal components of the primary pressure  
22 boundary, listed here, mainly are the reactor vessels, steam  
23 generators, the pipings, pumps, and valves. Also, there is  
24 some instrumentation. Maintaining the high reliability of  
25 these components for the license renewal period is the thrust

1 of this workshop.

2 Let me briefly discuss some of the issues related to  
3 these components.

4 [Pause.]

5 MR. SHAO: Reactor vessel materials in the region  
6 become brittle by neutron irradiation and thus load carrying  
7 capabilities -- it loses its toughness and when it loses its  
8 toughness, the reactor vessel is most susceptible to operating  
9 in accident loadings. The method for calculating thinning and  
10 embrittlement is provided by so-called Reg Guide 1.99, Revision  
11 2.

12 Some of the older reactor vessels have high copper  
13 and nickel contents, and they are most susceptible to  
14 embrittlement. The four factors that are most important to  
15 embrittlement -- and these are the four factors, are copper,  
16 nickel, neutron fluence, and the irradiation temperatures.

17 In addition to embrittlement, the thermal stresses  
18 can also cause cumulative damage to the vessels. Both the  
19 reactor vessel internals, the irradiated, stretch, corrosion,  
20 cracking, may be an area of concern for certain vessel  
21 internals and core support structures.

22 We have seen many points of degradation. Here is a  
23 list of the degradations. The first one is firesign stress  
24 corrosion cracking. Mainly it results from religious stresses  
25 and occur at a new band and road transition in the tube area.

1 If understand the French have all kinds of problems with this  
2 area.

3 The secondary size stress core cracking occurs at the  
4 two sheet crevices and two support plate intersections. The  
5 fatigue crack corrogation was caused by frozen in use. The  
6 tube donting, which is regressing in diameter is caused by the  
7 corrosion of the carbon steel support plates. The  
8 intragranular attack, the corrosion attack of grain boundaries  
9 usually occurs at low flow areas. Flooding and wear occur the  
10 support plate and the anti-vibration member areas.

11 Pitting and wastage occurred in the sludge part  
12 region above the two cheese. Lastly, steel tube was prepared  
13 up causing a tube failure at Los Anna. The two-plugging  
14 failure was initiated also by primary stress corrosion  
15 cracking.

16 This is a list of potential dsgradation in piping  
17 that should be considered in license renewal. The BW piping  
18 has experienced intragranular stress growing cracking. IGSCC  
19 is mainly caused by the combination of sensitized material,  
20 religious stresses and high oxygen content and impurities.

21 For the cast stainless steel, the tests at Fermaton,  
22 Argonne National Lab and Western National Lab indicate the cast  
23 stainless steel piping loses load carrying capability when aged  
24 for a long time at operating temperatures. Thermal fatigue  
25 also may result from the poor mixing of hot and cold fluids.



1 Erosion corrosion is a flaw resisting general corrosion of  
2 carbon steel piping and it has occurred in Surry and to some  
3 extent at Trojan.

4 In the pump area, the pump shafts experience high  
5 cyclic alternate stresses which cause cumulative material  
6 damage. Mechanical removal of bearing material may occur due  
7 to long-term pump operations. The heat, humidity, flow,  
8 pressure and vibration may cause degradation in pump seal  
9 gasket and packing.

10 Erosion and corrosion of pump internal are caused by  
11 local high flow turbulence and chemical attack. The loosening  
12 of parts and distortion of certain compartments may result from  
13 long-term pump operations.

14 In the valve area, the valve disk and disk connection  
15 hinges experience high cyclic stresses and impact loading due  
16 to valve operation and flow excitations. This closure impacts  
17 may cause mechanical removal of material at valve seats. The  
18 heat, humidity, valve pressure and motion may cause seal  
19 leakage and insulation failure.

20 The full pressure set for valve actuation may drift  
21 but that may not be an aging problem. It's a current problem.  
22 Local high flow turbulence and chemical attack may cause  
23 erosion and corrosion of valve internals. Distortion of  
24 internal parts may result from long-term operations. Also, the  
25 mechanical removal of material at the valve stem and worm gear

1 may occur due to abrasion.

2 The valve, disk and seat may be locked which may  
3 interfere with opening or closure. For motor operated valves,  
4 the bearing may be worn or broken due to long-term operation.  
5 The binding torque switch or limit switch may cause losing  
6 control of valve stem motion. So these are the lists of  
7 potential degradations we have seen now and we will see more in  
8 the next 20 years if the plants get an extension.

9 Do you have any questions on this?

10 If not, we go to the --

11 MR. CINADR: One question on pumps. Just as a topic,  
12 pumps just generally wear out and they do not deliver as they  
13 once did. These are all kind of catastrophic -- these are end-  
14 of-the-light problems, but there's another category somewhere  
15 between where it's just a worn out pump and it will not perform  
16 as it used to. Is that something that can be found or  
17 considered?

18 MR. SHAO: Hopefully, we'll find out from the IST  
19 program. We have an IST program, an inspection program, and  
20 this IST program should find out whether a pump is worn out or  
21 not.

22 MR. RICHARDSON: I would add to that. As the pump  
23 degrades in its performance, as Larry points out, that ought to  
24 be picked up in the normal operation of the plant and that loss  
25 of pump performance ought to be detected and the pump

1 maintained and refurbished or replaced or whatever.

2 But I think we would consider that more in the normal  
3 surveillance --

4 MR. CINADR: Normal.

5 MR. RICHARDSON: Yes. Not something associated with  
6 life extension or anything. It's just the normal wear-out of  
7 pumps, as you point out. They don't deliver fluid at the rate  
8 that they were intended to and, when that happens, then, as  
9 part of the maintenance program, they would have to be  
10 refurbished.

11 MR. SHAO: For the reactor vessel piping, we have the  
12 ISI program. For the pumps and valves, we have the IST  
13 program. Hopefully, those would be picked up by these  
14 programs.

15 MR. CINADR: Thank you.

16 MR. LANDERMAN: Are you asking for comments now?

17 MR. SHAO: Yes.

18 MR. LANDERMAN: The name is Ed Landerman. You  
19 mentioned on the casting, casting the steel, if they lose maybe  
20 -- making a comment on your comments. You said they lose load  
21 bearing capability. I would say that maybe that's the way  
22 you're wording it, but that is not what happens. They  
23 certainly do not lose their load bearing capability. They  
24 certainly have those comparable properties that they had  
25 originally.



1                   What you're talking about is a change in  
2 consideration of the toughness of that material.

3                   MR. SHAO: But suppose you have a regular toughness,  
4 I don't know, 300 or whatever it is. After 10 years or 20  
5 years, constant thermal embrittlement, you don't have 300  
6 anymore.

7                   MR. LANDERMAN: You have the same load bearing  
8 capability.

9                   MR. SHAO: Originally, you have a bigger margin.  
10 That's okay. Suppose in your design margin you go to one, you  
11 may be in trouble. The original design margin may be ten.  
12 Even if you lose some toughness, you're still okay.

13                   MR. LANDERMAN: I just want to make the comparison  
14 that this is no difference in surveillance tests of reactor  
15 vessels. We know there are changes in properties.

16                   MR. SHAO: I would say the same thing about reactor  
17 vessels, but for other things, it may be different. You don't  
18 lose any capability. Some material, like -- suppose you have  
19 stainless steel piping. It can be there 20 years and your  
20 toughness would be the same.

21                   MR. LANDERMAN: Okay. It's just a comment on that  
22 term. I think the analogy is more with changes of  
23 embrittlement to reactor vessels.

24                   MR. SHAO: Reactor vessels are no different.

25                   MR. LANDERMAN: Than stainless steel.

1           MR. RICHARDSON: I think another way of saying it is  
2 stainless steels that age are more susceptible to catastrophic  
3 failure through brittle failure.

4           MR. SHAO: The reactor vessel and cast iron steel are  
5 hopefully the same. Anymore questions?

6           MR. CORWIN: Bill Corwin, Oak Ridge National Lab.  
7 Two comments. One, I notice there was no mention of thermal,  
8 long-term thermal aging with respect to the reactor pressure  
9 vessel. I understand that's not currently within our codes,  
10 but I know that the British, in their licensing, are including  
11 up to a 30 degree C shift, even for modern reactor materials  
12 for long-term thermal aging in their pressure vessel.

13           Just a comment; I hadn't heard that specifically  
14 addressed and I didn't know if that was going to be considered  
15 in the life extension process.

16           Another comment is with respect to the adequacy of  
17 Reg Guide 199. I don't recall exactly how high the fluents  
18 limits are in that, that are explicitly addressed by 199, but  
19 some of the higher fluents plants may very well run off the top  
20 end of the scale in 199 and that's -- the higher fluents  
21 regions are something which may need to be reinvestigated  
22 relative to the rulemaking.

23           MR. SHAO: That's true, because we may not have the  
24 data for real high fluents.

25           MR. KATZ: I noticed you left off the list two

1 components; pressurizers and CRDM. Is there some reason for  
2 that?

3 MR. SHAO: No particular reason. I just say these  
4 are the key components.

5 MR. LANDERMAN: One other comment. It falls within  
6 the reactor vessel and piping, which is a highlight, and that  
7 is -- it seems to me it should be highlighted. It's a similar  
8 metal combination. Everywhere we've talked about similar  
9 metal, concerns about casting, reactor vessel. An area of  
10 concern, as it should be considered, would be the dissimilar  
11 metal welds that are part of all these components or most of  
12 these components.

13 MR. SHAO: You're saying maybe bimetallic welding.

14 MR. LANDERMAN: Bimetallic, yes.

15 MR. SHAO: But bimetallic welding hopefully would be  
16 picked up also in the methodology, also in the fatigue  
17 stresses, with differential expansion and also methodology.

18 Any more questions?

19 MR. SMEDLEY: When you're talking piping, are you  
20 talking mainly out of the control room?

21 MR. SHAO: I'm talking about piping, pressure on all  
22 pipes. It can be any piping. If you allow thermal stress on  
23 the surge line. Recently, we found in many plants they have  
24 some kind of high thermal stresses which was not analyzed in  
25 the original FSAR.



1           MR. RICHARDSON: I might say to you that if you're  
2 going to ask questions or are going to make comments, if you  
3 would stand up and identify yourself and speak very loudly  
4 because it has to be picked up by these microphones up front to  
5 be recorded.

6           MR. SHAO: Any more questions?

7           [No response.]

8           MR. SHAO: If not, why don't you start.

9           MR. RICHARDSON: Okay. Good afternoon. My name is  
10 Jim Richardson. We've put together some seven questions that  
11 we as the staff have to you as industry and citizens to help us  
12 put together the rule. These are certainly not totally  
13 inclusive of all the questions that need to be raised in the  
14 area and I'm sure there are questions that you have or comments  
15 that you have that go beyond these.

16           The way I would like to operate this is, first, I  
17 would like to hear your comments on these specific questions  
18 and then, after we get through these seven questions, I'm sure  
19 some of you may have comments outside of these specific  
20 questions and we would welcome those comments.

21           But, first, I would like to get through these seven  
22 specific questions.

23           MR. SHAO: Do you think it's a good idea to have a  
24 summary of each question?

25           MR. RICHARDSON: A summary of each question.

1           MR. SHAO: Well, after we go through each question,  
2 we have a summary.

3           MR. RICHARDSON: Okay. The first question deals with  
4 the surveillance program in the reactor vessel and, of course,  
5 Appendix H of Part 50 of the Federal Regulations have set forth  
6 the surveillance requirements. However, those requirements are  
7 based on the assumption of a 40 year life.

8           The question that we're raising is what additional  
9 requirements should be set forth and implemented to account for  
10 life beyond 40 and how should the surveillance program be  
11 adjusted to account for that, considering the fact that  
12 surveillance capsules have been removed on a periodic base with  
13 the assumption that end-of-life comes in 40 years.

14           Is there someone that would like to address that  
15 question?

16           MR. SMEDLEY: I'm Rick Smedley.

17           This Appendix H thing is right in Appendix G, which  
18 means it's in the Reg Guide 199, rev. 2, which is quite  
19 conservative. Now, with modern calculation methods of reactor  
20 pressure, do you foresee the requirements being more exact, for  
21 instance, the Reg Guide 1.154 analysis and the NUREG 4744  
22 analysis, one having to do with the steam criteria and the  
23 other having to do with the upper shelf?

24           MR. RICHARDSON: As I understand your question -- or  
25 your comment, and your question to us is, do we anticipate a

1 more exact type of analysis for licensing renewal.

2 MR. SMEDLEY: I'm just interested in the 50 foot-  
3 pound criteria. Some of us are going to exceed the steam  
4 criteria of 5061. CE just came up with a new method of  
5 analysis, and I think they put in a proposal, but I'm not sure.  
6 I can foresee everybody having to go with this system. Have  
7 you considered that in this?

8 MR. SHAO: The 50 foot-pound criteria is being  
9 changed anyway. We know it's considered in the regulation. If  
10 you have some new data, you can always submit to NRC a topical  
11 report. We can look at it.

12 MR. SMEDLEY: What are you going to change it to?  
13 That's what we want to know.

14 MR. RICHARDSON: Well, you're really getting into an  
15 area that I want to avoid in this workshop, and that is  
16 operational problems.

17 MR. SHAO: It is an operational problem.

18 MR. RICHARDSON: There is certainly a sharp  
19 distinction. We want to confine the rulemaking, as was stated  
20 this morning, to those phenomena that are peculiar to the aging  
21 phenomena beyond 40 years. I don't mean to be avoiding your  
22 questions.

23 MR. SMEDLEY: But I also think that you should  
24 consider before 40 years. If we go over 20, then sure as hell  
25 we're going to be beyond.



1           MR. RICHARDSON: Well, I guess I would like to turn  
2 the question around, if I may. Do you think that the NRC  
3 should tighten its rules and go for a more stringent analysis?  
4 Does that make sense from your perspective?

5           MR. SMEDLEY: I don't think you have to tighten the  
6 rules. I think, as was indicated, you may have to make the  
7 rules more realistic.

8           MR. SHAO: We realize that 50 foot-pounds is from  
9 many years ago. Also, when you do a Reg Guide 1.99 revision 2,  
10 and you cannot do the steam criteria, you do it more  
11 realistically, fracture mechanics, perhaps, and you always have  
12 a way out. It doesn't mean you're stuck right there.

13           Fifty foot-pounds, we would entertain anything that's  
14 more realistic, and for pressure and thermal shock, we can  
15 always develop more realistic standards.

16           MR. MARSH: My name is Tad Marsh. I'm from the  
17 Staff, the mechanical engineering branch.

18           With respect to low-temperature compression  
19 protection, there's many things the licensees can do to address  
20 pressure maximum, pressure limits, as the fluence increases on  
21 the vessel, just one of which is the adjustment of the Appendix  
22 G curve. There are other operational means they can use to  
23 reduce pressure.

24           The CE topical report -- if there is one -- or at  
25 least the CE methodology, and some of the others that we've

1 heard of, use not just adjustments in the Appendix G curve, but  
2 also operational things that can be done with respect to the  
3 PORB set point, with respect to using the RHR systems, so that  
4 you indeed have a bigger operational window in which to  
5 operate. Should it be life extension, or if you have problems  
6 even before life extension.

7 MR. RICHARDSON: Do we have other comments on this  
8 particular question that we have of you?

9 MR. PAVINICH: I'm Wayne Pavinich, from TENERA.

10 I think the question is talking about the  
11 surveillance program, not what to do once you have an  
12 embrittlement problem, so I think people are missing the boat a  
13 little bit. ASTM, E-10, who had jurisdiction on E-1-85, which  
14 tells you how to run a surveillance program, which I believe is  
15 referenced in Appendix H, is already taking a look at that, a  
16 draft standard, or an outline of a draft standard for review.

17 MR. RICHARDSON: Okay. Thank you.

18 Other comments on this question? Can you offer  
19 assistance in us addressing this question?

20 MR. LANDERMAN: Ed Landerman, consultant.

21 I'm not sure whether Appendix H really addresses  
22 annealing. It does certainly cover time dependency, but this  
23 would be a new time basis on any of it. The comment is whether  
24 it's covered under Appendix G, but it's maybe something that  
25 should be considered.

1           MR. SHAO: This is a valid point. Right now, I think  
2 we see annealing as a viable method to restore the original  
3 toughness, and I think we need to have criteria on annealing,  
4 so right now we are trying to develop some criteria. But we  
5 don't have a criteria now.

6           MR. HEDGECOCK: Pete Hedgecock, from NUTECH.

7           Building a little bit on what Wayne Pavinich said,  
8 there are a number of us here from ASTM committee E-10. With  
9 respect to the annealing, we did revise the standard E-509  
10 several years ago, and there is some further revision. We need  
11 some guidance in that.

12           We also have a reconstitution standard, for  
13 reconstituting specimens, because one of the problems that you  
14 face as you go on in life is that you're running out of sample  
15 material which is valid, upon which to refine many of these  
16 analyses that you were speaking of earlier. So ASTM is  
17 undertaking some of that work already, which I hope will be of  
18 help to you.

19           MR. RICHARDSON: Question: What is the time frame  
20 for completion of those standards?

21           MR. HEDGECOCK: E-509 is already on the books and is  
22 due for revision, I think, a year after next. I think it's E-  
23 12 or -13 that's the reconstituted specimen standard. That was  
24 issued about a year ago. We need some feedback and practical  
25 experience on that, which will probably lead to revision before



1 the normal five-year period.

2 MR. RICHARDSON: I guess another question I have  
3 related to that: Is there a relationship being developed with  
4 some of the foreign countries that are having the same type of  
5 experience? I'm thinking particularly of the Soviet Union.

6 MR. HEDGECOCK: Yes. As a matter of fact, Neil  
7 Randall, of your staff, who's a member of that subcommittee,  
8 mentioned this at our last meeting. We were hoping to get an  
9 update on some of the Russian experience. You mentioned  
10 earlier some of the factors influencing the degree of  
11 embrittlement, and among them were copper and nickel, as the  
12 constituents of the seats and weldments. The question is about  
13 some of the European steels, where they have high phosphorus  
14 and sulfur levels. We have asked the NRC representative to go  
15 back to the work that you're doing at Oak Ridge and see if you  
16 can come up with some correlations on these elements. We have  
17 some correlations on those, and they were submerged into copper  
18 and nickel being the most significant elements.

19 There's some question that the European data now have  
20 to be looked at with respect to the --

21 MR. SHAO: The Russian reactor has a lot of  
22 phosphorus in it.

23 MR. HEDGECOCK: They have high phosphorus, in  
24 European steels. We don't.

25 MR. RICHARDSON: Thank you.

1           MR. KATZ: Larry Katz, Westinghouse.

2           On the subject of annealing -- I'm the chairman of  
3 the special working group, plant life extension, ASME. We have  
4 moved ahead on an initiative on an annealing procedure which is  
5 on the docket for the subgroup for repairing and replacements,  
6 based on E-509. That is actively under way in that group,  
7 where they're trying to write a draft procedure based on that.

8           MR. SHAO. Is there an NRC member in this group?

9           MR. KATZ: Yes, there are.

10          MR. CORWIN: Bill Corwin, Oak Ridge, again.

11          A comment that ties a lot of this together: Yes,  
12 there are standards that ASTM either has or is developing, and  
13 certainly ASME as well, on how to anneal the vessels, and how  
14 one can follow the material properties of the vessels through  
15 an anneal. It all hinges on the availability of adequate  
16 numbers of surveillance specimens, which have seen the  
17 operating history.

18          Even with reconstitution, it's very likely that there  
19 will be an inadequate base for a number of the older plants,  
20 even if they were willing to reirradiate, starting from  
21 scratch. A lot of times there's not the archival material  
22 available with which to perform the proper irradiation.

23          One of the concerns that's undoubtedly going to fall  
24 back on NRC is, what type of substitutions can be made, or if  
25 data are not available, how does one make the judgement calls

1 where it's just simply impossible to get an adequate amount of  
2 surveillance data. That's going to be a key problem as plants  
3 either are annealed or simply go through extended lifetimes.

4 MR. RICHARDSON: Any comments or last questions?

5 MR. SHAO: Do you want to take the next question.

6 MR. RICHARDSON: Well, I guess if I were to summarize  
7 the question, one; I heard that the national standards ASTM is  
8 undertaking this problem and looking at it. However, as Bill  
9 points out, we're still going to come up short on surveillance  
10 samples, and how does one deal with that? It's a nagging  
11 problem that we're going to have to face.

12 Annealing is certainly one approach that's going to  
13 have to be considered. The FRC and the industry are going to  
14 have to struggle with an annealing criteria. What is an  
15 acceptable annealing criteria?

16 In fact, as you anneal, how much recovery do you get  
17 and how do you measure that? Then what do you do post-  
18 annealing with respect to samples? Do you insert new sample?  
19 Do you have -- is there archival material available to start a  
20 new sample program that starts the annealed condition.

21 These are problems, of course, that we struggle with,  
22 but the feedback I'm getting from you is a focus on improved  
23 standards and look at annealing. Those are the two main points  
24 that I got out of it.

25 MR. SHAO: The next question is related to cast



1 stainless steel. You know, maybe I didn't use the right  
2 phrase, but the cast stainless steel, after operating for a  
3 long time, has a tendency to lose its toughness. That's one  
4 issue.

5 The other issue that's not listed here is; it's very  
6 difficult to inspect cast stainless steel, so really there are  
7 two issues. It may lose the original margin, and it's very  
8 difficult to inspect, so how should we tackle this issue during  
9 life extension or license renewal. Can somebody say something?

10 MR. HEDGECOCK: Pet Hedgecock from Newtech. On the  
11 issue of cast stainless steels and their embrittlement with  
12 aging, it is very much a compositional matter and determined by  
13 the chemical composition, the length of time and the  
14 temperature at which it's exposed, but there are ways of  
15 culling out a large percentage of the subject components, given  
16 that you have some history on these materials.

17 You can show, by fracture mechanics, what kind of  
18 flaw they would tolerate which might turn out to be a through-  
19 wall thickness, leak-before-break issue as opposed to a  
20 fracture problem. I think you can put the problem in  
21 perspective in an individual component through some such  
22 analysis.

23 Then, of course, if you are still faced with your  
24 second problem which is the inspection itself, and there is  
25 some work going on, I believe. You've probably read all the

1 reports that I have, and there is some hope for improved  
2 inspection techniques, plus ultrasonics isn't the only way one  
3 needs to inspect cast stainless. One has radiography which is  
4 not a small undertaking, but it's being done on comp bodies, in  
5 particular.

6 I think you can handle the problem by history of the  
7 material, taking the research data that's been done in this  
8 country and in Europe and Japan on aging and embrittlement of  
9 cast stainless steels. Then looking for the susceptibility of  
10 the particular component and the amount of embrittlement that  
11 you showed by fracture mechanics could be of concern.

12 If you've done that, of course, you can relate back  
13 to what kind of flaw size you should be looking for, and  
14 hopefully your research work on NDE technique development will  
15 allow you to decide what you can inspect for realistically.

16 It doesn't offer a solution, but at least there's a  
17 methodology there, I think, that could be followed.

18 MR. SHAO: What if some of the valves are made of  
19 cast stainless steel?

20 MR. HEDGECOCK: Again, if you look at the valves, I  
21 suspect you'll find that a lot of the bodies are subjected to  
22 much lower stresses than the piping and the elbows, for  
23 example, therefore, their flaw tolerance is probably much  
24 greater in term of the fracture mechanics analysis. The only  
25 concern one would have on pump bodies is the extensive amount

1 of post-casting weld repair that may have been done, leaving  
2 fairly high residual stresses.

3           Again, this should be looked at on a fractured cast  
4 basis.

5           MR. LANDRUM: Ed Landrum. I still want to make the  
6 relationship between reactor vessel surveillance and changes in  
7 properties of the castings. Certainly, there are a number of  
8 attempts and work on getting that kind of data, but I think  
9 it's minimal compared to the number of plants out there.

10           I could say, originally, on reactor vessels, the  
11 intent was to use a correlation monitor material and not an  
12 induced surveillance and get a lot of data. I believe we don't  
13 have sufficient data of aged stainless steel castings at the  
14 temperatures of operation.

15           Certainly, the analyses can be done, but I believe  
16 it's with limited information. When you asked what  
17 uncertainties and what measures, and I'm saying there's a need  
18 for additional data on the effect of aging. We're talking  
19 about a time dependency. We're talking about another 20 years.  
20 We're talking about a lot of parts being taken out of service.

21           It seems to me that that's the kind of measures that  
22 the NRC ought to be able to implement, to get that data and  
23 have a feedback cycle, just like you do with the surveillance -  
24 - the reactor vessel surveillance stuff.

25           MR. SHAO: Any other comment?



1           VOICE: I read your question slightly differently. I  
2 said, I read your question slightly differently. I think the  
3 question you're asking is; is a change in fracture is  
4 sufficient to change your inspection, your current inspection  
5 requirements? I think that there are bounding analyses would  
6 tell you that the answer is no.

7           A loss in toughness, the worst case that we would  
8 expect, wouldn't change your present Section 3 inspection  
9 reports. Therefore, you would probably need to do very little  
10 in the way of monitoring the -- fracture toughness. What you  
11 really need to do is to determine that the boundary of  
12 toughness which we now use, which is like a fracture of 2  
13 deteriorations, is correct.

14           Parenthetically, I'm not sure I understand why this  
15 is a life extension issue, as opposed to a curve point.

16           MR. SHAO: I don't read the question the way you read  
17 it, but this is one potential solutions. Any other questions  
18 or any other comments?

19           [No response.]

20           MR. SHAO: Okay, let me summarize this question here.  
21 Regarding cast stainless steel, the general feeling is that  
22 there is not sufficient data. Maybe some work needs to be done  
23 in this area. The problem is not only on the amount of  
24 toughness and maybe the difficulty inspection, however, we can  
25 look at some of the components out of service, see how they

1     behave and we can do some fracture mechanics, do some kind of  
2     bonding analysis. Hopefully we don't have to change the  
3     inspection intervals.

4             MR. RICHARDSON: The third question has to do with  
5     the in-service inspection and in the in-service testing  
6     programs. As you heard this morning, at least on a preliminary  
7     look, it is our intention to exclude the in-service inspection  
8     and the in-service testing programs from license renewals since  
9     this is an ongoing program that hopefully will detect the  
10    degrading mechanisms and take corrective action as the plant  
11    progresses through its life, not only for life extension but as  
12    the plant exists today.

13            The question that we're asking here is, in your  
14    opinion, do the current in-service inspection and in-service  
15    testing programs adequately pick up and detect the aging  
16    mechanisms that may be critical to safe operation of those  
17    components and materials? Are the ISI programs and the IST  
18    programs that we have on the books or coming on the books, are  
19    they sufficient to pick up the aging degradation such that they  
20    do not have to be modified or addressed in licensing renewal.

21            MR. KATZ: I'm Les Katz of Westinghouse. There are  
22    three groups looking at that question in the industry at the  
23    moment. ASME, special working group, collects for the pressure  
24    boundary, O&M for IST and IEEE 3.4 for electrical and  
25    instrumentation. The ASME pressure boundary PLEX group has

1 been in business for about three years and we so far have not  
2 recommended any specific changes in the code to enhance  
3 inspections.

4           However, we do have a lot of things on the agenda  
5 where people are still searching for those and one of the  
6 things that didn't occur, there has been, I think, as a result  
7 of the findings of the pilot studies, a new ASME group looking  
8 into core structures considerably. There is a subgroup on core  
9 structures currently underway as a result of recommendations on  
10 that issue.

11           There are some additional inspections being looked at  
12 that came directly out of the pilot studies and one of those is  
13 maybe more enhanced inspection of surge line for the thermal  
14 inspecting and so on, inspection of that. The modern  
15 initiatives that have moved forward were in the repair area.  
16 There has already passed a repair procedure for steam generator  
17 2 plugging -- I'm sorry -- sleeving -- which is new, and as I  
18 mentioned earlier, there is a reactor vessel annealing  
19 procedures underway and we're continuing to look for issues and  
20 either writing them off or making recommendations so as far as  
21 I'm concerned, that's a question that still is unanswered,  
22 totally.

23           MR. SHAO: What about the ISI of reactor vessel  
24 internals? Do they require additional inspections for their  
25 license? Core reactor vessel internal as a whole.



1           MR. KATZ: I don't think that you're a direct problem  
2 is associated with life extension. I don't see them that at  
3 all. I think and the ASME believes that the treatment of core  
4 structures has not been adequate in Section 11, totally  
5 adequate, and it's been emphasized more by the work that came  
6 out of the pilot studies -- not safety issues but probably  
7 economic issues in regard to understanding when these things  
8 may need repair and so on. I don't think it's strictly a PLEX  
9 issue at all on core structures.

10           MR. RICHARDSON: Bill?

11           MR. CORMAN: Bill Corman. I think there are a couple  
12 of aspects one needs to look at in this. A lot of the current  
13 inspection techniques look at geometric changes, looking at  
14 flaws, cracks, thinning, whatever. There's also the focus that  
15 could be applied if it is deemed necessary and necessary in  
16 this case I think is an economic justification or how close are  
17 you coming to the margins and that is whether or not you can  
18 look at changes in properties nondestructively or very closely.

19           I understand that there was a meeting in conjunction  
20 with the recent older reactor safety meeting where a number of  
21 experts from around the country got together and looked at  
22 innovative ways of nondestructively examining properties in  
23 situ and that may be something that ends up being required.  
24 Again, it's a question of how much damage can you tolerate.  
25 You need to only look at the geometric changes or do you also

1 need to try and assess the property changes in some of these  
2 materials like the aged stainless.

3 MR. RICHARDSON: Thank you.

4 Other comments, responses to those questions?

5 Well, if I were to summarize what I heard from the  
6 two gentleman, one would be that a number of bodies have been  
7 formed and are looking at these very questions. The ASME, PLEX  
8 group, IEEE, O&M, are looking at these very issues and the jury  
9 is still out as to whether the ISI, IST programs need to be  
10 changed. I would read that not so much in terms of life  
11 extension as changes needed in the program as they exist today  
12 for operating reactors.

13 So it may not be as much a life extension issue as  
14 the need for improvement in ISI, IST in general. That's at  
15 least the flavor that I got from what your response was. The  
16 second aspect is, it may be helpful to look at some innovations  
17 that may allow us to look at changes in material properties as  
18 opposed to the traditional way of just looking at geometric  
19 changes in the materials and their behavior in a non-  
20 destructive way that may give us insights regarding the aging  
21 degradation mechanism associated with materials and this may be  
22 worthwhile looking into and again, the jury is out but it may  
23 have promise on the horizon.

24 Okay. Thank you.

25 MR. SHAO: The next issue is weld overlay. For those

1 people who are not familiar with this subject, it is a lot of  
2 IGSCC piping for repairing these cracks. Instead of replacing  
3 the piping, they put a weld overlay. We believe this, although  
4 it's safe for current operation, whether this weld overlay is  
5 safe for another 20 years, mainly because the examination is  
6 very difficult and when you put on weld overlay, the stress  
7 pattern is changed. For some people, they'll even worry about  
8 seismic analysis because some plants have so many weld overlay,  
9 the stiffness of the piping is changed.

10 So any comment on this?

11 MR. HEDGECOCK: This is Pete Hedgecock. One comment  
12 came from the previous question. The answer there was that the  
13 jury is still out and there are improved techniques being  
14 developed. One would hope that they would be applied to weld  
15 overlays as they develop. That doesn't answer the second part  
16 about the stress patterns, I realize.

17 MR. SHAO: Aside the stress pattern, there are two  
18 types of stress pattern. One is localized stress ride  
19 underneath the weld overlay. The other stress pattern is  
20 general stresses under seismic loading or dynamic loading,  
21 whether the stiffness of the piping is changed or not.

22 MR. PAVINICH: Wayne Pavinich of TENERA. I believe  
23 that when you do a weld overlay, you have to update your piping  
24 analysis. That's a requirement right now. I think it's done  
25 as a matter of routine; am I correct?



1 MR. SHAO: Have you done that?

2 MR. PAVINICH: Does anyone disagree with that? Is  
3 that true? I thought you had to know what the stress patterns  
4 are and I'm not sure you know what the stress patterns are if  
5 you do weld overlay.

6 MR. SHAO: But usually, we feel -- when you do one or  
7 two overlays, it's very localized and you do a stress analysis  
8 in this local area and --

9 MR. O'DONALD: Bill O'Donald. Just one comment about  
10 the weld overlays is that something that should be a cautionary  
11 thing. When you do a weld overlay because of shrinkage, you  
12 can create residual stresses at other welds that have  
13 previously been stress improved and sometimes those welds will  
14 then crack because the residual stresses are in tension in  
15 those welds and it's a good idea to take a look at the system  
16 and stretch your leads to the other welds again that are put  
17 under tension when you put in a weld overlay.

18 MR. SHAO: Okay. Dr. McDonald is also the inventor  
19 of the mechanical device which also -- stress in crack piping.  
20 That -- is also true of NRC to take care of cracking the pipe.

21 MR. DEARDUFF: Art Dearduff, Structural Integrity  
22 Associates. I believe that NUREG 0313 today requires when a  
23 weld overlay is applied that you do go back and look at the  
24 effect of the shrinkage stresses which result on the rest of  
25 the piping system and the other weld overlays that are on the

1 system. So it is being addressed today from the standpoint of  
2 the piping integrity.

3 MR. SHAO: The shrinking stress is one thing. The  
4 stiffness is another thing.

5 Also, you change the stiffness of the piping.

6 What do you people thing, the weld overlays should  
7 continue for another 20 years or -- get rid of it and replace  
8 piping?

9 [Laughter.]

10 MR. LANDERMAN: You qualify the word by ending is  
11 difficult and I'm sure there are a number of people out there  
12 who will keep trying to make that less difficult.

13 MR. SHAO: -- do a better piping analysis. Okay, let  
14 me summarize this.

15 We can include the weld overlay design by doing two  
16 things, by improving NDE technology and do a better piping  
17 analysis to take care of the residual stresses, weld shrinking  
18 stresses and stiffness effect.

19 MR. RICHARDSON: The fifth question we had was a  
20 multi-question, on a number of issues here. And I will  
21 summarize them as a group and then ask that you comment on any  
22 or all of them.

23 The first one being that it is the recognition that  
24 NDE technology over the years has changed, and we have gotten  
25 better at it.

1           The question is for plants that for years have  
2 started out with an NDE technology that by today's standards  
3 was not very sensitive, should we require a rebaselining, using  
4 the better techniques that are available today? That is the  
5 first question of Question 5.

6           The second being, should the in-service inspection  
7 intervals and the extent of the sampling remain the same,  
8 should they be increased or should they be decreased as a  
9 licensing renewal issue?

10          Third, considering that with aging, in particular  
11 with materials such as cast stainless steel, there is a loss of  
12 toughness. Therefore, should our flaw acceptance standards,  
13 our acceptance criteria if you will, be modified to recognize  
14 and account for the loss of toughness?

15          The next question, again, recognizing the  
16 uncertainties in the level of degradation and in the  
17 effectiveness of our NDE techniques, should we impose as a  
18 condition of license renewal a requirement of continuous or  
19 near continuous surveillance or NDE techniques during the  
20 extended life?

21          Now, all of those questions have some relationship to  
22 each other. There is also some disparity in those questions.  
23 I invite your comments on any or all of those parts of Question  
24 5.

25                 MR. KATZ: Les Katz, Westinghouse.



1           We very recently addressed in the special working  
2 group the issue of rebaselining, one of the issues that came  
3 up, because many of the reports that we read on plant life  
4 extension, some of the early work, and we had recommended such  
5 a rebaselining. We put together a task force that looked at  
6 that, and they came back with a resounding recommendation that  
7 we do not recommend any kind of a rebaseline inspection, and I  
8 think for good reason.

9           First of all, with regard to less efficient  
10 techniques, the NRC in 10 CFR 50.55(a) does require that the  
11 program be rated every ten years, and therefore it would be  
12 hoped that new techniques would be picked up as a result of  
13 that. We also see absolutely no reason for going back to 100  
14 percent inspection, which would be very high radiation effect,  
15 on personnel, would be very bad on availability, and in our  
16 view would have gained very little new information with regard  
17 to the flaw in the root.

18           So we made a resounding recommendation that we hope  
19 sticks, that says that no rebaseline should be required. We  
20 amended rules of Section 11 so that what you do in the first 40  
21 continues on exactly the way it has been.

22           With regard to ISI intervals, we have also looked at  
23 that and although we didn't look at them in any real scientific  
24 approach, we feel as if the intervals and the sampling is about  
25 right, has been successful in covering things, and should also

1 continue.

2 I won't address the toughness with aging, because we  
3 haven't look at it.

4 One other point I wanted to make was that with regard  
5 to monitoring, it just was a new change in the code which will  
6 be published I think in the next edition which talks about the  
7 use of acoustic emission, and does allow that, in lieu of the  
8 enhanced inspections the code now requires when a flaw is  
9 accepted by analysis. So we have already made some inroads.  
10 And it is not specifically related to life extension. It is a  
11 now thing which I think is very good.

12 MR. SHAO: If I understand you right, you recommend  
13 acoustics emission?

14 MR. KATZ: It is in the final review process in ASME,  
15 and it is allowed now. It is an option to more, to an enhanced  
16 inspection program which is also required if you have to accept  
17 by analysis.

18 MR. RICHARDSON: But that is really not a licensing  
19 rule question. It is a general improvement in the rule.

20 MR. KATZ: It is a milestone in that it is the first  
21 monitoring technique that I know of in Section --

22 MR. SHAO: Also, you recommend, suppose you extend  
23 life for 20 years, two more inspection, every ten years?

24 MR. KATZ: We have, yes, the group, the task people  
25 worked on that, recommended that it stay just the way it is.

1 No increase, no decrease, but just about the way it is.

2 MR. LANDERMAN: Ed Landerman. Yes. My comment falls  
3 between 3 and 5. I've commented on the dissimilar metal wells,  
4 and somewhere it doesn't fall out of all these questions. But  
5 it does fall out in the sense of, I don't know whether you want  
6 to call it rebaseline, but certainly a close look at an  
7 evaluation of that inspection, because it is probably the most  
8 difficult. We are talking about inconel or stainless  
9 inspection. And so whether you want to call it a new baseline  
10 with new techniques or an assessment of where we are, I think  
11 there is a need to look at that.

12 MR. SHAO: You mean --

13 MR. LANDERMAN: Well, a dissimilar metal well,  
14 inconel or stainless.

15 MR. RICHARDSON: Are you getting at that as a  
16 specific requirement for license renewal?

17 MR. LANDERMAN: It is currently in Section 11. You  
18 raised the question here about less efficient, do we need an  
19 adequately, you know, are current inspections adequate. I am  
20 just raising that question, to assess that.

21 MR. RICHARDSON: But again, that may be a question  
22 that is related to operational plans, not necessarily a license  
23 renewal issue in itself.

24 MR. LANDERMAN: Whether it is an additional issue as  
25 effective aging, I don't know.



1 MR. RICHARDSON: I see. Okay. Thank you.  
2 Other comments, responses to this three-part  
3 question?

4 [No response.]

5 MR. RICHARDSON: Well, to summarize this, the  
6 feedback that I get is, at least one arm of industry that is  
7 represented within the code activity is saying there is no need  
8 to rebaseline in general, that the ten-year inspection interval  
9 where programs must be updated to encompass new technology as  
10 reflected by the code is sufficient. There is no need for  
11 going back to a 100 percent inspection. You pay a dear price  
12 for that in terms of exposure and you get little benefit from  
13 it, and that the ISI intervals, the ten-year intervals and  
14 other intervals that are employed, are about right. They seem  
15 to be working. So far, there is no reason to believe that  
16 those intervals shouldn't be about right for beyond 40 years.

17 And a final note, that it would be good to take a  
18 look at these bimetallic welds, that although I don't see that  
19 as a necessary, necessarily as a license renewal issue, but  
20 certainly something that needs to be paid attention to in the  
21 process. Okay?

22 MR. SHAO: This morning somebody raised some question  
23 on fatigue requirements. The next question is how should we  
24 treat fatigue in license renewal?

25 As you probably know, the ASME curve, the ASME

1 fatigue curve is mainly based on virgin materials. During the  
2 operating life the material has seen a lot of harsh water  
3 environment and high temperatures but there is one saving grace  
4 -- in the ASME curve they use a factor of 2 on stress and 20 on  
5 cycles. For that margin we feel maybe it's good for 40 years,  
6 but what about for 60 years? Should we use a different curve?

7 Another question is what happens if the accumulative  
8 damage factor reach one, then what do you do about it?

9 So I invite some comments how to tackle this  
10 question.

11 Dr. O'Donnell?

12 MR. O'DONNELL: I have some viewgraphs, Larry. May I  
13 show them?

14 MR. SHAO: [Nods affirmatively.]

15 MR. O'DONNELL: I'm Bill O'Donnell. I'm Chairman of  
16 the ASME Sub-group on Fatigue so I take the blame for a lot of  
17 the fatigue methods that are in the code, and the NRC came to  
18 our committee and pointed out that our curves are based on data  
19 in error and their research over the past 10 years including  
20 about 10 NUREGs shows that if you tested reactor water you get  
21 a lot less fatigue life because of the accelerated crack growth  
22 that you get due to environmental effects.

23 Of course there is the International Crack Growth  
24 Committee has done a lot of work on that same subject.

25 The NRC has also pointed out that they feel that the

1 fatigue life, the fatigue properties are lower as elevated  
2 temperatures and that we didn't take that into account  
3 adequately in our design curves and they have raised a number  
4 of issues, such as the load sequence effects -- perhaps we're  
5 not calculating the usage factors correctly and it also is true  
6 that our curves are like 30 years old and they need to be  
7 updated.

8 As a result of that and also some criticisms that the  
9 code doesn't do anything for weldments that is very worthwhile  
10 and that the practice in the industry is that some people are  
11 using fatigue strength reduction factors for weldments, for  
12 metallurgical nudge effects and other people are not and they  
13 feel that the code should make that practice more uniform.

14 There are a lot of issues that the NRC has raised  
15 about the adequacy of the design curves and we are working  
16 right now to upgrade them.

17 Another one is that for the early materials we only  
18 go to 10 to the sixth cycles, whereas vibrations take you to 10  
19 to the tenth cycles and besides cycle thermal mixing fatigue  
20 takes you to 10 to the tenth cycle so the curves need to be  
21 extended for burning materials for their cycles.

22 As a result the Subgroup on Strength of Weldments and  
23 the Subcommittee on Design and others worked up the program  
24 which I approved the fatigue design curves that are in the code  
25 and the Pressure Vessel Research Committee is the research arm



1 of the ASME code and they are trying to get this program to  
2 upgrade these curves underway and it's like a three year  
3 program that KPRC has just started.

4 I have a couple of viewgraphs just to show you the  
5 kinds of things.

6 [Slide.]

7 MR. O'DONNELL: This is a graph on a NUREG NRC did  
8 showing that sure enough at higher temperatures the fatigue  
9 properties are actually lower, whereas there had been the  
10 assumption that in the low cycle regime when the material was  
11 more ductile at higher temperatures the curve should be higher.  
12 In reality the data shows that for ferritic materials and  
13 possibly for austenitics as well the curve is actually lower in  
14 the low cycle regime than higher temperatures, contrary to  
15 common sense. It has to do with thermal strain agents.

16 MR. SHAO: The question is -- I know the curve is low  
17  
18 -- the question is the factor of 2 on stress and 20 on cycles.

19 MR. O'DONNELL: Yes, that's a good question and let  
20 me address that with this next curve.

21 [Slide.]

22 MR. O'DONNELL: This curve shows that if you take  
23 pressure vessel steel A-Clad 33, and you assume that the  
24 cladding protects it against early crack initiations -- after  
25 water -- but that once you get an underclad crack that you lose

1 the integrity of the cladding, you can see where the  
2 assumptions are very important in all of this. This is why we  
3 need national consensus standards involved in making these  
4 assumptions.

5 If you make the assumption that the reactor water  
6 accelerates the crack growth once the crack is initiated, you  
7 go from this type of failure code here to this lower failure  
8 curve. This is the mean failure code for those assumptions.

9 If you look at the difference in life it's like a  
10 factor of 5 or so.

11 Now the code put in a factor of 2 for environmental  
12 effects so if we were to construct a curve, just a design curve  
13 based on this, we would reduce the 20 to a 10. That would give  
14 you a factor of 2 but unfortunately this difference is like a  
15 factor of 5 so that if you make those assumptions and you put  
16 environmental effects into the curve, you would have to reduce  
17 the curve quite a bit, so this is why we are trying to put  
18 together this PVRC ASME consensus standards approach to make  
19 sure the assumptions and the factors of course include the  
20 scattering of the data, the size effects and the surface finish  
21 effects in addition to the environmental effects.

22 To get this lower curve we took the crack growth  
23 rates from section 11 for reactor water. Section 11 is working  
24 on improving their -- and this is an illustration of what  
25 section 11 is looking at right now for environmental effects on

1 crack growth rates. They are factoring in the cyclic rate  
2 effects into this whole thing.

3 The reason I wanted to take a few minutes to present  
4 those curves is to make sure that you know that the ASME code  
5 and the PVRC are trying to update these fatigue curves and they  
6 are trying to put environmental effects into them and they are  
7 trying to account for aging effects and to run the curves out  
8 to high enough cycles so that we can do vibrations and high  
9 cycle thermal fatigue.

10 MR. SHAO: Any other comments?

11 MR. KATZ: One other addition to the ASME worth  
12 mentioning, in section 11 there is a task group on fatigue who  
13 are in the process of writing a white paper on fatigue and they  
14 are looking at, you know, what to do about the fact that you  
15 may run on usage factor -- and one of the recommendations to  
16 come out of that group is that -- it's not firm yet but one of  
17 the preliminary recommendations is that indeed if one views  
18 actual transients rather than design phases they probably  
19 become free and I think the background incorporated somehow  
20 into these options and code, that would be a big help.

21 MR. SHAO: Anything else?

22 MR. CINADR: Does the NRC consider the usage factor  
23 of recalculations? In other words, that indicates something as  
24 you approach one, how many times can you --

25 MR. SHAO: If you want to sharpen your pencil --



1 MR. CINADR: Does that tell you something?

2 MR. SHAO: If this gentleman tells you that you need  
3 I training and you get into trouble and you want to use X  
4 training and you have some data to back it --

5 MR. CINADR: If everyone records that -- this is no  
6 problem.

7 MR. RICHARDSON: I think from a personal point of  
8 view

9 -- if I discover somebody out there sharpening the pencil to  
10 push because they are pushing the cumulative usage factor  
11 toward one I am going to start getting concerned just because  
12 of the great uncertainties associated with the loads that go  
13 into the fatigue calculations and the fatigue properties  
14 themselves.

15 I start getting worried when we need to sharpen our  
16 pencils. That would certainly be of concern to me.

17 MR. SHAO: When you do a design calculation at that  
18 time the specification gives you a 10 pound cycle -- if you're  
19 realize maybe only --

20 MR. RICHARDSON: I understand that. It would just  
21 cause me to take a closer look and challenge it at least so  
22 that I really in my heart of hearts agree with what they are  
23 doing.

24 MR. CINADR: And there will be more of that as time  
25 goes on.

1           MR. RICHARDSON: Absolutely. I think our job is  
2 going to get tougher and tougher.

3           MR. SHAO: Okay, let me summarize this.

4           MR. DEARDUFF: Art Dearduff, Structural Integrity  
5 Associates.

6           I guess I take issue a little bit with your comment  
7 about looking at anyone who wants to sharpen the pencil because  
8 you have got to realize that in the original design of these  
9 plants the criteria was that the usage factor be less than one  
10 and most of these components were designed by the low bidder  
11 and so when you get this stress analysis and you tilt the  
12 founding transients and he could take all of the predicted  
13 transients from the plant, divide that by the allowable cycles  
14 for his one analysis and he got usage factor of less than one,  
15 his job was done. He didn't get paid any more to do additional  
16 analysis to show that that usage factor was really zero in many  
17 cases, so with just a little bit more going back and looking at  
18 the original design analysis you can show that it is not a  
19 concern even though the stress report reported a number which  
20 many times has made its way into technical specifications --

21           MR. RICHARDSON: Well, I didn't mean to imply that I  
22 or the NRC would in fact reject a design that had a usage  
23 factor near one, not at all. It would cause me to look a  
24 little harder -- when one starts to approach a usage factor of  
25 one it just causes me to want to look the calculations over a

1 little closer than I would with a calculation that came in with  
2 some very conservative back of the envelope calculations that  
3 come out with a cumulative usage factor of .1. I turn the game  
4 up a little bit.

5 MR. SHAO: I think your point is well taken but a lot  
6 of things now is done based on boundary analysis -- very  
7 conservative and your usage factor, less than one, that's it,  
8 so that in the license renewal you have to sharpen your pencil  
9 if you want to get out of it.

10 MR. DEARDUFF: Another observation is that industry  
11 continues to address fatigue through inspections. As you are  
12 well aware, there's been a number of actual fatigue failures  
13 which have been observed or cracking has been observed in  
14 plants.

15 MR. SHAO: -- well documented, backed by data  
16 analysis or you do it with good data and actually we'll look at  
17 it.

18 MR. DEARDUFF: I just wanted to say though that we  
19 have to look at the fact we can't just look at the fatigue  
20 usage curve, the usage curve here. There should be a balanced  
21 program of analysis with existing curves combined with  
22 inspections --

23 MR. RICHARDSON: Of course, of course, I understand.

24 MR. DEARDUFF: -- and you shouldn't just ask them to  
25 use a new peak usage curve.



1 MR. SHAO: Any other questions?

2 [No response.]

3 MR. SHAO: Okay. Let me summarize this.

4 On the fatigue requirements, there was a concern with  
5 each of the fatigue curves because the fatigue curve was based,  
6 actually the fatigue curve was based on virgin material, not  
7 this material being faced with different kind of involvement in  
8 high temperatures but now ASME PVRC has a three year program to  
9 try to adjust these issues.

10 Also, there was some questioning related to whether  
11 the original analysis shows that the cumulative damage factor  
12 reaches one then they want to look at the cycle, look at the  
13 analysis, look at the assumptions when they can sharpen the  
14 pencil and do a better analysis to show the cumulative damage  
15 factor of less than one.

16 MR. RICHARDSON: The last of the questions that we  
17 thought about before coming to this workshop is sort of a  
18 change of pace. We've been talking about non-destructive  
19 examination and analysis. Sort of the last question is, are  
20 there any tests that we ought to require to demonstrate  
21 operability in terms of license renewal?

22 Now, of course, there are tests under the IST program  
23 and others that require some testing. What we're asking is, is  
24 there a need for additional tests to demonstrate operability,  
25 vis-a-vis licensing renewal?

1 MR. SHAO: Well, I think the integrity is a form of  
2 operability. I would say integrity/operability.

3 MR. RICHARDSON: I guess a pipe becomes inoperable,  
4 it collapses. Any thoughts?

5 MR. HEDGECOCK: Are you including tests to determine  
6 material condition to actually measure some form of aging in  
7 the material?

8 MR. RICHARDSON: Why not?

9 MR. HEDGECOCK: Okay. If you include those, there is  
10 some work going on in ASTM, some work at Oak Ridge National Lab  
11 on an indentation method which is not non-destructive, but is  
12 very mildly invasive, and from it, one hopes that we'll be able  
13 to produce actual mechanical properties. There's been some  
14 correlation on irradiated materials and papers published  
15 already. This might be applicable to other materials where the  
16 aging phenomena are not just related to the radiation.

17 MR. RICHARDSON: Is this analogous to a hardness  
18 test?

19 MR. HEDGECOCK: It's very much like a hardness test.  
20 You just get a lot more information out of the same process and  
21 derive correlations --

22 MR. RICHARDSON: More than just field stress?

23 MR. HEDGECOCK: Yes.

24 MR. RICHARDSON: Okay. Yes, over here.

25 MR. McCUMBER: This is Joe McCumber with Yankee

1 Atomic. I think, in general, as to one of the questions, I  
2 think, that came up earlier as far as rebaseline, I think any  
3 type of test we feel should be done and technically required  
4 based on the degradation you're concerned with cannot be tied,  
5 necessarily, to the extended life, or licensing, or anything  
6 like that.

7 MR. RICHARDSON: Yes. I think we fully recognize  
8 that there are, from time to time, the necessity to perform the  
9 test to demonstrate operability. A recent generic letter that  
10 we have on the streets really addresses that in spades, and  
11 that's not what we're talking about. It is those tests above  
12 and beyond the routine tests that would be associated with  
13 license renewal, to either rebaseline, whatever, to assure  
14 ourselves that this is operable for the next increment of life.  
15 Yes, your comment is very valid.

16 Well, I guess I would summarize it by the one comment  
17 that we got, was that the ASTM is working on some quasi-non-  
18 destructive techniques involving indentation to determine  
19 mechanical properties, and that this may prove to be a useful  
20 tool in licensing renewal applications.

21 Well, we've come to the end of the seven questions  
22 that occurred to us. This list is far from exhaustive, as I  
23 said earlier.

24 We're at break time, or very near break time, and  
25 what I'm going to suggest is that we take the break, but before



1 we take the break, can I get a feel for -- are there those  
2 among you that would like to raise additional issues in this  
3 general area of primary system integrity in terms of life  
4 extension, keeping in mind that the purpose of the workshop is  
5 to hear from you where you think we are going too far, or where  
6 we're not going far enough. Are we straying off of the path of  
7 the real central issue of assuring safety for license renewal  
8 in light of the philosophy that you heard this morning, and  
9 that is the assumption that the licensing basis, the current  
10 licensing basis is sufficient for extended life, and we need  
11 only concentrate on those issues that deal with aging  
12 degradation?

13           So I guess I would like at least a show of hands of  
14 those that would like to extend the discussion, or have  
15 something to say beyond what you've said in response to these  
16 few questions that we've put forth.

17           [Show of hands.]

18           MR. RICHARDSON: Okay. So it seems like we may have  
19 a half a dozen or so.

20           MR. CHARDOS: Jim Chardos of GPU. It would seem to  
21 me to make sense, after the break, to maybe go through the  
22 speakers that have signed up to give some kind of a  
23 presentation, and then based on what you hear there, you might  
24 want to expand this discussion about the current licensing  
25 basis, age-related degradation. I know part of what I'm going

1 to talk about, and maybe some others, will touch on that  
2 subject of licensing basis, age-related degradation, the  
3 significance thereof, and so on.

4 MR. RICHARDSON: Okay. So let's take a break, and  
5 we'll be back at three o'clock.

6 MR. SHAO: There are a couple of persons requesting  
7 to comment. The first one is James Chardos, representing the  
8 NUMARC/NUPLEX Working Group.

9 MR. CHARDOS: Good afternoon. On behalf of the  
10 NUMARC/NUPLEX Working Group, I'd like to make a presentation on  
11 pressure boundary and then detail, to some extent, the reactor  
12 vessel for PWRs.

13 I'd like to, before I get started, mention that  
14 NUMARC Working Group and NUMARC itself will develop and has  
15 developed answers for those seven questions, so we will put  
16 something in writing in the next week or two, within the period  
17 allotted us.

18 [Slide.]

19 MR. CHARDOS: We had talked earlier today about the  
20 reg guides and SERs and Frank Gillespie mentioned words about  
21 industry reports from the -- reports from the industry being  
22 reviewed as topical reports or possibly part of the reg guide.

23 From our point of view, it's not mandatory that a reg  
24 guide be developed for the industry reports that we contemplate  
25 at this time. As it mentions, topical reports would be

1 sufficient given some form of an SER endorsing those reports.

2 A guide will be acceptable with some caveats here.

3 In terms of getting something that's together, a benefit from  
4 analysis or something that's developed by consensus within the  
5 Working Group, we've got those reports put together that can be  
6 used for that reason. If the conceptual rule -- and we talked  
7 a little earlier about this in terms of the rule versus what's  
8 in the register, in terms of being together on two points, one  
9 of which is the credit for ongoing programs that the NRC has in  
10 terms of inspection and enforcement.

11 It only requires review for those efforts that have  
12 significant age-related degradation. So those are kind of like  
13 two caveats for usage, as well as we talked before and others  
14 have about reg guides and not holding up the two lead plants,  
15 given their submittals are in the June and December timeframe  
16 of 1991.

17 So that kind of gets back to the schedule we saw  
18 earlier today in terms of reg guides, and then some more reg  
19 guides. There were two submittal dates of reg guides. And we,  
20 as an industry, would back that given it doesn't, as a last  
21 concern here, effect the lead plant submittals and eventually  
22 their review and hopefully receiving a renewed license.

23 [Slide.]

24 MR. CHARDOS: In terms of specific reports which we  
25 believe address the pressure boundary, these are the four that



1 we have that just reflect the pressure boundary. As you can  
2 see, there's the PWR reactor vessel; the PWR reactor vessel and  
3 then the BWR and the PWR pressure boundary reports.

4 These are four of ten reports that NUMARC/NUPLEX  
5 plans on eventually submitting between now and the summer of  
6 next year, with the express purpose of using these as  
7 benchmarks for the industry and for the NRC. So these four are  
8 four that reflect on the reactor coolant pressure boundary, two  
9 of which deal with the reactor vessels.

10 As you see, the BWR reactor vessel has been submitted  
11 to the NRC in October of this year, and the other ones, these  
12 three have schedules which we've already previously submitted  
13 to the NRC which are all between now and the June/July  
14 timeframe of next year.

15 [Slide.]

16 MR. CHARDOS: Next, I'll kind of go through quickly -  
17 - I have an outline of industry report and get back to the  
18 licensing basis and those kinds of issues, as we talked before.

19 The process for an industry report and kind of the  
20 format of the two we've already put in, the BWR reactor vessel  
21 and the PWR containment, follow the following format. In terms  
22 of a total group for the containment or the reactor vessel, you  
23 determine which components are, in fact, safety related and  
24 safety significant.

25 With that grouping of components or subcomponents,

1 you now describe all the plausible degradation mechanisms that  
2 apply to this particular component or subcomponent. It's worth  
3 noting here that in the proposed rule, a list -- a number of  
4 degradation mechanisms, and with or without inclusion in the  
5 rule and definitions thereof, for each of these reports, you  
6 need to look at the mechanisms that, in fact, effect the  
7 component or subcomponent. Some of them will not and do not.

8           The next bullet kind of follows to that in terms of  
9 determining which ones are potentially significant to those  
10 that, in fact, are applicable to the component. And then the  
11 last two talk about those that are potentially significant,  
12 determine if the existing programs for inspection and for  
13 testing and analysis as currently implemented are adequate to  
14 bound the age-related degradation within acceptable limits.

15           So that tells you for particular degradation  
16 mechanisms if the existing programs are adequate and bound to  
17 degradation within limits, then you don't have a problem. For  
18 those, which is the last bullet, where you may have significant  
19 degradation beyond established limits, then you either put  
20 together a program for aging management.

21           So that's kind of a -- if you look at a format of the  
22 report, the last section of the report picks up the last bullet  
23 and tells people, utilities, which ones they think are  
24 significant, that may be outside established limits and may  
25 require each particular utility to put together a program to

1 address those degradation mechanisms.

2 [Slide.]

3 MR. CHARDOS: For the four reports I talked about  
4 earlier, we've tried to, as shown here, display the appropriate  
5 mechanisms or degradations that apply to each of those four.  
6 If you look at the BWR reactor vessel, we've listed the six  
7 that we believe are, in fact, at play here and need to be  
8 addressed.

9 For the PWR reactor vessel, those are the ten or so  
10 that apply. Then down below, for both the PWR and the BWR  
11 pressure boundary, there's those five. Once again, these  
12 groups of five, ten or six all come, to some extent, from that  
13 list in the proposed rule of degradation mechanisms that, in  
14 fact, need to be addressed when you go through and review a  
15 component or a system. So those are the mechanisms that will  
16 be addressed for these reports.

17 MR. SHAO: May I ask a question?

18 MR. CHARDOS: Certainly.

19 MR. SHAO: Why is creep a problem? Is it the high  
20 temperature creep?

21 VOICE: He didn't say it was a problem.

22 MR. CHARDOS: No. I said that's something we need to  
23 address or review and if, in fact, it's bounded, then it would  
24 be not a problem. I just mentioned that. Therefore, for  
25 creep, the answer would be temperatures not high enough;



1 therefore, not a problem. But you need to at least review it  
2 to make sure that's the case and not just dismiss it offhand.  
3 You ought to be safe by addressing it as not addressing it.

4 MR. SHAO: Am I right, to have creep, you have to  
5 have over 150 degrees --

6 MR. CHARDOS: Correct, but --

7 VOICE: Could you repeat that question?

8 MR. SHAO: The question is he lists creep as an aging  
9 mechanism. My reaction is the temperature in the PWR is not in  
10 the creep range. If you're not in the creep range, why  
11 consider creep, then?

12 MR. CHARDOS: Only from a completeness point of view  
13 so that, in fact, was addressed and dismissed as opposed to  
14 leaving it open and not addressing it.

15 MR. SHAO: But if you do have a creep there, I'd like  
16 to know it.

17 MR. NICHOLS: I'm Bob Nichols from EPRI. The report  
18 that is complete, which is the BWR pressure level report, gets  
19 rid of creep completely. It doesn't even treat it as a  
20 plausible aging degradation mechanism. The report which is in  
21 the process of being developed, the PWR vessel, and so far it's  
22 carried that along as a plausible mechanism. It may not be  
23 there when we get through with the final review. Is that  
24 clear?

25 MR. SHAO: Yes. That's why I was very surprised to

1 see creep here.

2 MR. NICHOLS: It may not be there when we finish the  
3 final review.

4 MR. CHARDOS: All right. Those degradations not  
5 evaluated in the BWR reactor vessel and the P and B reactor  
6 coolant systems and are listed in the outline of the review --  
7 we talked before about creep and shrinkage, service, wear, and  
8 chemical and biological effects.

9 So in these cases, these three were not as plausible.  
10 So we're talking about mentioning being plausible. At this  
11 point, for the PWR, we're carrying it along as a possible  
12 plausible, but in this case, in those three, we've said no,  
13 they're not plausible and so, therefore, they're not carried.

14 It's kind of a degree of conservatism here, because  
15 how far do you carry it along in the report before you say it's  
16 not plausible and, therefore, I will not consider it.

17 [Slide.]

18 MR. CHARDOS: At this point, I'd like to just simply  
19 address, if I could, the BWR reactor vessel age-related  
20 degradation. Now, this is a report I mentioned that we have  
21 submitted in October of this year and we talked about --  
22 earlier, there were two groups of mechanisms, degradation.  
23 Going back to the previous slide, the last bullet was for those  
24 of which you needed to put in place an age-related management  
25 or management program to address age-related degradation for

1 certain issues.

2 This last bullet here mentions that there are, in  
3 fact, three of those mechanisms which require a plant specific  
4 management methodology during the license renewal period. And  
5 these three, as the report outlines, is stress, corrosion,  
6 cracking of attachment welds to the reactor vessel; fatigue of  
7 the CRD or control rod drive return line nozzles for the BWR-2  
8 reactor vessels; and neutron radiation embrittlement of some  
9 worst case vessel weldments is a concern for a few applicants.

10 And that last one really is, to some extent, a  
11 current day problem for maybe two or three. It may, in fact,  
12 be a 40 to 60 or 40 to 70 year problem for two or three also.  
13 So it's kind of a limited concern for two or three between now  
14 and age 40 and two or three or so after age 40 in the license  
15 renewal period.

16 But these, once again, are the three that fall out,  
17 which a licensee or an applicant would need to put together put  
18 a plant-specific program to address these three. That's really  
19 the significance of this particular slide. These are three,  
20 but they're reviewing all of them for the PWR. These are the  
21 three for which they have, after review, fallen out that need  
22 to be addressed. They could possibly be outside of established  
23 limits.

24 We talked before about being within bounded limits,  
25 outside limits, and inside limits.



1           MR. SHAO: Is the reactor containment considered in  
2 this program or a separate program?

3           MR. CHARDOS: In a separate report for both BWR and  
4 PWR. At the end, I'll kind of go through the report we're  
5 putting out, in terms of submittals, and the BWR reactor vessel  
6 internals and the PWR reactor vessel internals are two more  
7 reports that were not part of the pressure boundary.

8           MR. SHAO: What about reactor vessel supports?

9           MR. CHARDOS: That's in the reactor vessel itself.  
10 The supports are covered in the reactor vessel.

11           [Slide.]

12           These are mechanisms which have established programs  
13 for inspection and testing for which the degradation is bounded  
14 within acceptable limits. We talked before about being bounded  
15 within limits and those that may be outside established limits.

16           These here, namely neutron irradiation, vessel belt  
17 line weldments, in the majority of the BWRs -- and for a PWR,  
18 LPCI nozzles -- stress corrosion cracking of CRD stop tubes and  
19 neutron flux holders, fabricated from stainless steel and  
20 subject to welding stress, fatigue of PWR reactor vessel  
21 feedwater nozzles, stress corrosion cracking, and fatigue of  
22 nozzle safe ends, depending on the geometry, and material  
23 selections, fatigue damage of reactor vessel studs, and fatigue  
24 damage of reactor vessel support skirts.

25           These mechanisms have been reviewed, and the report

1 mentions that these are covered and are bounded within existing  
2 programs for inspection and testing, and are therefore not a  
3 problem. They have been reviewed and been found to be not a  
4 problem.

5 So this is kind of the second set of mechanisms that  
6 were reviewed and found not to be a problem.

7 MR. BLOCH: What's the criterion for "not a problem"?

8 MR. CHARDOS: In terms of established limits -- take  
9 fatigue on the feedwater nozzles for the skirt. There are  
10 limits established for various mechanisms.

11 MR. BLOCH: The initial design safety margins were  
12 what?

13 MR. MARSH: So you evaluated out to the extended  
14 life, and the cumulative fatigue limits were not exceeded. Is  
15 that correct?

16 MR. SHAO: Yes.

17 MR. CHARDOS: On the PWR, you used to have cracks.  
18 It's in NUREG that periodically, of course, you inspect.  
19 There's an internal and an external inspection requirement. I  
20 think it's NUREG 0619 that requires you periodically, every so  
21 many outages, to look at the external PT, internal PT, so  
22 that's an established program. You're talking about  
23 temperature monitoring and those kind of things that address  
24 fatigue of feedwater nozzles.

25 MR. MARSH: You put on thermal sleeves?

1 MR. CHARDOS: Right. Thermal sleeves.

2 So that's a program that's under way, and it's  
3 covered.

4 MR. MARSH: Notwithstanding the words that the code  
5 uses to look at the fatigue usage factor, the fatigue usage  
6 curves themselves, right?

7 MR. CHARDOS: Correct.

8 MR. MARSH: You're saying you need the curve.

9 MR. CHARDOS: Correct, and that's separate, as we  
10 heard before.

11 MR. MARSH: So your conclusion may be changed,  
12 depending on the code.

13 MR. CHARDOS: Yes. True.

14 MR. MARSH: Do you have a mechanism for that, to  
15 review your conclusions?

16 MR. CHARDOS: Well, as part of the NUMARC/NUPLEX  
17 working group, we have PNCS representation on the working  
18 group, and we have people sitting on both groups, and so we  
19 have feedback from one to the other, so we don't lose sight --

20 MR. SHAO: Let me ask you a generic question. Do you  
21 have any designs relating to the vessel? How do you tell  
22 generically that everything's okay. How do you know you're  
23 being independent?

24 MR. CHARDOS: Pretty much, in the report, if you look  
25 at it and you see "feedwater nozzle" and "feedwater sparger"



1 and "thermal sleeves," you go through the various thermal  
2 sleeve designs, whether it's single-ring, double-ring, welded,  
3 forced, and you do --

4 MR. SHAO: But how do you know the design located is  
5 the worst design? Different geometry, different diameter,  
6 different thickness, different thermal mixing, how do you know  
7 the design you are looking at is the worst design?

8 MR. STANCAVAGE: My name is Peter Stancavage, from  
9 GE.

10 We did not investigate all 30 feedwater nozzles. We  
11 looked at about 12 of them and took the worst of those, and  
12 then we supplemented that by the inspection programs that  
13 plants are undertaking and confirmed that cracking is not going  
14 on.

15 MR. SHAO: But how do you create another 60 years  
16 now?

17 MR. STANCAVAGE: Well, extension programs.

18 MR. SHAO: Another 20 years?

19 MR. STANCAVAGE: Yes.

20 MR. SHAO: But you need 60 years.

21 MR. STANCAVAGE: Well, the extension programs say,  
22 every three cycles, one has to inspect feedwater nozzles, and  
23 that inspection program would continue throughout the service  
24 life of the plant, whether that's 40 years or 60 years or 80  
25 years. The basis for concluding -- at least on the feedwater

1 nozzle -- that fatigue is well managed is inspection more than  
2 analysis. Support is good at the other end.

3 We looked at a number of other configurations, that  
4 the usage factor, based on existing codes, would always be less  
5 than one for 80 years.

6 MR. SHAO: But you analyzed the geometry and came to  
7 this conclusion?

8 MR. STANCAVAGE: Yes.

9 The report is based on assumptions, and each  
10 individual plant has to verify that those assumptions are true.

11 MR. SHAO: What you're saying is that this is a  
12 public report, and each licensee submits his own findings of  
13 the bounding.

14 MR. CHARDOS: Right. Absolutely.

15 MR. SHAO: Does that mean you're bounding -- that's  
16 very conservative.

17 MR. NICKELL: Bob Nickell. It should be pointed out  
18 that one of the issues that fell through to requiring a plant-  
19 specific management was the CREL nozzles on the BWR IIs. That  
20 happened to be one that fell outside the limits and had to be  
21 treated as a special case. It required that additional plant-  
22 specific management program. That's an example. You can't  
23 cover everything by bounding analysis always.

24 MR. SHAO: If you have a lot of margin, you can do  
25 that. But if you don't have enough margin, it could be very

1 difficult.

2 MR. CHARDOS: So you've really only extended it 20  
3 years, right?

4 MR. SHAO: Yes. The life expectancy.

5 MR. CHARDOS: For conclusions on the PWR reactor  
6 vessel and the PWR and BWR pressure boundary, we mentioned  
7 before that those are reports that were submitted on a  
8 previously agreed upon schedule within the next six months or  
9 so, and those reports will have detailed evaluations,  
10 conclusions, similar to the ones that I've mentioned here for  
11 the BWR reactor vessel, and those will in fact be submitted and  
12 reviewed and, hopefully, approved by the NRC.

13 As I mentioned before, we're putting out 10 topical  
14 reports. The four that I mentioned were the BWR and PWR  
15 reactor vessel and the P- and the B- pressure boundary. Some  
16 of the other ones that either had been submitted or will be  
17 submitted are the PWR containment, which went in in the summer  
18 of this year, in August. We had the BWR containment and  
19 containment cables and class I structures, and the PWR and BWR  
20 reactor vessel internals. Those make up the 10 reports that  
21 the industry plans on submitting.

22 MR. SHAO: The reactor vessel supports are here.

23 MR. CHARDOS: The reactor vessel supports for the BWR  
24 reactor vessel are in the report. The PWR reactor vessel will  
25 address its vessel supports. The pressure boundary should



1 cover that. We have to take a look at the scope.

2 MR. SHAO: What about the steam generator supports?

3 MR. CHARDOS: I have to take a look at that. I'm not  
4 exactly sure if that's covered or not. I'm not sure if the  
5 steam generators are specifically covered in the pressure  
6 boundary for the PWRs. I'm not exactly sure. I'll have to get  
7 back to you on that.

8 MR. SHAO: The steam generators may have an aging  
9 problem, because the temperature fluctuates.

10 MR. CHARDOS: We'll take a look at that.

11 That's all I have.

12 MR. MARSH: I have a question.

13 MR. CHARDOS: Yes.

14 MR. MARSH: Back in the earlier slide, you talked  
15 about designating some systems and structures as safety  
16 significant. What does that mean? What are you saying?

17 MR. CHARDOS: As defined, a component whose failure  
18 would affect the function of the system or the component to do  
19 its safety function.

20 MR. MARSH: Now you're talking about active machine:  
21 pumps and valves, for example.

22 MR. CHARDOS: Or support plates.

23 MR. MARSH: So "safety significant" doesn't extend to  
24 active machinery? It's only for passive machinery?

25 MR. CHARDOS: Both.

1 MR. MARSH: It does cover pumps and valves?

2 MR. CHARDOS: Yes.

3 MR. MARSH: I didn't hear any words discussing those.

4 MR. CHARDOS: I think pressure boundary IRs --

5 MR. MARSH: That's all in the pressure boundary  
6 portion of it. I'm talking about pumps and valves, their  
7 capability to perform their job. Active machinery.

8 MR. CHARDOS: Specifically, like main coolant pumps.

9 MR. MARSH: Not main coolant pumps. I'm not sure if  
10 that's safety significant. Safety injection pumps, high-  
11 pressure coolant injection pumps, check valves, those kinds of  
12 things.

13 MR. CHARDOS: Currently, I don't believe we have any  
14 reports contemplated to cover that.

15 MR. BURTON: My name is Rich Burton. I'm with EPRI.

16 The 10 IRs that Jim is going to go over shortly, to  
17 show you what they are, are basically only in safety class I  
18 systems, in containments, for instance. I realize there is a  
19 bunch of others we discussed. The screening methodology or  
20 methodology to identify something to evaluate for license  
21 renewal has a process such that all systems are evaluated using  
22 a very similar basis, looking at effective programs,  
23 significance, and so forth, for all systems. They are not  
24 generic reforms in a plant, the valves and RHR and LPCI  
25 systems, and so forth.

1 MR. CHARDOS: Anything else?

2 [No response.]

3 MR. CHARDOS: Thank you very much.

4 MR. SHAO: Anyone from Northern State Power want to  
5 comment? Anybody from Northern State Power?

6 The next speaker will be from Yankee Atomic, Cedric  
7 Child.

8 MR. CHILD: My name is Cedric Child. I'm with Yankee  
9 Atomic Electric and we're currently doing the lead plant PWR  
10 analysis on our plant -- on our Yankee Plant out in Roe,  
11 Massachusetts.

12 Roe is a pressurized water reactor. As mentioned  
13 previously, the pressurized water reactor pressure boundary  
14 consists of the reactor vessel, which would include the control  
15 rod drive mechanism housings, the main coolant system piping  
16 and the main coolant system components such as the pumps, the  
17 valves, the primary pipe of the steam generator and the  
18 pressurizer.

19 Now, all these components are safely Class I  
20 components, so, a discussion which really hasn't arisen here as  
21 to significance of safety or significance to safety doesn't  
22 really apply for the reactor pressure boundary components.  
23 They're all safety Class I, they all have significant safety  
24 requirements.

25 Now, these -- the next step in the plant life renewal



1 process is to evaluate these components against degradation  
2 mechanisms and maybe we should step back here we talk about  
3 degradation mechanisms because the degradation mechanisms that  
4 we're analyzing for are really nothing new. They've been  
5 identified, they're generally well understood based on years of  
6 experience.

7 We've had some discussion here earlier about possible  
8 changes undergoing in the understanding of these degradation  
9 mechanisms. The quote that came quite often was the jury is  
10 still out on these mechanisms. We're continually understanding  
11 the relationship between the environment and the materials and  
12 these interactions will continue to develop. These  
13 understandings will continue to develop as we go along. This  
14 has been a factor of the operating plants and there's no reason  
15 to expect this to change at all just because we're going into a  
16 plant license renewal.

17 However, the industry and Jim Chardes present the  
18 concept of the industry reports, particularly in the reactor  
19 pressure boundary area we are renewing the unique aspects of  
20 degradation mechanisms and how they are tied in in the license  
21 renewal area.

22 We've seen lists of degradation mechanisms. You've  
23 seen the list of degradation mechanisms that were listed for  
24 the IRs. We feel that we should -- as part of our evaluation  
25 we'll be looking at age related mechanisms and looking at the

1 significant mechanisms in the plant license renewal area.

2 Now, in addition to the industry work that's going  
3 on, that is, the industry reports, each plant will then  
4 demonstrate their applicability to the industry report on a  
5 plant unique basis and that's a point that I think got a little  
6 muddled a little while back that we will be looking at the IRs.  
7 The IRs -- the industry reports -- are doing the best they can  
8 to encompass on a generic basis the relationship between  
9 degradation mechanisms and materials but it will be up to the  
10 individual plants to show that the conclusions reached in the  
11 industry reports are applicable.

12 As an example of a degradation mechanism, let me just  
13 touch on fatigue, because that's a primary one in this area and  
14 I might be stepping into it here but fatigue is a mechanism  
15 that's always been considered in plant design. What has  
16 changed has been the complexity of supporting analyses. This  
17 complexity has increased with the development of codes. The  
18 original B-31-1 codes, for instance, had implicit within it an  
19 assumption that the plant would go from -- would go through a  
20 full temperature cycle some 7,000 times. With the introduction  
21 of ASME 3 we're now doing explicit calculations for design  
22 cycles.

23 Generally speaking our system, at least the reactor  
24 pressure boundary system, has been very resistant to fatigue  
25 problems. Where we've been explicitly designing for fatigue we

1 have not found -- we have not had many problems develop in that  
2 area.

3 MR. SHAO: Can I ask a question on this?

4 MR. CHILD: Sure.

5 MR. SHAO: Since Class I is B-31-1 --

6 MR. CHILD: Right, B-31-1, yes.

7 MR. SHAO: B-31-1 power has fatigue in a general  
8 sense, okay, but they don't have a local discontinuity area  
9 with fatigue?

10 MR. CHILD: That's right, that's right. The --

11 MR. SHAO: Then how do you really know that what is  
12 the really fatigue at, let's say, the local discontinuity area?

13 MR. CHILD: Well, the point I was making was that  
14 fatigue was considered. It wasn't considered to the degree it  
15 is today.

16 MR. SHAO: How do we know that for licensing for the  
17 local continuity area there's no fatigue problem?

18 MR. CHILD: Well, what we're going to have to do is  
19 still understand the differences between these codes and make  
20 sure that these differences are understood and accounted for.  
21 There's nothing new here that wasn't brought up already.

22 MR. SHAO: Yes, I know, but for 40 years people say,  
23 well, maybe you don't have to do a detailed analysis, maybe  
24 it's okay. Now, for another twenty years how do we know the  
25 additional, the additional damage because you don't really, we



1 don't really have a good detail analysis, how do we know this,  
2 this local area is okay?

3 MR. CHILD: Well, let's consider my next slide then.  
4 What are the options open to us in the area of fatigue? I'm  
5 not saying we're going to dismiss fatigue. We still have to  
6 consider fatigue, but let's look at the options that may be  
7 open to us.

8 First of all, if you are a plant that's done a  
9 detailed Section 3 analysis, you can re-do your analyses to  
10 include the additional cycles that you will see for the renewal  
11 period.

12 MR. SHAO: That's the easy one.

13 MR. CHILD: That's the easy one.

14 Now, if you're a plant that does not have a current  
15 design, let's say, current design basis under Section 3, there  
16 are some options open to you. One is to demonstrate a  
17 similarity with a plant that has done Section 3 plants -- has  
18 done a Section 3 analysis. If you can show similar geometry  
19 and similar loading then you can reference to this Section 3  
20 analysis and determine where they have found areas of high  
21 fatigue usage.

22 MR. SHAO: Their temperature had to be the same?

23 MR. CHILD: That's right, that's right, because your  
24 cycles and your geometry would have to -- you would have to  
25 show a similarity in loading and as well as geometry and if so

1 then you can use the trends that their analysis has shown to  
2 demonstrate where you're going to get high fatigue usage and  
3 when you know those areas you can then do the detailed  
4 analyses.

5 The point I'm making is that there need not be an  
6 exhaustive Section 3 analysis. You can by benefit of history,  
7 by considering areas of geometry differences, you might want to  
8 look at those particular areas and do a detailed analysis.

9 There are other areas where you can economize. We  
10 talked about using the actual plant transients to better  
11 quantify the frequency of events.

12 MR. SHAO: Detailed analysis or not?

13 MR. CHILD: You would only need to do the detailed  
14 analysis for those areas where you have had high fatigue usage,  
15 where you by one way or another feel that there will be high  
16 fatigue usage and there's another area that's being looked at  
17 now and is being discussed under Section 11 through the various  
18 ASME code committees, and that's to look at a crack growth  
19 potential.

20 MR. SHAO: Okay, has anybody done an analysis dealing  
21 with sharpening your pencil and you have to change your  
22 operating procedure?

23 MR. CHILD: You're asking me is there any place?

24 MR. SHAO: Yes.

25 MR. CHILD: Where they have sharpened the pencil?

1 MR. SHAO: Sharpen the pencil -- you have to change  
2 your operating procedure or --

3 MR. CHILD: I'd guess I'd have to defer to someone  
4 like Art Dearduff.

5 MR. DEARDUFF: Art Dearduff. Inherently there have  
6 been quite a few of these things that have gone on where cracks  
7 have been found in plants and so inherently that means that its  
8 usage is greater than one and analyses have in many cases have  
9 shown inclement life, no cracks.

10 MR. SHAO: Yes, but this is after the fact.

11 MR. DEARDUFF: It's after the fact but it's --

12 MR. SHAO: If many years ago they found cracks, and  
13 the changed the design, but if you had found anything before  
14 the cracks, you found it, you do a good analysis, you do a  
15 detailed analysis and you found that the damage --

16 MR. CHILD: May I try to re-phrase the question?

17 MR. SHAO: Yes.

18 MR. CHILD: Has designed -- has a fatigue analysis  
19 ever influenced the design?

20 MR. DEARDUFF: I'm certain it has. You know, the  
21 MSSS vendors have been doing fatigue analysis, well, let's say,  
22 even before that when they were designing --

23 MR. SHAO: I'm thinking for operating plants. For  
24 plants who are designed for B-31-1, if somebody re-do that  
25 analysis using Section 3 and find out that fatigue damage is



1 too high.

2 MR. CHILD: Has there been an instance where someone  
3 has done S-31-1 and had to do, I mean, re-do?

4 MR. DEARDUFF: Yes.

5 MR. SHAO: Right.

6 MR. DEARDUFF: People had to re-do fatigue  
7 calculations on the surge line using Section 3 techniques and  
8 that influenced some designs in some plants, so the answer is  
9 yes, after the fatigue was found --

10 MR. CHILD: Until plant life renewal came along those  
11 plants then had a basis in B-31-1, had no reason to re-do it  
12 through Section 3 except to solve particular problems.

13 MR. SHAO: B-31-1 never found a surge line --

14 MR. DEARDUFF: Neither did Section 3.

15 MR. SHAO: If you do it right.

16 MR. CHILD: Do you wish to discuss this more?

17 MR. BLOCH: Go ahead.

18 MR. CHILD: I did bring up the crack growth potential  
19 in which you consider the possibility of a crack just below the  
20 level of detection and you determine the time it would take for  
21 that crack to propagate. Now, you can couple that with your  
22 surveillance program as necessary, or if necessary. You may  
23 find that the crack will not propagate, that it would relieve  
24 itself and that's an alternative method to doing a fatigue type  
25 analysis, or to do an analysis to show the effects of fatigue.

1           Then finally, as an add-on, as another possibility  
2           which wouldn't replace, but would be in addition to these  
3           methods above, there are various fatigue monitoring systems  
4           being looked at now. The point that I wish to make here is  
5           that there are several methods available for managing an age-  
6           related degradation.

7           The methods can be summarized as: further analysis to  
8           demonstrate that the projection degradation is acceptable  
9           through the renewal period, or demonstrating the current  
10          programs are adequate to assure the degradation mechanism does  
11          not impact safety. For the renewal period, you may want to go  
12          to some procedural enhancement, and that's where the question  
13          of trending is a possibility as a means of assessing the  
14          effects of a degradation mechanism.

15          You can modify operating practices and in many cases,  
16          you can consider component replacement or refurbishment. In  
17          managing degradation mechanisms, programs should only be  
18          required for components important to safety. That's not an  
19          issue here when we're talking about reactor pressure boundary,  
20          but in a general sense, as a message that Yankee wants to make  
21          in this workshop, is that we should only be required to  
22          institute programs for components important to safety.

23          No additional programs should be required for those  
24          components that are already covered by existing programs, and  
25          finally, any rule that's set up, should allow a flexibility for

1 managing degradation.

2 MR. BLOCH: Does it follow that a program is adequate  
3 for the first forty years, continues to be adequate after that?

4 MR. CHILD: Does it follow that a program adequate --

5 MR. BLOCH: We have a program that is now in  
6 existence that is adequate for the first forty years, but  
7 questionable beyond that?

8 MR. CHILD: Well, you make a demonstration that the  
9 components -- that the existing programs are satisfactory for  
10 the remaining -- for the license renewal period. If the  
11 existing program -- maybe I've gotten cause and effect a little  
12 mixed up here, but if the existing program is satisfactory,  
13 there's no need to impose additional programs. Let me express  
14 it that way.

15 So, additional administrative controls are only  
16 applicable to special actions necessary to manage age-related  
17 degradation in support of licensing renewal and then such  
18 action should become license commitments for the license  
19 renewal. That concludes my presentation. Yes?

20 MR. MANOLY: The scope of the program we're talking  
21 about on safety; I don't think that's consistent with the  
22 NUMARC documents. The NUMARC document does not say --

23 MR. SHAO: Safety related.

24 MR. MANOLY: No, it doesn't say that. There is a  
25 distinction between new position and the NUMARC position on the



1 screening.

2 MR. CHILD: Well, I really don't want to get into a  
3 discussion of screening here. It's not really applicable.  
4 Screening is not really applicable when you talk about the  
5 reactor pressure boundary. That was my point from the start.

6 MR. MR. MARSH: We have plans for those check valves  
7 that form part of the pressure boundary itself. That is, that  
8 section that isolates inside the pressure boundary from outside  
9 the pressure boundary.

10 I'm talking not about the quality now specifically to  
11 this and the other moveable parts that form a part of that  
12 boundary.

13 MR. CHILD: Well, I think what we would have to do  
14 is, we would have to -- that's getting into the question of  
15 operability and integrity of the valves. We would expect to  
16 undergo a program to review our current valve inspection  
17 techniques and periods of inspection and see if that's adequate  
18 or if that can continue for the remainder of life. Joe?

19 MR. McCUMBER: This is Joe McCumber again from  
20 Yankee. In general, a lot of this discussion came up in the  
21 fluids one this morning. We look at any fluid system as having  
22 a couple of functions; one being the pressure boundary and the  
23 other being operability. The operability function, from what  
24 we've seen so far, the programs in place are doing a pretty  
25 good job, we feel, in detecting or managing aging.

1           The concerns, the concerns with pins and disks and  
2 all of that have been identified and there are several programs  
3 to disassemble and inspect as required. So, we're hoping, at  
4 least from what we've seen right now, we think that that would  
5 be the case. There may be augmentations or enhancements  
6 required, but, you know, we will look at them individually.

7           MR. MARSH: Do I hear you saying that you're going to  
8 be systematically looking at programs that you have that are  
9 required and make sure that they are disassembly programs and  
10 comparability programs; that they are adequate?

11           MR. CHILD: Yes.

12           MR. MARSH: You mean systematically go through all of  
13 those programs?

14           MR. CHILD: That's right.

15           MR. BURKE: Rich Burke, EPRI. The IR -- and I could  
16 be wrong here -- on TRAC being tentative. I believe this is on  
17 the pressure boundary, and someone tell me if I'm wrong --  
18 someone from General Electric or from Westinghouse or from B&W.  
19 However, the programs that answered this yesterday, in other  
20 words, the operability function would be part of the  
21 methodology to evaluate plant equipment for license renewal for  
22 all those affected programs.

23           Those types of things, where all these other  
24 committees are now involved with now looking at the  
25 operability. There are so many problems going on, we decided

1 not to address those within these -- these are pressure  
2 boundary reports, looking at the integrity of that pressure  
3 boundary.

4 Those programs would be considered effective if  
5 implemented as part of this methodology doctrine.

6 MR. MARSH: These valves are not just your normal  
7 operability valves. These are pressure boundary valves.  
8 You've got to be sure that you cover these check valves and  
9 MOVs.

10 MR. BURKE: Pressure boundary integrity is  
11 specifically being looked at, PIVs, light water reactors,  
12 pressurized water reactor. The reactor cooling system. It  
13 does not look at a scope timed to 35 seconds of an MSIB or the  
14 spring packs, and so forth. It doesn't look at things like  
15 that in this particular industry report.

16 Those types of things that you're addressing would be  
17 part of the methodology for license renewal, to look at the  
18 functions independently, but not as part of this report. The  
19 answer is that it's just not part of the scope.

20 MR. MARSH: Okay.

21 I've got an itch that hasn't been scratched yet.  
22 PIVs have been a problem within the industry, not necessarily  
23 for BWRs, but for PWRs. We've seen numerous cases where  
24 they've not been functional, and there ended up being leaks to  
25 the outside of the containment. What program is going to



1 ensure that these are adequate?

2 MR. BURKE: What particular program are we working  
3 on?

4 MR. MARSH: Be as specific as you can. Tell me how  
5 you're going to make sure that the PIVs of the primary pressure  
6 boundary are going to stay adequate for the extended life.

7 MR. BURKE: The PIVs specifically --

8 MR. MARSH: Those are the valves that I'm talking  
9 about: the pressure valves and the isolation valves.

10 MR. McCUMBER: Again, Joe McCumber from Yankee  
11 Atomic.

12 We look at any pressure boundary valve in two ways.  
13 The pressure boundary will be looked at based on the material  
14 construction, and the environments that it's within. The level  
15 at which we will look at it will depend on how harsh those two  
16 things combine. If there is a concern, we will look at it  
17 closer.

18 The operability, again, we look at the package of  
19 programs that are looking at that function right now and make  
20 sure that valve does what it needs to do. Right now, there  
21 seems to be significant program coverage on the safety  
22 injection valves, looking at the types of things you've brought  
23 up, as far as leakage and the valve discs. They've been issues  
24 that have been identified over the last 10, 20 years. I think  
25 we are covering them. I think they may get more coverage than

1 some other valves, depending on the service conditions, the  
2 environmental conditions.

3 MR. CHILD: I'm getting the suspicion that what  
4 you're saying is that the current testing method for these  
5 valves are not adequate in today's -- I mean, it's not a PLEX  
6 issue; it's an operating issue that you're raising.

7 MR. MARSH: It may be partly that, but I don't want  
8 to say it's only a current possibility issue, because I think  
9 for the extended life we have to make sure that the degradation  
10 mechanisms won't appear later on.

11 MR. McCUMBER: Did I get closer to an answer?

12 MR. MARSH: Yes. You were closer that time.

13 You've got a program where you systematically do the  
14 simple check valves, and sometimes routine is bad.

15 MR. McCUMBER: Well, I think in general that's not  
16 done today. For the important valves, it is beginning to  
17 happen today. There are valves that are being disassembled.  
18 Many plants have instituted programs that look at critical  
19 valves based on their safety importance and their environmental  
20 condition, and disassembling them, looking for the problem.

21 MR. MARSH: Is that going to be a plant-specific  
22 issue, or is this an industry issue?

23 MR. CHILD: Well, I would think it would be -- if  
24 it's indeed an industry issue, it should be looked at on an  
25 industry basis.

1 MR. MARSH: Well, it is an industry issue.

2 MR. BURKE: The answer is yes.

3 We at EPRI put each of those concerns in and  
4 identified the industry concerns. You can find the answer to  
5 your question right here. It is a very expensive check valve  
6 text program. It includes long-term deteriorations, if there  
7 are any.

8 We could spend a lot of time on this, but I'm not  
9 sure it's appropriate.

10 MR. MARSH: I think I've got enough to chew on.  
11 Thanks a lot.

12 MR. RICHARDSON: Anything else?

13 [No response.]

14 MR. RICHARDSON: Our third and last speaker who has  
15 requested some time for presentation is Edgar Landerman.

16 MR. LANDERMAN: I think I've made my point.

17 MR. RICHARDSON: You've made your point?

18 MR. LANDERMAN: Yes.

19 MR. RICHARDSON: That, then, brings to an end those  
20 that have asked for time. I guess we will open it up for  
21 anybody else that would like to make comments in this  
22 particular area, that is, primary pressure boundary.

23 VOICE: I'd just like to comment on Mr. Child's  
24 presentation. I thought it was very excellent. I'm  
25 particularly to hear again that not only are we considering



1 license renewal, but I think some of us -- or at least I did --  
2 got the wrong impression today that what is happening during  
3 the 40 years doesn't really make that much difference. It  
4 really does. The operation, the maintenance, the inspection,  
5 the testing, the monitoring of all those things, are in license  
6 renewal. I think he made that very clear. That also includes  
7 the record-keeping, certification of the documentation. I  
8 think all of those things are very important, and I was glad to  
9 hear him speak up.

10 MR. RICHARDSON: Good. Any other comments?

11 MR. ZIGLER: I'm Gil Zigler. I'm with the ASME  
12 subcommittee on vibration monitoring. We've been working on  
13 the vibration monitoring program for the primary site of PWRs  
14 and BWRs since 1976. One of the basic problems that we've been  
15 having -- and we would like just to make this point one more  
16 time -- is this question of operating industry records,  
17 training information, and documentation, which have not been  
18 maintained by operators, vis-a-vis one that has a very good,  
19 close -- whatever that may be -- monitoring program. It's an  
20 issue that we have been trying to tackle within our  
21 subcommittee, and we find it an interesting point to debate.

22 I would hasten to add quickly that the NRC should  
23 carefully look at this question about the differentiation  
24 between a plant that has a known, proven track record, vis-a-  
25 vis a plant that does not have a known, proven track record.

1 We have several analogies. In our subcommittee, we have been  
2 using the analogy of the aircraft.

3 MR. RICHARDSON: Thank you.

4 Any others?

5 [No response.]

6 MR. RICHARDSON: If not, I want to say -- and I'm  
7 sure I speak for Larry -- we appreciate your participation and  
8 comments. I understand that there will be some written  
9 comments submitted. We appreciate those. That ends this  
10 session, and the workshop will reconvene tomorrow morning at  
11 8:30. It will be three sessions going on, so consult your  
12 program.

13 Thank you very much.

14 [Whereupon, at 4:05 p.m., session 2 was concluded.]

15

16

17

18

19

20

21

22

23

24

25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


in the matter of:

NAME OF PROCEEDING: Session 2 Public Workshop

DOCKET NUMBER:

PLACE OF PROCEEDING: Reston, VA

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



MARK HANDY  
Official Reporter  
Ann Riley & Associates, Ltd.



1

Call of the ASME Subgroup on Fatigue Strength + Construction  
of ASME Code Program to <sup>Develop</sup> Improved Fatigue Design Basis

The purpose of this program is to update the fatigue curves in  
the ASME Code, extend them to high cycles to include ~~thermal~~ <sup>mechanical</sup> ~~substantive~~ <sup>substantive</sup>,  
rapid thermal cycling (mixing) and ~~potential~~ <sup>potential</sup> load sequence effects and improved usage factor  
evaluation methods. A major goal of the  
program is to include aging and environmental  
~~effects~~ <sup>with</sup> special considerations <sup>as needed</sup> or callouts.

The ASME Code, including the Subgroup on Strength  
of Weldments, the Subcommittee on Design ~~and~~  
have approved a 3 year development program being  
implemented by ~~the~~ their research arm, the Pressure Vessel  
Research Committee (PCVRC) will be soliciting  
both technical and financial support for this  
program from the industry.

Fig (1) shows a comparison of the new ~~ASME~~ <sup>new</sup> general  
fatigue failure curves <sup>being developed</sup> for ~~parallel~~ <sup>steel</sup> ~~with~~ <sup>with</sup> data obtained in an NRC <sup>research</sup> ~~program~~ <sup>program</sup>.  
~~NRC is active in the development of new fatigue~~  
~~design curves in the ASME Code, and they have pointed~~

NRC has pointed out that the low cycle end of the curve is significantly  
lower at higher temperatures. Indeed, this is born  
out by statistical analyses of available data.

Fig (2) shows the latest results of an analysis of  
reactor water environmental effects on the fatigue  
life of reactor pressure vessel steels. This curve was  
~~developed~~ <sup>developed</sup> ~~from~~ <sup>from</sup> ~~the~~ <sup>the</sup> ~~latest~~ <sup>latest</sup> ~~data~~ <sup>data</sup>

(2)

the ferritic steel from reactor water effects on crack initiation. However, once an unbridled crack is initiated, the integrity of the cladding is assumed to be compromised, and reactor water effects ~~are~~ were assumed to increase the crack growth rates per Section VI of the ~~ASME~~ <sup>ASME</sup> Code. Of course the design curve used in the Code includes a factor to account for environmental effects. Thus, when environmental effects are explicitly taken into account, this factor should not be superimposed. The ~~ASME~~ <sup>ASME</sup> Subgroup on Fatigue has tentatively agreed to reduce the factor on mean failure life from 20 to 10 when reactor water effects are explicitly taken into account. This factor must account for scatter in the data, surface finish and size effects.

Fig. (3) <sup>illustrates</sup> ~~the~~ the more advanced environmentally assisted crack growth <sup>rate</sup> model being developed by the International Crack Growth Committee and the Metals Properties Council Task Force on Crack Propagation. This approach includes cyclic rate and mean stress <sup>effects</sup> to ~~consider~~ <sup>consider</sup> effects. It can also be ~~used~~ <sup>used</sup> to ~~generate~~ <sup>generate</sup> fatigue life curves ~~which~~ which include ~~reactor water~~ <sup>reactor water</sup> environmental effects. ~~It is intended to be used in the ASME Code.~~

We are looking for support for the ASME Code activity ~~and~~ ~~the~~ Pressure Vessel Research Committee program. ~~on this subject is being sent to the ASME Council.~~



③

Having

the numerous "how safe is safe enough" issues decided by national consensus standards committees has been found to be the ideal approach to setting acceptance criteria.  
such







FIG. 3 NEW ENVIRONMENTALLY ACCELERATED CRACK GROWTH MODELS IN CONVENTIONAL  $da/dN$  VS.  $\Delta K$  DOMAIN

300.C (220.F).  
 Wt. 88 Strain-life plots for smooth specimens of 2A 100-B steel in air at 31°C (88°F) and






FIG. 2 A533B PRESSURE VESSEL STEEL FATIGUE FAILURE CURVE CORRECTED FOR REACTOR WATER CRACK PROPAGATION COMPARED WITH FATIGUE FAILURE CURVE IN AIR AT 550°F



*Handy  
NRC  
11-13-89*

**NRC WORKSHOP ON LICENSE RENEWAL  
NOVEMBER 13-14, 1989  
SESSION 2**

**PRESENTATION  
ON  
REACTOR PRESSURE BOUNDARY**

*Tape 11 A*

**BY  
CEDRIC L. CHILD  
YANKEE ATOMIC ELECTRIC COMPANY**

**REACTOR PRESSURE BOUNDARY  
- PWR -**

**REACTOR VESSEL  
MAIN COOLANT SYSTEM PIPING  
MCS COMPONENTS**

***ALL SAFETY CLASS I COMPONENTS***

# DEGRADATION MECHANISMS

- IDENTIFIED AND GENERALLY WELL UNDERSTOOD BASED ON YEARS OF EXPERIENCE
- UNDERSTANDING OF ENVIRONMENTAL/MATERIALS INTERACTIONS CONTINUE TO DEVELOP
- INDUSTRY REVIEWING UNIQUE ASPECTS OF DEGRADATION MECHANISMS IN THE LICENSING RENEWAL ARENA
- EACH UTILITY WILL DEMONSTRATE APPLICABILITY TO INDUSTRY STUDIES ON A PLANT UNIQUE BASIS



# FATIGUE

- HAS ALWAYS BEEN CONSIDERED IN PLANT DESIGN  
COMPLEXITY OF SUPPORTING ANALYSES  
INCREASED WITH DEVELOPMENT OF CODES
- SYSTEM DESIGN GENERALLY RESISTANT TO FATIGUE  
PROBLEMS

# CURRENT FATIGUE OPTIONS

- REANALYSIS TO INCLUDE THE ADDITIONAL LICENSE RENEWAL PERIOD
- SHOW SIMILARITY TO PLANTS WITH SEC III ANALYSIS TO DETERMINE REGIONS OF HIGH USAGE. DO DETAILED ANALYSES OF THESE REGIONS
- USE ACTUAL PLANT TRANSIENTS TO BETTER QUANTIFY THE FREQUENCY OF EVENTS
- DETERMINE CRACK GROWTH POTENTIAL AND AUGMENT THE PLANT SURVEILLANCE PROGRAM AS NECESSARY
- CONSIDER FATIGUE MONITORING SYSTEMS

## **MANAGING DEGRADATION MECHANISMS**

- **PROGRAMS SHOULD ONLY BE REQUIRED FOR COMPONENTS IMPORTANT TO SAFETY**
- **NO ADDITIONAL PROGRAMS SHOULD BE REQUIRED FOR THOSE COMPONENTS ALREADY COVERED BY EXISTING PROGRAMS**
- **RULE SHOULD ALLOW FLEXIBILITY FOR MANAGING DEGRADATION**



## SEVERAL METHODS AVAILABLE FOR MANAGING DEGRADATION

- FURTHER ANALYSIS TO DEMONSTRATE THAT THE PROJECTED DEGRADATION IS ACCEPTABLE THROUGH THE RENEWAL PERIOD
- CURRENT PROGRAMS ARE ADEQUATE TO ASSURE DEGRADATION MECHANISM DOES NOT IMPACT SAFETY
- FOR THE RENEWAL PERIOD, PROCEDURAL ENHANCEMENT MAY BE NECESSARY
  - e.g., Trending
- MODIFICATIONS TO OPERATING PRACTICES
- COMPONENT REPLACEMENT OR REFURBISHMENT

## ADDITIONAL ADMINISTRATIVE CONTROLS

- ONLY APPLICABLE TO SPECIAL ACTIONS NECESSARY TO MANAGE AGE RELATED DEGRADATION IN SUPPORT OF LICENSE RENEWAL
- SUCH ACTIONS BECOME LICENSE COMMITMENTS FOR LICENSE RENEWAL