

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission

Title: Public Workshop on Technical and
Policy Considerations for Nuclear
Power Plant License Renewal:

Docket No. Electrical and I&C Systems

SESSION 7

LOCATION: Reston, Virginia

DATE: Tuesday, November 14, 1989

PAGES: 1 - 61

*103
0/1*

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

PUBLIC WORKSHOP
ON
TECHNICAL AND POLICY CONSIDERATIONS
FOR
NUCLEAR POWER PLANT LICENSE RENEWAL

ELECTRICAL and I&C SYSTEMS
SESSION 7

Sheraton Resort Hotel
Conference Rooms A, B and C
11810 Sunrise Valley Drive
Reston, Virginia

Tuesday, November 14, 1989

8:30 a.m.

1 SESSION LEADERS:

2 Ashok C. Thadani, Director, Division of
3 Engineering Technology
4 Milton Vagins, Chief, Electrical and Mechanical
5 Engineering Branch, Division of Engineering
6

7 PARTICIPANTS:

8 George Sliter, EPRI
9 Robert McCoy, Yankee Nuclear Power Station
10 Bill Simmsac, Yankee Nuclear Power Station
11 Kirt Collins, NUMARC
12 Faust Rosa, NRC
13 J.B. Gardner, Consultant
14 Peter Bloch, NRC
15 Karl Neil, NRC
16 Mannie Day, NRC
17 Bill Hingle, Yankee Nuclear Power Station
18 Mr. Farmer, NRC
19
20
21
22
23
24
25

1 PROCEEDINGS

2 (3:30 a.m.)

3 MR. THADANI: Let's begin Session No. 7 on
4 Electrical Systems. I am Ashok Thadani, director,
5 Division of System Technology, the office of Nuclear
6 Reactor Regulations. Co-chairing this session is Mr. Milt
7 Vagins. He is chief, Electrical and Mechanical
8 Engineering Branch, Division of Engineering.

9 Our purpose here is to receive comments from your
10 discussions and questions. Before we get started, Milt
11 has a short presentation to try to focus our attention on
12 the specific issues. Milt.

13 MR. VAGINS: Those of you who are in the session,
14 before I start, I'd like to do a little housekeeping. Can
15 you hear in the back? The transcripts will be available
16 of all the sessions of the workshop. I would like for all
17 prepared speakers to give us a copy of their viewgraphs,
18 if they have them. The transcripts will be available from
19 Ann Riley & Associates, 1612 K Street, N.W., suite 300,
20 Washington, D.C. 20006.

21 Again, before we begin, I want to reiterate what
22 the basic concepts of the License Renewal Rulemaking is
23 following in the area of technical issues, and there are
24 four basic driving requirements. The rule will define or
25 specify a proposed screening process of equipment and

1 structures. It will define some structures systems and
2 components for evaluation, some for exclusion. It will
3 define a specific set of degradation mechanisms for
4 evaluation and also define requirements for corrective
5 action when degradation is not being monitored. This is
6 the basic overall philosophy. We tie that together with
7 the understanding, the basic logic of license renewal, and
8 that can be expressed in four simple words, "assurance of
9 continued safe operation." No enhancement, but assurance
10 of continued safe operation. That is the key, and that is
11 what we'll be driving to.

12 The questions that were sent out to you on the
13 original set of questions were six. Question three, which
14 dealt with industry experience with electrical equipment
15 which exhibit high failure rates during their design life
16 was inadvertently built in. It was decided by the staff
17 that that is really a today issue. If we are
18 experiencing -- and I say if we are experiencing a high
19 failure rate of equipment today, then we must solve that
20 problem. It is to not a license renewal issue. So that
21 kind of question will not be addressed unless somebody
22 really wants to address it. But again, understanding if
23 we have a problem today is incumbent upon both the
24 industry and the NRC to solve that problem.

25 VOICE: You would expect on the written responses

1 that would not be addressed?

2 MR. VAGINS: Again, I think the written responses
3 would be irrelevant because it's not a license renewal
4 issue. I regret and I apologize that that did creep in.
5 It is contra to everything else we've done. The key word,
6 again, is today issues to be solved today. License
7 renewal will address those issues which are not defined or
8 resolved and by the degradation of something beyond the
9 scope of the present license.

10 In that case, let's look at the five remaining
11 questions, and I'll paraphrase them. The first one is
12 what additional criteria for electrical equipment included
13 in the EQ program, but not periodically replaced, is
14 required. The big question here, of course, is cable,
15 cables within containment. How do you propose, or how do
16 you suggest that we deal with equipment that is EQ to end
17 of life no further, and is going to be very, very
18 difficult to replace.

19 The second question dealt with additional
20 programs to address aging degradation of electrical
21 equipment located in mild environments. Again, not
22 subject to EQ as is the case with equipment subject to
23 harsh environments.

24 Third is: programs to establish the in situ
25 condition of cable and components and the potential for

1 future degradation. Again, to a great deal this goes back
2 to cable. But it also deals with electrical equipment
3 that is not normally followed too closely. Some of that
4 will be relays, for instance, for requirements for
5 electrical equipment important to safety. That is an
6 electrical question. How do we deal specifically with
7 electrical equipment? Again, the importance is not
8 necessarily safety related.

9 Fifth was functional testing of electrical
10 equipment as a prerequisite for license renewal. Is
11 functional testing or new baseline testing of value or
12 importance or need? We would like your input on that.

13 Let's talk a little bit about the electrical
14 systems themselves. Just an example, so we're all talking
15 about the same thing, we have those electrical systems
16 relied upon for the integrity of pressure boundary and to
17 effect safe shutdowns and accident prevention and
18 mitigation. I've listed some of the equipment. We all
19 know reactor protection system and engineered safety
20 features, are Class 1. But then there are other systems,
21 electrical systems, whose failure can cause or adversely
22 affect a transient or accident, significantly challenge
23 structures, systems and components relied upon for the
24 integrity of the reactor coolant pressure boundary, safe
25 shutdowns, or mitigation and, of course, main generator

1 and reactor control system and switchyard. Failure of
2 these components challenge the system. In some cases the
3 switch-off failure leading to station blackout seriously
4 challenges our safety systems.

5 This is just a short, very short, and hardly, by
6 no means, comprehensive list, but just to give you an idea
7 of breakdowns to various areas of equipment we're looking
8 at. We're certainly looking at the importance of balance
9 of plant in license renewal.

10 With that brief summary, I'll open the floor to
11 questions. Then we will move into the prepared
12 statements. Are there any question or comments about what
13 I just said? Please stand up and identify yourself and
14 talk into the microphone.

15 MR. COZENS: I'm Kirt Cozens. NUMARC, and I just
16 wanted to verify your use of the term "challenge to
17 safety" in connection to important to safety systems.
18 Does this go beyond the definition of important to safety
19 that has been written in the NRC rule and also beyond what
20 the industry has proposed for screening structures,
21 systems and components for degradation.

22 MR. VAGINS: It depends on what the industry
23 screens and how you define what the rule is. When we say
24 challenge to safety -- importance to safety, if a system
25 fails which prevents a safety system from working, then,

1 yes, that is in the rule, the proposed rule. The question
2 is how far beyond. For instance, if a switch yard, if
3 that fails, we face severe problems, and yet that is not
4 really defined as safety related or -- obviously it's
5 important to safety. So should we deal with it? It's
6 also a system in which we have determined that
7 transformers age. These are part of the aging programs,
8 so the question becomes: we'd like to know your views of
9 how we treat these other systems. We want your input.

10 MR. THADANI: As you know, there was a session
11 yesterday, there was considerable discussion on this
12 specific issue in the screening techniques session. The
13 question was raised on the initiator important to safety.
14 There is no question about what the answer is; they are in
15 fact very important. They impact safety.

16 The question was raised, well, is that part of
17 equipment important to safety and does that include any
18 initiation? The language, if I were to take a look at the
19 language, one could interpret it any way one wants. The
20 response from certainly one industry member was that you
21 pick up some of those systems simply because you're
22 looking at mitigating systems. If you are looking at the
23 definition of important to safety, I think the words are
24 something like "systems are required to prevent or
25 mitigate accidents"; and so you would pick up feedwater

1 systems, and one could also interpret that to mean that
2 you could also pick up power supplies, because you need
3 them to be able to mitigate certain types of events.

4 We have received a number of comments on that,
5 and I think we do need to deliberate on the significance
6 of those comments. We will probably summarize those
7 comments this afternoon. But to reiterate, the focus
8 really should be the concern of significant aging
9 degradation with equipment important to safety.

10 MR. VAGINS: Again, I want to reiterate, the
11 key is, as Mr. Thadani has pointed out, what is changing
12 within the new license period. And here we're dealing
13 with aging degradation which, of course, as you know, has
14 a continuing function, and doesn't start at year 41. It
15 starts now and goes on continually.

16 With that comment, I would like to ask the
17 speakers who have submitted or have requested time to
18 speak. First of all the representative for from NUMARC.
19 Do we have a representative from EPRI? Yes.

20 MR. SLITER: Good morning. I'm George Sliter,
21 from EPRI. I'm the manager of EPRI. I'm here to comment
22 on the aging and qualification program. I'm also a
23 technical advisor to the NUMARC/NUPLEX Task Group for the
24 cable industry report for life extension of cable. I'll
25 be talking this morning about life extension of electrical

1 systems and components. It's important to point out in
2 starting, because yesterday we heard about mechanical
3 systems and reactor pressure vessels. For electrical
4 systems and components, we have a unique situation, as
5 compared with mechanical systems, for two reasons.

6 One, aging of electrical components is addressed
7 explicitly in existing regulations and standards. It's
8 addressed explicitly in the equipment qualification rule
9 10 CFR 50.49. That is the first reason. So age is
10 certainly not a new thing. It's not a new thing in
11 general, but specifically for electrical equipment.

12 Secondly, the scope of the NRC conceptual rule
13 that you have before you says that it probably will follow
14 the scope of the equipment qualification rule and that is
15 components and equipment important to safety. I think
16 it's very appropriate for the conceptual rule to follow
17 the definition of important to safety that Milt Vagins
18 went over this morning, except that it is my understanding
19 that something like the switch yard outside the bounds of
20 equipment important to safety called out in the rule. The
21 reason is we know that the plant is designed for loss of
22 off-site power, and any failure in the switchyard would be
23 no more challenging to the safety system of a plant
24 anymore than loss of off-site power. So the rule itself
25 would not include, for example, a switchyard in its

1 important to safety definition.

2 May I have the the first graph, please? So to
3 continue on this morning's note, we have an EQ rule. It's
4 10 CFR 50.49. It addresses aging degradation of all
5 significant safety components. Typically when people talk
6 about the rule in equipment qualification, they say it
7 applies only to harsh environment equipment. Indeed, it
8 says that that is the main focus of the 50.49 rule, and
9 that it does not cover mild environment equipment.

10 I want to make two points there. First of all,
11 regulations, peripheral regulations do address the
12 qualification of mild environment equipment. For example,
13 one place it shows up is in the statements of
14 consideration supporting 10 CFR 50.49, and I quote from
15 those statements of consideration. The commission has
16 concluded that, "The general quality and surveillance
17 requirements applicable to electrical equipment as a
18 result of other Commission regulations, including 10 CFR
19 Part 50, Appendix B, -- see, for example, Regulatory Guide
20 1.43, Quality Assurance Program Requirements, Revision 3,
21 are sufficient to insure adequate performance of
22 electrical equipment important to safety located in mild
23 environments."

24 Secondly, of importance to that for mild
25 environments, is the fact that the screening criteria will

1 definitely be applied to mild environment equipment,
2 looking for significant aging degradation that may impact
3 the long term operation of a plant.

4 Secondly, the EQ rule covers both old and new
5 plants. Typically we think sometimes that the rule covers
6 only the new plants because the rule does endorse
7 IEEE-323, which does apply and is committed to only by the
8 newer plants, but the rule endorses, as well as the DOR
9 guidelines, and it is important to know that those older
10 plant regulations for the older plants do address aging
11 explicitly. A quote from the DOR guidelines. "Equipment
12 using materials that have been identified as being
13 susceptible to significant degradation due to thermal and
14 radiation aging are included. Component maintenance or
15 replacement schedules should include consideration of the
16 specific aging characteristics of the component
17 materials."

18 Next, it's important to note that the equipment
19 qualification rule does not limit the component life to 40
20 years, and it allows the re-evaluation of the qualified
21 life, i.e., if you initially qualified to 20 years, the
22 rule says you can re-evaluate it and maybe qualify it on
23 the basis of operating data or new data for five years.

24 On the other hand, if qualified for 40 years, you
25 look at the data, the operating environment, and you

1 qualify it for, let's say, 60 years. So the EQ rule
2 exists and it will be continued for the extended term.

3 There are generally two types of equipment, short
4 lived components that are replaced periodically on an
5 interval less than 40 years, and for these components, no
6 additional license renewal is required.

7 Another is long lived components. They will
8 generally require extension of their qualified life or
9 alternatively, be replaced. Of the several equipment
10 types that have a qualified life of 40 years, cable is
11 especially important. It has inherently great
12 significance because it's the lifeline of the plant power
13 control and safety systems in plants, and it is also very
14 expensive and difficult to replace. Therefore, the
15 industry report right now is being prepared for cable in
16 containment.

17 The remainder of my remarks will mainly give you
18 examples of how long-lived components are being addressed.
19 I'm now turning my attention to ongoing work for the
20 industry report for cable. First, let me go over
21 something that has been talked about at other sessions,
22 but in case someone has come only to this session, let's
23 talk about a general outline of industry reports that are
24 being prepared. This gives you the steps and process to
25 first determine the component systems and structures that

1 are safety significant. For cables, this would mean that
2 the cable circuits and systems are those that are called
3 out as important to safety in the equipment qualification
4 rule, and you would determine that when you go through
5 your screening process. Next the IR would describe all
6 plausible aging degradation mechanisms, anything that can
7 realistically be thought of as degrading a cable.

8 Third, you would determine which age related
9 degradations are potentially significant. And by
10 potentially significant we mean degradation that could
11 reasonably be expected to cause common mode failure. It's
12 important in all of this equipment life extension work to
13 recognize that it's not a single failure that we're
14 looking for. Random failures can be demonstrated due to
15 built in redundancy of safety systems. Is it reasonable
16 to expect that they could cause a common mode failure not
17 only during operation of a plant, but also under any harsh
18 environment that it might see in an accident?

19 Next for those potentially significant age
20 related degradation mechanisms, we need to determine if
21 established inspection, testing or analysis procedures, as
22 currently implemented, bound age related degradation
23 mechanisms within acceptable limits. These acceptable
24 limits for cable are called out by the rule and by
25 associated regulations and standards. In particular for

1 cable, the acceptable limits are called out in IEEE
2 Standard 383. Lastly, for the significant age related
3 degradation mechanisms that could be beyond the
4 established limits or cannot be shown to be within
5 established limits, utilities would establish degradation
6 management activity for the cable. In my remaining
7 slides, I'll show you some of the options that are under
8 consideration for cable in this area.

9 Now I'll go through some of the highlights of the
10 emerging industry report on cable in containment. The
11 work is being prepared DOE, and it is being reviewed by
12 the NUMARC/NUPLEX Utilities Task Group for Cable. It's in
13 progress and the target date is June of 1990 for the
14 completion of the IR. The main scope of that IR is cables
15 in containment that are significant to safety. Any mild
16 environment or even harsh environment cables outside
17 containment would be outside the industry report. Again,
18 we can tell which cables are in the scope by using the
19 screening criteria and that is applied in the industry
20 report.

21 Next, going down the IR process we identify in
22 the report the evaluation basis, the standards of
23 regulation that applied to cables. Those are, again, the
24 qualification requirements of 10 CFR 50.49 and in all
25 qualification documents that call out the maintenance that

1 one needs to do to maintain a qualified life of equipment,
2 whether it be replacement, refurbishment, inspection, or
3 whatever.

4 Secondly, it's important to note that the way
5 equipment was qualified was by using a conservative design
6 to estimate temperature and radiation. So there is
7 built-in conservatism that for many long-lived component
8 can be taken advantage of when you go for life extension.

9 Next, operating experience for cables has been
10 very positive. It turns out that actual environments in
11 the plants are generally substantially milder than those
12 used in the design of the cables. This has come out, for
13 example, in EPRI in a plant aging program which has
14 electrical components including extensive cabling in eight
15 operating plants in the United States, and measurements
16 from that program are showing annually that the
17 environments are significantly milder than those designed
18 for it.

19 Secondly, cables have shown an extraordinarily
20 high reliability in normal operation, which is no
21 surprise. They're passive, they're designed for really
22 harsh environments, and here they are sitting in a normal
23 operating environment, and it turns out in the Sandia
24 program looking at cables they have looked at the
25 experience record and shown there has been less than one

1 half age-related cable failures per plant here in
2 operation for the past 20 years of U.S. nuclear plant
3 operation.

4 When we say failure, and it's something that
5 should be brought out in a number of these sections but
6 really isn't, a lot of people talk about failure rate
7 curves. In many cases, they are nothing more than a thing
8 not meeting some surveillance requirement, it's outside
9 its normal acceptable limits so it's more of a -- it could
10 be as little as slightly out of calibration or not meeting
11 some limit, and it's called a failure and it's plotted.
12 Those are simply the new failures that are of importance
13 when one is trying to protect how reliable and safe a
14 plant is. So let's turn now, going on to the IR for
15 cables.

16 My next bullet in the next viewgraph lists all of
17 the plausible age related testers that could produce aging
18 in cables. They include temperature and self heaters,
19 i.e., heating in cable radiation, moisture, chemical
20 effects, mechanical effects, stress and strains,
21 abrasions, and electrical degradation. The IR will go
22 through and analyze all of the plausible age related
23 mechanisms, and that work is now underway. The list could
24 be quite long. It includes mechanisms that act on
25 conductors or that act on insulation itself and that act

1 on the jacket, the entire system, and cable system, and
2 installation system. However, when it comes down to which
3 ones are the plausible or perhaps safety or significant
4 degradation mechanism, the three general ones I have here
5 really cover all of the grounds. The first is thermal and
6 radiation embrittlement of insulation, and by that I mean
7 the insulation system which could cause cracking and loss
8 of its function, especially during an accident.

9 Secondly, and especially for instrumentation
10 cable, a loss of installation resistance of the cable.
11 And third, general categories, mechanical wear that
12 includes things like vibration creep over the hard points
13 when it's hanging over a hard point along its cable tray
14 and mechanical wear due to handling during maintenance as
15 the plant operates. What will happen now is the IR will
16 look at the plausible ones and identify which of those are
17 potentially significant with respect to common mode
18 failure. That has not been determined yet. So note that
19 there are other plausible, conceivable degradation
20 mechanisms that are listed in the PLEX rule. I think
21 right now the conceptual PLEX rule puts down all the
22 conceivable ones, but we'd like to point out that some of
23 those are simply not plausible for cable in relation to
24 corrosion of the polymeric insulation and chemical effects
25 just are not plausible for cable. So for the component

1 life evaluation, to establish the bounds, what will be
2 done is a re-analysis of qualified life according to the
3 EQ rule using the original data for the cable, but taking
4 advantage of the conservatisms -- mainly the conservatism
5 in the design of the cable to accommodate environmental
6 conditions.

7 While you're at it, you also need to address any
8 issues that have been brought up over the years by
9 research. For example, the effects of combined
10 environments acting simultaneous and the cable dose rate
11 and the effects, if any, of those that have shown to be
12 significant, they will be taken into account in this
13 re-analysis.

14 Secondly, the evaluation and bounds also relate
15 to maintenance that is based on current regulations and
16 standards.

17 Now we're into the screening process here. We've
18 listed a plausible mechanism and those that are bound to
19 it. It may turn out that some cannot be shown to be
20 within the acceptable bounds for say, a 60-year life and
21 for those managing methods for aging degradation, they
22 will and are being developed for the industry report.
23 Those management options could include such things as
24 environment monitoring, condition monitoring, and
25 inspection reconfiguration, operational changes, and

1 requalification based on new test data not commissioning
2 test data and replacement.

3 Environment monitoring is very important
4 especially if you want to take advantage of conservatism
5 for life extension. I'd like to announce that there will
6 be an EPRI workshop on environmental monitoring of
7 equipment this coming year, April 10, 1990, to exchange
8 information on the topic of monitoring environments.

9 In Condition monitoring there is lot of work
10 going on developing improved methods and if those are
11 useful for life extension, and if they turn out to be
12 practical, they could be used. Inspection would look at
13 such things as located hot spots in the plant and also
14 looking near the ends of cables near a termination because
15 these are areas that are subject to degradation for
16 maintenance handling. So either in your maintenance
17 program itself or additionally as a separate walk-down,
18 you'd want to look at those areas.

19 Reconfiguration means rerouting cables. If it's
20 in a hot spot, you might want to reroute it. Operational
21 change might be reducing a current in a cable to reduce
22 self-heating.

23 In conclusion, then, I'd like to state the
24 NUMARC/NUFLEX working group conclusions with regard to
25 electrical systems. It appears that there is no need for

1 a regulatory guide in lieu of the existing rigorous
2 equipment qualification regulation 10 CFR 50.49, and the
3 guidance that contained in Regulatory Guide 1.8. The
4 outlined conceptual rule seems to be month to month with
5 regard to the use of existing EQ rules. But it needs to
6 reflect more the NRC philosophical positions regarding the
7 credit for ongoing programs, which here are clearly
8 equipment qualification programs, and also the need to
9 address only significant age related degradation, and the
10 screening process developed by the industry will identify
11 those significant age related degradation areas. Thank
12 you.

13 MR. VAGINS: Are there any questions or
14 discussions on what George has presented? The only
15 comment that I have, of course, is that mice and rats have
16 been known to change the configuration of electrical
17 systems and they're not included in either your studies or
18 mine. Mice are a plausible possibility. Are there any
19 questions?

20 I think George made a very fine presentation and
21 I think this is one area in the electrical area where we
22 have got to try and the NRC has spent a great deal of
23 effort in the aging programs long before it became
24 fashionable; it is not the only area. I think pressure
25 vessels for the last 25 years have spent time on aging

1 there, too.

2 Question?

3 MR. ROSA: Faust Rosa, NRC. George, at the
4 meeting I attended a couple of years ago in San Francisco,
5 the question of detecting mechanical damage to cables in
6 condos was a pretty heavy topic of discussion. What are
7 the developments in that area, because I think the
8 possibility of widespread mechanical damage may pose quite
9 a problem?

10 MR. VAGINS: I think that issue was raised in one
11 of the questions. So let's bring up that question.

12 MR. SLITER: I was going to raise my hand and ask
13 the question, so I'll ask my questions first because it
14 has to do with yours, I think. Then I'll answer question
15 number four. It says most cable has been qualified for 40
16 years, 100 year life as demonstrated in certain installed
17 applications and conditions, including environment,
18 pressures, cable, electrical loading and cable mechanical
19 loading for which a cable was designed.

20 Here is my question. Given that manufacturers
21 have provided certain important initial parameters for new
22 cable, what kind of programs should be proposed that could
23 be instituted to establish the in situ condition of a
24 cable and the potential degradation that would take place
25 beyond the current design life? What is the meaning of

1 importance of initial parameters?

2 MR. ROSA: I would attempt to address things like
3 mechanical strengths of the insulation, the jacket, the
4 insulation resistance of new cable, for instance, things
5 of that nature.

6 MR. SLITER: The answer to your question, Faust,
7 is first and most importantly, that the issue you raised
8 is a new issue. The plants need to have installed their
9 cables according to good practice, and if they are not, it
10 is a new issue. Given faulty installation, it is not
11 plausible or significant that aging would worsen things.
12 If you damage the cable on the way in, that is your main
13 damage. The aging is not going to increase too much over
14 years.

15 So the important thing to realize is that cables
16 need to be installed properly, and if indeed there is some
17 kind of a problem somewhere in the installation, it more
18 than likely would be taken care of by the single failure
19 thing. It would have to be widespread and rampant abuse
20 of installation practice before you could ever get into a
21 mode in which you're likely to have a failure mode. So,
22 first, it's a new issue. Second, it's covered by
23 redundancy of safety related systems. But let's just tack
24 on here now, outside the scope of life extension that it
25 is indeed an issue for at least one particular plant.

1 We all know that TVA had that particular problem,
2 and indeed if any plant is having problems in their cable
3 systems, it would be good if we had a condition to monitor
4 or an in situ test technician that could go in and test
5 the cable and tell whether it was okay or not. EPRI is
6 trying to develop some methods.

7 MR. VAGINS: I do want to make reference to what
8 was said about cable. Today there is a problem that will
9 extend into life extension. I think monitoring programs
10 are significant. NRC has cable monitoring programs that
11 NIST -- I'll never learn to say that correctly -- it was
12 the NBS, and of course George has his programs and we will
13 hopefully come up with some good cable monitoring methods,
14 and they, of course, will then be available to be applied
15 to now, to tomorrow, and the day after.

16 Are there any more questions or discussions for
17 George's presentation, which I think is a good one? The
18 next speaker scheduled is someone from Northern States
19 Power, Monticello. Anybody here? How about Yankee?
20 Yankee will speak.

21 MR. MCCOY: Good morning. My name is Bob McCoy.
22 I'm here representing Yankee. I'm a senior electrical
23 engineer there for over five years. The last few of those
24 years I've been on the licensing renewal project. I'm
25 also vice chairman of IEEE Working Group 4, which is

1 presently writing a guide on the aging assessments of
2 Class 1 equipment, and I'm also helping George with the
3 cable industry record.

4 The primary function of electrical and I&C
5 systems is to provide power, control, instrumentation to
6 fluid and mechanical systems. The I&C systems are
7 generally composed of similar and interchangeable
8 components.

9 Section XX.9.1 requires that as Section 9 as
10 we go through, require identification of design
11 requirements, functional and environmental conditions,
12 degradation of mechanisms, and also requires programs to
13 identify, evaluate, and trend effects of relevant
14 degradation for all equipment important to safety.
15 I stress that it requires it for all equipment.

16 It's our contention that Section 9's scope is
17 unnecessary. It's recognized that degradation concerns do
18 not exist for many components. This is because of design
19 considerations, benign environmental conditions,
20 inspection, and maintenance programs, refurbishment or
21 replacement programs. The rule needs to consider these
22 factors so that resources can be focused on the areas
23 warranting attention.

24 Section 9 differs in this regard from the NRC's
25 expressed philosophy on page 10 of the proposed rule which

1 states, "Those structures, systems, and components that
2 are effectively covered by existing ongoing NRC
3 requirements and/or licensee programs, or are not subject
4 to aging mechanisms, need not be addressed in the
5 application."

6 Now coming back to electrical and I&C components,
7 what causes degradation for electrical and I&C components
8 is temperature and radiation, with also some effect from
9 the operation of the equipment. Many of these components
10 are located in areas with controlled temperature and
11 radiation, and they're in the mild environment. Many of
12 those components are also covered by existing programs
13 which maintain, refurbish, and replace its components.
14 It's these programs that have been proven effective over
15 years of operation, and they are continued to be updated
16 as we learn more.

17 Some examples are I&C setpoints. We look at
18 instruments and see its setpoints starting to drift. If
19 it drifts too far or too often, we'll refurbish the
20 instrument. Another is battery testing. Periodically we
21 do a performance discharge test or a capacity test. We
22 replace the battery when it reaches 80 percent of its
23 capacity. This is in accordance with the IEEE standards.

24 Class 1E equipment must meet their safety
25 functions over the installed life of the equipment. This

1 is accomplished through a program of quality assurance,
2 design, qualification, production, transition, storage,
3 installation, maintenance, surveillance, and periodic
4 testing. Thus the Class 1E equipment is continually
5 maintained, refurbished and replaced. They must meet
6 their safety functions throughout the initial licensing
7 period. With the continuation of these programs, Class 1E
8 equipment can safely be licensed for a licensing term.

9 Some programs are periodically being replaced.
10 Functional testing, calibration, monitoring the cause of
11 degradation -- and what I mean by that is what George
12 Sliter talked about earlier. Maybe we can monitor the
13 environment if that is the cause of degradation. These
14 programs are continually updated and they improve with
15 time and knowledge. We're learning all the time.

16 Another example is environmental qualification in
17 accordance with 50.49. This requires that an aging
18 analysis be included to demonstrate the equipment's
19 operability. 50.49 will be applicable during the license
20 extension as well. So this should not be required to be
21 addressed on the application.

22 In conclusion on these existing programs, I'd
23 like to make it so that the rule should allow flexibility
24 to credit existing programs where they're found to be
25 effective. What we're looking for are those components

1 that are not uneffective programs. Degradation mechanisms
2 are understood based on years of experience, but the
3 understanding is continuing, especially in environmental
4 and material interactions.

5 Some examples of the degradation mechanisms we've
6 come to find, are thermal and radiation embrittlement,
7 loss of dielectric strength, and loss to dielectric
8 strengths also means loss of installation resistance.
9 They have different connotations. For most components,
10 analyzation and inspection of actual conditions will help
11 to define the degradation mechanisms. Some will be
12 defined by further evaluations. For example, the cable
13 industry, as George discussed earlier, is under an
14 industry investigation to determine if conservatism in the
15 design and application is adequate to allow continued
16 operation through an extension period or should we apply
17 some additional inspection programs.

18 Managing degradation mechanisms. Additional
19 programs should only be a requirement for equipment
20 important to safety. No additional programs should be
21 required for those covered under existing programs --
22 existing and effective programs. For example, the EQ rule
23 should allow flexibility to credit these programs.

24 Several methods that can be viewed for managing
25 degradation. One is further analysis which can show that

1 the degradation is acceptable. Another is a current
2 program that can assure that the degradation results in no
3 safety impact. We urge that procedures may have to be
4 enhanced in some cases and that is another method of
5 managing degradation. For example, we can use some
6 trending. We can change operating practices if the
7 degradation is based on the operation of the equipment, or
8 we can replace and refurbish it even periodically or based
9 on some indication.

10 I touched on trending on the last slide. But
11 trending should not be applied unilaterally to all
12 equipment. Some examples where existing programs
13 suffice -- if we replace the equipment before it
14 degrades, for example, setpoint drift; or if there is
15 existing programs that periodically refurbishes the
16 components we need not trend; or third, by operating so
17 that degradation is not a concern. For example, the
18 number of systems for the environmental conditions.

19 The point I'm trying to make is we should
20 efficiently apply trending only where meaningful and
21 justified. Administrative controls should be implemented
22 to those specifications that are required to manage
23 degradation. These can be maintained as licensed
24 components.

25 I'd like to bring us back to Section 9 of the

1 proposed rule. Section 9 should be a screening process.
2 The screening process should be based upon important to
3 safety not covered under existing programs and subject to
4 significant degradation. Thank you.

5 MR. VAGINS: I think Mr. McCoy's presentation,
6 again, reflects Yankee's continuing and ongoing valued
7 efforts which, along with Monticello and Northern States
8 Power, represent real efforts. Are there any questions or
9 any statements concerning Mr. McCoy's presentation, which
10 I thought was very thorough?

11 MR. ROSA: Faust Rosa. I have sort of a hang up
12 with cables in containment. I don't understand how an
13 ongoing equipment qualification program on cables in
14 containment can be used to the extent of the qualification
15 of those cables?

16 MR. SLITER: I think, Faust, the problem you may
17 have is not understanding the total concept and approach
18 that the industry has used to qualify cable. I suggest
19 you look in IEEE-323, not that it applies to all plants,
20 but the concepts do. Qualification is not only a test in
21 the local chamber. It goes way beyond that. In the
22 introduction to 323 it says, "Qualification is based not
23 only on testing, but on a good design installation,
24 maintenance, QA, the whole smear that is qualified cable.
25 And there is no question in anyone's mind that if someone

1 does a poor job in any one of those areas, they may
2 violate the qualified status of cable. It's advisable not
3 to violate any one of those. What is it you don't
4 understand?

5 MR. ROSA: I guess it's the fact that the proving
6 element in the qualification programs for cable or any
7 other equipment is a test. And we have performed tests on
8 these cables in the local environment, and now it appears
9 that the direction that you're taking seems to point to --
10 let's use those test results and the consideration of all
11 of those elements you just mentioned and extend the
12 qualification of that cable for some period of time. I
13 don't know how effective that is going to be, and that is
14 my problem?

15 MR. SLITER: When we reinterpret test data --
16 when I say that, I mean reanalyze it. We're talking about
17 a measured environment which is valid, and we are also
18 being very careful to address any significant aging issues
19 that have been brought up by research over the years.
20 Those items are the places where there could be
21 substantial differences in one answer over what we got
22 originally. We'll address both of those. But my main
23 answer goes back to what you brought up. You said you
24 don't understand how that single test tells you
25 everything. My only response is the one I said a moment

1 ago, that it is not the only way we can qualify cable.
2 Qualification includes all of the good features I talked
3 about, done according to industry practice, and one of
4 them is cable installation and it needs to be done
5 properly. So I think a cable test is just one element of
6 a good qualification program.

7 MR. GARDNER: J.B. Gardner, consultant. I was
8 going to add another word of clarification that might
9 help. Test qualification, EQ procedures consists of two
10 things. We make a device look old, 40 years, and then we
11 test it. Now when you make a device look old, you go
12 through some routine of pre-aging, which you think is good
13 for 40 years under certain assumed conditions. It's good
14 for 100 years under different assumed conditions, or 20
15 years under other assumed conditions. That is all in
16 equivalence. So what George is talking about, okay, we
17 did it for 40 years, we think, sometime ago. But we get
18 new data now and we say that wasn't 40, we really tested
19 it for 80. So that is the concept of how you extend a
20 qualification. I like to call it qualification extension,
21 not requalification, because requalification brings to
22 mind doing the whole smear and testing, including
23 everything else. But the extension simply means you use a
24 test as it was, but you use the condition as it is now
25 revealed rather than as it was assumed. That permits you

1 to have a different requalification for productive years
2 of successful operation.

3 I'd like to comment on one thing, George. In
4 addressing this question of using prequalification data,
5 as you realize, the plants have been qualified and are
6 under three different sections. The older plants were
7 permitted to qualify without pre-aging, and I think
8 therein lies a good question as to how you demonstrate a
9 cable which was never pre-aged as part of the
10 qualification test. They can now be proven to be
11 suitable, especially most of those old cables that are not
12 even made today and are not available.

13 MR. SLITER: I agree with you, and that is one of
14 the main things we need to look at in the industry report
15 and that is being examined, of course. On what basis do
16 you make the judgment that you have demonstrated that you
17 do not have a cable that has aging effects that could give
18 you a problem?

19 MR. BLOCH: Peter Bloch from NRC. I wanted to
20 ask if I understand correctly that something is not
21 significant to safety if it would bring down the redundant
22 piece of equipment, but does not cause a common mode
23 failure? Maybe you can comment a little more?

24 MR. SLITER: There are certain types of
25 degradation, some that could be expected to cause common

1 mode failures. For example, if two redundant systems both
2 went through the same compartment that was not found to be
3 too hot, they would both degrade, crack, and there could
4 be a common mode problem in that.

5 Another example of common mode would be, of
6 course, the accident environment, which is directly
7 addressed, and you just go through degradation mechanism
8 after degradation mechanism and ask yourself is it
9 reasonable to assume that you could have 26 of these
10 affecting redundant safety training? If the answer is
11 yes, then it needs to be addressed in a qualification
12 program.

13 The early founders of nuclear plants, in their
14 approach to qualification, realized there was no way that
15 they could assure that there would be no failures of
16 safety related equipment. We depend on defense and
17 redundancy. An example of this would be maintenance
18 errors. If someone is putting back a piece of equipment
19 and he gouges off cable, the accident comes along and he
20 fails a piece of equipment. He did it the same day and
21 that same guy -- it's not reasonable to suspect he would
22 have done damage to the other system. That is known as
23 random failure. If a failure is easily detectable, you
24 see, you can fix it.

25 MR. BLOCH: Can you have failure which doesn't

1 cause common mode failure?

2 MR. SLITER: Sure.

3 MR. BLOCH: Are those safety significant?

4 MR. SLITER: No, because you have a redundant
5 system.

6 MR. BLOCH: You say it takes down the margin of
7 safety for the operation of a plant?

8 MR. SLITER: It takes down the margin of safety.
9 It's not a question of taking down the margin of safety.
10 It's a question of whether the margin of safety is
11 acceptable in the way the plant was designed with its
12 redundant system, whether it was to insure an acceptable
13 margin of safety. It's taking advantage. You're just
14 looking at it from another point of view. You are taking
15 advantage of the margin of safety. You don't operate your
16 plant after an accident. You should shut down and repair
17 everything that has been going wrong.

18 MR. THADANI: George, I had a similar question.
19 It's still not clear to me what you really mean by the
20 fact that a plant is designed to be able to take a single
21 failure?

22 MR. SLITER: Yes. The plant was designed for
23 that, and the very reason it's designed to be able to take
24 single failure is -- it's not like I'm going to have a
25 single failure. It's not likely that that would happen.

1 But if that were to happen, I have back up. The question
2 is are you suggesting it's okay to change the likelihood
3 of initial failure, single failure, and if you change the
4 likelihood of the failure in a significant way, then you
5 have, in fact, reduced the margin of safety.

6 The next question is how significant is it? It's
7 not clear to me how you interpret that or what is your
8 level of threshold.

9 MR. SIMMSAC: Bill Simmsac. Yes, having been
10 involved with the putting together of NUMARC, it was never
11 intended to screen criteria upon equipment. Redundancy is
12 not a reason for disposing of it. Just because you have
13 one train versus another doesn't mean you can get rid of
14 both trains. The criteria is meant to be applied in the
15 following manner:

16 If you have any system to perform that function,
17 then if that equipment is important enough to be looked at
18 with regard to license renewal, it was never the intention
19 to use redundancy as an argument for screening out
20 equipment.

21 MR. VAGINS: Whether it's redundant or whether
22 it's only a single occurrence failure, if it is age
23 related, it will be covered by the rule. There is no such
24 thing as a nonsignificant, age related failure, because it
25 is an indication of the existing age. There must be

1 something aging somewhere else. To define a single
2 component age is extremely unlikely. You're going to find
3 similarities. The program has to cover all failures.

4 I hope that clarifies the issue. I don't think
5 it meant anybody is going to stop and say we don't care if
6 it fails because this is backup. We don't want any
7 possible failure.

8 MR. SIMMSAC: Earlier we began a section -- you
9 had a slide up there that showed a main generator and
10 control switch area being --

11 MR. VAGINS: No, I said we'd like to have your
12 opinion, but we'd like to have your thoughts and what they
13 should be.

14 MR. SIMMSAC: If you considered them, is it only
15 to the extent that the equipment ensures proper isolation?
16 For example, on the electrical side you make sure your
17 station service system is effectively isolated from a grid
18 in case of a problem, so you don't bring down the
19 greenhouse system?

20 MR. VAGINS: Yes. I personally desire that we go
21 further, but I think what the NRC is proposing is if those
22 systems fail or interfere with our safety system or
23 prevent a system --

24 MR. SIMMSAC: So with regard to the switchyard in
25 Yankee's case, our transformers are separate from the

1 switchyard, but the isolation is still with transformers
2 and switchyard, and the screening is not, but station
3 service transformers and their isolation equipment are.
4 So that philosophy is what we're using. If we do it that
5 is great.

6 MR. VAGINS: It also stands to reason if we
7 determine indeed transformers out there are aging, you're
8 going to look at them. If your switchyards go down, you
9 don't want loss of off-site power. I assume you're going
10 to do something about it.

11 MR. MR. SIMMSAC: We're looking at it up to the
12 extent that the controls effectively produce a reactor
13 trip and isolate a steam system properly. It's an
14 economic conversation. So, I guess based upon this
15 interchange, the interpretation in the phrase in Section
16 3C-1, where you can make a definition to prevent or
17 mitigate a consequences, this is the flavor in which you
18 mean that phrase to be used.

19 MR. VAGINS: If you sat in on the screening
20 section yesterday, you would know that there was some
21 discussion about broadening it to this year.

22 MR. MR. SIMMSAC: That is where I want to make
23 the clear distinction between an initiator that could have
24 ramifications in the safety of the system, or rather
25 things just being a pure initiator that some equipment

1 brings the plant down.

2 MR. THADANI: I think you make a valid point.
3 You used a good example. You may have hundreds of
4 different ways you can trip the turbine, and it might not
5 be reasonable to, let's say, dig into each one of those
6 ways that the turbine can be tripped. And let's control
7 all of that, because if you really have a significant
8 problem, you ought to see it pretty quickly, I would
9 think.

10 On the other hand, I think as you noted, the trip
11 is a very important function and can help mitigate certain
12 types of events. We ought to focus on that function. I
13 agree with you, a difficulty comes in. But there may be
14 some other areas where certain initiators may be important
15 and those systems may not be classified in the classical
16 exception as mitigated systems. What do we do with those?

17 I think the conversation, particularly yesterday,
18 that we had was certainly helpful to me, and I think it
19 will force us to look back through that issue a little
20 more carefully. As you see, we're doing a lot of soul
21 searching and we want as much input as possible. We're
22 not looking at it too closely from the age viewpoint
23 because the challenges are not severe.

24 But again, we're not looking at them. Therefore,
25 the question now becomes strictly one of license renewal.

1 We're not looking at them. Are they aging and can they
2 cause more challenges than we'd like? That is one way of
3 looking at that. The other way is maybe challenges will
4 increase, but they aren't significant. This is the kind
5 of input we need from you guys from outside.

6 MR. NEIL: Karl Neil, NRC. On the switchyard,
7 I'd like to make one comment. In loss of off-site power,
8 the reliability of the switchyard has to be maintained
9 from the aging standard for a renewal period. My question
10 relates to has there been a number?

11 We've heard it often enough here in the last two
12 days, the philosophy and the conceptual rule with respect
13 to the scope of what is required. In other words, the
14 philosophy says we'll give credit for ongoing programs.
15 The most recent speaker from Yankee pointed out that he
16 would like credit for ongoing programs, ongoing effective
17 maintenance procedures, things likes that. In terms of
18 ongoing programs that the NRC administers, we know what
19 they are. I don't think we're going to have much
20 difficulty giving them appropriate credit in the rule and
21 addressing that. But in terms of licensee programs, I see
22 some difficulty in how do we incorporate it in the rule
23 provision so that licensees can take credit for their
24 individual programs? My question is what are the
25 suggestions with respect to specifically, how do we do

1 this in the rule? How would you suggest we write the rule
2 so that licensee programs can be given credit for?

3 MR. VAGINS: I think the question was pretty
4 clearly presented. Does anybody have an answer to it?

5 MR. DAY: Mannie Day, NRC. I had a question
6 along the same lines. How many of these programs that you
7 have mentioned are tied to industry standards? Or are
8 they just programs that exist at Yankee?

9 MR. MCCOY: Where there is industry criteria for
10 programs, that criteria is utilized, as I mentioned, in
11 battery testing and things like that. But a lot of the
12 programs are based on our own experience and feedback we
13 get, such as circulars and notices that we factor into our
14 maintenance programs.

15 MR NEIL: Karl Neil, NRC. I think that was
16 exactly what I had in mind. If there are some standards
17 that we could refer to, then we could list those in the
18 consideration and include them in the rule somehow. I
19 think that would be an easy way of handling it. But if
20 you're talking about a specific plant procedure in
21 individual plants that are all different, it's going to be
22 more difficult. I think if you want credit for those,
23 you're going to have to address them in some kind of way
24 in the rule, and I don't see my way clear to doing that at
25 the moment. If I sat down and wrote that part of the rule

1 right now, it wouldn't flow easily.

2 MR. VAGINS: I don't see any simple way to handle
3 that. It would have to be, since each plant would be
4 different. We keep addressing and discussing the
5 uniqueness of our plants. But I don't see any way to
6 submit a program for approval by the NRC as part of their
7 relicensing basis.







8 MR. ROSA: Faust Rosa, again, NRC. I might offer
9 a suggestion to the industry. There is a pretty strong
10 economic incentive to keeping a plant operating. Failures
11 like main transformer failures, unit transformer failures,
12 switchyard failures, these all impact the operability of a
13 plant from an economic standpoint. The rule might address
14 the level of operability of a plant as a measure of the
15 programs within the plant for keeping these things in a
16 reliable condition.

17 MR. VAGINS: That is something of course that the
18 agency has been playing around with for a long time. But,
19 again, we want to make sure we don't infringe on the NRC's
20 function, safety. It is their interest, yes. A really
21 safe plant doesn't do anything. It's very safe. It's
22 there.

23 MR. HINGLE: Bill Hingle from Yankee. I'd like
24 to comment just a moment on the use of existing programs.
25 I think Karl Neil was questioning that. I think in some







1

IMAGE EVALUATION TEST TARGET (MT-3)









1

IMAGE EVALUATION TEST TARGET (MT-3)









1

IMAGE EVALUATION TEST TARGET (MT-3)



1

IMAGE EVALUATION TEST TARGET (MT-3)



1 cases you can credit programs which meet specific criteria
2 and that has been proposed in screening methods, to apply
3 those criteria to the evaluating of programs we think we
4 have in place to cover certain pieces of equipment. Those
5 run something like this: The programs document, approve,
6 and routinely implement in accordance with those
7 procedures. If a program assures all components of
8 significant safety functions, or aging is addressed, and
9 if the programs establish the acceptance criteria and
10 requirement for follow-up action.

11 So what you could do is establish criteria that
12 have to be met that wouldn't be produced in a document.
13 All the information is on the application. We would
14 propose that we would have that documentation. In other
15 words, we have to begin through satisfying ourselves that
16 we meet those bases, and that could be audited. It seems
17 to me that you could write it in your rule like that and
18 it would be audited.

19 MR. THADANI: Let me, for the record, at least,
20 say that industry's responsibility is more clearly safety
21 as well, and the second part of NRC's responsibility is
22 safety, yes, indeed. But after a certain level of safety,
23 we do have to take that into account. So I think it's a
24 little bit more than what we stated earlier. We can't
25 just go beyond our basic level of safety without proper

1 consideration to cost.

2 MR. VAGINS: I want to reiterate what I said, and
3 that is that in no way did I intend to say we're not
4 interested in operability. I said how to measure, how to
5 interpret operability, again, from the viewpoint of
6 safety. Obviously, the prime responsibility for safety
7 lies with the owners and utilities, not with the NRC. So
8 obviously, you guys are concerned with safety, too. There
9 is no such thing as a utility not concerned with safety.

10 I'm just kind of curious -- as things go on,
11 people talked about monitoring methods. How many
12 utilities out there right now use thermographic
13 inspections of control centers, you know, control centers,
14 circuit breakers, et cetera? Yankee went up. Are there
15 any other utilities here? That is kind of interesting.

16 I suggest that maybe utilities ought to think
17 about that. For instance, having plants have phenolic
18 boards. You talked about mild environments. I have a
19 couple of electrical radios that go back 30 years and
20 other things that are sitting in my house which seem to be
21 in a mild environment, particularly if you don't have
22 children. Phenolic boards, I wonder how many people are
23 looking at them. It's been a very good exchange, and I
24 would like to keep going. Are there any other comments?
25 Mr. Aggarwal has some comments he would like to make.

1 MR. THADANI: I recommend we take a break and
2 come back. Let's make sure the focus of this session is
3 clear to everybody. I'm not looking for any input from
4 you on the issue of source term. Whether we're going to
5 change a source term for license renewal purposes or not
6 is a separate matter. You're certainly free to make
7 comments, but recognize that I'm not looking for feedback
8 on that issue. Other than that, why don't we take a
9 break. I know there is lot of interest, but let's take a
10 break for a few minutes. We'll hear from you soon.

11 (Short recess.)

12 MR. THADANI: Satish raised some stimulating
13 questions, and I know there were a lot of people anxious
14 to respond to those questions. George, you wanted to
15 start out?

16 MR. SLITER: Satish, one of the main responses
17 I've heard over and over -- I won't dwell on it -- is that
18 almost all the issues you raised in your comments have to
19 do with now issues and they should be handled in the now
20 environment and not in the plant life extension. I must
21 point out that what was in your conversation, I felt was
22 addressed in my presentation, describing how the industry
23 addresses mild environment equipment, balance of plant
24 equipment, important to safety, et cetera. I think you
25 should rest assured that the industry approach to life

1 extension of electrical equipment has come up with a
2 screening process which should be assurance to you from
3 that for life extension at that mild environment equipment
4 and equipment that is important.

5 The safety in a plant will be looked at, again,
6 with respect to identifying significant aging mechanisms
7 and assuring ourselves and the regulator that they have
8 been adequately handled. So it's indeed another
9 opportunity for the NRC to make judgments on adequacy for
10 those programs for life extension.

11 MR. VAGINS: Any others? We have one more
12 scheduled speaker, Mr. Gardner.

13 MR. GARDNER: I'm J.B. Gardner, consultant. I
14 have been involved in cables for some 40 years and on
15 nuclear application of them for about 20 of that; on the
16 manufacturing side the last 9 years as a consultant. All
17 of my remarks are cable oriented. I'm going to try to hit
18 points that may have been omitted or sidestepped by
19 previous speakers.

20 Age related degradation, aging effects, as I'd
21 like to call it, are the name of the game and relative to
22 the rule that is being considered. There are a number of
23 mechanisms that are described there and I would like to
24 suggest that it might be good to name the mechanisms in
25 the rule, simply to get the NRC and the utility industry

1 talking or addressing the same terms so that new worms
2 don't get picked out of the can unexpectedly when people
3 go for extensions. But if they're enumerated, they should
4 be segmented into those that are pertinent to different
5 sorts of materials. I think it is very different from
6 those important organics which may be very different from
7 those that are pertinent to electronics. I think just to
8 put down the shopping list pretending that they all
9 pertain the same thing to all would be very misleading.

10 That brings us now into -- oh, there is an
11 omission to that which certainly is pertinent to cables
12 and to other things, too, because I see 100 percent
13 humidity in number specifications for plants, and I
14 believe that moisture, as George pointed out, is very
15 definitely an age-related mechanism of failure which has
16 not been addressed and should be in the industry both now
17 and later.

18 Common cause failures is the driving agency for
19 qualification. This is noted in both 323 and in 189. So
20 I think that is the thing that we should all keep in mind.
21 That is the name of the game in terms of prime effects on
22 safety. You can't talk about common cause failures
23 without thinking about what is the failure mode that we're
24 looking for in the common cause. That is a wild English
25 expression in gram r. But anyway, I think the point

1 should be clear. We should be thinking of common cause
2 failures. To do that, you have to think in failure modes.
3 To do that properly in the case of cables, we have, both
4 now and in the future, a problem that it isn't really
5 cables, but cable systems which connect all of these
6 active elements in our plants together. The industry is
7 way short, and I say the industry, IEEE for instance, in
8 addressing all the connections, interfaces of many kinds,
9 which are necessary for the cable system to work.

10 Again, this is both a new and a future issue.
11 Whether you want to then disclaim the thing as being a
12 concern of extension, I'll mention that a little later.

13 I have a real concern because there are many open
14 issues in qualification of cables. These have been very
15 well pointed out in some Sandia research and reporting.
16 Some of those have also been reported recently in the IEEE
17 studies, and the work that is going on both point out the
18 open issues, as well as point out how some of them can be
19 addressed. I think that is a very constructive way to go.

20 Again, it's sloping over between now and future
21 concern. But the question I have with much of the work is
22 that not only is it just focusing on cables, but there has
23 been a lack of operational requirements being
24 realistically described. Going back in history, the
25 operational requirements that were put in the

1 specifications to cables suppliers were grossly inadequate
2 in light of present day technology in knowing what the
3 systems require. And this is the case again.

4 One could consider it a new issue, but certainly
5 if we are going to delve into new technology, new signs to
6 free research to help solve the problems, the question
7 comes to mind, if we use new research, do we use the other
8 products and research? Say to yourselves we need to
9 address all of the aspects that research turns up, not
10 just the goodies that will help us follow through.

11 That is an ethical side of what Mr. Aggarwal was
12 saying. If we use some benefits, do we also have the
13 obligation to use all of what the research is turning up
14 in the light of life extension? I think the bottom line
15 then of what I'm trying to bring to light is that EQ
16 extension is the name of the game for the cables, and much
17 of the electrical system follows along the lines that
18 George Sliter pointed out so well. This focus is on
19 common cause failures. It gets into the system and all of
20 the modes of failures which a common cause might inflict.

21 Turning now to the rule, I've mentioned already
22 the degradation mechanisms being mentioned therein and
23 that they should be segregated. The other is that I think
24 the rule would be very helpful if you mentioned in it
25 something about relation of equipment qualification,

1 because in the electrical system, this is the name of the
2 game. I see very little, if any, mention in the rule to
3 this key element. For the moment, I think that will
4 conclude my remarks. Thank you.

5 MR. VAGINS: Is there anybody who would like to
6 comment on that? My general comment, of course, is that
7 emphatically, no, we are not going to ignore the negatives
8 and emphasize the positives. That is just not in the
9 game, and NRC will not do that. But as I mentioned to you
10 privately and as I'd like to tell the audience, in some
11 sense, negatives are tomorrow's positives.

12 What do I mean by that? We have a system now
13 which is in place. It says you're good for 40 years. I'm
14 not going to say whether it's correct or not. That is
15 another issue. Right now it's in place. If you want to
16 use a positive to expand it, you have to prove your case.
17 If we find a negative to challenge today's rules, we're
18 going to change it today. We have to find it. We have to
19 prove it. We have to make sure it's true. Rest assured
20 that is our mission in life.

21 One of the biggest missions of the NRC -- and by
22 the way, the mission of the Office of Research that was
23 put into statutory words in the Organization Act of 1974
24 is that the Office of Research will do confirmatory
25 research. So one of our biggest missions in life is to

1 say these are the rules in hand. Are they any good?
2 Prove it. Unless we get completely out of the budget, can
3 you tell us -- which Gramm-Rudman is doing to us today --
4 we would like to solve the problems and we are going to
5 within whatever possibilities of funds we have. But I
6 just want to emphasize that again. No, we're not going to
7 ignore the negatives. It is our job to look at the
8 negatives and to make sure they do not impact safety.
9 It's the responsibilities of plants and the owners. It's
10 their first responsibility, and they are primarily
11 responsible for safety.

12 So I think that is true. As far as how slow we
13 move, well, sometimes it's hard to prove and sometimes it
14 takes a long while to do it. But I think we have a track
15 record of eventually doing it. If we can find something
16 which needs immediate safety action or immediate safety
17 concern, we will act immediately. That doesn't mean
18 shutting down plants, by the way. Sometimes we can handle
19 the problems in other ways, as we did with the pressurized
20 thermalshock issue.

21 Are there any more comments to either Mr.
22 Gardner's comments or Mr. Aggarwal's comments?

23 MR. FARMER: Farmer, NRC. As you're well aware,
24 Sandia performed the detailed assessments of the source
25 terms using all the latest mechanistic calculational

1 methods, and the results came out showing that dose
2 equipment inside containment is essentially consistent
3 with those in the old TID. That is happenstance, but that
4 is the way it came out. So based on that, at least this
5 time there really is no basis of changing the rules. If
6 there was any change, it might be that we look at severe
7 accidents and doses are ten times higher than what they
8 qualify for.

9 MR. VAGINS: Severe accidents is another issue,
10 and the Commission says that it will be closed before
11 license renewal. Of course, it doesn't remove the concern
12 that Mr. Aggarwal brought up of Category 1 on plants. If
13 we have plants -- if plants have done the equivalency
14 study, I think we do have a problem. I think Yankee knows
15 that. We're waiting to see what they do with the
16 extension of these plants.

17 Again, one of the areas most of us deal with
18 regularly has a great deal to do with debt. And the
19 professional societies and the IEEE are very active in
20 looking at aging degradation maintenance methods, et
21 cetera. I would only encourage them to continue. We
22 would love to have a system where we could sit back and
23 endorse industry standards. That would make it the
24 simplest thing in the world. So with the professional
25 societies and IEEE, we're able to move to the issue in

1 time. That would be one way of addressing it. But it's
2 pretty obvious that they're not going to be able to be
3 exceptionally timely in the next two years.

4 MR. GARDNER: In line with your last comment,
5 working group 3.46, EPRI is indeed rushing through some
6 guidelines which I hope will contribute to the general
7 question of plant life extension. So we hope that it is
8 of some help to try, of course. There are many people in
9 this room that are contributing to that. I might add that
10 my observation, unfortunately, is that the rest of the
11 IEEE community is not very active in addressing
12 qualification issues. That is the way it seems to be
13 right now, today.

14 MR. VAGINS: To some extent it boils down to
15 whose objection is being barred and who is going to
16 support whom and who is going to what meetings. And in an
17 era of cutbacks and fund restrictions, unfortunately we
18 get impacted in professional societies. But anyway, it
19 still stands as a fact that if we had standards to cover
20 everything, we would use them. We have in the past and we
21 will continue to use them. Are there any other questions
22 or comments? Any other speakers?

23 MR. BLOCH: I want to speak briefly. Peter
24 Block. I have been a judge on the Licensing Board Panel
25 since 1981. I have worked with experts at my side as we

1 judge cases involving licensing of nuclear power plants.
2 My concern in being here is to think ahead to the time
3 when there will be an application before me and my fellow
4 judges, and I want to speak on trending. I want to speak
5 on it because of the Comanche Peak Nuclear Power Plant
6 case where the intervenors came in and proved the records
7 of the plant were not being trended. Appendix B to Part
8 50 currently requires that you trend the nonconformances
9 that you find in plants. It's a requirement that you must
10 learn what is happening in your plant and learn from it.
11 I can't think of any more important a requirement to keep
12 a plant safe than to find out what is going wrong and to
13 learn why it is going wrong.

14 Even though it's a new issue, it's obviously of
15 extreme, great importance when it comes to plant life
16 extension, because whatever is going wrong as a plant ages
17 can go wrong in a different way and in an increasing way.

18 If you trend, you'll see those components that
19 are failing more frequently and you'll know what the
20 problem is. The records will allow you to see what the
21 problem is. Now whether or not trending becomes a part of
22 the plant life extension rule, there is a possibility that
23 it could become an issue in the plant life extension case
24 because it's relevant to plant life extension and because
25 it's already part of the regulations.

1 Just encourage people to consider the importance
2 of good plant records and good analysis of records for
3 trending for licensing cases and for the safety of the
4 plant itself. I'm disturbed that in speaking to people, I
5 have learned from the experts who know, that Appendix B is
6 hardly known to exist in the community and it's not being
7 enforced. Nonconformances are not being carefully trended
8 in many plants, and in other areas as well. It's not an
9 easy thing to have a good system that allows you to do
10 that, but my understanding is many plants don't do that.
11 Thank you.

12 MR. VAGINS: That is an interesting statement.
13 George, would you like to make a comment?

14 MR. SLITER: I'd just like to point out something
15 that goes beyond that. We have to be careful of our
16 terminology. I fully agree with all of the good words you
17 said, and a rule, when it's written, needs to clarify if
18 it mentions trending. You've heard arguments as to why it
19 may not specifically have to be called out: one, because
20 it's in Appendix B; two, because Yankee has made the point
21 that it could be only one element of an entire program.
22 It's probably more important for long term things.

23 The problem here is one of terminology, and there
24 are two types of trending. There is a trending of the
25 actual degradation of a mechanism as time goes on, and

1 sometimes we use the word conditioning monitoring. Note
2 the result in the record and that is called trending.

3 The other one I think is mainly the one you
4 talked about. It's trending of failures. It's important
5 that whatever decision is made that we clarify what we
6 mean. The rule right now -- let's take a look at it. It
7 says, "A description in technical basis for a program of
8 identifying and evaluating trending of the effects of all
9 that relevant degradation mechanisms need to be."

10 What are the effects of failure or the actual
11 degradation? Technically I think you can make an argument
12 that for many types of equipment, it is not necessary.
13 Practically it does not make technical sense to trend the
14 aging of it. For example, for a relay or pressure
15 transmitter that has a three to five year life, you trend
16 it over six months. I think you're pretty sure that aging
17 is well controlled because of your replacement. However,
18 if the transmitter starts failing, Appendix B is correct
19 in saying you should be trending failures because you have
20 a problem, whether it be in design or not. It doesn't
21 matter what kind of problem it is. So the distinction
22 should be made.

23 MR. VAGINS: Let me clarify one thing. The staff
24 was very heavily thinking in this issue of trending
25 performance. One issue we dealt with, particularly in

1 aging programs, was that when failures occur, in some
2 items they occur catastrophically. Whereas trending can
3 pick up a performance diminishing and we could note it.
4 For instance, if we could trend if we run ISTs and we
5 trend the performance of the valves, the increase of
6 thrust requirements increase friction. These are items
7 that we're talking about in aging mechanisms. We're not
8 talking about failure trending. A failure is not
9 acceptable, period.

10 Therefore, how do we know how close we are in
11 some instances, and trending might be able to give us that
12 information. Areas where things can change. In other
13 words, one thing we don't have is a performance right now.
14 We don't have a performance level. We are either
15 functional or not functional. Many times we do have it in
16 some instrumentation, but basically for valves, for
17 mechanical equipment, and electrical equipment. What is
18 the proper functionality? Is it only when it works or
19 should we stop and replace it at a certain point before it
20 breaks.

21 Failure trending is not going to tell you that.
22 It will tell you what the replacement or refurbishing
23 period is, but it won't give you the overall picture from
24 an aging viewpoint. That you can get from performance
25 training. The staff is continually looking at this. We

1 want to try to prevent any kind of failure, within
2 significant failures. We're not going to worry about
3 light bulbs.

4 MR. GARDNER: J.B. Gardner. Just reinforcing a
5 comment I think George Sliter made earlier and relevant to
6 trending, getting to root causes is a very important part
7 of that. The NPRD is what I have been looking at in the
8 course of several projects that have been very
9 unsatisfactory from the point of view of what I believe and
10 what a number of other associated people believe about
11 failures to wrong equipment. Trending in that area can be
12 your enemy, not your friend at all, unless root causes are
13 really carefully discovered from the diagnosis of
14 failures. Particularly in the cable areas where you have
15 these in phases. They can be the culprit.

16 MR. VAGINS: Of course we're all aware of
17 weaknesses in -- you looked at the cause factors. They
18 are difficult to determine and I'm positive that I've been
19 told that they are trying to correct that to improve the
20 failure of the cause basis. A better identification of
21 that is again today's problem. We know that. It will
22 affect the future, obviously, but it affects us right now.
23 So we're aware of that.

24 MR. NEIL: Karl Neil, NRC. The question is on
25 trending. I made note of it. It has been mentioned in

1 several sessions. I've been in that industry and didn't
2 want to trend items where they're going to replace or
3 refurbish. I think George just implied that also. I
4 guess I didn't quite understand why he didn't want to
5 trend failures in things that you normally replenish or
6 refurbish because it would seem to me that if you
7 replenish or refurbish it, you're verifying and using the
8 right life of the component. It might be different in
9 different locations and different applications and
10 different service conditions. So I never could quite -- I
11 made a mental note of that, and I'd like to hear a
12 justification for that.

13 MR. SLITER: I think you misheard me. I
14 specifically said I agree it makes more sense to trend the
15 failures of the short life component. But it makes much
16 less sense to trend its parameter degradation as a
17 function of time for a long life component. Long life
18 components have a tendency -- you don't want to wait for
19 failure to occur, you want to look at their condition as
20 time goes on. For short term components, it doesn't make
21 sense to trend them. But it may make sense to trend
22 failures.

23 MR. VAGINS: Are there any other comments or
24 anybody wishes to make a statement?

25 MR. ROSA: Faust Rosa. I noted that earlier on

1 the term here and now issue as opposed to a license
2 extension issue was mentioned. Drawing on my experience
3 with implementation, I just want to bring to everyone's
4 attention the fact that appears to be an area where there
5 is likely to be some controversy in the application of any
6 license extension rule. I urge both the NRC people who
7 work on the framing of that rule and the industry people
8 who are commenting on it to focus on making a clear
9 distinction between the here and now issues, as opposed to
10 license extension issues.

11 MR. VAGINS: I'm a little confused, Faust. What
12 specifically are you referring to for license renewal, as
13 far as the station blackout rule?

14 MR. ROSA: We've had problems with implementing
15 the station blackout rule because the rule and its
16 guidance has not been as clear as it could have been in
17 some areas. I think this area of making a distinction of
18 here and now issues and life extension issues is of
19 importance in that respect.

20 MR. THADANI: I think, Faust, you're right. On
21 the basis of just the comments that we've heard today,
22 it's fairly clear to me that we need to focus our
23 attention on this issue and try to clarify what is meant
24 by today's issues versus future issues. I think that is
25 an important point. I agree with you. The example you

1 use in terms of station blackout is also a good example.
2 That says the industry and NRC, I think, work very hard up
3 front to try to develop guidance for the industry and for
4 individual utilities to follow. This guidance and
5 direction would show that they were meeting the station
6 blackout rule. What some of the audits have indicated is
7 that there might still be some misunderstanding about the
8 intent or what was meant by a license that was put
9 together about the NUMARC and NRC and that underscores the
10 need for us to be very carefully up front and not to have
11 these issues coming up and making those ad hoc decisions
12 later on. So in that sense, I think you're exactly right.
13 It's an issue we must focus our attention on because there
14 is enough confusion.

15 MR. VAGINS: Are there any other comments or
16 questions? I found the session very stimulating and
17 interesting. But if we're at the end of it, we're at the
18 end of it. Thank you.

19 (Whereupon, at 11:00 o'clock a.m. the hearing was
20 concluded.)

21

22

23

24

25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission


in the matter of:

NAME OF PROCEEDING:

DOCKET NUMBER:

PLACE OF PROCEEDING:

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



Official Reporter
Ann Riley & Associates, Ltd.

G. SLITER
LIRE

NUREG/CP-4564
BNL-NUREG-51971
AN. RV

OPERATING EXPERIENCE AND AGING-SEISMIC ASSESSMENT OF BATTERY CHARGERS AND INVERTERS

W.E. Gunther, M. Subudhi, and J.H. Taylor

**Manuscript Completed: March 1986
Revisions Made: April 1986
Date Published: June 1986**

**PLANT SYSTEMS AND EQUIPMENT ANALYSIS GROUP
ENGINEERING TECHNOLOGY DIVISION
DEPARTMENT OF NUCLEAR ENERGY
BROOKHAVEN NATIONAL LABORATORY
UPTON, NEW YORK 11973**

**Prepared for
UNITED STATES NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REGULATORY RESEARCH
WASHINGTON, D.C. 20555
FIN A-3270**

- An inverter manufacturer's representative stated that an inverter capacitor failure occurring at one station was caused by the excessive ripple voltage from the battery charger supplying the dc bus, coupled with the length of time the capacitor was in service. As a precautionary measure, all capacitors and SCRs in the inverter were replaced by the utility.
- One utility improved inverter performance by installing cooling fans on the top of each inverter cabinet.
- Fuse coordination was cited as a design problem by a maintenance supervisor whose plant had experienced several inverter trips due to blowing the input fuse to the inverter before the fuse in the branch circuit could operate. The fast acting fuses were required by the inverter manufacturer to ensure internal inverter circuitry protection.

Some of the actions taken by utilities who have experienced inverter and battery charger failures which affected plant safety and availability were to increase preventive maintenance scope and intervals, replace troublesome equipment, and improve system designs. Improvements in materials and procedures also help to reduce the failure rate and could explain the shape of the curve (Fig. 4-15) obtained when plotting inverter and charger failures against plant age.




Figure 4-15: Battery Charger/Inverter Failure History

Failures early in plant life can be correlated to aging by considering the following:

- Electrical equipment is typically installed and energized early in the plant construction process. It is then subjected to electrical transients, dirt, extreme temperatures, and other stresses prevalent during the construction and preoperational testing phase which could contribute to failures when loads are placed on the equipment during early plant operation. Electrical overloads and dirt were two reasons given by an inverter manufacturer for equipment failures during plant startup. Feedback from field service personnel to the main office indicated that circuits

LICENSE RENEWAL WORKSHOP

SESSION 7

ELECTRICAL SYSTEMS

1. ADDITIONAL CRITERIA FOR ELECTRICAL EQUIPMENT INCLUDED IN THE E.Q. PROGRAM BUT NOT PERIODICALLY REPLACED
2. ADDITIONAL PROGRAMS TO ADDRESS AGING DEGRADATION OF ELECTRICAL EQUIPMENT LOCATED IN MILD ENVIRONMENTS
3. PROGRAMS TO ESTABLISH THE INSITU CONDITION OF CABLES AND COMPONENTS AND THE POTENTIAL FOR FUTURE DEGRADATION
4. REQUIREMENTS WITHIN THE RULE FOR ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY
5. FUNCTIONAL TESTING OF ELECTRICAL EQUIPMENT AS A PREREQUISITE FOR LICENSE RENEWAL

**NRC WORKSHOP ON LICENSE RENEWAL
NOVEMBER 13-14, 1989
SESSION 7**

**PRESENTATION
ON
ELECTRICAL AND I&C SYSTEMS**

**BY
ROBERT R. MCCOY
YANKEE ATOMIC ELECTRIC COMPANY**

ELECTRICAL AND I&C SYSTEMS

- PRIMARY FUNCTION TO PROVIDE POWER, CONTROL, INSTRUMENTATION TO FLUID AND MECHANICAL SYSTEMS
- GENERALLY COMPOSED OF SIMILAR, READILY REPLACEABLE COMPONENTS

SECTION XX.9

REQUIRES

- IDENTIFICATION OF DESIGN REQUIREMENTS, FUNCTIONS, AND ENVIRONMENTAL CONDITIONS
- IDENTIFICATION OF DEGRADATION MECHANISMS
- PROGRAM TO IDENTIFY, EVALUATE, AND TREND EFFECTS OF RELEVANT DEGRADATION

FOR ALL EQUIPMENT IMPORTANT TO SAFETY

SECTION XX.9 SCOPE

UNNECESSARY

- **WELL RECOGNIZED THAT DEGRADATION CONCERNS DO NOT EXIST FOR MANY COMPONENTS BECAUSE OF:**
 - DESIGN CONSIDERATIONS**
 - BENIGN ENVIRONMENTAL CONDITIONS**
 - INSPECTION AND MAINTENANCE**
 - REFURBISHMENT OR REPLACEMENT**
- **PROCESS NEEDS TO CONSIDER THESE FACTORS SO THAT RESOURCES CAN BE FOCUSED ON THE AREAS WARRANTING ATTENTION**

NRC EXPRESSED PHILOSOPHY

“Those structures, systems, and components that are effectively covered by existing ongoing NRC requirements and/or licensee programs, or are not subject to aging mechanisms need not be addressed in the application (and need not be within the scope of the hearing process).”

ELECTRICAL AND I&C COMPONENTS

- **TEMPERATURE AND RADIATION EFFECTS ARE
ARE MAJOR DEGRADATION CAUSES**
- **MAJORITY LOCATED IN MILD ENVIRONMENTS
WHERE TEMPERATURE AND RADIATION CONTROLLED**
- **MAINTAINED/REFURBISHED/REPLACED THROUGH
EXISTING PROGRAMS**
- **EXISTING PROGRAMS PROVEN EFFECTIVE**

EXISTING PROGRAMS

- MONITOR/MAINTAIN/REFURBISH/REPLACE
- PROVEN DURING ORIGINAL LICENSING TERM
- CONTINUOUSLY UPDATED BASED ON INDUSTRY EXPERIENCE
- CONCLUSION - RULE SHOULD ALLOW FLEXIBILITY TO CREDIT THESE PROGRAMS

- AN EXAMPLE OF AN EXISTING PROGRAM WHICH COVERS DEGRADATION MECHANISMS IS THE ENVIRONMENTAL QUALIFICATION PROGRAM

DEGRADATION MECHANISMS

- IDENTIFIED AND GENERALLY WELL UNDERSTOOD
BASED ON YEARS OF EXPERIENCE
- UNDERSTANDING OF ENVIRONMENTAL/MATERIALS
INTERACTIONS CONTINUE TO DEVELOP
 - THERMAL AND RADIATION EMBRITTLEMENT
 - LOSS OF DIELECTRIC STRENGTH
 - MECHANICAL WEAR

MANAGING DEGRADATION MECHANISMS

- **PROGRAMS SHOULD ONLY BE REQUIRED FOR COMPONENTS IMPORTANT TO SAFETY**
- **NO ADDITIONAL PROGRAMS SHOULD BE REQUIRED FOR THOSE COMPONENTS ALREADY COVERED BY EXISTING PROGRAMS**
 - FOR EXAMPLE EQ
- **RULE SHOULD ALLOW FLEXIBILITY FOR MANAGING DEGRADATION**

TRENDING

NEED NOT BE REQUIRED UNILATERALLY, EXAMPLES:

- A PROGRAM EXISTS WHICH EFFECTIVELY MANAGES AGING BY REPLACEMENT PRIOR TO DEGRADATION NEED NOT TREND DEGRADATION:
 - SET POINT DRIFT ON INSTRUMENTS
- A PROGRAM EXISTS WHICH SCHEDULES PERIODIC REFURBISHMENTS INVOLVING REPLACEMENT OF SHORT LIVED SUB-COMPONENTS NEED NOT TREND DEGRADATION
- A PROGRAM EXISTS WHICH SHOWS BY ANALYSIS THAT AGING IS NOT A CONCERN IF THE EQUIPMENT IS OPERATED WITHIN CERTAIN LIMITS NEED NOT TREND DEGRADATION
 - NUMBER OF CYCLES, ENVIRONMENTAL CONDITIONS

NEED ONLY BE APPLIED WHERE MEANINGFUL OR JUSTIFIED

ADDITIONAL ADMINISTRATIVE CONTROLS

- **ONLY APPLICABLE TO SPECIAL ACTIONS NECESSARY TO MANAGE AGE RELATED DEGRADATION IN SUPPORT OF LICENSE RENEWAL**
- **SUCH ACTIONS BECOME LICENSE COMMITMENTS FOR LICENSE RENEWAL**

SECTION XX.9

SHOULD PRESENT A SCREENING TYPE PROCESS

- **EQUIPMENT IMPORTANT TO SAFETY**
- **EQUIPMENT NOT COVERED UNDER EXISTING PROGRAMS**
- **EQUIPMENT SUBJECT TO POTENTIALLY SIGNIFICANT DEGRADATION**

ADD FLEXIBILITY IN IMPLEMENTATION

SEVERAL METHODS AVAILABLE FOR MANAGING DEGRADATION

- FURTHER ANALYSIS TO DEMONSTRATE THAT THE PROJECTED DEGRADATION IS ACCEPTABLE THROUGH THE RENEWAL PERIOD
- CURRENT PROGRAMS ARE ADEQUATE TO ASSURE DEGRADATION MECHANISM DOES NOT IMPACT SAFETY
- FOR THE RENEWAL PERIOD PROCEDURAL ENHANCEMENT MAY BE APPROPRIATE
 - For example: Trending
- MODIFICATIONS TO OPERATING PRACTICES
- COMPONENT REPLACEMENT OR REFURBISHMENT