

December 1, 1989

Docket No. 50-344

Mr. David W. Cockfield
Vice President, Nuclear
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

DISTRIBUTION

<u>Docket File</u>	WJones
NRC & Local PDRs	JCalvo
JZwolinski	ACRS (10)
JLee	GPA/PA
RBevan	OC/LFMB
OGC	PD5 Plant File
DHagan	Region V (3)
EJordan	
TMeek (4)	

Dear Mr. Cockfield:

SUBJECT: ISSUANCE OF AMENDMENT NO. 156 TO FACILITY OPERATING LICENSE
NO. NPF-1, TROJAN NUCLEAR PLANT (TAC NO. 72066)

The Commission has issued the enclosed Amendment No. 156 to Facility Operating License No. NPF-1 for the Trojan Nuclear Plant. The amendment consists of changes to the Technical Specifications in response to your application (LCA-172) dated February 6, 1989, as supplemented October 25, 1989.

The amendment changes Trojan Technical Specification 3/4.6.1.2 revising the surveillance requirements for containment leak testing to make Trojan Technical Specification 4.0.2 not applicable.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

original signed by

Roby B. Bevan, Project Manager
Project Directorate V
Division of Reactor Projects III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 156 to NPF-1
2. Safety Evaluation

cc w/enclosures:
See next page

* see previous concurrence

PD5/DRSP JLee 11/14/89	PD5/DRSP* AAImond 11/7/89	PD5/DRSP RBevan/mw 11/2/89	OGC CPW 11/17/89	D:PDV:DRSP GWKnighton 12/1/89
------------------------------	---------------------------------	----------------------------------	------------------------	-------------------------------------

OFFICIAL RECORD COPY
[TROJAN AMEND 72066]

8912070261 891201
PDR AD0CK 05000344
P PDC

DF01
11

Docket No. 50-344

Mr. David W. Cockfield
Vice President, Nuclear
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

DISTRIBUTION

Docket File
NRC & Local PDRs
JZwolinski
JLee
RBevan
OGC
DHagan
EJordan
TMeek (4)

WJones
JCalvo
ACRS (10)
GPA/PA
OC/LFMB
PD5 Plant File
Region V (3)

Dear Mr. Cockfield:

SUBJECT: ISSUANCE OF AMENDMENT NO. TO FACILITY OPERATING LICENSE
NO. NPF-1, TROJAN NUCLEAR PLANT (TAC NO. 72066)

The Commission has issued the enclosed Amendment No. to Facility Operating License No. NPF-1 for the Trojan Nuclear Plant. The amendment consists of changes to the Technical Specifications in response to your application (LCA-1/2) dated February 6, 1989.

The amendment changes Trojan Technical Specification 3/4.6.1.2 revising the surveillance requirements for containment leak testing to make Trojan Technical Specification 4.0.2 not applicable.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

Roby B. Bevan, Project Manager
Project Directorate V
Division of Reactor Projects III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. to NPF-1
2. Safety Evaluation

cc w/enclosures:

See next page

PD5/DRSP	PD5/DRSP	PD5/DRSP	OGC	D:PDV:DRSP
JLee	AA [unclear]	RBevan/mw		GWKnighton
/ /89	11/16/89	/ /89	/ /89	/ /89

OFFICIAL RECORD COPY
[TROJAN AMEND 72066]



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

December 1, 1989

Docket No. 50-344

Mr. David W. Cockfield
Vice President, Nuclear
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Dear Mr. Cockfield:

SUBJECT: ISSUANCE OF AMENDMENT NO. 156 TO FACILITY OPERATING LICENSE
NO. NPF-1, TROJAN NUCLEAR PLANT (TAC NO. 72066)

The Commission has issued the enclosed Amendment No. 156 to Facility Operating License No. NPF-1 for the Trojan Nuclear Plant. The amendment consists of changes to the Technical Specifications in response to your application (LCA-172) dated February 6, 1989, as supplemented October 25, 1989.

The amendment changes Trojan Technical Specification 3/4.6.1.2 revising the surveillance requirements for containment leak testing to make Trojan Technical Specification 4.0.2 not applicable.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

A handwritten signature in dark ink, appearing to read "Roby B. Bevan".

Roby B. Bevan, Project Manager
Project Directorate V
Division of Reactor Projects III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 156 to NPF-1
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. David W. Cockfield
Portland General Electric Company

Trojan Nuclear Plant

cc:
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Trojan Nuclear Plant
Post Office Box 0
Rainier, Oregon 97048

Mr. Michael J. Sykes, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97501

Mr. William T. Dixon
Oregon Department of Energy
Salem, Oregon 97310

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596