



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PORTLAND GENERAL ELECTRIC COMPANY  
THE CITY OF EUGENE, OREGON  
PACIFIC POWER AND LIGHT COMPANY  
DOCKET NO. 50-344  
TROJAN NUCLEAR PLANT  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 156  
License No. NPF-1

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Portland General Electric Company, et al., (the licensee) dated February 6, as supplemented October 25, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-1 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 156, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

*H. Rood for GK*

George W. Knighton, Director  
Project Directorate V  
Division of Reactor Projects III,  
IV, V and Special Projects

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 1, 1989

ATTACHMENT TO LICENSE AMENDMENT NO.156  
TO FACILITY OPERATING LICENSE NO. NPF-1  
DOCKET NO. 50-344

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

Remove Pages

3/4 6-4

Insert Pages

3/4 6-4

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

---

- f. Type B tests for penetrations employing a continuous leakage monitoring system shall be conducted at P (60 psig) at intervals no greater than once per 3 years.
- g. All test leakage rates shall be calculated using observed data converted to absolute values. Error analyses shall be performed to determine the inaccuracy of the measured leakage rates due to maximum measurement accuracy and instrument repeatability; the measured leakage rates shall be adjusted to include the measurement error.
- h. The provisions of Specification 4.0.2 are not applicable. |