

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission
Advisory Committee on Reactor Safeguards

Title: Meeting of the Thermal Hydraulic
Phenomena Subcommittee

Docket No.

LOCATION: Bethesda, Maryland

DATE: Thursday, December 7, 1989 PAGES: 1 - 137

[Closed session includes
pages 138-249]

ACRS Office Copy - Retain
for the Life of the Committee

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PUBLIC NOTICE BY THE
UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

DATE: Thursday, December 7, 1989

The contents of this transcript of the proceedings of the United States Nuclear Regulatory Commission's Advisory Committee on Reactor Safeguards, (date) Thursday, December 7, 1989, as reported herein, are a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected or edited, and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

Meeting of the Thermal Hydraulic
Phenomena Subcommittee

7920 Norfolk Avenue
Room P-100
Bethesda, Maryland
Thursday, December 7, 1989

The above-entitled proceedings commenced at 8:30
o'clock a.m., pursuant to notice, Ivan Catton, Subcommittee
Chairman, presiding.

PRESENT FOR THE ACRS SUBCOMMITTEE:

I. Catton
W. Kerr
D. Ward
P. Davis
V. Schrock
P. Boehnert, Cognizant ACRS Staff Member

1

2

STAFF AND PRESENTERS:

3

R. Barrett

4

S. Diab

5

G. Burdick

6

E. Throm

7

D. Bessette

8

G. Wilson

9

R. Lee

10

M. Ortiz

11

12

AUDIENCE SPEAKERS:

13

T. Scarbrough

14

O. Rothberg

15

K. Campe

16

J. Isom

17

J. O'Brien

18

B. Jones

19

L. Shotkin

20

21

22

23

24

25

P R O C E E D I N G S

[8:30 a.m.]

MR. CATTON: The meeting will now come to order.

This is a meeting of the Advisory Committee on
Reactor Safeguards Subcommittee on Thermal Hydraulic Phenomena.

I am Ivan Catton, Subcommittee Chairman.

The ACRS members in attendance are Bill Kerr and Dave
Ward.

We also have ACRS consultants Pete Davis and Virgil
Schrock.

The purpose of this meeting is to discuss (1) the
proposed NRR and RES programs for resolution of the interfacing
systems LOCA issue; (2) the status of the NRC-RES Technical
Program Group's efforts to apply the Code Scaling,
Applicability, and Uncertainty methodology to calculation of
the effects of the small-break LOCA; and (3) the status of the
development of the Westinghouse best-estimate ECCS/LOCA model.

A portion of the meeting will be closed to the public
in order to protect information deemed proprietary by the
Westinghouse Electric Company.

Mr. Paul Boehnert is the cognizant ACRS Staff Member
for this meeting.

The rules for participation in today's meeting have
been announced as part of the notice of this meeting previously
published in the Federal Register on November 28th, 1989.

1 A transcript of the meeting is being kept and will be
2 made available as stated in the Federal Register notice. It is
3 requested that each speaker first identify himself or herself
4 and speak with sufficient clarity and volume so that he or she
5 can readily be heard.

6 We have received no written comments or requests to
7 make oral statements from members of the public.

8 If anybody has any comments --

9 [No response.]

10 MR. CATTON: -- I see none -- we'll proceed with the
11 meeting.

12 I call upon Mr. Rich Barrett of NRR to begin.

13 MR. BARRETT: Thank you, Mr. Chairman.

14 I am Richard Barrett. I am Chief of the Risk
15 Applications Branch in NRR.

16 This morning I would like to talk to you about an
17 issue which we have known about for at least 15 years but which
18 we have recently become more concerned about and we are placing
19 more emphasis on, namely the interfacing systems LOCA.

20 Now as I am sure most of you know, an interfacing
21 systems LOCA is a break in the piping or seals, gaskets, in the
22 low-pressure systems which are connected to the reactor coolant
23 system -- for instance, the residual heat removal systems in a
24 PWR.

25 These kinds of breaks can be caused when the low-

1 pressure systems are exposed to the reactor coolant system
2 pressure due to the failure of the pressure isolation valves
3 either through mechanical, electrical or, as we are learning
4 more recently, through human errors.

5 [Slide.]

6 MR. BARRETT: We are concerned about this type of an
7 accident because the break occurs outside of the containment or
8 can occur outside of the containment and therefore what you
9 have is a loss of two out of your three fission product
10 barriers, namely the reactor coolant boundary and the
11 containment.

12 We are concerned because there is a possibility for
13 core damage very early in the accident either because the
14 nature of the accident results in a loss of the injection
15 capability or because even if you do have injection, the
16 injected water will not make its way to the sump or not
17 necessarily make its way to the sump and therefore you could
18 lose recirculation to the core.

19 There is a possibility of early, perhaps lethal doses
20 off-site and also because of the timing of the accident there
21 can be limited opportunity for protective actions off-site,
22 such as evacuation.

23 Now we recognize that there is a wide spectrum of
24 possible scenarios associated with an interfacing systems LOCA.
25 You can have interfacing systems LOCAs which proceed very

1 slowly. You can have interfacing systems LOCAs which have much
2 less than lethal doses off-site but the project that I want to
3 talk to you about today is concerned about the high consequence
4 type of interfacing systems LOCAs, the ones I described for you
5 just a moment ago.

6 [Slide.]

7 MR. BARRETT: As I mentioned, we have known about
8 this accident since WASH-1400. WASH-1400 included in the
9 analysis an analysis of the so-called Event V, where Event V
10 was a failure in a particular type of pressure isolation line.
11 It was a failure of a configuration where you have two check
12 valves as the pressure isolation boundary.

13 What they found was that you can get a fairly high
14 frequency for this type of an accident if you have that kind of
15 a configuration because, depending on how you test those lines,
16 you can have an undetected failure of one of the check valves
17 and so all that is required to create the accident is the
18 failure of the other check valve.

19 What they concluded was that you can greatly reduce
20 the probability of this type of accident if you can
21 independently leak test both check valves in lines of this type
22 so you won't have that undetected fault.

23 As a result, in the 1980-1981 time frame there were
24 some -- a number of orders were sent out to PWR plants, mostly
25 to PWR plants, there were a couple of BWR's also -- which had

1 this kind of configuration, either two check valves or two
2 check valves and an open MOV, requiring them to independently
3 leak test both check valves.

4 Those orders went to I believe 34 PWR's and 2 BWR's.

5 MR. CATTON: But you need more than a leak, don't
6 you, to get into trouble?

7 MR. BARRETT: Well, the point was not so much that
8 you -- yes. To get into this kind of a high consequence
9 situation, yes, you do.

10 MR. CATTON: You almost need a catastrophic failure
11 of the check valve.

12 MR. BARRETT: Yes, but if you are not independently
13 checking them, if you are only leak testing the two as a pair,
14 you could have a catastrophic failure that is undetected.

15 MR. CATTON: Somehow I am missing something. I
16 missed it when they reduced the probability of this failure 15
17 years ago by the testing.

18 How does the leak tell me about impending
19 catastrophic failure?

20 MR. BARRETT: That's an excellent point and a little
21 bit later in the presentation I would like to get into that.

22 MR. CATTON: Somebody will, good.

23 MR. BARRETT: It does not tell you about impending
24 failure. The purpose of the testing is not -- we call it leak
25 testing but it's really testing to see if the valve has failed.

1 If you are just testing the two as a pair, one of
2 them could be completely failed and you would not detect it,
3 but you are absolutely right. Leak testing does not tell you
4 about impending failure and there is an awful lot of activity
5 that is going on right now to try to go beyond leak testing.

6 We won't get into that in detail today but I will
7 mention it a little later on.

8 MR. CATTON: The bottom line is two orders of
9 magnitude as a result of leak testing, so I think it is kind of
10 important.

11 MR. BARRETT: Oh, yes, but bear in mind that that was
12 simply because independent leak testing would eliminate that
13 undetected, totally failed valve.

14 MR. CATTON: Okay.

15 MR. BARRETT: Okay. At the time we put out the
16 orders we also changed the standard review plan so that in the
17 future all plants that were licensed after that time there was
18 a requirement for independent leak testing of all pressure
19 isolation valves, not just the ones that were in Event V type
20 configurations and there was a decision that was made that we
21 would try to backfit that requirement, namely that all pressure
22 isolation valves would have to be independently tested but that
23 would be backfitted through the IST process. As part of the
24 SERS for the IST program that requirement would be implemented.

25 MR. KERR: I know a lot of these acronyms, but what

1 is -- remind me what IST is?

2 MR. BARRETT: Oh, yes, okay. That's the integrated
3 -- I'm sorry, the In-Service Testing program, the in-service
4 testing that's required for all valves and pumps.

5 It's the in-service testing of all valves and test
6 in-service inspection -- ISI and IST, In-Service Inspection of
7 the integrity of piping and such.

8 However, in 1985 it was decided by the Committee for
9 the Review of Generic Requirements that the decision that I
10 just talked about was really a backfit and that as a backfit we
11 would have to do a backfit analysis. We would have to show
12 that a decision to require the independent leak testing of all
13 pressure isolation valves was cost beneficial, and so Generic
14 Issue 105 was instituted to do that.

15 To this date we have not yet been successful in
16 demonstrating that leak testing of all pressure isolation
17 valves is cost beneficial.

18 Now as Dr. Catton pointed out, leak testing a valve
19 does not necessarily detect an impending failure of that valve.

20 A valve can have a completely failed hinge pin and
21 yet it will be held nicely in place by the differential
22 pressure until you have some sort of a transient and it falls
23 off and I simply want to mention that more recently now there
24 has been a great deal of effort to -- and discussion about
25 being more proactive about check valves, about the maintenance

1 of check valves, about removal of check valves, inspection and
2 testing for possible undetected faults.

3 MR. KERR: What specifically has been done?

4 MR. BARRETT: Well, I will mention two efforts.

5 One very important one is the INPO-SOER 86-3.

6 That effort along with some EPRI work that has been
7 done in terms of giving guidance on how to maintain and inspect
8 check valves, essentially it's not a requirement on the
9 industry but it essentially tells the industry that these --
10 that these valves should be removed and inspected after they
11 have been in service for a certain amount of time.

12 Also, there's been guidance given on how to maintain
13 these valves, how often to test them and that sort of thing.

14 MR. KERR: This is an industry initiative.

15 MR. BARRETT: That's an industry initiative. I'd
16 also like to mention one NRC initiative that's recent, and
17 that's Bulletin 89-02. That was a followup to some problems
18 that were observed in Anchor-Darling valves, check valves where
19 there was, I believe, some stress corrosion cracking of the
20 hinge pins, where the hinge pin mounting and some valves were
21 failing because of that.

22 89-02 placed a requirement on the utilities to
23 dismantle and inspect valves of this make or of similar make
24 and to report to the NRC as to what they found in terms of the
25 inspection of these valves, what their physical condition was.

1 So we're moving away from just leak testing of valves
2 and becoming more proactive about maintenance and testing and
3 inspection of valves. There's a whole major effort on check
4 valves, and I really don't want to get into it in detail today,
5 but the NRC NRR has a whole check valve initiative. It has a
6 whole plan for motor operated valves and we're trying to work
7 very closely with the people in the mechanical engineering
8 branch who are spearheading this whole effort.

9 I think if you want to know about that, it might be
10 useful to have a separate briefing.

11 MR. KERR: I am aware of the motor valve, some of the
12 initiatives. I was really referring to check valves where you
13 said that we had become much more proactive and I was curious
14 as to what you had had in mind.

15 MR. SCARBROUGH: I'm Tom Scarborough with the
16 Mechanical Engineering Branch. As Rich said, we do have
17 programs that we're initiating on check valves and motor
18 operated valves. We gave a briefing to Mr. Michelson's
19 subcommittee on October 3rd, I believe. I think maybe some of
20 you were here, but --

21 MR. KERR: I didn't necessarily want all the details
22 of the programs. I do appreciate the information. I was
23 curious as to what he meant when he said "we are becoming more
24 proactive." I think I have an idea now of what it is that he
25 is referring to.

1 MR. SCARBROUGH: Very good.

2 MR. KERR: Thank you.

3 MR. BARRETT: Thank you, Tom.

4 MR. CATTON: You didn't mention the industry program,
5 NIC, which is probably the best of the lot.

6 MR. BARRETT: Exactly, yes. I was about to mention
7 NIC. It's Nuclear Industry Check valve Program and it's --
8 again, we are working closely with them, right, Tom?

9 MR. SCARBROUGH: Right.

10 [Slide.]

11 MR. BARRETT: Now, the situation, if you will pull
12 out a modern PRA and you look for the ISLOCA, what you'll
13 generally find is that the interfacing systems LOCA is still
14 treated as a check valve failure problem. There's not a lot of
15 treatment of human errors, and there's also not a lot of
16 treatment of accident management to mitigate an interfacing
17 systems LOCA once it has started.

18 The assumption is generally made that once an
19 interfacing systems LOCA, especially a large interfacing
20 systems LOCA has occurred, that that means core melt.
21 Generally, you will also find that what you calculate is very
22 low core damage frequencies in the vicinity of ten to the minus
23 6 per reactor year.

24 But even at those low frequencies, you'll find that
25 interfacing systems LOCA is a major, if not dominant

1 contributor to early fatalities because of the bypass of
2 containment.

3 MR. DAVIS: Excuse me, Rich. I think it's useful to
4 point out that those conclusions apply only to PWRs, and I
5 don't know if that's all you're going to talk about or not, but
6 the items on the slide that you just showed are only for PWRs,
7 as I understand it.

8 MR. BARRETT: Yes. I will point out that we are
9 concentrating on PWRs at this time in this program, yes.
10 Thanks, Pete.

11 [Slide.]

12 MR. BARRETT: We have seen a lot of recent
13 operational experience which indicates that interfacing systems
14 LOCA may not be just a check valve failure problem. It may not
15 be a mechanical problem. It may actually, in fact, be
16 dominated by human errors. Recent operational experience in
17 this country and abroad has demonstrated a wide variety of
18 possible human actions to bypass the various safegaurds against
19 the loss of the pressure isolation boundary.

20 If you want, we can give you a little bit more detail
21 about that later, but these -- this experience indicates that
22 the human error may, indeed, dominate the ISLOCA problem.

23 MR. KERR: When you say, "may, indeed," what does
24 that statement mean?

25 MR. BARRETT: Well, we've seen a lot of different

1 kinds of problems of human error, but we haven't taken those
2 problems and evaluated them in an integrated way within the
3 context of a PRA.

4 MR. KERR: Well, but this program that you're
5 anticipating apparently depends on your evaluation of some
6 major new perspective on risk. When all I hear is that
7 something may, indeed, contribute to risk, I'm curious as to
8 what that means.

9 MR. BARRETT: Well, a major part of this program is
10 to make that evaluation. We're not at the --

11 MR. KERR: You haven't yet made it, then?

12 MR. BARRETT: No, we have not.

13 MR. KERR: In spite of these two rather formidable
14 documents from BNL?

15 MR. BARRETT: The two documents from BNL are the main
16 technical products from Generic Issue 105 and they concentrate
17 primarily on the questions of the testing and the checking of
18 check valves.

19 MR. KERR: Okay.

20 MR. BARRETT: What's new about this particular
21 project I'm going to talk about is the human error component of
22 it.

23 [Slide.]

24 MR. BARRETT: Okay, as a result of this recent
25 experience, primarily with human errors, Dr. Murley has

1 initiated a special project with the idea in mind of getting an
2 early answer as to what is the severity of ISLOCA in light of
3 all of this new experience that we're seeing.

4 The decision was made not to wait for the results of
5 the IPE program, the Individual Plant Examinations, the PRAs
6 that will be done by all plants in response to the Severe
7 Accident Policy Statement, partly because the schedule for the
8 IPEs is more protracted than we would like.

9 We would like to have an answer to this question
10 earlier than we would expect to see the IPEs, but also partly
11 because we're not confident that, given the current way in
12 which PRAs are done, that the human element will be addressed
13 in the way we would like to have it addressed.

14 MR. KERR: Are you confident that it can be addressed
15 in the way you would like to have it addressed?

16 MR. BARRETT: We're confident -- yes, we're confident
17 that we can do a better job, in general, than what is done now.

18 MR. KERR: That's an answer to a different question.

19 MR. BARRETT: Well, I recognize that human
20 reliability analysis is a difficult area of study, and we're
21 going into this to do the very best job we can with it.

22 MR. KERR: Is there some reason though, that you
23 think you can do a much better job than is being done at
24 present so that you will be able to answer this question?

25 MR. BARRETT: Well, yes.

1 MR. KERR: What evidence do you have that you're
2 going to affect these improvements in existing methodology?

3 MR. BARRETT: Well, basically, we're going to take
4 the existing state-of-the-art human reliability analysis
5 methods and apply them to this interfacing systems LOCA and
6 we're also going to take into account, the existing information
7 about the types of failure modes that we've seen in the
8 operational experience.

9 It's a package of putting together all of these
10 things in a way that has not generally been done, or has not --
11 I think I can say it has not been done. So, it's not a matter
12 that it could not have been done.

13 It's just that, in general in PRAs, it is not done.
14 So, we're trying to do a special study to take the operational
15 experience, the human reliability methodology; put it into a
16 PRA type of analysis and come up with a one-time answer as to
17 how severe this human element is in the ISLOCA.

18 MR. DAVIS: I can appreciate your desire to get this
19 finished faster than the IPEs might produce a reasonable
20 answer, but I'm not so sure that I understand why you don't
21 think the IPE will give you the type of answer you want on this
22 question.

23 Wouldn't it be possible for the NRC to provide the
24 utilities with guidance on this issue for including in the IPES
25 that would ensure that you would get the right kind of

1 analysis.

2 MR. BARRETT: Yes, I think that's very possible. In
3 fact, I think that's one of the possible outcomes of this
4 study. At the moment, I wouldn't know what guidance to give
5 them.

6 MR. DAVIS: The only concern I have is that this
7 issue, like many issues, is extremely plant-specific. I think
8 that was illustrated amply by the Brookhaven studies. That's
9 why it seems to me that an attempt at a generic resolution is
10 going to have a problem in trying to capture all the different
11 designs, which to me means that an IPE approach might be a
12 little more appropriate.

13 MR. BARRETT: I think that's a good comment, Pete,
14 and I -- that is one of the things that -- we're keeping that
15 as an option that when we complete this study and we have the
16 insight that we get from the study, it could be that the way to
17 resolve this problem is to put those insights out to the
18 industry and ask them to address them in the IPE, or for those
19 plants that have completed their IPES, to update their IPES
20 with these new insights.

21 MR. CATTON: In the human factors --

22 MR. WARD: You're not willing to commit to that
23 approach or plan on that approach at this stage; is that right?

24 MR. BARRETT: I don't think we know enough yet, Mr.
25 Ward. I think it's possible that we'll find a generic problem.

1 It's possible we'll find no problem, and we may find a generic
2 solution. We may find some limited set of applicable
3 solutions, but this is definitely a possibility. I think it's
4 too early to tell.

5 MR. CATTON: In the human factors area, we had sort
6 of a tutorial here a few months ago and it showed that there --
7 at least it was discussed that the range was of almost two
8 orders of magnitude on the errors of commission. This was a
9 result of an ISPRA study.

10 What are you going to do with that?

11 MR. BARRETT: That's a difficult point. We recognize
12 that human reliability analysis is even more uncertain than the
13 rest of PRA analysis.

14 MR. CATTON: A comment was also made that the method
15 that's used by NRC -- I don't remember what you call it, but it
16 gave the lowest value for the errors.

17 MR. BARRETT: It was --

18 MR. CATTON: Consistently.

19 MR. BARRETT: -- the most accurate or the least
20 accurate?

21 MR. CATTON: Well, I mean the most -- with the least
22 conservatism --

23 MR. BARRETT: Oh, I see.

24 MR. CATTON: Of all of the different approaches that
25 were looked at.

1 MR. BARRETT: Okay, I wasn't -- I'm not sure which
2 method you're talking about.

3 MR. CATTON: I'm not in the human factors business.
4 I just remember the range and where the NRC approach fell with
5 respect to the band.

6 MR. BARRETT: We're going to be very careful about
7 the human reliability analysis. It would be nice if the human
8 reliability analysis would give us a hard and fast answer that
9 we could just point to and say these numbers lead you to these
10 conclusions.

11 What I think we may find is that the numbers will --
12 that the human reliability analysis will point us to the areas
13 where risk is most sensitive to variations in performance and
14 so that may -- we may have to settle for that kind of an
15 answer. We may find, for instance, that the risk is most
16 sensitive to the procedures which will be in place to deal with
17 an ISLOCA.

18 On the other hand, we may find that the risk is most
19 sensitive to the quality of maintenance work, people are
20 working on MOVs and check valves. That may be all we learn
21 from this thing, but that will at least point us to where we
22 should concentrate any effort in trying to solve the problem.

23 We recognize the uncertainties in human reliability
24 analysis.

25 MR. CATTON: In the area of the valves, in some of

1 the sequences, isolation was important. What numbers did they
2 use for the probability that they would get it done? Did they
3 use the 1150 numbers, or the more recent ones in the Brookhaven
4 report?

5 MR. BARRETT: I don't know that. I'm not sure.

6 MR. CATTON: There's a factor of 20 difference.

7 MR. BARRETT: In whether or not you can isolate once
8 you've lost the pressure isolation boundary?

9 MR. CATTON: Once you have to close against full
10 flow?

11 MR. BARRETT: I don't recall what was used in those
12 reports, what value was used. I believe the value --

13 MR. CATTON: I got the feeling in reading through the
14 Brookhaven reports that if it was supposed to close, it was
15 assumed to close.

16 MR. BARRETT: If I recall, the isolation for the very
17 largest lines was given no credit at all in the Brookhaven
18 report for PWRs for the RHR lines.

19 MR. KERR: There must be somebody here who knows an
20 answer to the question.

21 MR. BARRETT: Is there anyone here who can speak to
22 that? I believe that for the smaller lines, there was credit
23 given, and it was -- this is Owen Rothberg Office of Research,
24 the sponsor of the Brookhaven work.

25 MR. ROTHBERG: We did a study of the NUREG CR5140

1 that talked about the closing of motor-operated valves, and we
2 predicted a failure rate of eight percent.

3 MR. CATTON: That's what I'm referring to.

4 MR. ROTHBERG: Yes. Right. I don't believe that the
5 current studies reflect that at all. The Brookhaven studies
6 that you have don't reflect that.

7 MR. CATTON: It sounds to me like they ought to be
8 redone, then, if that's important. There's also the testing
9 that --

10 MR. KERR: Well, that depends on how much confidence
11 he has in the data to which he referred.

12 MR. CATTON: Well, I think the eight percent is real.
13 There are the tests that were just recently done in Germany
14 that show that the manufacturer's recommended torque settings
15 are not sufficient to get some of these valves closed. That
16 ought to be incorporated into it, as well.

17 MR. ROTHBERG: We just had a pour block failure at
18 Palisades.

19 MR. KERR: I'm sorry, you just had what?

20 MR. ROTHBERG: Pour block valve failure at Palisades
21 and a failure to close against flow.

22 MR. CATTON: Go ahead.

23 MR. BARRETT: All right. Thank you.

24 Let me simply point out that in addition, at the
25 outset, we're going to concentrate on pressurized water

1 reactors. We have not yet decided what we will do about the
2 questions related to BWRs, but we have decided to concentrate
3 first on the PWRs.

4 [Slide.]

5 MR. BARRETT: The goal of the program is to assure
6 ourselves that we have high confidence that the high
7 consequence type of ISLOCA that I described will not occur for
8 the current generation of plants, and in order to --

9 MR. KERR: Excuse me. I gather, from reading some of
10 the material, that that means that that likelihood will be less
11 than ten to the minus six per reactor year?

12 MR. BARRETT: Yes. When we talk about a numerical
13 goal, that's the goal.

14 MR. KERR: That's the likelihood. Now, what sort of
15 confidence do you want to have in that likelihood?

16 MR. BARRETT: Well, I don't think that we want to say
17 that there's a mean value of ten to the minus six, and we have
18 a confidence level -- or rather that -- I think what we're
19 saying is that a mean value of ten to the minus six would be
20 fine.

21 MR. KERR: But that, by itself, doesn't have a lot of
22 significance, particularly at that low likelihood, unless you
23 are going to say something about -- and indeed, you're --
24 that's why it says "high confidence."

25 MR. BARRETT: Yes. We feel that if you say that you

1 want to have high confidence that an accident of this type will
2 not occur for the current generation of plants, then you might
3 say that, well, there are about 2500 years of operation left in
4 the current generation of plants. That would say that if you
5 thought you might have one of these, that would give you a--

6 MR. KERR: I'm not asking for illustrations of what
7 one might say. I mean, if you're going to get to some point
8 and say, "Well, I have achieved my goal," it seems to me you're
9 going to have to have some measure of what the goal is, and I'm
10 just trying to find out what that is.

11 MR. BARRETT: Well, the goal --

12 MR. KERR: How will you know when you've gotten
13 there?

14 MR. BARRETT: If we can calculate a ten to the minus
15 six of core melt, and with reasonable errors of -- you know,
16 typical errors in PRAs are a factor of three or so, with the
17 human error being so important here, I think that we probably
18 have to settle for an uncertainty of more like an order of
19 magnitude or more. I still think that that would say --

20 MR. KERR: I'm not trying to disagree with what your
21 criteria are going to be; I just want to know what they are.

22 MR. BARRETT: Well, we would like to have a
23 calculated core damage frequency of about ten to the minus six,
24 mean value, and I'm not sure --

25 MR. KERR: Well, that doesn't have anything to do

1 with the "high confidence" which I see at the top of that
2 slide.

3 MR. BARRETT: Well, the way I interpret "high
4 confidence" is if you go up one or two sigmas along the
5 uncertainty curve, that you're still meeting the goal that
6 you've set for yourself, that you're not going to have one for
7 this generation of plants.

8 MR. KERR: Okay. What is one or two sigmas for this
9 curve?

10 MR. BARRETT: If you're taking log normal
11 distributions, we'd be talking about sigma in a logarithmic
12 sense --

13 MR. KERR: Excuse me. Are you going to assume this
14 is log normal with the human error contribution that will be
15 there?

16 MR. BARRETT: I didn't mean to get into a discussion
17 of the exact type of distribution. What I meant was that the
18 uncertainties in PRAs tend to be more logarithmic than
19 arithmetic. They tend to be a factor of too high, or a factor
20 of too low, a factor of ten high, a factor of ten low, rather
21 than plus or minus a fraction.

22 MR. KERR: Okay.

23 MR. BARRETT: What I meant was that even if we
24 calculated ten to the minus six and the error factor is a
25 factor of ten, so that you might reasonably expect that the

1 number could be ten to the minus five, I still think that meets
2 the criteria.

3 MR. DIAB: May I comment?

4 MR. BARRETT: Yes. Go ahead, Sammy.

5 MR. DIAB: This is Sammy Diab. Our objective, first
6 of all, is to try to have an assessment, a realistic
7 assessment, of the level of risk out there on the plants. The
8 second step would be to take that realistic assessment that we
9 think is presently occurring and to go from that into a goal of
10 how to improve the level of vulnerability of those plants, and
11 that's where the goal would come in.

12 MR. KERR: I recognize that the goal could come in
13 there, I just still don't know what it is. Mr. Barrett has
14 told me that achieving a ten to the minus six -- with some
15 likelihood that it might be as high as ten to the minus five --
16 is a possible goal, but it's not necessarily the one that
17 you've selected at this point.

18 MR. DIAB: It is a possible goal, and the reason that
19 we are not exactly certain at this point is because it depends
20 really on the quality of the PRA analysis that you do, and it
21 depends on the level --

22 MR. KERR: I'm sorry. Your goal doesn't depend on
23 the PRA.

24 MR. DIAB: The numerical goal does, sir, to some
25 extent, because, you know, at ten to the minus six of value of

1 core damage frequency, if you have not included all the
2 relevant assumptions into the analysis, a ten to the minus six
3 may be not adequate enough. On the other hand, if you include
4 all the relevant factors that you can possibly include, ten to
5 the minus five may be adequate.

6 MR. KERR: Okay. Would it be fair to say that at
7 this point, you don't know what your goal is going to be?

8 MR. BARRETT: No. I think it would be more fair to
9 say that we would like to demonstrate a ten to the minus six
10 mean value with an error factor that is like an order of
11 magnitude, but we recognize that we're in a region of numerical
12 space here that's highly uncertain, and we're using methods of
13 human reliability which are even more --

14 MR. KERR: Look, I'm not trying to be critical of the
15 situation; I'm trying to find out how you are going to
16 determine that you have or have not achieved your goal. Unless
17 you know what you're goal is, I don't see how you're going to
18 know whether you've achieved it.

19 MR. BARRETT: Well, what I mean is if w can do a PRA
20 analysis that we feel we have confidence in, as I think Sammy
21 was saying, if we feel that we have included everything that's
22 important, and that we have confidence in that analysis, and it
23 says ten to the minus six with an error factor of ten, we'll be
24 satisfied that we will have met a numerical goal.

25 What we're concerned about is that because of the

1 very low number that we're shooting for, and because of the
2 uncertainties and limitations of the method, we may have to
3 fall back to a qualitative type of goal.

4 MR. KERR: If what you're telling me is that you will
5 do this until you feel good about it, that's a goal that is
6 easy to define, and that apparently is about all you can say at
7 this point, that you want to do enough analysis that when you
8 get through, you feel good about the results.

9 MR. BARRETT: Well, that would be our fallback
10 position, yes.

11 MR. KERR: Okay.

12 MR. WARD: Rich, if you do use a number of ten to the
13 minus six, how does that square with the part of the safety
14 goal policy which suggests a goal of ten to the minus six for
15 accidents that involve a major off-site release?

16 MR. KERR: That's a suggested part of the safety
17 goal.

18 MR. WARD: No, that one actually is part of the
19 policy. That's in the policy.

20 MR. KERR: Sorry. The policy statement asks the
21 staff to examine that as a possible addendum. I think it's
22 real important that the distinction be made.

23 MR. WARD: That's correct. The question remains:
24 How would you square this with that? The emphasis here on
25 ISLOCAs is on scenarios where the containment is not intact,

1 and that, in fact, is the reason for the interest in it. So if
2 your project goal is a number of ten to the minus six, is that
3 for a set of events of which the ones that have containment
4 open are just a subset, or how do you square it with that
5 number?

6 MR. BARRETT: That is a goal that we have for the
7 high consequence type of event that we're talking about that I
8 described earlier, one in which you have a rather large break;
9 you have relatively unsuccessful attempts to mitigate the event
10 or to delay the event; not much reduction in the source term,
11 and so there are large doses offsite early.

12 MR. WARD: Okay. Well, then I have a problem with
13 the safety goal in that if this same number is adopted as part
14 of the safety goal policy, there isn't anything left over for
15 any other events.

16 MR. BARRETT: Okay. I understand that. You know, we
17 could say that we want to have a goal of five times ten to the
18 minus seven, and that would leave something left over for other
19 events, but I'm not sure -- when we're in that area of PRA
20 analysis, I'm not sure that that would make much sense to me.

21 I don't want to get into a situation where I'm trying
22 to add .5 and .5 times ten to the minus six to get to a
23 proposed safety goal.

24 MR. WARD: I would agree that the numbers are
25 difficult but conceptually are you saying that this event is

1 pretty much the total risk from the operation of PWR's or that
2 it represents half the risk?

3 MR. BARRETT: No. I'm not saying that, no. I do
4 know in past PRAs it quite often dominates the risk of early
5 fatalities. You may say early fatalities somehow define what
6 is a large release so in many past PRA's it has been a major
7 part of the most severe accidents, which I think is what that
8 part of the safety goal is trying to address.

9 I wouldn't want to say that by solving this problem
10 to 10 to the -6 we have met that part of the safety goal.

11 MR. KERR: And the probability of 10 to the minus 6
12 is synonymous with "will not occur," is that what that first
13 bullet implies?

14 MR. BARRETT: Yes.

15 MR. DAVIS: Before we leave this numbers game, in
16 NUREG 1150 for Surrey at least the V sequence did dominate the
17 risk and the probability of an interfacing systems LOCA in that
18 analysis was about 4 times 10 to the minus 6, which would be
19 above the objective here.

20 However, the off-site risks were extremely low, well
21 below the safety goal and my concern is we're starting to
22 develop a whole bunch of different kinds of criteria that
23 aren't consistent for these problems.

24 I am wondering if that is really the way to approach
25 it. Do you have any thoughts on that, Rich?

1 MR. BARRETT: If I am not mistaken, the NUREG-1150
2 analysis of bypass events included steam generator tube
3 ruptures that -- in the 4 times 10 to the minus 6 but I think
4 the answer to your question about numerical criteria is our
5 real concern with this particular project is really a safety
6 concern in the sense that we are worried about a particular
7 issue and the issue is are there accidents that are possible or
8 even likely at our reactors in which there will be no -- little
9 or no time for off-site response.

10 The question that comes up because of the recent
11 operational experience is, well, is ISLOCA one of them, and we
12 really want to see if this is a problem that we should be
13 losing sleep over or if this is a problem that is down in the
14 probability range that we are used to seeing in PRA's.

15 I think that is really the question we are trying to
16 get at, whether a particular PRA calculates 4 time 10 to the
17 minus 6 for a particular plant or another plant gets 3 times 10
18 to the minus 7, there are a lot of variation in the methods.

19 MR. KERR: At this point it is your view that the
20 answer to that will depend a great deal on the way in which
21 human error is evaluated --

22 MR. BARRETT: Absolutely.

23 MR. KERR: -- and in which there's at this point
24 still a very large amount of uncertainty.

25 MR. BARRETT: Yes, sir.

1 MR. KERR: So any calculations that you get are going
2 to be plagued with considerable uncertainties so you are going
3 to have to have a method of decision-making that takes into
4 account large uncertainties.

5 MR. BARRETT: Yes, sir. Exactly.

6 MR. WARD: Rich, let's -- are you -- you know, in
7 developing this program are you -- I mean do you look to the
8 safety goal policy as guidance at all in what you are going to
9 do here? Perhaps, you know, I guess you're in the information
10 developing stage now, and I can understand that --

11 MR. BARRETT: Yes.

12 MR. WARD: -- but once you satisfy yourself that you
13 have enough information to lead to some sort of a decision,
14 some sort of a program, do you think that the safety goal
15 policy will be an influence on that decision or that program?

16 MR. BARRETT: I think so. I think that the part of
17 the safety goal that you mentioned, the one about 10 to the
18 minus 6 of a large release would be that the controlling part
19 for this particular type of accident, because it is a low
20 likelihood an accident --

21 MR. KERR: Please, let's not refer to that as part of
22 the safety goal policy. It is not. It was a request to the
23 Staff to examine that as a possible one. I don't want to get
24 it built in to safety goal policy when it isn't yet. At least
25 I don't think it is.

1 MR. BARRETT: No, I don't believe it is yet part of
2 the safety goal policy.

3 MR. KERR: Okay.

4 MR. BARRETT: With regard to the actual quantitative
5 safety goals for individuals, I don't believe that the
6 interfacing systems LOCA challenges either the early fatality
7 risk to an individual or the latent fatality risk to an
8 individual and it would have to go up quite a bit in frequency
9 before it began to challenge the core melt, the implicit goals
10 regarding core melt frequency, so it's really the -- I believe
11 the quantitative design criterion that was referred to, that
12 was suggested to the Staff for evaluation that would be the
13 controlling factor.

14 MR. WARD: One other point I'd like, could you, I
15 guess I don't quite yet have a very good feel for why this
16 particular issue has been singled out for attention.

17 Certainly there are some troublesome things about the
18 sort of scenario that you have described but I think I could
19 make some of those same, almost some of the same series of
20 statements about the issue or group of issues that were
21 involved in Generic Issue 99.

22 There is a chance that there is an event in which the
23 containment is open -- Generic Issue 99 is concerned with that.
24 There have been a lot of precursor events that have been
25 troublesome, probably even many more for 99. Rough estimate

1 risk analyses indicate it may be a major contributor to core
2 melt and perhaps to off-site risk. Human contribution may be
3 very important. There are all kinds of subtleties,
4 difficulties in the operation under shutdown conditions where
5 they are not as tightly controlled.

6 Although for most of the situations where you are
7 concerned with GI-99, the decay power may be lower, that's more
8 than compensated for in a lot of scenarios by the fact that the
9 water levels can be down, but yet GI-99 has not been given the
10 high profile treatment and the formal treatment that this has.

11 I think maybe that's better but I am just wondering
12 why this one has been singled out in comparison with GI-99 and
13 probably half a dozen others that one could name.

14 MR. BARRETT: I think I share your concern about
15 accidents at shutdown. I don't know that I would say there are
16 a half a dozen others but I do agree with you that accidents at
17 shutdown are becoming more and more of a concern as, again,
18 being brought forward by the operational experience.

19 I guess I really can't answer the question as to why
20 this is being treated in one way and Generic Issue 99 is being
21 treated in a different way. I don't know.

22 I'd simply like to point out that in trying to meet
23 the goal we are going to not only look at the likelihood of the
24 initiating event, the loss of the pressure isolation valves,
25 but we are also going to be looking at the likelihood of a

1 break in the most likely break locations and also the
2 effectiveness of accident management both to prevent core melt
3 and to mitigate the off-site consequences.

4 [Slide.]

5 MR. BARRETT: Let me just briefly show you a very
6 simplified schematic chart of how the program is structured.

7 Sammy Diab will give you a little more information
8 about what these various project elements mean, but I simply
9 want to point out that this is a very strongly interactive type
10 of a project, heavy involvement on the part of NRR and the
11 Office of Research and also some involvement on the part of
12 AEOD and we have been getting a fair bit of help from the
13 regions in the inspection program.

14 I simply want to point out here that the heart, the
15 key to this program is that element right in the middle there,
16 it's the analysis, the PRA, human reliability, structural,
17 thermal hydraulic analysis that's being sponsored by the Office
18 of Research and a lot of the other projects that we are doing
19 are designed to bring information to that analysis effort,
20 namely the selected plant audits and the analysis we've been
21 doing of operational experience.

22 Now just a note with regard to the schedule.

23 We hope that by late in 1990 we would like to have
24 our technical conclusions about the severity of the IS LOCA in
25 light of the new experience, also have some answers as to

1 whether or not any additional regulatory action is needed and
2 what, if any, are the most effective types of regulatory action
3 that we might want to recommend.

4 MR. CATTON: What role do the Brookhaven reports play
5 in this? It seems to me they are finished.

6 MR. BARRETT: The Brookhaven reports are an important
7 source of information for this audit. We also have
8 participation in the program by one of the principal authors of
9 the Brookhaven report and so we are starting from the
10 Brookhaven reports and moving onward to bring the human element
11 into the analyses, so it is a jump-off point.

12 MR. KERR: So the Brookhaven reports do not take
13 account of the human element?

14 MR. BARRETT: Not in the detail that we would like
15 to, no.

16 MR. CATTON: They did put together a model and you
17 would just be going back into that model and changing things?

18 MR. BARRETT: I am not exactly sure if we are going
19 back into the very same model. Maybe Gary Burdick from the
20 Office of Research can tell me about that.

21 MR. CATTON: I see he's on the Agenda. Maybe he can
22 tell us about it when he has his turn.

23 MR. BARRETT: Fine.

24 [Slide.]

25 MR. BARRETT: I would like to finish up here so we

1 can get on with some of the more, some more detail. I simply
2 want to talk for a second here about our interactions with the
3 ACRS.

4 As you may recall, Dr. Murley was here in April to
5 describe why he wanted to have this project. Today what we
6 wanted to describe for you simply is the goals of the project
7 and the way we have structured it and how we are going about
8 it.

9 We hope to have some very preliminary results that we
10 could come back in the Spring and describe to this
11 Subcommittee, if you are interested, and we will schedule any
12 future briefings that seem appropriate. We would like to keep
13 you fully informed and we are very interested in what your
14 comments are.

15 I would like to also point out that we have told the
16 Commission about this. We gave them a very brief presentation
17 back in October about describing this as one of five emerging
18 technical issues that NRR is looking at.

19 Are there any further questions before I turn this
20 over to Sammy Diab?

21 MR. KERR: Yes. Has the existing Commission
22 abrogated its severe accident policy statement?

23 MR. BARRETT: Have they abrogated it?

24 MR. KERR: Yes.

25 MR. BARRETT: I don't believe so. I believe that --

1 MR. KERR: Well, the reason I ask is because as I
2 remember that the Commission concluded presumably with the
3 approval of the Staff at that time that existing reactors were
4 in, taken in the main, appropriately safe but that since PRA's
5 in some cases had identified outliers that a program was going
6 to be put together to try to identify outliers.

7 Now it seems to me that the program is in place, it
8 is underway and if there are outliers, either that program
9 should identify them or else it's probably an inappropriate
10 program and yet here is something which the Staff has concluded
11 won't be looked at rapidly enough by the IPE program or won't
12 be looked at appropriately by the IPE program, which says to me
13 that either that policy has been discarded or else somebody has
14 concluded that indeed operating reactors aren't safe enough
15 unless they get a very quick look at this particular problem.

16 I could mention two or three other programs that have
17 been undertaken in a similar way and this leads me to wonder if
18 the IPE program as a method of locating outliers has been
19 deserted?

20 MR. BARRETT: I think that's anything but the case.
21 First of all, I don't know of anybody who believes that the
22 current generation of plants is not safe enough. I have never
23 heard that statement made and I --

24 MR. KERR: Well, this is a fairly large-scale program
25 aimed at something or other. It is not aimed just at new

1 plants, is it?

2 MR. BARRETT: No. No, it's not. It's aimed at the
3 existing plants.

4 I think that with regard to the IPE, I think that
5 that is a program that is proceeding along the lines of the
6 policy and along the lines of 88-147 and I believe that given
7 the fact that every single plant is going to do a PRA in
8 response to the IPE. I believe that the vast majority of any
9 vulnerabilities out there, severe accident vulnerabilities,
10 have a good chance of being identified --

11 MR. KERR: Well, as Mr. Davis --

12 MR. BARRETT: -- and I don't think that should stop
13 us from --

14 MR. KERR: -- Davis has pointed out, and certainly as
15 NUREG 1150 points or at least says, this issue is likely to be
16 very plant-specific and it's going to be I think strange if one
17 can draw generic conclusions, particularly in light of the fact
18 that the people who did 1150 have concluded that you probably
19 can generic conclusions about plants from individual PRA's.

20 This seems like a natural to fit into the IPE
21 program. I can't understand this rather large-scale effort
22 apparently outside the IPE program, when it seems to me that
23 this is one of the more logical issues to go into that.

24 MR. BARRETT: I think it could very well be that this
25 will end up in the IPE program once we have a sense of whether

1 or not -- we have a suspicion here based on the operational
2 experience that there may be a bigger problem than we have seen
3 in past PRA's. We have to either confirm or deny that
4 suspicion --

5 MR. KERR: But you can't confirm or deny it until you
6 look at every plant.

7 MR. BARRETT: Well, we are going to look at a few
8 representative plants --

9 MR. KERR: Representative of what?

10 MR. BARRETT: Yes.

11 MR. KERR: 1150 says -- and maybe it's wrong; I
12 rather think it may be -- but 1150 claims that you can't draw
13 conclusions about plant safety by looking at a small population
14 of plants. And that population is going to be bigger than
15 yours.

16 MR. BARRETT: Yes, I understand that, Dr. Kerr. But
17 I believe that by looking at a few plants and doing a full
18 analysis of those plants, we can tell what types of issues are
19 likely to be important, are likely to be unimportant, in any
20 given plant.

21 If we can take those insights, and the results of
22 this analysis, and this is just one option, if we find out that
23 ISLOCA truly is a big problem, we can give those out as
24 guidance for furtherance of the IPE.

25 But I would say right now there are plants out there

1 that are starting their PRAs in response to the IPEs. And I
2 don't feel that, I don't know that anybody has confidence that
3 what we have learned from the operational experience recently
4 would be included in those analyses. I don't think too many
5 PRA analyses would say that.

6 So what we are trying to do here is a learning
7 exercise as to how you can improve what we do about this
8 particular action.

9 MR. KERR: So particularly, does not give you the
10 insights that you need to deal with this issue.

11 MR. BARRETT: I don't think there is any PRA out
12 there that does it. I may be mistaken, but this may end up in
13 the IPE process, but by and large, I think the answer to your
14 question is I think the Commission is steady going ahead with
15 the severe accident policy.

16 MR. KERR: Okay. And you are confident that the IPE
17 procedure now being described is incapable of providing the
18 insights that you talk about?

19 MR. BARRETT: I believe that there may be some PRAs
20 that are done under the IPE that will address this in some
21 varying degrees of quality. There will be other PRAs that
22 don't address it at all. I think you will see a whole
23 spectrum.

24 MR. CATTON: So this is an example of what you expect
25 in an IPE?

1 MR. BARRETT: I'm not sure I understand the question,
2 Dr. Catton.

3 MR. CATTON: Well, if this winds up being a part of
4 the IPE, what you are doing is an example of what you would
5 expect to find.

6 MR. BARRETT: Oh, yes. Well, we are probably doing
7 more analysis of this particular issue than you would want to
8 have in an IPE, because it is more of a learning process. We
9 are re-learning what the ISLOCA is about. Whereas in an IPE,
10 you are not going and reinventing the wheel with regard to
11 every accident sequence. So I would not expect that every IPE
12 would spend this level of effort.

13 MR. KERR: I'm sorry. The IPE is inventing the wheel
14 in the sense that it is looking at a specific plant.

15 MR. BARRETT: Yes, sir.

16 MR. KERR: And it seems to me in order to get a
17 solution to this issue, if it is an important issue, you have
18 got to look at the specific plant.

19 MR. BARRETT: You're right. And I believe that is
20 what will happen. It could very well be that the mechanism for
21 doing that will be through the IPE, through guidance to the
22 IPE. The mechanism may be through some sort of a generic
23 question, generic communication requesting information from the
24 licensees. I don't know at this point. But you are absolutely
25 right. The early indication we have is that it is very plant

1 specific. But the procedures that are applicable are quite
2 different from vendor to vendor and from plant to plant. The
3 configurations vary by a great amount. And there are many
4 other factors that vary.

5 MR. DAVIS: Rich, I think what you are saying, and I
6 agree with it, is that there are some generic elements of this
7 problem that are very troublesome. One of them is how to
8 handle the human reliability question.

9 MR. BARRETT: Yes.

10 MR. DAVIS: And another one is what is the
11 reliability of valves under the conditions of the LOCA, and so
12 forth. So it seems to me that the research will be directed at
13 trying to resolve some of those issues before you request that
14 it be put in the IPE so that you get some consistency back in
15 the analysis that is done as part of the IPE. Is that sort of
16 what you are trying to do here?

17 MR. BARRETT: Exactly.

18 MR. DAVIS: Okay.

19 MR. BARRETT: Exactly.

20 MR. KERR: In terms of future plants, is any thought
21 being given to an investigation or trying to reach a conclusion
22 as to whether check valves, for examples, should be used in
23 future plants? Maybe they shouldn't be used.

24 MR. BARRETT: That suggestion has been made, I
25 believe, by EPRI among others, that check valves should not be

1 used as a pressure isolation boundary. I'm not familiar myself
2 with the details of that conclusion. But I know that that
3 suggestion has been made. I don't know what the status of that
4 question is with regard to the events, the light water reactors
5 that are being proposed now.

6 MR. KERR: Well, if it would fit into this effort in
7 some fashion, it strikes me as something that could be fairly
8 important to future plants. And if it turns out that there is
9 a major decrease in risk that can be associated with that, we
10 ought to know it as soon as feasible.

11 MR. BARRETT: There are many design features in the
12 future plants that try to take into account the interfacing
13 systems LOCA. More robust piping, in the case of the PWRs,
14 having a lot of the RHR system and RWST inside of the
15 containment. So there are design features. But that is a good
16 question, you are right.

17 MR. CATTON: Are you finished?

18 MR. BARRETT: Yes, I am.

19 MR. CATTON: The next speaker is Sammy Diab.

20 [Slide.]

21 MR. DIAB: Good morning. My name is Sammy Diab. And
22 just to follow up to what the previous discussion urged, the
23 goal is, in a qualitative sense, is that we would like not to
24 have an ISLOCA event occur in the current generation of plants.
25 That may be 10 to the minus 6. It may be even less than that.

1 However, the precursors that we have been seeing, the
2 operating experience that we have been seeing, are too numerous
3 for comfort.

4 In other words, we have been seeing like maybe one a
5 month or maybe two a month that could fit into a pattern where
6 it suggested that an ISLOCA could have happened if you add one
7 or more of these precursors.

8 MR. KERR: What number would you be comfortable with?

9 MR. DIAB: I'm sorry. I really don't want to discuss
10 numbers.

11 MR. KERR: If you're seeing numbers that you are
12 uncomfortable with, what number would you be comfortable with?

13 MR. DIAB: We are simply trying to assess the
14 situation and see if that is indicative of a problem.

15 MR. KERR: I know you are, Mr. Diab. And I'm trying
16 to understand how you reached the conclusion that the number
17 you are seeing is too great.

18 MR. DIAB: Well, when you begin to see heat exchanger
19 seal ruptures and when you begin to see like tens of thousands
20 of gallons dumped from the primary system, either in the
21 auxiliary system, the auxiliary building or maybe in the
22 containment building, inadvertently, and when you see this
23 happening like month after month, it is really not a very
24 comforting thought, especially when all of these things are
25 designed at the plant.

1 MR. KERR: Look, we all know that it would be ideal
2 to never have any accidents. What I'm trying to determine is
3 what number do you expect is likely to occur in spite of
4 anything we can do, and what number brings you to a conclusion
5 that a fairly large program is necessary?

6 MR. DIAB: If you are speaking of precursors, which I
7 mentioned, the numbers I mentioned --

8 MR. KERR: Yes.

9 MR. DAVIS: -- I would like to see none. I would
10 like to see no precursors.

11 MR. KERR: Excuse me. I'm not talking about what you
12 would like to see. I'm talking about what you expect as
13 something that is reasonable. We aren't going to get to a
14 situation where you never have failures in these plants. I
15 mean, we can't possibly.

16 MR. DIAB: I really don't want to suggest a number
17 here, but if we have 100 plants in the course of a year, we
18 shouldn't be seeing more than 1 or 2 or something like that.
19 With these type precursors, that's just an ISLOCA.

20 MR. KERR: Okay. And you are seeing now about how
21 many?

22 MR. DIAB: I think we are seeing much more than that.
23 Just look at the events that come in every other week.

24 MR. KERR: So you are seeing about 25 per year, or
25 26? That would be every other week.

1 MR. DIAB: We're seeing about that many. Some of
2 them are more significant than others. But the ones that make
3 it to the list of significant precursors are less than that per
4 year.

5 MR. KERR: Are less than that?

6 MR. DIAB: Yes, are less than that per year. And we
7 are, you know, talking about significant ISLOCA-related
8 precursors.

9 MR. KERR: Thank you.

10 MR. CATTON: Is there a compilation of these
11 somewhere?

12 MR. DIAB: Yes, there is a compilation. We have a
13 list of events that we could probably provide to you.

14 MR. CATTON: And you will provide it to us?

15 MR. DIAB: Yes, we will. The one that we have
16 compiled is really not a complete list. But we could --

17 MR. CATTON: The ones that led you to take the
18 position you are taking.

19 MR. DAVIS: The Brookhaven report lists the more
20 significant ones.

21 MR. CATTON: When I went through the Brookhaven
22 report, I didn't see anything like 26 per year. Matter of fact
23 there's a much less number, and some of the ones that they
24 thought were significant, I didn't really think they were all
25 that significant. That could be an erroneous conclusion on my

1 part. But I would like to see your basis.

2 MR. DIAB: Dr. Catton, I didn't say 26 per year. Dr.
3 Kerr said.

4 MR. CATTON: You said --

5 MR. KERR: Well, you said every other week.

6 MR. CATTON: You said two a month and then another
7 time you said every other week. And either way that comes out
8 to 24 to 26.

9 MR. DIAB: When you look at the events, that is
10 correct. If you look at the events, you will see every other
11 week something. But then when you analyze it, you boil it
12 down, it doesn't boil down to one per week or one per every two
13 weeks.

14 But anyway, let me get on with --

15 MR. WARD: But whatever that number is, you want to
16 get it down to about one a year.

17 MR. DIAB: Okay. I can see that you want to hear a
18 number from me.

19 MR. KERR: Well, we want to hear a number, if you are
20 using numbers to make your decision. And you said you were
21 seeing to many.

22 to me, that means the number is too big.

23 MR. DIAB: That's correct.

24 MR. KERR: I don't know what else it could mean.

25 MR. DIAB: That's correct. I would like to see none.

1 MR. WARD: Well, Sammy, that's our problem.

2 You are uncomfortable, or you don't want to talk
3 about probabilities here. But the probabilities are there.
4 And I guess I would maintain that zero is an inappropriate goal
5 for you.

6 MR. DIAB: That is correct.

7 MR. WARD: That --

8 MR. DIAB: It may be a goal that may not be
9 achievable. But this is really semantics, right now.

10 MR. WARD: No, I don't think it is. I think it is
11 fairly important philosophy.

12 If you insist that nuclear power plants do everything
13 they can to drive this particular number down to zero, you are
14 probably going to continue what has been happening, that of
15 putting so many constraints on the operation of a plant in a
16 particular area that it either gets too expensive to run the
17 plant or that you are devoting all your resources to one issue,
18 and then neglecting other things.

19 And that is why we are not just arbitrarily picking
20 at this, but we think it is an important, you know, technical,
21 philosophical, engineering concept, that you are really dealing
22 with probabilities, and asking for zero doesn't wash. That's
23 not good engineering. You're concerned about a lack of
24 balance.

25 MR. DIAB: Mr. Ward, remember, when Dr. Murley came

1 here and addressed the committee, he didn't really come down
2 with the number. He said I've been seeing 20 per year, I would
3 like to see less than one per year. He said that he was not
4 comfortable with the rate of ISLOCA-type precursors that have
5 been occurring.

6 And we only want to be sure, because of the
7 seriousness of the consequences, potential consequences.
8 We want to be sure and we want to make an assessment as
9 realistic as possible and from that, maybe come back to the
10 conclusions, as maybe, you know, that we have looked at these
11 events or the chances of such an event occurring, and it's not
12 as serious -- you know, it's not too serious to -- you know, as
13 compared to its already established value in the literature, or
14 some other conclusion.

15 So we are checking the status basically.

16 MR. SCHROCK: I guess it's also puzzling to me that
17 you've got in the BNL report, largely events that are six,
18 seven years or more ago. Many of them are back in the 70's,
19 and there are none in the list since 1985.

20 MR. DIAB: Yes, there is. There are several events.
21 You're looking at a somewhat older list.

22 MR. SCHROCK: Well, I mean, it's a 1989 report.

23 MR. DIAB: That's correct, but I think their
24 information had been -- I think we used information up to a
25 certain point, but we'll provide you with a list that we have

1 compiled in-house and it's really not complete, but we will be
2 glad to provide you with that list.

3 MR. CATTON: I hope that this will be more than just
4 a list; that you will give the basis for coming to the
5 conclusion that you have.

6 MR. DIAB: Well, we -- you know, if you so request,
7 we could probably expand it somewhat description-wise, but it's
8 like an abstract, a list of abstracts. One could go back to
9 the individual events and analyze it some more and see exactly
10 what happened and why it happened.

11 Moving right along here now, I'd like to discuss with
12 you this morning the project overview. In order to be able to
13 assess the level of risk associated with such an event, the
14 project has been structured basically to have three main
15 elements that complement one another.

16 The operating experience, search -- and this is again
17 to look into the literature for the ISLOCA type precursor data
18 and the combinations of failures that collectively would lead
19 to an ISLOCA.

20 Another element, a second element is an audit
21 program. The audit program, again, it's intended for a few
22 selected plants that will help give us a snapshot, so to speak,
23 of the vulnerabilities, ISLOCA vulnerabilities for these
24 particular plants.

25 It would also provide us with --

1 MR. KERR: Excuse me. What is a vulnerability?

2 MR. DIAB: A vulnerability could be a design feature.
3 It could be a layout feature, the way a valve, say, is
4 installed, the access to such a valve. Say you have a valve, a
5 pressure boundary valve that is located in such a place where
6 it cannot be reached in case of an emergency.

7 Another vulnerability could be the operating staff,
8 for instance -- deficiencies in the procedures, deficiencies in
9 the training and the like; certainly that sort.

10 The audit program would also provide us with the --
11 it's an excellent vehicle for collecting and gathering an in-
12 depth information that we could use on a plant-specific basis
13 here in the analysis of the project. The audit program would
14 also enable us to have a qualitative assessment of the
15 perceived risk at a plant, at such a plant.

16 It, again, would also provide the necessary input for
17 the analytical quantitative risk. Of course the third element
18 is the analysis.

19 MR. KERR: Excuse me. In dealing with the human
20 factors, do you anticipate a generic treatment eventually of
21 human performance? Are you going to try to make that plant-
22 specific?

23 MR. DIAB: No, it's generic as far as audit program?

24 MR. KERR: As far as whatever it is you're going to
25 do about human performance.

1 MR. DIAB: Right, well, in this program, we are
2 approaching the human performance area -- I really don't want
3 to use the words, "generic basis" here, but we're approaching
4 it uniformly. You know, whatever we apply to plant A will
5 apply to plant B, and some things will fall out as significant
6 and some things will prove needless in some plants.

7 I'm really not sure if I'm answering your question.

8 MR. KERR: I would use the term, "generic" to
9 describe that, but I won't try to insist that you use it.

10 MR. DIAB: Have I answered your question?

11 MR. KERR: Yes, thank you.

12 MR. DIAB: The analysis element of the project;
13 again, it's structured to provide a focused human reliability
14 analysis and a PRA analysis. It will also involve
15 thermohydraulic and stress analyses of the particular plant
16 features.

17 [Slide.]

18 MR. DIAB: Now, I'd like to refer you back to the
19 project plan that Richard has shown you earlier. In
20 particular, I would like to discuss the two elements on the
21 lefthand side.

22 The first is the operating experience. The
23 compilation of operating data and failure data has been done by
24 the Office of AEOD. The output of that search is being
25 provided to NRR and to the Office of Research, and this is on a

1 continuous basis.

2 So, as events do occur, they are being communicated
3 to both offices.

4 MR. CATTON: Will there be an AEOD report on this?

5 MR. DIAB: No, I don't believe so, but the data is
6 transmitted through appropriate channels to the Office of
7 Research and to the NRR.

8 MR. CATTON: I would have thought that with something
9 like this, it would have been appropriate for them to write a
10 report, if the problem is as important as you imply.

11 MR. DIAB: Well, what the AEOD are doing --
12 researchers are doing; it's really that they are compiling the
13 data. They are searching the data for things that look like an
14 ISLOCA that will either individually or collectively provide an
15 ISLOCA.

16 They are also providing descriptions of the
17 significant events.

18 MR. KERR: These are precursors? When you say, "it
19 looks like an ISLOCA," do you mean something that could have
20 been?

21 MR. DIAB: Yes, something that could have developed
22 into an ISLOCA.

23 MR. KERR: What does -- how close does it have to
24 have been to one in order that it be considered a precursor, or
25 is that a matter of judgment?

1 MR. DIAB: No, it's really a matter of judgment and
2 the -- you know, there are certain definitions for a precursor
3 and I'm really not going by those. I'm going by the -- if a
4 failure -- say you have a two-valve system, a pressure
5 isolation valve. I think Rich mentioned this example earlier
6 about the WASH-1400.

7 If a valve -- a check valve and the seat was off or
8 the disk was off the seat, either rusted or with a foreign
9 object or whatever, all you need is a failure of the other
10 valve. If a failure of one of the two valves is reported, I
11 think that's a significant piece of --

12 MR. KERR: That's considered a precursor?

13 MR. DIAB: That is considered a precursor, yes. Of
14 course, they vary in degree.

15 MR. KERR: That's interesting because I thought the
16 reason you put two valves in is because you expect that one of
17 them may fail and that the other one of them may take care of
18 the situation.

19 MR. DIAB: You put the two valves because of the
20 defense-in-depth. You know, if one fails, you'd like to rest
21 on the other one.

22 So this compilation of data will, again, be as an
23 input to provide an insight to the NRR run of the program and
24 it also provides the input to the research. We have
25 identified, in order to assist the AEOD to do their research;

1 we have identified about a dozen low pressure systems.

2 They would then go and look at the high pressure/low
3 pressure interfaces and search any such interface for previous
4 periods.

5 MR. KERR: Excuse me. They're going to look at LERS
6 or what?

7 MR. DIAB: LERS, basically.

8 MR. KERR: Thank you.

9 MR. DAVIS: Are you comfortable that the reporting
10 requirements that currently exist will capture all of these
11 important precursors?

12 MR. DIAB: I think the reporting requirements that
13 are in existence ever since January of 1984 would make the
14 reporting consistent. I think the staff here feels comfortable
15 that it will.

16 MR. DAVIS: Thank you.

17 MR. DIAB: This again will provide the basic
18 ingredients for the PRA.

19 Next, I would like to discuss the plant audit
20 program. Again, this is intended for --

21 MR. KERR: Excuse me.

22 When you look at the precursors -- let's take, for
23 example, two check valves in series -- you will find that there
24 will be some failures, I assume. Now, is somebody going to
25 compare an observed failure rate that you see with the failure

1 rate that is used in existing PRAs? Existing PRAs certainly
2 don't assume that check valves always work.

3 I'm trying to understand what a precursor is.

4 MR. DIAB: I'm using the term "precursor" somewhat
5 loosely. In my opinion, a precursor is -- you're going to have
6 to go by this -- a failure in a system or a component of a
7 system that, given other failures, could have resulted in a
8 particular event.

9 MR. KERR: But that sort of thing is certainly not
10 something that is neglected in PRAs, because their failure is
11 given. It seems to me that what you'd get from the search of
12 LERs, if it is significant, is some failure rate that has been
13 observed, that is significantly different from the failure rate
14 that is typically used in PRAs. I mean, the fact that you get
15 failures is, in itself, not going to be very significant.

16 MR. DIAB: Here we're trying to assume that -- We're
17 really going to look at this problem as it has existed in the
18 past. We're trying to make an assessment of this perceived
19 problem, to see if it really justifies our concern.

20 MR. KERR: But you aren't doing it in a vacuum. The
21 problem has been treated in existing PRAs.

22 MR. DIAB: That's correct.

23 MR. KERR: It's just that, apparently, you think,
24 it's been treated incorrectly.

25 Now, what was said earlier led me to believe that it

1 was not mechanical performance that you thought had been
2 treated incorrectly, but human performance. I don't think
3 you're going to get much human performance information from the
4 LERs. Are you?

5 MR. DIAB: There are some root-cause analyses that
6 are present in the LERs, and also, this data, this information
7 that we're obtaining, will also be analyzed further by the
8 Office of Research, in search of any possible root causes.
9 Keep in mind that the people who are going to be using this
10 data are PRA specialists, and they are not going to operate in
11 a vacuum.

12 MR. BURDICK: This is Gary Burdick from the Office of
13 Research.

14 We are taking a fresh look, in the Research program,
15 at both hardware reliability numbers and human reliability. We
16 are not relying on numbers that have been used in past PRAs at
17 all. That includes the Brookhaven report. We're taking a
18 fresh look across the board at this problem, hardware- and
19 human-wise. I'll be covering this when I make my presentation.

20 Sammy's not involved in the calculational aspects
21 here at all.

22 MR. KERR: And he doesn't understand what you're
23 doing?

24 MR. BURDICK: Yes, but it's my job to answer
25 questions concerning the Research program. Sammy Diab is in

1 the Office of NRR.

2 MR. KERR: Okay. So when he is stumped, he can feel
3 free to ask you to back him up.

4 MR. BURDICK: Certainly.

5 MR. KERR: Okay.

6 MR. DIAB: I believe Gary will be able to answer some
7 of these questions.

8 MR. KERR: Okay.

9 MR. CAMPE: Excuse me. Kas Campe from NRR, Risk
10 Applications Branch.

11 I'd just like to comment on an earlier question you
12 had in reference to LERs, and whether or not they contained
13 information that would be related to human errors, human
14 factors. I believe it's fair to say that a fair number of
15 these LERs -- at least the ones that I have seen personally --
16 do call out things like poor or incorrect or misinterpreted
17 operating procedures, operator errors, and things of this
18 nature, bad maintenance practices. All of these are flags of
19 one sort or another that say that there is, perhaps, here
20 something worthwhile to look into from the human factors point
21 of view.

22 So the LERs can contain some information that is
23 related to human factors and human errors.

24 MR. KERR: Well, I think they can if, number one,
25 they are properly interpreted, and if, number two, the people

1 who wrote the LER understood what the human factor contributed,
2 and there's some question about both of those, I would think.
3 But my point was that if you report a failure of a valve, or
4 whatever, even though human performance may be contributed to
5 it, what you see is a failure. In the PRAs, what you see is a
6 failure, and it seems to me one ought to compare the two
7 failure rates to see if existing PRAs have significantly missed
8 -- I mean, what we are ultimately looking for is some sort of
9 failure, and since we haven't have very many interfacing-system
10 LOCAs, I guess we have to introduce human performance. We have
11 had, however, failures of valves, and those are failures,
12 whether human performance contributed to it or not. Since
13 these same failures appear in PRAs, it would make sense, it
14 seems to me, to compare what you see with your fresh look to
15 what has been used.

16 MR. CAMPE: That's a valid observation. I was just
17 commenting on whether or not LERs can be interpreted, perhaps,
18 in human error type information. There's a lot of room for
19 interpretation, admittedly. It's not an all-or-nothing kind of
20 situation.

21 MR. DIAB: Dr. Kerr, also, this type of information
22 that's being provided by AEOD, when it goes to the Office of
23 Research, they also manipulate the information some more and
24 look into it some more, in order to be able to understand
25 whatever they can understand from the description of the

1 events.

2 MR. CATTON: I thought part of AEOD's charter was to
3 search for precursors. Why is it that they haven't found what
4 you find? They just weren't interested in it, or something?

5 MR. BURDICK: This is Gary Burdick from the Office of
6 Research.

7 There is a definition of a precursor that is used
8 within the context of the precursor program. Although I
9 haven't been involved with that program for a number of years,
10 I believe it still has to do with the event's causing the
11 failures of multiple trains in the same system, or causing
12 failures in at least two safety systems.

13 MR. CATTON: So the definition is what led them to
14 miss this.

15 MR. BURDICK: We're looking for more information on
16 failures than you would find simply from the precursor program
17 itself.

18 MR. DAVIS: But, Gary, I thought AEOD sponsored an
19 accident precursor program at Oak Ridge in which --

20 MR. BURDICK: That's the program I'm talking about.

21 MR. DAVIS: Yes, but they didn't use that definition,
22 as I recall.

23 MR. BURDICK: They did. That program began in the
24 Office of Research. I was the branch chief that had it at the
25 time. We transferred the program some years ago over to AEOD.

1 MR. DAVIS: But they took these events and put them
2 through event trees and actually calculated probabilities that
3 these specific events would end up in a core-damage situation.

4 MR. BURDICK: That's true, but in order to be
5 considered a precursor, it had to satisfy the definition I just
6 gave.

7 MR. DAVIS: Okay. Thank you.

8 MR. CATTON: Maybe it should be redefined, then.

9 MR. KERR: So there had to be multiple failures.

10 MR. BURDICK: That's right.

11 Well, the failure of multiple trains in the same
12 system, or precipitating failures in at least two safety
13 systems.

14 MR. KERR: So what you're looking for is not so much
15 precursors, but you're really trying to look for better data on
16 failures of components.

17 MR. BURDICK: That's it, and get a handle on the
18 human aspect, also.

19 MR. KERR: So that's not really a precursor study;
20 it's really a data analysis of failures.

21 MR. BURDICK: That's right.

22 MR. KERR: Okay.

23 MR. DIAB: The next element I'd like to discuss with
24 you is the plant audits activities. This has been primarily
25 run by the Office of NRR with assistance from the regions. The

1 team we have is made up of eight multidisciplinary experts and
2 a team leader, and the areas of expertise really cut across all
3 the plant features that are relevant, like instrumentation and
4 control, maintenance, procedures, and human reliability.

5 The blocks of time that the team use basically fall
6 into three categories:

7 A preparation period before visiting the plant site.
8 In that period, they study the material we obtained from the
9 plant beforehand, system descriptions, procedures, maintenance
10 records, et cetera. They also chart strategy for inspecting or
11 auditing the plant once on site. They decide on systems of
12 interest, and they find that, of course, from the system
13 description and the plant layout. They also decide on
14 significant scenarios that they would like to address once on
15 site.

16 When they go to the plant -- which is the second
17 phase -- they basically spend two weeks there, and they verify
18 their initial strategy. Are the systems the correct systems to
19 look at? Are the scenarios the significant ones? Et cetera.

20 They then come back and write their report,
21 subsequent to this.

22 In order to streamline the audit process --

23 MR. KERR: How many of these audits do you plan to
24 make? How many plants?

25 MR. DIAB: So far, we have done two.

1 MR. KERR: No, I said, how many do you plan to make,
2 total?

3 MR. DIAB: Three or four, all together. I can
4 discuss this a little bit later.

5 MR. KERR: Do the plants that are audited have to pay
6 fees to the NRC for being audited?

7 MR. DIAB: I really don't know the answer to that.

8 MR. BARRETT: We've conducted two so far. The first
9 was conducted as an audit, and I think, as such, the licensee
10 did not have to pay fees. The second one was conducted as a
11 formal inspection, and I believe they did have to pay fees.

12 I believe our team leader for the second inspection
13 is here. Maybe he could clear that up.

14 MR. ISOM: Jim Isom with the Special Inspections
15 Branch.

16 I don't know the answer to that question. All I know
17 is that the second inspection was done as an inspection, rather
18 than an audit.

19 MR. KERR: It would seem to me that you really ought
20 to pay the clients, because I'm sure this takes a lot of effort
21 on the part of the client's staff. Since, by Congress, the
22 clients pay you guys when you go in because they've done
23 something or other, it would seem only fair that they get paid
24 for the staff time that has to be expended on this sort of
25 thing. Have you considered asking your management for this

1 authority?

2 MR. BARRETT: No, we haven't considered asking our
3 management for this authority. We routinely go to the
4 licensees with --

5 MR. KERR: Look, Rich, I know you routinely go to the
6 licensees. This is what bothers me. We are seeing more and
7 more programs where you go the licensees, and these guys have
8 to spend a lot of resources on this. These are resources that
9 could be used for something else.

10 MR. BARRETT: You're absolutely right. There's a
11 major effort going on right now -- you may or may not be
12 familiar with it -- in which NRR and the regions are trying to
13 assess this very question, what kind of impact are we having on
14 the licenses.

15 MR. KERR: And I can predict what the result is going
16 to be.

17 MR. BARRETT: Well, I can't.

18 [Laughter.]

19 MR. BARRETT: But not only through the inspection and
20 audit process, but also through generic communications. So it
21 could very well be that what you're suggesting may change in
22 the near future.

23 [Slide.]

24 MR. DIAB: Let me move on to the next viewgraph here.
25 In order to streamline the audit process, we have structured

1 the audit activities in general to fall along the same lines as
2 the defense-in-depth concept, basically three layers of
3 inspection or audit.

4 Number one: How can things go wrong? How can an
5 ISLOCA event take place? Number two: How can it be discovered
6 and rectified or recovered in a timely fashion. The third
7 layer, of course, given that the above two have taken place, is
8 to minimize offsite consequences.

9 The idea here is to look for plant features that
10 either limit the chances or likelihood of occurrence in the
11 first place, number one. Number two, if an ISLOCA has already
12 taken place, how or what types of features or actions can be
13 taken to either delay or prevent core damage?

14 MR. KERR: Now, is the NUMARC program that is being
15 carried on in accident management not looking at this for
16 ISLOCAs?

17 MR. DIAB: I can't answer that.

18 MR. BARRETT: The NUMARC program is not specifically
19 looking at ISLOCAs.

20 MR. KERR: No, I didn't ask if it was not
21 specifically looking. I mean is it neglecting -- maybe I
22 should have said -- ISLOCAs?

23 MR. BARRETT: No, it's not neglecting ISLOCAs in the
24 sense that the guidance that will be given to the utilities by
25 NUMARC will be very much based on the IPE process, so whatever

1 comes out of the IPE process, whatever comes out of generic
2 PRAs in the past will be input to this. But to the extent that
3 we're going beyond the IPE, then you would say that --

4 MR. KERR: Why should it go beyond the IPE, I mean if
5 accident management is accident management?

6 MR. BARRETT: Well, I don't believe it's planning to
7 go beyond the IPE except insofar as they would like to also
8 take into account generic PRA results rather than just plan-
9 specific PRA results. But given the fact that it's based on
10 current PRAs and PRAs in the IPEs, it will not go as far as
11 this unless --

12 MR. KERR: I don't see how one can establish an
13 accident management structure at a plant, and then have a
14 separate accident management structure for ISLOCAs.

15 MR. BARRETT: I don't believe this slide is meant to
16 mean that there would be a separate structure for accident
17 management.

18 MR. KERR: Well, it appears to me that the NRC is
19 doing accident management for this issue, and I'm in favor of
20 accident management, but including the rather major program the
21 NUMARC already has, I'm puzzled that NRC is undertaking another
22 one for this issue.

23 MR. BARRETT: Right now, this is simply a study to
24 find out, given the current procedures and the current status
25 of training and what have you, what is the likelihood that

1 accident management in this particular area would be effective
2 for the types of scenarios that we're looking at? Remember,
3 this is just a study. We're not trying to get the utilities to
4 do anything different here. It's a snapshot of the current
5 situation given the current --

6 MR. KERR: At some point, if you don't try to get the
7 utilities to do anything different, either it's not a problem,
8 or else the study is worthless.

9 MR. BARRETT: Well, that's the point. I think once
10 we've decided what the current situation is, and we've put that
11 through the PRA models, we'll know whether or not ISLOCA is
12 truly a bigger problem than we thought. Once we know that, and
13 we've done a complete study from front to back, we'll have a
14 sense of where improvements are needed, if they are needed, and
15 some of them may be accident management improvements.

16 MR. KERR: No, but -- well, I guess I'm not getting
17 through.

18 MR. WARD: I think what's bothering us is both with
19 regard to IPE and accident management. If you said that the
20 staff has a particular concern about ISLOCA, and you're going
21 to develop some information on it, and you're going to take
22 this information and use that as part of the total body of
23 information you have to make some judgments when you're
24 reviewing IPEs, or make some judgments when you're reviewing
25 accident management procedures, or even better, if you make

1 that information available to the people who are doing IPEs and
2 developing accident management, I think we wouldn't have any --

3 I mean, that seems like a good program. But that doesn't seem
4 to be your purpose. Your purpose seems to be to do something
5 in addition, in parallel, in place of, ahead of the IPEs and
6 the accident management programs. That's the problem, I think,
7 that we're having. At least that's the one I'm having.

8 MR. BARRETT: Okay. Then let me answer the question.
9 We don't plan to do anything in terms of changing plant
10 programs, changing procedures, training, hardware, or anything
11 at the plants at this time. What we're trying to do right now
12 is a study to better understand the ISLOCA program, or a
13 problem, event.

14 It could very well be that the right way, eventually,
15 once we figure out this problem, is to take what we've learned
16 and give it to the utilities as some sort of an add-on to the
17 IPE generic letters, and ask them to go and do -- you know,
18 augment their plant-specific evaluation. Pete suggested that.
19 I think it's a good suggestion.

20 We're not talking about doing anything with the
21 licensees or to the licensees at this point. We're not talking
22 about anything of that type until we understand the problem
23 better. What we're describing today is what we plan to do over
24 the next nine to twelve months to better understand this
25 problem. Your suggestions about how to implement what we

1 learned is an excellent one.

2 MR. KERR: Well, then I misunderstood, because I
3 thought what I heard was that you were in the process of
4 developing an accident management strategy as part of your
5 audit.

6 MR. BARRETT: No. No, sir.

7 MR. KERR: What did I hear?

8 MR. BARRETT: Well, to understand the risk of this
9 accident, one component is the ability, for instance, to
10 isolate the break once it has occurred, and you could call that
11 part of an accident management, or that's an action to manage
12 the accident.

13 There are other things that go beyond that. Suppose
14 you had melted the core. There are certain actions you might
15 take to mitigate the magnitude of the release. Those are
16 accident management type actions.

17 The audit is an attempt to go and look at some PWRs
18 as they stand right now and make an assessment of whether or
19 not, in an ISLOCA, actions of that type would be successful,
20 would be likely to succeed or not likely to succeed, and, if
21 not, how important is that? If it is important, and it's not
22 likely to succeed, what could we do to improve it? Is it
23 training? Is it better procedures? Is it something that we
24 could perhaps add to the accident management program of NUMARC?
25 Right now, this is an open question.

1 MR. DIAB: Precisely. This is basically a study to
2 assess the ISLOCA situation out there, to basically see if it
3 is a problem or if it's not a problem, and if it is a problem,
4 what kind of problems do we see? Then in order to implement
5 some of these recommendations, this will be a second phase that
6 will have to interact with other programs that are underway.

7 MR. WARD: Sammy, when you say whether it is a
8 problem or is not a problem, in your first item up there,
9 you've got the likelihood.

10 MR. DIAB: Uh-huh.

11 MR. WARD: So that means you're recognizing that this
12 is a problem, if I could use the term, in probabilistic space,
13 and that your earlier statement about wanting to reduce the
14 number of precursors, or the number of events to zero, is not
15 really a, you know, technically sound goal for a problem that
16 exists in probabilistic space. I'm not trying to be abstract,
17 but it's important philosophy here, I think.

18 MR. DIAB: You're right. I mean a likelihood of zero
19 occurrence, it probably is technically --

20 MR. WARD: Is zero. Yes.

21 MR. DIAB: -- unsound. It may not be achievable.
22 But you're asking me what would you like to see? I'd like to
23 see none of that. But the point is, the likelihood -- of
24 course, it varies from plant to plant, from an operating crew
25 to an operating crew, from a shift to shift, also from a

1 certain plant configuration to another plant configuration. It
2 depends on a multitude of factors, and the audit program,
3 together with the research program, the audit program is trying
4 to get some of this information, and the research program is
5 geared to analyze this information into a numerical sense.

6 MR. DAVIS: I hope the likelihood in that first
7 bullet is not going to be zero. I think that likelihood you'd
8 like to be one, wouldn't it, the likelihood that an ISLOCA will
9 not occur?

10 MR. DIAB: That's correct. That's correct. I'm
11 talking about the likelihood of ISLOCA occurring; you're
12 talking about of it not occurring.

13 MR. SCHROCK: It seems to me that the information you
14 get from your audit program will depend on what you've chosen
15 to audit, and I wonder what criteria you had in making a
16 decision on which plants to audit.

17 MR. DIAB: A very good question. The structure of
18 the audit activities really, like I mentioned earlier, went
19 really basically over three layers: initiation, and then
20 mitigation and control, and the third one would be if none of
21 the above has worked, then what can be done to limit off-site
22 consequences?

23 I think this covers just about any possibility of
24 having an ISLOCA that progresses into a bad event, that
25 progresses into a core damaging and fission products offsite.

1 MR. SCHROCK: I don't understand that answer. That
2 guided you in deciding which plants to audit?

3 MR. DIAB: No. This is areas of review, or areas of
4 audit.

5 MR. SCHROCK: Yes. My question was motivated by the
6 recognition that you think it's very plant specific.

7 MR. BURDICK: I'm going to deal with that in my
8 presentation.

9 MR. SCHROCK: All right.

10 MR. BURDICK: I'll tell you why we selected the
11 plants we did, and I'll deal with the plant specific nature of
12 the problem.

13 MR. CATTON: Sammy, we're running about 45 minutes
14 behind. Could you maybe pick up the pace a little?

15 MR. DIAB: I am, I think, fairly close to finishing
16 here.

17 [Slide.]

18 MR. DIAB: The next three viewgraphs --

19 MR. CATTON: I understand it's not your fault.

20 [Laughter.]

21 MR. DIAB: I appreciate it. The next three
22 viewgraphs get into a little bit more detail, Professor
23 Schrock, about what exactly is being looked at, and this is
24 really not an exhaustive conclusive list. This just lists a
25 few examples. For the sake of speed here, these are pretty

1 much self-explanatory. I'm fairly done, unless you have other
2 questions.

3 MR. CATTON: Are you finished?

4 MR. DIAB: I'm finished.

5 MR. CATTON: That was quick. I appreciate that.

6 Next, we're going to hear from Mr. Burdick from
7 Research. I think, in deference to my colleagues, we'll take a
8 break.

9 [Recess.]

10 MR. CATTON: Let's get started.

11 [Slide.]

12 MR. BURDICK: I'm Gary Burdick from the Office of
13 Research, and I am going to be talking about the research
14 program on the ISLOCA for the near term, and this is dealing
15 with an assessment of the problem for the ISLOCAs that bypass
16 containment and could lead, as Rich was saying, to an ISLOCA of
17 major concern, more so than the ones that would occur inside
18 containment. This is also supporting the development of the
19 resolution of the Generic Issue 105, when encompasses both
20 those ISLOCAs outside and inside containment.

21 [Slide.]

22 MR. BURDICK: The research program got started in
23 response to a user request from Tom Murley to Eric Beckjord,
24 and that asked, in effect, for a reassessment of this problem
25 if the ISLOCA is outside containment. I was at the April 6th

1 ACRS full committee meeting, where Tom Murley expressed his
2 concerns to the Committee. I understand, from that meeting and
3 from his user-request memo, that there would be an evaluation
4 of -- what was needed was an evaluation of both hardware and
5 the human actions, a reevaluation, because past PRAs, past
6 studies had been weighed in the balance and were found wanting
7 in both these respects.

8 So, in devising this ISLOCA research program, we
9 identified a number of objectives that we had to achieve in
10 order to perform this reevaluation. So, we had to get farther
11 into the low-pressure systems, because past PRAs, past analyses
12 did not get very far beyond the pressure isolation valves.

13 We had to take a look at the fragilities of the
14 components in those systems -- there was a suspicion that
15 failure rates in use were, perhaps, too low -- again, take a
16 look at the human actions and the performance shaping factors
17 that affected those human actions, try to identify those that
18 were important to ISLOCA.

19 There was a possibility that if the human was
20 contributing more to the ISLOCA problem, we might identify
21 simple ways to reduce the importance of the human element --
22 perhaps, additional training, sensitizing people to plant,
23 perhaps.

24 We had to determine ISLOCA sequence timing, flow
25 rates, and if necessary, accident-management strategies -- that

1 is, if the problem was important enough -- timing, because we
2 had to determine how long people had to act; flow rates, how
3 long it would take compartments to fill up.

4 We had to look at effects on other equipment. There
5 could be common-cause failures. The effluent could wipe out
6 equipment that you might be relying upon to get water back into
7 the primary, and we had to do this all in a PRA framework in
8 order to assess these contributions.

9 The PRA framework would be useful if we had to go
10 through backfit analyses a la the backfit rules, 50.109, and we
11 had to carry these analyses out to estimate the consequences in
12 order to factor those into the cost-benefit analyses of
13 potential fixes, and we had to conduct this program, devise a
14 program that would provide for a spectrum of possible fixes to
15 the problem, if there was one.

16 We do not, a priori -- we do not know that this is a
17 serious problem. We do not yet fully understand the nature of
18 the problem, but we had to have a program that would cover,
19 like I said, a spectrum of possible bases.

20 [Slide.]

21 MR. CATTON: What do the Brookhaven reports do for
22 you?

23 MR. BURDICK: The Brookhaven reports are being
24 examined by Idaho -- the Idaho National Engineering Laboratory
25 -- along with other past PRAs, other sources of information, to

1 take out of them what is useful and use it. The Brookhaven
2 reports had a focus on the cost-benefit of valve testing. The
3 modeling that was done in the Brookhaven reports was not to the
4 depth -- it was not, in other PRAs, past PRAs, to the depth
5 required to go into the analysis of the human contributions to
6 the problem.

7 MR. CATTON: Well, the human factors part was weak,
8 but the reports certainly are thick enough.

9 MR. BURDICK: Well, if that's how you judge the
10 utility of reports -- we are using whatever is useful out of
11 them.

12 MR. KERR: Mr. Burdick, I was waiting for this slide,
13 because there were some things that were not on the previous
14 slide that, it appears to me, should have been.

15 Number one, you say you aren't quite sure how bad the
16 problem is, and you're doing a study to determine how bad it
17 is, and presumably, this is going to be done in PRA space.

18 How are you going, when you have finished the study,
19 to determine whether things are bad enough to do something?

20 Then, once you have determined, maybe, that things
21 are bad enough to do something, how are you going to determine
22 how much one has to do? Presumably, that will be on a cost-
23 benefit analysis basis, because Mr. Barrett has said that this
24 is not being done because existing plants are unsafe, but
25 rather, because there is some feeling that they could be made

1 safer.

2 Third -- and then, I'll stop -- has anybody tried to
3 estimate whether this problem can really be solved using PRA
4 space?

5 MR. BURDICK: We're not only looking at the problem
6 quantitatively; we're looking at it qualitatively, as well.

7 We don't know the nature of the problem at this
8 point. It could be that there are a lot of qualitative
9 factors, a lot of things that you might do at a plant that
10 could effectively handle this problem, and I mentioned a couple
11 of them that I consider kind of qualitative -- training,
12 sensitization of people that certain things might be important,
13 that if they do not keep an eye on certain situations that
14 their plant could deteriorate with respect to this problem.

15 MR. KERR: Excuse me. You're ahead of me. I thought
16 you first were going to, after you had made the study, decide
17 whether you had a problem or not. You've already passed that
18 point, and you're sure you have a problem.

19 MR. BURDICK: No. I'm saying we have not
20 convinced ourselves, at this point, that this is a serious
21 problem.

22 MR. KERR: Okay. What I am trying to understand is
23 how you're going to decide, once you have done the study, that
24 here is or is not a problem? What criteria are going to be
25 used? What's the decisionmaking process going to be? Are you

1 going to get six experts in a room and, as a result of their
2 vote, it is or is not a problem or what?

3 MR. MR. BURDICK: We're going to use the PRA portion,
4 certainly, to get estimates of frequency and consequences. We
5 are going to look at the constituents of the problem and, in a
6 cost-benefit context, see if there is something that might be
7 worthwhile --

8 MR. KERR: Now, you're telling me what you are going
9 to do if you decide there's a problem. I'm still back at
10 deciding whether there is a problem or not. How do you decide
11 that?

12 MR. BARRETT: Gary, let me take a shot at that. I
13 think we may be discussing what we talked about earlier, and
14 that is what's our criterion for what's an acceptable level of
15 risk.

16 MR. KERR: Well, if you are going to use risk as the
17 criterion, I am not sure what it is that's going to be used in
18 the decisionmaking process that says we do or we do not have a
19 problem.

20 MR. BARRETT: I think, as we discussed earlier, we
21 see a lot of PRAs out there that say the core-melt frequency
22 from this accident is 10 to the minus 6, and what we want to do
23 is put the human factors, the human reliability area in there,
24 do a little more careful analysis of the whole thing, including
25 accident management, and see if that conclusion of 10 to the

1 minus 6 still holds up, and if that's the case, then I think
2 we'll be very satisfied, and if we had total confidence in the
3 PRA process at the 10 to the minus 6 level, we would probably
4 state that as a hard-and-fast goal, that 10 to the minus 6 is
5 our goal, but we're keeping in mind that we may not -- when we
6 finish this study, we may not have such a hard-and-fast PRA
7 answer.

8 MR. KERR: See, the reason I ask this is because I
9 would have great difficulty in a situation in which you find
10 yourself setting up criteria, and I wonder if, since Murley and
11 others -- maybe yourself -- are convinced this is a serious
12 problem, maybe you should forget about PRA and say here are
13 some things we can do to make the risk less, because I'm not
14 sure but what you are going to go through this study and the
15 results are going to be very inconclusive in terms of numbers,
16 because there is going to be a big uncertainty, and you still
17 won't be in any better position to make a decision than you are
18 right now.

19 MR. BARRETT: Well, that could be the case, but --

20 MR. KERR: Is there something that leads you to
21 believe that you will be in a better position?

22 MR. BARRETT: Well, I think we have to be, because
23 right now, if I thought that I had a fix in mind that I could
24 impose upon the industry that would somehow fix this perceived
25 problem, the first thing I would have to do would be convince

1 myself, my management, and you that there was a reasonable risk
2 benefit to it, and I can't do that today.

3 MR. KERR: What leads you to believe that you might
4 be able to do it a year from now?

5 MR. BARRETT: Well, the fact that we have structured
6 a study that uses the best available information and methods
7 that will include in the analysis of ISLOCA for the first time
8 in an integrated way, this total treatment of human
9 reliability, along with the other types of failure modes.

10 MR. KERR: But you don't have any idea of what the
11 uncertainty is if you start trying to calculate uncertainty at
12 this point, do you?

13 MR. BARRETT: No.

14 MR. BURDICK: If we decide that there is a
15 significant problem here, the only way that we are going to be
16 able to sell any fix to that problem, I think, is within a PRA
17 context. If you have some other tool that we can use, I'd be
18 happy to --

19 MR. KERR: All you have to do is to say that existing
20 plants are not safe enough and you don't have to worry about
21 cost/benefit analysis.

22 MR. BARRETT: I don't know what basis I would have
23 for making that statement.

24 MR. KERR: Well, you are going to have to use the
25 same basis for making that statement that you're going to have

1 to use for making this decision, which is that things are worse
2 than existing PRAs had led one to believe.

3 MR. BARRETT: But they could be worse by epsilon, or
4 they could be worse by a factor of ten; we don't know yet.

5 MR. KERR: That's my question; how much worse are
6 they going to have to be before you decide something needs to
7 be done?

8 MR. BARRETT: I think that unless they're
9 qualitatively the same level of risk that we currently
10 perceive, I think we're going to take a hard look at whether
11 something needs to be done.

12 MR. KERR: That's because you will have concluded
13 that existing plants are not safe enough. I don't see how else
14 you can convince yourself that something needs to be done.

15 MR. BARRETT: Yes, I suppose so.

16 MR. BURDICK: I think that if you look at the SECY
17 paper on the closure of severe accident issues, you will see a
18 cartoon in there which includes a number of activities, IPEs,
19 containment work, accident management and along the top, there
20 is a continuing line that goes clear across the page. That's
21 called Operational Reliability.

22 When you do these things like IPEs, you do a PRA;
23 these things are snapshots in time of the safety of that plant.
24 It doesn't mean that you walk away and think everything is
25 hunky-dory for all time. Eternal vigilance is the price of

1 safety as well, I think, as of liberty.

2 You have to continually look at the situation.

3 Things can be all right at a plant at a certain time. Due to
4 management changes and other factors, the plant can vary in its
5 safety profile.

6 At the April 6th ACRS meeting, I recall Tom Murley
7 saying that this should be one of those elements of the
8 operational reliability. What we are doing now is going out
9 and being responsible as regulators and assessing a situation
10 that Tom Murley, at least, has considered to not quite jive
11 with what past assessments have indicated.

12 MR. KERR: Mr. Burdick --

13 MR. BURDICK: We are doing the best we can with the
14 tools we've got, and when you say "when are we going to decide
15 there's a problem," what exactly do you mean by a problem?
16 Problems have a lot of different natures, and what is
17 considered a problem, you know, could be a small item like
18 maybe additional sensitivity of the people at the plant to this
19 problem, maybe additional training.

20 The fix could be then maybe a bulletin, a Generic
21 Letter, maybe not a backfit. But before we can make those
22 kinds of judgments, we have to make an honest assessment of the
23 problem with the tools we have; try to get its nature and get
24 our hands around the constituents, and that's what we're trying
25 to do here.

1 MR. KERR: Mr. Burdick, I want to go on record as
2 applauding eternal vigilance in safety and a number of other
3 areas. Let the record be clear.

4 What I am trying to understand -- and it's
5 unfortunate that I have to try to understand this -- but if
6 we're going to advise the Commission, we need to understand
7 what you're doing. I'm trying to understand how you are going
8 to decide, through whatever means, that there is or is not a
9 problem.

10 At this point, I don't understand how you are going
11 to make the decision after you have carried out this study. I
12 won't pursue it any further. I just want to explain to you why
13 I'm asking these questions.

14 I'm trying to understand the decision process. At
15 some point, you're going to have to make a decision. The
16 impression that I get is that nobody on the Staff at this point
17 knows how the decision is going to be made. You have faith
18 that having developed all this new information, the decision
19 will sort of maybe rear its ugly head automatically.

20 I think somebody ought to be giving serious thought
21 to how you are going to make the decision, because I don't
22 think it's going to be easy.

23 MR. BARRETT: Dr. Kerr, I apologize for interrupting
24 again, but I think that we have a way in mind of how to make
25 the decision. We have criteria in mind as to what's acceptable

1 and what's unacceptable for this accident. I think that
2 realistically speaking, when we're finished with the study,
3 we're going to have to exercise a certain amount of judgment.

4 I don't believe that the numerical results are going
5 to dictate a conclusion as to whether or not this is
6 acceptable. We have a general idea in mind of what's an
7 acceptable level of risk for this sequence, but as I said,
8 we're going to have to exercise a certain amount of judgment.

9 I would like to say one further thing though. I
10 don't believe that to make an improvement to any plant, that we
11 have to first conclude that the plant is not safe enough. I
12 think that's an important point.

13 I think that the plants are safe enough. They meet
14 our rules and our regulatory guidance and they're safe enough.
15 What we have to conclude, according to our backfit rule, is
16 that any improvement that we plan to implement is a substantial
17 improvement in safety and meets the test of cost/benefit.

18 We can do that, even if we still believe the plants
19 are safe enough.

20 MR. KERR: I know you can under existing rules, but
21 it seems to me that if you do it for only that reason, it is
22 somewhat capricious. You're saying that on the one hand,
23 they're safe enough to protect the public, and yet you are
24 spending public money to improve them.

25 I mean public money in the sense that the rate payers

1 and others pay for this. So, I think as a responsible
2 regulator, you have to decide before you start applying
3 cost/benefit analysis, that something needs to be done because
4 the public really ought to be protected better than it is now
5 being protected.

6 It was in that sense that I was using the term, not
7 in the legalistic sense in which current regulations can be
8 interpreted.

9 MR. BARRETT: I understand.

10 MR. BURDICK: I think it is true to say that we do
11 not at this point have any reason to say that they are not safe
12 enough. Let me get into the program here. Let me start with
13 the configuration review, because here it is that we try to
14 cover as many plants as we could in the following manner:

15 We looked at the systems involved in interfacing
16 systems LOCAs, and identified as well as we could, a set of
17 systems that were representative, as representative as possible
18 of those existing in the family of operating plants. The
19 intent was then to analyze these systems in the context of a
20 half a dozen specific plant studies, a half a dozen plants
21 which, in fact, had these systems.

22 The output then of these systems analyses could be
23 used -- with a little modification -- if necessary; if the
24 problem indicated that this should be done; to go to plants
25 that contained those systems, and with a little extra effort,

1 walk through looking for common cause failures and those kinds
2 of things.

3 You might then be able to deal with the plant-
4 specific nature of the problem. I'll get into a more detailed
5 discussion of each task --

6 MR. CATTON: If there is more detail, how much time
7 do you plan to use?

8 MR. BURDICK: Thirty minutes is what I had allotted.
9 How many have I taken?

10 MR. CATTON: Well, I'm going to cut this off at
11 11:15, so you guys have 20 minutes more.

12 MR. BURDICK: All right, we also have an engineering
13 analysis test to look at fragilities. Thermohydraulic analyses
14 will probably be taken off from existing results from other
15 studies. I think we can do that. We may have to do some core
16 physics analysis, depending upon whether or not there are
17 sources of unborated water that would have to be used.

18 Accident management analysis initially is restricted
19 to the normal recovery analysis in the PRA unless it indicates
20 that there is some additional activity warranted because the
21 problem has popped up in the PRA analysis.

22 Of course, we have a large human factor effort which
23 is initially looking at operating experience to develop an
24 initial shot at developing performance shaping factors. We are
25 going to the plants with NRR on these audits, gathering

1 additional information which can be used to refine the
2 performance shaping factors.

3 MR. SCHROCK: You said you were going to answer the
4 question that I raised about the criteria for which plants to
5 chose for audit.

6 MR. BURDICK: Oh, well, I thought --

7 MR. SCHROCK: You'd thought you'd done that?

8 MR. BURDICK: Yes, I thought I had done that, but in
9 the six plants that came out of the configuration review, the
10 six plants that embodied the representative systems, these are
11 the ones that we would use in the plant audits.

12 MR. CATTON: Would that be the same six plants that
13 Brookhaven looked at?

14 MR. BURDICK: No, it would not.

15 MR. CATTON: Any reason? Their criteria for
16 selecting them sounded the same as the one you just gave.

17 MR. BURDICK: No, I did not. They -- I'm looking at
18 the systems and trying to cover as many operating plants as I
19 can with these representative systems. Brookhaven did not do
20 that.

21 MR. CATTON: They said they did, but that's beside
22 the point, I guess.

23 MR. DIAB: Dr. Catton, if I may comment on this? The
24 two or more most important or significant criteria for
25 selection besides the systems are the vendors, the type of

1 vendor and again, the human factors or opportunity for human
2 failures.

3 As far as the vendors go, we have planned to cover
4 all three PWR vendors. As far as the human reliability, it
5 really is more generic. You know, the human failures means the
6 failures are not plant-specific, so for any plant you have the
7 same hardware --

8 MR. BURDICK: You're taking up my time, Sammy.

9 MR. CATTON: That's right.

10 [Slide.]

11 MR. BURDICK: Again, this configuration review
12 identified these representative systems for analysis in these
13 six plants. And the audit plants are selected on this basis.

14 There was a data analysis task, to review the
15 operating history for these events, to get information on
16 reliability, down to the component level; to estimate PRA
17 parameters; to identify the important human actions also for
18 input to the PRA but also in a qualitative sense, also.

19 There was an engineering analysis task to calculate
20 the component fragilities with respect to pressure and
21 temperature and the low pressure system or systems.

22 Under this task we are going to estimate the
23 likelihoods of failures at specific systems locations like
24 flanges, valve packing, et cetera. And again, estimate the
25 flow rates and timings, so that we know how long the humans

1 have to act.

2 [Slide.]

3 MR. BURDICK: Under the human factors task, we are
4 going to, as I said, analyze the human actions from the data
5 analysis to get the preliminary identification of performance
6 shaping factors; go through the plant audits and collect
7 additional human factors information. We're going to try to
8 improve these audits as we go through them and then we'll
9 perform this review, recommend audit procedure revisions, and
10 the final task here to develop the final performance shaping
11 factors for estimating the human error contribution.

12 We had to do some methods development. The past PRAs
13 had not put all these elements together in the depth that we
14 are doing in this program. We needed to take a fresh look at
15 how to do that.

16 [Slide.]

17 MR. BURDICK: The sixth task is to apply the method
18 to the six plants identified in Task 1. There is, of course, a
19 program management task that is the glue that holds all these
20 elements together.

21 Now, the way we intend to package these results, in
22 the achievement of these objectives, is in a library of system
23 models that can be used in ISLOCA evaluations. And we want to
24 provide guidelines for the assessment of designs and
25 procedures, things that we have determined are important to the

1 ISLOCA problem.

2 You may, if we decide it is desirable to do so, use
3 these models in going to specific plants and assessing the
4 seriousness of the situation at that specific plant. And there
5 would be the list of other items here that should be looked at
6 in an ISLOCA context also, things like if it is important that
7 a certain valve be turned or activated to alleviate perhaps an
8 ISLOCA situation, is that valve even accessible to operators at
9 a certain plant. That kind of thing.

10 so we are dealing with, we are covering these bases,
11 the plant specific nature of the problem we are trying to deal
12 with, if it becomes necessary that we do this.

13 [Slide.]

14 MR. BURDICK: This program has been underway since
15 just July 24. We've completed our first plant. A letter
16 report will be forthcoming around the third week in January.
17 We are going to sit down with the contractor and go through his
18 analysis and make a determination of a number of things. One
19 thing we are going to be looking at very closely is how the
20 human element, how human factors were dealt with.

21 Now, the configuration review, that has been
22 completed. The data analysis has been completed. The
23 engineering analysis on Davis-Besse, that is currently underway
24 but will be finished in time to get the results in the letter
25 report. Human factors work of course is underway.

1 The first plant here is going ahead before the
2 analysis methods have been completed. We're using the first
3 plant as a pilot kind of plant in this study. We may have to
4 come back and modify some things after the final method has
5 been completed.

6 We have now, as I said, completed the application on
7 Davis-Besse. The audit program, by the way, is a super way to
8 get information needed in this kind of activity.

9 The program management of course has been underway.
10 And we are working on the evaluation guide and systems analyses
11 with delivery in late Fiscal Year 1990.

12 Are there any questions?

13 MR. SCHROCK: You are doing this for PWRs at the
14 present time. What is the plan on BWRs, now? Will that begin
15 when this one ends, or is it not going to be done, or what?

16 MR. BURDICK: We have boilers on the list to do at
17 the end of the program.

18 We are going to, however, be assessing the situation
19 along the way, not only in January, late January, after the
20 completion of Davis-Besse, but also after the next plant, we
21 are going to again assess what we have learned to date and what
22 is this program producing and is it necessary in fact to go
23 ahead with the rest of these plants, or have we now learned
24 enough at that point to make some decisions.

25 MR. SCHROCK: Does that imply that you will have a

1 decision about BWRs based on the information you are gathering
2 on PWRs?

3 MR. BURDICK: It may be. But we would have to be
4 very careful about that. There may be aspects to the boiler
5 situation that still bear some looking into.

6 MR. DAVIS: I have quick question, Mr. Chairman.

7 It would seem to me, Gary, that one of the more
8 important parameters in this assessment is one which PRAs
9 usually ignore. And that is aging of the components and how
10 that might affect the valve performance.

11 I didn't hear you mention anything about that. Is
12 that going to be looked at as part of this assessment or don't
13 you agree that it is even an important parameter?

14 MR. BURDICK: That's included in the program, but
15 that is a little out of my area of expertise.

16 John?

17 MR. O'BRIEN: My name is John O'Brien, the Office of
18 Research.

19 With respect to the fragilities of components, aging
20 is explicitly considered. And I'm talking about structural
21 analysis.

22 But in the case of valves, I think it is embedded in
23 the failure rates. You know, you just take whatever failure
24 rates we get from in-service experience base, and that includes
25 age experience as well as new experience.

1 So I think it is just in the data base.

2 MR. DAVIS: Well, you have to be a little bit
3 careful. You can do some trending analysis to predict a future
4 failure rate.

5 Is that what you have in mind? If you just take the
6 raw data, I don't think you'll get the aging effect, because
7 that tends to smear the --

8 MR. O'BRIEN: I don't believe it is the intent of
9 this program to give probability of ISLOCA as a function of the
10 age of the plant. but to give an average over the life of the
11 plant. I believe that is our intent right now.

12 I would like Owen Rothberg to respond to that. But
13 that's my view. This is not to give ISLOCA as a function of
14 the age of the plant. That's my view.

15 MR. DAVIS: Well, I thought I saw that you were going
16 to use the existing lifetime of the plant, 25 reactor years, as
17 part of the basis for coming to a conclusion.

18 It could be that the aging effect is very important,
19 and that towards the end of the lifetime this --

20 MR. O'BRIEN: That's true.

21 MR. DAVIS: -- effect could be much more probable.

22 MR. O'BRIEN: And in selecting the six units, one of
23 the criteria is that they would look at new units and old
24 units, Westinghouse units and CE units and so on. So aging
25 would be reflected in the specific unit being studied.

1 MR. DAVIS: Thank you.

2 MR. O'BRIEN: Degradation is included, however, in
3 the data going in in general.

4 MR. DAVIS: Thank you.

5 MR. CATTON: We are going to have now what, about a
6 one-minute wrapup?

7 MR. BARRETT: Yes. I'll give you a one-minute
8 wrapup. And to do so, I won't even go to the podium.

9 I would just like to reiterate that we believe that
10 recent operational experience warrants a closer look at the
11 interfacing systems LOCA, not so much because of the number of
12 events that we've seen or the severity, even so much the
13 severity, but because of the types of events that we're seeing.
14 These are types of events which we don't feel are currently
15 modeled in PRAs.

16 I think the strongest message that we've gotten from
17 you today is that we need to take into account, be cognizant of
18 the plant specificity of the interfacing systems LOCA,
19 particularly in terms of the hardware, the interfacing systems
20 LOCA hardware.

21 I think I heard a strong recommendation that we
22 should structure this program in such a way that we develop
23 information that hopefully can be used in the context of the
24 existing IPE program, and the accident-management program of
25 NUMARC. And we will certainly try to do that, if it is

1 appropriate, to the extent that it is appropriate.

2 We also heard a request from the Chairman concerning
3 more information about the events that we've seen, the actual
4 events that we've seen, and what we think is important about
5 those events and why those events have motivated this program.
6 And we will provide that as soon as we can.

7 And also I would like to, I heard a couple of good
8 questions here that I don't think we dealt with very well. I
9 think we need to, we are still in the process, we really
10 haven't dealt yet with the question of what we are going to do
11 about BWRs. We have really concentrated so far on the PWR
12 question. And we will be thinking about how to handle BWRs.

13 And I think that with regard to the question on
14 aging, I think that we could probably give some more thought
15 about that, too, in terms of how specifically, how well we are
16 indeed addressing it with what we have come up with so far.

17 And finally, I would like to say that we intend to
18 keep you fully informed of this program. As Gary mentioned, we
19 hope to have some preliminary results from our contractors by
20 mid-January. Giving us time to digest that, we would plan
21 perhaps sometime in the Spring to come down and give you some
22 idea of what is preliminarily coming out of the study, if that
23 is satisfactory with you.

24 MR. CATTON: Sounds good to me.

25 If there are no further comments, we will move on.

1 Thank you.

2 MR. BARRETT: Thank you, Mr. Chairman.

3 MR. CATTON: Next on the agenda is the Small-Break
4 LOCA Technical Program Group Activities, and I believe Dave
5 Bessette is going to give it to somebody else.

6 [Slide.]

7 MR. LEE: Instead of David, I will be doing the
8 presentation. I will give you a very brief introduction to
9 this CSAU for small-break LOCA for the PWR.

10 MR. CATTON: What does "CSAU" stand for?

11 MR. LEE: It's code scaling applicability and
12 uncertainty, and the objective is that we like to use the
13 RELAP5/MOD3 code and apply the CSAU method to the small-break
14 LOCA.

15 MR. CATTON: One of the first steps in the CSAU
16 method is the documentation.

17 MR. LEE: Right.

18 MR. CATTON: Is the documentation complete?

19 MR. LEE: The MOD3 code is scheduled for release in
20 the early part of January, and the documentation, the draft of
21 that, will be coming out within a few months after that.

22 MR. CATTON: So, that would make it March, right?
23 How can you initiate the process now?

24 MR. LEE: We will respond to that question later.

25 In terms of the program structure, it is similar to

1 the large-break LOCA CSAU effort, and we formed a TPG group,
2 the Technical Program Group, similar to the one for the large-
3 break LOCA, and the members of that is shown on the next vu-
4 graph.

5 [Slide.]

6 MR. LEE: I do the monitoring of this program for
7 NRC, as of today, and INEL, there are two persons. Marcos and
8 Gary Wilson are the two key people at INEL that coordinate this
9 effort for us.

10 The TPG members consist of two of us from NRC, Brent
11 Boyack from Los Alamos, Professor Griffith from MIT, Professor
12 Hsu from UM, Professor Ishii from Purdue, and Gary Lellouche
13 from Saul Levy, and of course, the two key persons from INEL.

14 You can see that some of these people here -- for
15 example, Hsu and Ishii, those people are very familiar with the
16 type of experiment data that we will be using for this purpose,
17 and then, from ACRS, Professor Schrock will be attending all
18 our meetings, starting with the second meeting we had just 2
19 days ago.

20 [Slide.]

21 MR. LEE: We initiated this effort back in June of
22 this year. We are expecting to complete it by the end of
23 fiscal year '91. We have had two meetings since then, and
24 those are the dates shown here.

25 So, Gary is going to give you the summary from the

1 first meeting, as well as what we have done in the last
2 meeting.

3 MR. CATTON: Gary, there are two things I'd like you
4 to address, maybe. One is the fact that the MOD3 is not a
5 mature code, and part of the process, really, depends on some
6 maturation. The second is try to help me understand how you
7 are going to do it without documentation over the next 3 or 4
8 months.

9 MR. WILSON: All right, Ivan, I'll address both of
10 those.

11 [Slide.]

12 MR. WILSON: Of course, I'm Gary Wilson from INEL.
13 I'm program manager on this particular program. I'm going to
14 give you a brief overview, and then, Dr. Ortiz, who is the
15 principle investigator on the program, will show you results.

16 I'd like to add a cautionary note to the things that
17 Marcos and I are going to say to you this morning. We are
18 approximately 4 months into an 18-month program. So, I believe
19 most of the things that we'll show you this morning, in terms
20 of a product and of results to date, are valid. However, this
21 is a status report. The work is ongoing. There can be certain
22 things that we show you this morning that will change as we
23 proceed. So, please keep that in mind.

24 [Slide.]

25 MR. WILSON: These are the major topics that I am

1 going to address. I'm going to give you just a quick overview
2 of the CSAU methodology, and Ivan, I'll try to cover the two
3 questions you asked, at least in summary form, at that point in
4 time. Then, Dr. Ortiz is going to show you results of work to
5 date, and then, I will conclude the presentation with the
6 future activities.

7 [Slide.]

8 MR. WILSON: Now, the CSAU methodology consists of
9 three elements, and they're shown here -- the requirements and
10 code capabilities element, the assessment and ranging of
11 parameters, and them, of course, the sensitivity calculations
12 and the uncertainty analysis that's involved.

13 As Richard alluded to, we are using the same process
14 that we used on the large-break LOCA. Now, when I say
15 "process", that's the real operational word. We're using the
16 same process.

17 There are items that are specific to the application.
18 CSAU small-break will differ in application, in some specifics,
19 from the large-break LOCA, but the process will be the same.

20 MR. CATTON: If the process is going to be the same,
21 Gary, what are you doing about steps 4 and 5? Step 4 says you
22 select a frozen code. "Frozen code" usually implies that part
23 of the -- at least, the code development assessment process has
24 been completed, and you can't have done that with MOD3 yet.
25 MOD3 is a new code.

1 MR. WILSON: If you will hold just a little minute,
2 I'll come to that in about two slides. Is that satisfactory?

3 MR. CATTON: I'm just trying to get you ready.

4 [Slide.]

5 MR. WILSON: I understand. Okay. I understand the
6 thrust of your concerns, and I will address that.

7 I put this up just to show you the methodology as a
8 process. I know you can't read it. It is in your handouts.

9 MR. CATTON: It's almost as illegible in our handout
10 as it is on the board.

11 MR. WILSON: Okay. We can take care of that. We can
12 get you copies of it. I believe nearly everyone on this
13 Committee has seen this particular overhead repeatedly, but I
14 can get you better copies, if that's desired.

15 MR. KERR: I want to commend you, because I think
16 almost every slide show should have at least one illegible
17 slide included, and I think that is an appropriate one.

18 MR. WILSON: Okay.

19 MR. SCHROCK: It is legible on the next page, though.

20 [Slide.]

21 MR. WILSON: The steps in the first element compare
22 the modeling requirements with basic code capabilities.

23 Now, in those particular six steps that are
24 associated with that first element, amongst other things, we
25 identify the plausible phenomena and processes that can take

1 place in the plant in the scenario that was selected.

2 We then determined the dominant phenomena in the
3 processes. We evaluate the codes in the context of that
4 important phenomena, and then we define a basic code
5 applicability, and this comes to the heart of the questions
6 that Ivan was just asking. How can we do part of this if the
7 code documentation does not exist?

8 [Slide.]

9 MR. WILSON: This overhead is just a flow diagram
10 form of what I just said. You can see that "select a frozen
11 code" up here is prominent in this particular element. I'll
12 come back to that in just a minute. I'd like to take these in
13 sequence.

14 We have specified the scenario. It's a small-break
15 LOCA. We have specified the plant or the NPP, the nuclear
16 power plant. We are going to look at a B&W power plant, and
17 the specific plant is the Oconee-3 plant.

18 Now, in scenario specification, I would say, in my
19 view, that, at this point in time, the scenario is specified to
20 about the 90-percent level. There are some details that are
21 still developing, as we go through this process, but basically,
22 we know what the scenario is going to look like.

23 I will now turn to "select a frozen code".

24 RELAP5/MOD3 has been the code that was selected. The
25 motivation for doing that was to move to a second systems code

1 that's available in the NRC stable of codes.

2 RELAP5/MOD3, in a pre-released version, was put out
3 last summer. It has undergone and is undergoing developmental
4 assessment. Part of that assessment is being done in the
5 international community, under the auspices of the NRC ICAP
6 program. More independent assessment is also in progress and
7 will continue.

8 We believe that the frozen version of the code will
9 be released in January. The documentation that goes with that
10 frozen version is partially complete. There is much of it that
11 is identical to RELAP5/MOD2, from which MOD3 came. They are
12 also in the process of writing the documentation that applies
13 to the new features of the code.

14 MR. CATTON: My recollection is that the RELAP5/MOD2
15 documentation was not adequately done.

16 MR. WILSON: Ivan, I guess I would disagree in the
17 sense that I think the documentation both for RELAP5/MOD2 and
18 for RELAP5/MOD3, as it develops in its schedule and our
19 schedule, will be sufficient for this TPG to do its job.

20 MR. CATTON: I don't know what to say to that. I
21 haven't seen the documentation. I did see the MOD2
22 documentation. The MOD2 documentation was incomplete.

23 MR. WILSON: The formal documentation for RELAP5/MOD3
24 I believe will be released along in the February time frame.

25 Fortunately, on this particular program, that code

1 resides at my laboratory. And Marcos and I and RTPG, on the
2 small-break LOCA program, have access not only to the existing
3 draft documentation and the final documentation that is
4 developed, we have access to the people that are doing the job.

5 Now, I agree, this would not be a way to conduct
6 another program, outside of the particular laboratory. But in
7 our case, I will again state, and I believe that TPG and the
8 small-break LOCA team will have access at the proper time to
9 the documentation that we need to do our job.

10 MR. CATTON: So you are going to skip part of Chapter
11 5?

12 MR. WILSON: No. We are not going to skip anything.
13 We are going to go right down the line, and wherever we need to
14 know something about the code, we will develop that. We will
15 have access to that information.

16 MR. CATTON: So you are not going to follow the
17 procedure that was followed before, which was that these things
18 are available before?

19 MR. WILSON: You are correct in the sense that we are
20 going to lead the procedure by a couple of months probably,
21 because we don't want to slow down the small-break LOCA
22 program.

23 Now, ultimately, in the end, all of the schedules
24 will come together and catch up with each other.

25 MR. CATTON: Gary, as you well know, one of the big

1 problems in this whole code development business has been using
2 the kind of excuse that you just used, that we will have it
3 when we are ready; it can always been delayed; well,
4 documentation, gee, I can talk to the guy who did it.

5 And the result is at any given point, you don't have
6 what you need. I don't think you are following the CSAU.
7 That's just my opinion.

8 MR. WILSON: Well, I guess in my opinion, we are
9 following the CSAU procedure in some cases by a couple of
10 months. We may be leading it over the most optimum way you
11 would apply the procedure.

12 MR. CATTON: One of the key elements to what was done
13 previously was getting that documentation in hand straightaway.
14 And you recall that yourself.

15 MR. WILSON: Well, as I recall, we did a number of
16 things in advance before we did get that documentation.

17 MR. CATTON: And then you redid some, anyway. Why
18 don't you continue?

19 MR. WILSON: All right.

20 In any case, what I've done is, I've outlined in red
21 where we are in this particular process.

22 Essentially, the items that are in solid red, we
23 believe are complete or 99 percent complete. You will notice I
24 did not outline this one in red. At two months or so I
25 probably can't.

1 We are in the process right now of doing this
2 identification and ranking of phenomena. That is where we are
3 in the process.

4 Marcos is going to show you some typical results of
5 that process. Now, again, as in the case of the large-break
6 LOCA, we are using two independent teams to do this. And we
7 have been even more strident in this program than we were in
8 the large-break LOCA program, for me to be able to stand up
9 here and tell you that the two teams are truly independent.

10 At the point in time both of those teams complete the
11 PIRT process we will bring their results together and compare
12 them and resolve differences.

13 [Slide.]

14 MR. WILSON: Continuing with a brief description of
15 the process, just to set things up for what the results of
16 Marcus is going to show you, the steps in Element 2 establish
17 the key code parameters and their variability. The work is
18 based on a defined assessment matrix. We will again plan to
19 use standard nodalization which removes it as an uncertainty
20 source. And then the individual parameter variabilities will
21 be stated in terms of probability -- that's the preferred
22 method -- or in terms of a bounding bias. And those ranges
23 will, as previously done, be traced to experimental data and
24 whatever studies might be appropriate.

25 [Slide.]

1 MR. CATTON: One of the key things in RELAP5/MOD3
2 that perplexes me, or one of many, maybe, is this business of
3 how you deal with the multidimensional flow using the piping
4 networks.

5 About 15 years ago that was shown to be inadequate.
6 What have you done in the interim period to show that this is
7 an appropriate way? How are you going to deal with this in the
8 CSAU? Are you just going to take a penalty for it, or what?

9 MR. WILSON: I guess I can't give you the answer now.
10 I can tell you how we are going to approach that.

11 MR. CATTON: I understand mathematically it is
12 incorrect, and you can show that it doesn't compare well with
13 experiment. And you can write down why.

14 MR. WILSON: Let me reiterate the approach. And then
15 we can make comments on that.

16 What we will first do is establish where we
17 definitely, where multidimensional behavior is critical to this
18 particular event. And I'm not sure that that is going to be a
19 very significant portion of the analytical space.

20 If we do establish that that is the case for certain
21 selected items, we will then look at how the code handles that.

22 If we believe that we can on a technical basis argue
23 that the code does a reasonable representation, then, hey, we
24 will probably cast uncertainty in terms of probability if we
25 can, bias if we can't.

1 If there is reason to believe that the code does not
2 handle that behavior correctly, then I believe we will probably
3 do a bounding bias and we will take a penalty.

4 [Slide.]

5 MR. WILSON: Continuing on, this is the element 2 in
6 the flow diagram. You establish the assessment matrix, you
7 define the nodalization, and again, as I mentioned earlier, we
8 are going to use a standard nodalization.

9 You then start into the process of determining code
10 and experimental accuracy, determine effects of scale, and so
11 on through the process.

12 What we have here is a double path. All that, what
13 that really denotes is that if you can cast your variabilities
14 and your uncertainties in terms of probabilistic
15 characterization, you go down through one path.

16 If you have to take biases based on a bounding basis,
17 you can go down through another path.

18 The same process that we used in the large-break.

19 [Slide.]

20 MR. WILSON: The last element in the methodology, and
21 really the ultimate goal to quantify uncertainty is
22 accomplished in Element 3.

23 You perform sensitivity analyses to convert the
24 variability in the individual contributors to uncertainty, into
25 their individual reflections in the safety criteria. And

1 Marcus will review for you the safety criteria that are
2 appropriate to small-break LOCA.

3 And then you combine those individual reflections in
4 the primary safety criteria into a singular statement about
5 code uncertainty.

6 [Slide.]

7 MR. WILSON: And just to cap it off, there is Element
8 3 in terms of a flow diagram.

9 Now, that is what I had intended to say in the
10 context of an introduction.

11 Dr. Ortiz will come up now and show you examples of
12 what we have accomplished in the last approximately four
13 months.

14 [Slide.]

15 MR. ORTIZ: I am first going to show you an overview
16 of what I will be talking about and that's the different steps,
17 as Gary mentioned them.

18 We went through a plant scenario selection and made a
19 selection and then we had two independent panels handling the
20 issue of the PIRT, the different steps of the panel -- of the
21 process were followed in parallel by the two panels. The final
22 step, the future step, is the resolution of the differences
23 between the two resulting phenomena rankings.

24 We used the analytical hierarchy process to define
25 the ranking of these phenomena.

1 MR. WARD: Can you remind us what PIRT stands for?

2 MR. ORTIZ: Phenomena Identification and Ranking
3 Table.

4 [Slide.]

5 MR. ORTIZ: So this scenario, as Gary mentioned, the
6 scenario we chose was Oconee and we also chose -- that was the
7 plant we chose the scenario was a small break in the worst
8 break configuration and we have yet to define that
9 specifically. We decided based on the information that we had
10 that the worst break configuration would be in the cold leg at
11 the discharge of the pump but we still are deciding whether it
12 is in the top, the side, or the bottom of the pipe.

13 MR. KERR: Excuse me, how do you decide? By doing
14 calculations for breaks at various spots?

15 MR. ORTIZ: We may have to do that.

16 MR. KERR: What have you done up to now?

17 MR. ORTIZ: Up to now we have just looked into the
18 documentation like PRA's and they consulted with the utilities
19 and the vendors and came up with -- according to their analysis
20 this is the worst place.

21 MR. KERR: Thank you.

22 MR. ORTIZ: Then we are going to examine the most
23 likely power shape for the accident and we are assuming that
24 since we chose a plant that is somewhat sensitive to operator
25 action we will not model the operator. We will assume that the

1 operator in principle does everything that he is supposed to do
2 according to the emergency operating procedures.

3 The scenario we're choosing is the one that will
4 display the maximum number of phenomena to the extent that
5 these phenomena are supported by experiments.

6 [Slide.]

7 MR. ORTIZ: So let me show you a viewgraph of --
8 that's what the plant looks like and this being the hea
9 exchanger, the steam generator and here is the core.

10 MR. DAVIS: Where would the break be?

11 MR. ORTIZ: The break would be -- this is the pump
12 out here -- somewhere in this pipe between the pump and the
13 vessel.

14 MR. CATTON: Why is that the worst location?

15 MR. ORTIZ: Well, according to the vendors, the
16 documentation and the utility itself, they have done analysis
17 to determine what would be the worst location --

18 MR. CATTON: But they don't have a best estimate
19 code. They just use Appendix K and the reason you are doing
20 this is to get away from that.

21 MR. ORTIZ: They have done calculations to see what
22 would happen if you have a break there.

23 MR. CATTON: But that is Appendix K calculations.

24 What vendor is doing best estimate calculations?

25 MR. BESSETTE: This is David Bessette from the NRC

1 Research Office.

2 What we'll try to do is choose the break location
3 that gives the maximum loss of inventory, that being the break
4 that stays in liquid break flow for the longest period of time
5 before transitioning to two phase or steam flow, so it means a
6 low location.

7 MR. CATTON: Well, that sounds sensible, but to say
8 that you got that information from the vendors is kind of next
9 to silly.

10 MR. BESSETTE: Yes, we'll just take -- we have an
11 idea just based on past analyses.

12 MR. JONES: This is Bob Jones from NRR.

13 The specific choice of the break, I wasn't involved
14 in the decision process but the reason it is likely to be the
15 worst location is that the high pressure injection system
16 injects in that piping, and if you put the break downstream of
17 the injection point you lose a portion of the injection flow
18 that's coming in, and that's why historically the vendor
19 calculation predicts that to be the worst case, not just
20 because of the model itself, the EM nature but the location of
21 the break relative to the injection point.

22 MR. CATTON: So actually it's based on somebody's
23 judgment and then an Appendix K calculation is what it sounds
24 like.

25 MR. JONES: Right. I think it was also looked at and

1 missed. Some of the locations certainly in the cold leg was
2 looked at in MIST.

3 MR. CATTON: You're right -- but again in MIST you'd
4 have a very small pipe.

5 Where do you put it in the pipe? Elevation in the
6 pipe?

7 MR. ORTIZ: We haven't decided that yet.

8 MR. BESSETTE: It will probably be the bottom.

9 MR. CATTON: The bottom? Why not the top? You are
10 looking for something that tests phenomena.

11 MR. BESSETTE: We could --

12 MR. CATTON: If you put it in the bottom the break
13 flow won't get into any difficulties until the pipe's
14 practically empty I guess.

15 MR. BESSETTE: I think that's just -- the bottom will
16 stay in liquid flow longer than the top.

17 MR. CATTON: But don't you want to test the
18 phenomena?

19 MR. BESSETTE: Varying the location from the bottom
20 to the top will vary the, will just vary the quality.

21 MR. CATTON: The pipe's half full of -- that's right.
22 The physics are tougher if it is in the top than in the bottom,
23 I think.

24 Anyway, why don't you continue?

25 MR. WARD: What he said is that the definition of the

1 worst break is the one that gets the inventory down fastest.

2 MR. CATTON: But then selecting it so that it always
3 sees just the liquid side is not testing the code and part of
4 what they are supposedly trying to do is to select something
5 that forces the code to exercise the most.

6 Now stratified flow is going to be important and I am
7 not sure how well the code deals with it.

8 MR. ORTIZ: It will see vapor flow even if we look
9 just at the bottom. At some point the inventory will come to
10 the point where we'll see vapor coming out of the break.

11 MR. CATTON: I think you are still missing the point.
12 If the pipe is half full of water and the break is in the top
13 or in the bottom, which exercises the code the most?

14 MR. ORTIZ: I guess in that case we went in the worst
15 break location given the criteria and that would be the bottom.

16 MR. SCHROCK: I think you have to ask what is the
17 code model and the geometries and I raise some objection to
18 what has been chosen now for RELAP 5, MOD3 in our last
19 Subcommittee meeting and I still plan to pursue that but the
20 fact is that you need to look at whether there is or is not a
21 branch line that is broken that represents the small break.

22 You can't just put a small break anywhere at all and
23 expect that you're representing something that is realistic.

24 It is going to be a pipe that's broken that creates this small
25 break. Now if you are talking about tears in a large pipe, 28

1 inch diameter pipe with a small tear in it, now you have a
2 geometry that is not in the code -- so the only kind of
3 geometry that the code attempts to address is the broken branch
4 line.

5 MR. CATTON: So? What did you select?

6 MR. ORTIZ: We haven't yet.

7 MR. CATTON: Okay.

8 [Slide.]

9 MR. ORTIZ: Of the primary safety criteria that we
10 selected, the first safety criteria was the liquid inventory in
11 the core the technical group would uncover for this particular
12 plant. It was unlikely that the core would uncover and then
13 the peak clad temperature would experience some excursion, but
14 that is why we put it as the second primary safety criteria.
15 So these are the two safety criteria that we chose.

16 Now, up to this point, it is common for both panels.
17 The panels have never heard of each other's results and these
18 are the same ground rules for both of them and now I am going
19 to present as an example, what the INEL panel has done.

20 [Slide.]

21 MR. ORTIZ: The first step in the PIRI after
22 selecting the safety criteria was to divide the transient or
23 partition the transient into phases that will better handle the
24 situation. There are different stages of the transient that
25 have different characteristics, so we break it down into stages

1 or phases, and this is the case of the INEL panel.

2 They have a total of ten phases. The first phase
3 occurs when we had the break and there is a rapid
4 depressurization of the system and they call that the subcooled
5 blowdown. Then we have, because of flashing and boiling all
6 over the reactor, the pressure tends to not drop so quickly and
7 we have the intermediate blowdown phase. This graph is not to
8 scale and is not meant to draw any conclusions from the numbers
9 or the relative positions of phases, just to show the different
10 phases.

11 Then we have the reactor trip. At that point, we
12 continue depressurizing because now, once the reactor is
13 tripped, there is not as much energy put into the system
14 anymore. Then we have another region of pressure
15 stabilization. At this point, the pumps have tripped, and we
16 have natural circulation in the loop and at some point, the
17 boiling on the upper part of the reactor will interrupt that
18 natural circulation and that's Phase 5.

19 Then it will go into a boiling/condensing mode. We
20 no longer have natural circulation around the loop. We have
21 the core boiling water and the condenser condensing the steam
22 and that is this stage 6. Then we have -- many things can
23 occur depending on the size of the break. When they occur in
24 time depends on the size of the break.

25 The next thing that would occur would be the refuel.

1 The HPI begins to refill the reactor and then we get to the
2 point in which the leak flow is equal to the injection flow and
3 things begin to stabilize.

4 Then we can go to two different modes. In the one
5 case, the natural circulation has been reestablished. That is,
6 we have flow around the loop, or we can have an intermittent
7 situation which we have and then we don't; then we have it and
8 then we don't, and that is 9-B, called feed-and-bleed.

9 So, the way the process works is that we chose the
10 phases and then I'm going to show you a slide of the process to
11 apply AHP. For each -- here are the steps.

12 [Slide.]

13 MR. ORTIZ: For each phase, we are going to partition
14 the system into components, physical components. They don't
15 necessarily have one single apparatus involved. It could be a
16 whole chunk of the system, depending on the nature of that
17 phase, so we partitioned the system into components and then we
18 ranked those components in a pair-wise basis.

19 Since the ranking is subjective, we want to make sure
20 that we have it as accurate as we can, and it is easier to rank
21 component A versus component B only and get a number, than to
22 rank component A versus B through Z. So the AHP process works
23 on pair-wise comparisons.

24 After we rank all these components, then we have a
25 weigh-in factor for that component on a systemwide basis. Then

1 the next step is; for each phase and for each component, we
2 identify the phenomena that are important or that are relevant
3 to that component in the context of the primary safety
4 criteria.

5 Then we rank the phenomena for that one component,
6 also on a pair-wide basis. At the end, we rank the phenomena
7 on a system basis for each phase, using the weigh-in factor
8 that the component had. This is a pictorial way of showing it.

9 For each phase we have different components --
10 Component N, Component N+1, and for each component we have
11 different phenomena.

12 [Slide.]

13 MR. ORTIZ: I will show you one of the many phases.
14 As I said, ten phases were chosen, so for instance, for Phase
15 No. 1, the Subcooled Blowdown, the panel of experts chose to
16 break down the system into these six components.

17 Then they decided that this phenomena were important
18 in that phase. The next step, or step that you saw before, is
19 this component is associated with that phenomenon. This
20 component has more phenomena associated with it.

21 Last, we will do the pair-wise comparison for this
22 component with this phenomenon. Now, just to show you the
23 volume of -- this is half the story. These are the phenomena
24 and these are the phases, 1 through 9-A and B, and these
25 indicate where this phenomenon is important.

1 MR. CATTON: Why don't I see stratified flow?

2 MR. ORTIZ: I said that this is half the story. We
3 have a total of 58 phenomena and I believe stratified flow is
4 there.

5 MR. CATTON: It is?

6 MR. ORTIZ: I remember seeing it. It was not in
7 that list?

8 MR. CATTON: I don't see it anywhere.

9 MR. ORTIZ: Oh, yes, it is here. Steam break flow --
10 what name they give to the phenomena may include several
11 things and that is part of the problem -- or that is part of
12 the process at the end of reconciling the results of both
13 panels. Sometimes they call a phenomenon by a different name
14 and the phenomenon that they use contains several things.

15 I'm sure that we discussed the stratified flow as a
16 part of the problem in both panels. It might not be called by
17 name, although I doubt it.

18 MR. CATTON: So you're going to generate new
19 descriptions for the physical phenomena to suit your needs?

20 MR. ORTIZ: There will be a description -- not to
21 suit my needs.

22 MR. CATTON: Is this to keep those of us who are not
23 following you --

24 MR. ORTIZ: Excuse me.

25 MR. CATTON: Never mind.

1 [Slide.]

2 MR. ORTIZ: Anyway, this is an example of the pair-
3 wise ranking and this is for Phase 1 that I showed you before.
4 We have these components and we rank the components and this
5 panel chose to rank from 1 through 3. If we use a 1, that
6 means that the components are of equal importance.

7 If we use a 2, it means that this component is
8 slightly more important than that component in the experts'
9 opinion. If we use a 3, it means that this component is much
10 more important than that component.

11 If it is the other way, we use the fractions. This 1
12 over 2 means that this component is slightly more important
13 than this one. This 1 over 3 means that this component is much
14 more important than this one.

15 Then we apply the AHP methodology and we come up with
16 the rankings. The AHP methodology generates rankings on a
17 scale from zero to 1, but that implies an accuracy that is not
18 really there, so what we do is that we normalize those or we
19 scale those from a scale from 1 to 9 and that's the result.

20 Nine is very important, and one is of very little
21 importance. Yes?

22 MR. CATTON: The reason I asked you about stratified
23 flow is that I don't believe the early RELAP-5/MOD codes nor
24 TRAC or any of them handled it well. For the small break LOCA,
25 it's important.

1 If you don't call it out, you're going to miss it.
2 I'm really disappointed that I don't see it.

3 MR. BESSETTE: I saw it under the two phase flow in
4 the hot leg. They didn't call it stratified flow.

5 MR. CATTON: But two-phase flow in the hot leg is
6 treated in a particular way in these codes and for the small
7 break and the possibility of stratified flow, you're going to
8 miss it because --

9 MR. SCHROCK: It could be the two-phase flow in the
10 hot leg without stratification, but --

11 MR. CATTON: Well, look how TRAC treated it for
12 years. They had counter-current stratified flow treated as
13 some sort of mixture of steam going through the water in one
14 direction and the water going in the other and we all know that
15 physically that's nonsense.

16 MR. ORTIZ: What I am showing you is the result of
17 one panel. I know that the other panel called it by name.

18 MR. WILSON: Gary Wilson, INEL. The code does have
19 stratified flow models in it. Both panels definitely
20 understand the criticality of stratified flow. Although it may
21 not be named explicitly -- at this point in time, explicitly i
22 the tables that Marco is showing you, stratified flow in the
23 appropriate areas, under the appropriate phase conditions, are
24 being addressed and evaluated.

25 Now, you have a very valid question about how well

1 the code handles that. Stratified flow, in my opinion, will
2 come out as one of the phenomena that at least in one or more
3 phases has to be addressed by the code to calculate these
4 transients.

5 We will then range the variability in the stratified
6 flow or in the key parameter that represents stratified code in
7 the flow and we will do sensitivity calculations. If the code
8 does not simulate the phenomena well, that should come out as a
9 part of the process and that's exactly what we're trying to do.

10 I assure you, Ivan, stratified flow and its
11 importance is recognized by both panels. It is being
12 considered by both. It is recognized by the code because the
13 code has stratified models in it.

14 [Slide.]

15 MR. BARRETT: Going back to the original slide, what
16 I just showed you is that, for one panel and one particular
17 phase, at this point the TPG group has completed the phenomena
18 ranking. We did that yesterday in our second meeting, and we
19 still have to process that to get the final system ranking.

20 The INEL group is in the process of doing the
21 phenomena ranking, and once we have those two together, we'll
22 proceed to the next step, which is the resolution of any
23 differences that there may be. That's the status of the
24 results today.

25 Now Gary will show you the future.

1 [Slide.]

2 MR. WILSON: I have only one slide that I'm going to
3 conclude with. You will have copies before we leave here.

4 The future work scope and the schedule include the
5 following milestones for this program:

6 As you can see, the first item is the one just
7 referred to by Marcus. We will take the PIRT results, the
8 phenomena identification results, from the TPG and from INEL,
9 and we will compare them. There will be a certain amount of
10 work to get them on a one-to-one basis so that we can make
11 those comparisons. This is roughly the third time that we've
12 applied this process, and our past experience indicates to us
13 there's a strong likelihood there will be some major
14 differences between the two panels. In fact, that's the reason
15 you use two independent panels: to be assured that you haven't
16 forgotten anything.

17 We will resolve those differences on the basis of
18 technical arguments. We will consult both panels. We will
19 argue the way through it. If there are differences because of
20 procedural errors or, for example, one panel called something
21 one thing and another panel called it another thing, we'll
22 resolve those. The non-significant ones, like procedural
23 errors, fall out automatically. There may be some real
24 differences of opinions. We will resolve those on technical
25 arguments.

1 If we are unable to get a resolution -- i.e., a
2 consensus between the two panels -- then we will take the
3 highest-ranking that exists between the two panels, and we will
4 factor that into how that particular phenomena is considered.

5 We are in the process of looking at the assessment
6 matrix. We intend to complete that process in February, at
7 least in draft form. We will have a draft assessment matrix
8 out at that time. Now, that assessment matrix is likely to
9 change as we go on, but we'll certainly have the basis for it
10 in February.

11 The next TPG meeting is scheduled for the last part
12 of February. INEL is in the process of setting key code
13 parameters and doing the initial of those parameters. That
14 information will be provided to the TPG in January. They'll
15 have a chance to take a look at that, and then, in February, we
16 will sit down and come to a consensus among the TPG of what the
17 key code parameters that we have to address are, and the ranges
18 that we have to vary those over.

19 We intend to get the first statements of code
20 applicability out in March.

21 Also in March we expect to conduct what for lack of
22 better words we've called a small-break LOCA CSAU workshop.
23 The intent for this workshop -- it's probably a two-day
24 workshop -- is to take the NRC's program and its results,
25 invite in industry, vendors and utilities, bring those parties

1 together who have some common interest, and exchange
2 information in some sense. Industry can probably act as a
3 reviewer of what we are doing. We will get their feedback. In
4 the same general sense, I believe that what we are doing we
5 will be able to pass on to industry so that they may benefit
6 from that. So that item, the small-break LOCA CSAU workshop,
7 that's what is intended. We'll conduct that in March, we
8 believe.

9 The final results for the PIRT will be out in April.
10 That's more than likely going to be a letter report.

11 All of this will be formally documented in the NUREG
12 at the end of the program, but we will have several levels of
13 formality of documentation as we go through the process.

14 Our schedule is to complete the sensitivity
15 calculations that are involved in the process in October of
16 next year. We will be doing documentation that will fit into
17 the NUREG CR all through the program, but in October of next
18 year we will turn and really get serious about documenting the
19 NUREG, and that sort of thing. We have scheduled to put out
20 the draft report or the draft NUREG in March of 1991, and then
21 to issue the NUREG CR for the total program in June of 1991.
22 That's our current schedules, the milestones.

23 MR. CATTON: When are you going to get the
24 documentation?

25 MR. WILSON: Step 5.

1 Oh, When will we get the documentation for the codes,
2 so that we can go through the process, is that the question?

3 MR. CATTON: That's correct. Because somewhere you
4 have to do the usual accuracy and convergence kind of studies.
5 Where are they?

6 MR. WILSON: With respect to the TPG, to our activity

7 --

8 MR. CATTON: No, no. These should be done before you
9 start. Where are they?

10 MR. WILSON: The code assessment of RELAP 5, MOD3.

11 MR. CATTON: I'll ask it again.

12 One of the big criticisms of the earlier CSAU effort
13 was the lack of certain information regarding the code
14 characteristics. These dealt with things like the accuracy,
15 time step, nodalization one should be using. The studies that
16 form the basis for that, that should precede the process you're
17 going through, where are these?

18 MR. WILSON: Okay. I understand the question now.

19 To the extent that the RELAP 5, MOD2, work as the
20 predecessor of the code we're using is applicable, those
21 results are already available.

22 MR. CATTON: I'm talking about MOD3.

23 MR. WILSON: I understand, but what I'm trying to
24 hint to you, Ivan, is that RELAP 5, MOD2, what was done on it
25 has certain applicabilities, because it was a predecessor code.

1 You have to understand the RELAP 5, MOD3, is not a
2 totally new code. It is changes in the prior code, RELAP 5,
3 MOD2.

4 Now, with respect to RELAP 5, MOD3, the developmental
5 assessment being done for that code, parts of it are available
6 already. I would say the majority of it is, at least in draft
7 form.

8 MR. CATTON: Do you have a new set of rules for the
9 CSAU?

10 MR. WILSON: I do not perceive that we do.

11 MR. CATTON: Well, from my vantage point, it
12 certainly looks like that.

13 MR. WILSON: I think you and I are debating time
14 here. I believe that, with respect to the optimum way you
15 would do the process, we are probably leading the optimum way
16 by about two months. I do not see that as a significant
17 problem, because the code happens to reside at the laboratory
18 that I work at, and I have access that other people might not
19 have.

20 MR. CATTON: Well, Gary, I'd like to see the code
21 accuracy and convergence studies.

22 MR. WILSON: Would you say that again, please.

23 MR. CATTON: I would like to see them. Certainly you
24 must have them.

25 MR. WILSON: The code information.

1 MR. CATTON: That's correct.

2 MR. WILSON: All right. We will take that as an
3 action item: to provide you with documentation of the code
4 that is available.

5 MR. CATTON: And also the basis for the nodalization,
6 and how you transfer from MOD2 to MOD3.

7 MR. WILSON: Okay, but we have not done that process.
8 At the time we do that process, we will provide that to you.

9 MR. CATTON: But usually that -- But how could you
10 assess the code then? Now I don't understand.

11 We're not getting anywhere with this conversation.

12 I don't have any more questions.

13 MR. WARD: I wonder if I could ask Gary a question
14 about the CSAU process more generally.

15 The end product of a CSAU analysis is a quantity
16 which purports to be an estimate of the uncertainty in, let's
17 say, PCT, based on three variables, a particular code, a
18 particular plant, and a particular transient. Back when ACRS
19 first commented on this program, in 1987, we were concerned
20 that there might be a fourth variable, and that is the code
21 user: The competence or the style or something of the code
22 user might introduce a fourth variable. Is that a realistic
23 concern, or is it being dealt with, or where do you stand on
24 that?

25 MR. WILSON: Now, what I'm about to say it my own

1 personal opinion. I don't believe it's totally out to lunch,
2 but I've got to admit that that's my own personal opinion.

3 In principle, I believe that uncertainly induced by
4 the user could be looked at in the same way that you looked at
5 nodalization. You could characterize that uncertainty, if you
6 chose to do so. I'm not sure how I would go about
7 characterizing user uncertainty in that regard.

8 In my view, past use of this process and the process
9 as we're going to use it in this thing will treat user
10 uncertainty somewhat in the same sense that we're going to
11 treat nodalization -- i.e., we're probably going to remove it
12 as a source of uncertainty. Now, I think I have some
13 confidence in that, because I think a large part of what we
14 call user uncertainty is associated with nodalization. We are
15 going to establish a standard nodalization that represents the
16 best or the optimum way to calculate this transient.

17 There is a small part of user uncertainty that is
18 induced by other factors. Of course, one of them could be,
19 "Does he screw up and just put in the wrong numbers?" You
20 handle that by quality control.

21 There is a small part fo that that's induced by how
22 the user approaches certain things that he may input to the
23 code. For example, friction factors, flow multipliers, those
24 sorts of things, are user input. I believe we are going to
25 assume that we are using a mature code user. I don't know

1 anybody in industry that makes safety decisions that doesn't
2 use mature code users. There are certain practices that mature
3 code users go through to establish quality. Some of those are
4 formalized. It was a part of the ICAP program. All of the
5 codes have and are continuing to in the code documentation
6 insert sections that say, "These are the good things you do.
7 Do this. Don't do that."

8 In summary, I think we're going to treat potential
9 uncertainty in the same sense that we treated nodalization:
10 We're going to kind of standardize it. We're going to assume
11 that we're using a mature code user. And, therefore, we'll
12 probably take that out as a real source.

13 MR. CATTON: But isn't that supposed to be in your
14 user's manual, the instructions for the use of the code? You
15 demanded that of TRAC.

16 MR. WILSON: That's just what I alluded to. The NRC
17 documentation has in the past -- and it is more and more so for
18 the codes in the user's manual -- specified user guidelines.
19 In fact, I think, for RELAP 5, MOD3, there's a separate report
20 along those lines.

21 MR. WARD: I have another question of the staff, but
22 I see NRR isn't here.

23 Again, a couple of years ago, when we were addressing
24 the use of CSAU, we suggested that it was going to be more
25 difficult for the staff to review an application that made use

1 of a realistic estimate in a CSAU approach or something else
2 for estimating uncertainty. It was going to take more skill,
3 training, experience on the part of the staff reviewers than
4 review of an Appendix K analysis, which was a little more of a
5 recipe. Has the staff addressed that issue, and if so, how?

6 MR. WILSON: Dave, may I make one introductory remark
7 to that? We heard that comment in the past, for example in the
8 large break LOCA. We tried to assist NRR, perhaps, by, in the
9 documentation, providing what we thought were successful keys
10 to success or success criteria based on our experience, to give
11 the NRR staff some idea of those things. So I think in part,
12 we have tried to do that in the research programs.

13 MR. KERR: In that connection, you commented earlier
14 that you did not know of any group that had made safety
15 decisions without having available a mature code user. Does
16 that include the NRC?

17 MR. WILSON: Was the question does that include the
18 United States?

19 MR. KERR: No, the NRC, the US NRC.

20 MR. WILSON: I guess I would like NRR to comment to
21 that.

22 MR. KERR: Well, you made the statement. You said
23 that you didn't know of a single organization that made a--

24 MR. WILSON: Okay. I will answer it. The people
25 that I know that are making decisions that I am personally

1 familiar with I believe have the necessary degree of
2 competency.

3 MR. KERR: They are mature code users?

4 MR. WILSON: If that is their function, to provide
5 that kind of information, yes.

6 MR. KERR: I was just trying to understand whether,
7 when you made that observation about organizations, that the
8 NRC was included among the organizations to which you referred.

9 MR. WILSON: Yes.

10 MR. KERR: Okay.

11 MR. BESSETTE: I think Gary speaks only for the
12 thermal hydraulics code.

13 MR. WILSON: That's true. You have to limit it.
14 We're talking about a thermal hydraulics code, a systems code.
15 That's my -- David's right in saying that that's my perception.

16 MR. SCHROCK: Gary, I have a lot of problem with this
17 argument that you're making because I've seen many instances of
18 what you would regard as mature users doing things that are
19 absolutely unacceptable engineering practice. An example is
20 the suggestion that to fix a code so it will replicate a single
21 experiment, let's change the interfacial drag coefficient by
22 orders of magnitude. That came from somebody that I think you
23 would regard as a mature code user.

24 MR. WILSON: But was that in an assessment sense, or
25 something like that, or was that in actual calculations that we

1 used to make safety decisions?

2 MR. SCHROCK: That was in the sense of how we make
3 this code do what it has to do.

4 MR. WILSON: But you've got to put it in the
5 framework, are you talking about a case where safety decisions
6 are being made. I may do any number of things in an assessment
7 environment that I would not do where I'm trying to make a
8 safety decision.

9 MR. KERR: What other decisions does the NRC make? I
10 mean, presumably the decisions they make are made on the basis
11 of establishing safety.

12 MR. SHOTKIN: I think the Chairman asked the
13 representative of NRR a question. Gary tried to be helpful by
14 answering the question. Maybe NRR would like to answer the
15 question.

16 MR. JONES: This is Bob Jones. I was hoping I could
17 duck it. I think, David, your question about the experience of
18 the staff and the guidelines for review and best estimate
19 calculations, I think we said at the time that we would end up
20 using probably National Engineering Lab help in coming to those
21 conclusions. As you'll hear later this afternoon, we are
22 expecting a large break LOCA application from Westinghouse in
23 the near future, and we will be seeking National Laboratory
24 assistance, and probably INEL's assistance. So we will be
25 tapping people with experience in the area to help us with

1 those decisions, and that's how we intend to do it.

2 MR. CATTON: Well, I would hope that you wouldn't let
3 Westinghouse respond to some of the questions the way that
4 they've been responded to here in that, "Gee, we don't really
5 need to worry too much about that because we're in the same
6 room as those who developed the code."

7 If you recollect from the earlier process we went
8 through, one of the keys to making this whole thing work well
9 is that it's auditable, and this appeal to the guy in the next
10 office for answers is not auditable. It's not traceable in the
11 simplest sense.

12 MR. WILSON: I think I disagree. I think, Ivan, that
13 you and I are again debating schedule. When we publish the
14 final document in June of 1991, we will have the same
15 auditability and traceability that we had in the large break
16 LOCA, maybe even more.

17 MR. CATTON: I guess you also don't remember all the
18 troubles we had with the people who knew the code during that
19 process. They just didn't remember what was in it, and they
20 would give answers. It was only when the documentation was in
21 hand, and you could see it, that you knew what you were doing.

22 MR. BESSETTE: You know, we'll go to the same thing
23 here. I mean, you'll recall that we had to wait for the
24 documentation when we did the large break --

25 MR. CATTON: I also recall that the co-developers

1 didn't want to supply the documentation on the schedule that
2 was needed, and it took a -- it was very painful to get it.
3 Maybe you can't get it when you do your TPG process in the same
4 laboratory.

5 MR. BESSETTE: But we haven't come to that step, yet.
6 We're still on the PIRf, and we can do PIRT independent of
7 code.

8 MR. CATTON: That's certainly true.

9 MR. BESSETTE: But when we come to look at code in a
10 -- you need the documentation when you look at code
11 applicability because you have to see if the code has the
12 models for the phenomena that you determine to be important.
13 You also have to decide how you're going to arrange these
14 bottles. Before we do that step, we'll have the documentation.

15 MR. CATTON: I hope so.

16 MR. BESSETTE: It's impossible to do that step
17 without the documentation.

18 MR. CATTON: This is it?

19 MR. WILSON: That concludes our part of our address.

20 MR. CATTON: Okay. Are you going to say anything,
21 Dave, or is that it?

22 MR. BESSETTE: That's it.

23 MR. CATTON: Okay. Virgil, if you could give me a
24 few comments on what you've heard, I'd appreciate it.

25 MR. SCHROCK: Well, I don't know exactly what to say

1 other than the comments I've already made. Your question about
2 is the TPG looking at stratification, I would confirm that in
3 the discussion yesterday, clearly in the PIRT process, that is
4 an item which was looked at.

5 Something that was not discussed there that occurred
6 to me this morning and came out of these discussions is that
7 leaving until a later time to identify the location of the
8 break seems now to me to be presuming that you can have small
9 break occurring in a 28-inch pipe in some way.

10 The point that I made earlier today is, I think,
11 important, and that is that there is no model in any of the
12 codes for a tear in a pipe. All we have is a model for branch
13 lines on the pipe. So if we're going to have a small break, it
14 seems to me it has to be in a branch line; it's not going to be
15 a small break in the big pipe. I don't know -- I'd like to
16 hear the staff view about that, but it's something that was not
17 discussed in the meeting that I attended of this TPG.

18 At a previous subcommittee meeting, I pointed out
19 that I had raised objections a year ago to the fact that INEL
20 was installing some program language that was provided by Keith
21 Ardron in the International Code Assessment Program without
22 questioning the basis for that. It's difficult for me because
23 it involves my own work, and yet I can't help commenting on it.

24 What our experiments show is that when you do the
25 experiment with air and water and with steam and water in the

1 same apparatus, the height for incipient two-phase flow is
2 different, and we attributed that difference to the different
3 physical properties, surface tension and viscosity, and we
4 provided a correlation for incipient pull-through on the basis
5 of those data.

6 The KFK model, which is installed now in RELAP 5,
7 MOD3, in fact, was simply air/water data, and so it couldn't
8 see that.

9 There are arguments that came back from Keith Ardron
10 that are a year old now that I had not seen until today which
11 are erroneous. He points out that there is a pressure effect
12 in the KFK correlation which is absent in our correlation.
13 Simply untrue. I mean, the fact that we were able to correlate
14 the data from INEL, which were at very high pressure, in
15 contrast to all other experiments, and also for steam water,
16 incidentally, is attributed to the fact that we took into
17 account the dependence on viscosity and surface tension, both
18 things that are temperature dependent, and therefore pressure
19 dependent in a single component system.

20 So, I don't know, I have a lot of trouble with the
21 next step in the code, which will be applicability. I see it
22 inadequate either for the case of branch lines, and I have to
23 point out that we simply don't have data for flow-through small
24 breaks in a big pipe, which implies that what you have is some
25 kind of a tear in the pipe. The geometry is not going to be

1 well represented by data that we've obtained when we have
2 measurement of critical flows through circular pipes that are
3 branch lines. It's not the same.

4 MR. CATTON: Thanks, Virgil. Pete, do you have any
5 comments on this morning's?

6 MR. DAVIS: Can I write them down for you?

7 MR. CATTON: I'd be delighted.

8 MR. DAVIS: Okay. I'll do it.

9 MR. CATTON: Thank you. And, Virgil, any comments
10 you have on what was earlier this morning, if you could write
11 them down, I'd appreciate it.

12 MR. SCHROCK: Okay.

13 MR. CATTON: Thank you. I think that's it for this
14 morning. Why don't we break for lunch and come back at 1:30?

15 [Whereupon, at 12:30 p.m., the subcommittee recessed
16 for lunch, and the open session adjourned, to reconvene in
17 closed session at 1:30 p.m. this same day.]

18

19

20

21

22

23

24

25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: ACRS Thermal Hydraulic Phenomena

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Marilynn Nations

Marilynn Nations
Official Reporter
Ann Riley & Associates, Ltd.

ASCA

SBLOCA CSAU

Status

Code Selected: RELAP5/MOD3

Plant & Scenario Selection:

Criteria and considerations.

Possible choices and final selection.

Primary safety criteria

PIRT:

TPG

Phases of the transient:

Plant Components

Components Ranking

(AHP)

Phenomena Identification

phenomena ranking

INEL

Phases of the transient

Plant Components

Components Ranking

(AHP)

Phenomena Identification

phenomena ranking

SCENARIO SELECTION

1. OCONEE
2. WORST BREAK CONFIGURATION
3. MOST LIKELY POWER SHAPE
4. INITIALLY ASSUME THAT THE OPERATOR PERFORMS AS DIRECTED BY EOP's
5. SCENARIO THAT DISPLAYS THE MAXIMUM NUMBER OF SBLOCA PHENOMENA TO THE EXTENT SUPPORTED BY EXPERIMENTAL DATA

ASL

SBLOCA CSAU

Status

Code Selected: RELAP5/MOD3

Plant & Scenario Selection:

Criteria and considerations.

Possible choices and final selection.

Primary safety criteria

PIRT:

TPG

Phases of the transient:

Plant Components

Components Ranking

(AHP)

Phenomena Identification

phenomena ranking

INEL

Phases of the transient

Plant Components

Components Ranking

(AHP)

Phenomena Identification


phenomena ranking

PRIMARY SAFETY CRITERIA

1. LIQUID INVENTORY IN THE CORE
2. PCT

SCENARIO SELECTION

1. OCONEE
2. WORST BREAK CONFIGURATION
3. MOST LIKELY POWER SHAPE
4. INITIALLY ASSUME THAT THE OPERATOR PERFORMS AS DIRECTED BY EOP's
5. SCENARIO THAT DISPLAYS THE MAXIMUM NUMBER OF SBLOCA PHENOMENA TO THE EXTENT SUPPORTED BY EXPERIMENTAL DATA




BABCOCK 241
RCS SUPPORTS AND RESTRAINTS
ELEVATION VIEW

Figure 5.5-8

SCENARIO SELECTION


1. OCONEE
2. WORST BREAK CONFIGURATION
3. MOST LIKELY POWER SHAPE
4. INITIALLY ASSUME THAT THE OPERATOR PERFORMS AS DIRECTED BY EOP's
5. SCENARIO THAT DISPLAYS THE MAXIMUM NUMBER OF SBLOCA PHENOMENA TO THE EXTENT SUPPORTED BY EXPERIMENTAL DATA



BABCOCK 241
RCS SUPPORTS AND RESTRAINTS
ELEVATION VIEW

Figure 5.5-8


SBLOCA PHASES ACCORDING TO INDEPENDENT (INEL) PANEL



- PHASE 1. SUBCOOLED BLOWDOWN
- PHASE 2. INTERMEDIATE BLOWDOWN
- PHASE 3. REACTOR TRIP
- PHASE 4. PRESSURE STABILIZATION
- PHASE 5. LOSS OF NATURAL CIRCULATION
- PHASE 6. BOILING-CONDENSING
- PHASE 7. REFILL
- PHASE 8. LEAK FLOW = INJECTION FLOW
- PHASE 9A. NC RE-ESTABLISHED
- PHASE 9B. FEED AND BLEED

AHP GENERAL APPLICATION

PHASE M



STEPS

1. DEFINE PRIMARY SAFETY CRITERIA
2. PARTITION TRANSIENT INTO PHASES
- FOR EACH PHASE:
 3. PARTITION SYSTEM INTO COMPONENTS
 4. RANK COMPONENTS ON PAIR-WISE BASIS
 5. RANK COMPONENTS ON SYSTEM WIDE BASIS
- FOR EACH COMPONENT:
 6. IDENTIFY PHENOMENA
 7. RANK PHENOMENA ON PAIR-WISE BASIS
 8. RANK PHENOMENA ON SYSTEM WIDE BASIS

	PHENOMENA									
	1	2	3	4	5	6	7	8	9a	9b
Critical Break Flow	1	1	1		1	1	1	1	1	1
Break Nucleation		1	1							
Two-phase break flow				1						1
Steam break flow			1		1	1				
Flashing		1	1	1	1	1				
Subcooling Margin	1	1	1			1	1	1	1	1
Loss of Subcooling Margin			1	1	1					
Boron Concentration	1	1	1							
Cold Leg Temperature	1	1	1	1	1	1	1	1	1	1
Cold Leg Pressure	1	1	1	1	1	1	1	1	1	1
Sonic Velocity	1	1	1							
Pump Cavitation		1	1							
Two-phase pump degradation			1	1	1					
Pump coastdown				1	1	1				
Pressurizer Volume Expansion		1	1							
Pressurizer Emptying			1							
Pressurizer refili							1	1	1	1
Pressurizer pressure										1
Neutronics:										
Moderation (slow down theory)	1	1	1							
Kinetics	1	1	1							
Doppler	1	1	1							
Peak to Average Flux Ratio		1	1	1	1	1	1	1	1	1
Heat Transfer:										
Nucleate Boiling		1	1	1	1	1	1			
Departure from Nucleate Boiling		1	1	1	1	1	1	1		
Conduction		1	1					1	1	1
Forced Convection		1	1	1	1					
Void collapse condensation (inverse flashing)		1	1	1	1				1	1
Condensation heat transfer (void compression)						1	1	1	1	1
Wall to coolant heat transfer				1	1	1	1	1	1	1
ECCS spillage (out the break)			1	1	1	1	1	1	1	1
ECCS Mixing			1	1	1	1	1	1	1	1
Shrink or Swell			1					1		1

PHENOMENA	1	2	3	4	5	6	7	8	9a	9b
Instrumentation & Control:										
Detector Response			1							
Instrumentation Delay			1							
Actuation			1							
Prompt Drop (rate of change of reactivity insertion)			1							
Secondary Saturation Pressure			1	1	1	1	1	1	1	
Primary-Secondary Heat Transfer			1	1	1	1	1	1	1	
Turbine Trip			1							
Main FeedWater Pump Runback			1							
Secondary Level				1	1	1	1	1	1	
two-phase flow in Hot Leg			1	1	1	1	1			
Asymmetric Loop Flow			1							
Decay Heat			1	1	1	1	1	1	1	1
Upper Head Voiding			1							
Turbine bypass Demand - Steaming			1	1		1	1	1	1	
Rod Drop time			1							
Upper plenum voiding				1	1	1				
Core Inventory				1	1	1	1	1		
Natural circulation transport time				1			1	1		
Candy Cane Voiding				1	1					
Internal Vessel Circulation				1	1	1	1	1	1	1
Thermal Stratification					1	1	1	1	1	1
Water Hammer					1					
Upper head refill							1	1		
Upper plenum refill							1	1		
Hot path Refill							1	1		
Upper head void									1	1

PHASE 1 SUBCOOLED BLOWDOWN

COMPONENTS	PHENOMENON
1. Break	1. Critical Break Flow
2. Pumps	2. Subcooling Margin
3. RCS Volume	3. Boron Concentration
4. Pressurizer	4. Cold Leg Temperature
5. Core	5. Cold Leg Pressure
6. CVCS	6. Sonic Velocity
	7. Neutronics
	a. Moderation(slow down theory)
	b. Kinetics
	c. Doppler

PHASE 2 INTERMEDIATE BLOWDOWN

COMPONENTS	PHENOMENON
1. Break	1. Critical Break Flow
2. Reactor Coolant Pumps	2. Break Nucleation
3. Upper Head	3. Flashing
4. Pressurizer	4. Subcooling Margin
5. Core	5. Boron Concentration
6. Hot Leg and Candy Cane	6. Cold Leg Temperature
7. Reactor Shutdown System	7. Cold Leg Pressure
8. Rest of System	8. Sonic Velocity
	9. Pump Cavitation
	10. Pressurizer Volume Expansion
	11. Neutronics
	a. Moderation(slow down theory)
	b. Kinetics
	c. Doppler
	d. Peak to average flux ratio
	12. Heat Transfer
	a. Nucleate Boiling
	b. Departure from Nucleate Boiling
	c. Conduction
	d. Forced convection
	e. Void Collapse Condensation (inverse flashing)

PHASE 3 POST REACTOR TRIP

COMPONENTS	PHENOMENON
1. Break	1. Critical Break Flow
2. Emergency Core Cooling System	2. Break Nucleation
3. Core	3. Steam Flow Through Break
4. Reactor Coolant System Volume	4. Flashing
5. Reactor Coolant Pumps	5. Subcooling Margin
6. Cold Leg	6. Loss of Subcooling Margin
7. Steam Generator	7. Boron Concentration
8. Operator	8. Cold Leg Temperature
9. Hot Path	9. Cold Leg Pressure
10. Emergency Safeguards Features Actuation	10. Sonic Velocity
11. Pressurizer	11. Pump Cavitation
12. Balance of Plant	12. Two-Phase Pump Degradation
13. Integrated Control System	13. Pressurizer Volume Expansion
14. Chemical & Volume Control System	14. Pressurizer emptying
	15. Neutronics
	a. Moderation (slow down theory)
	b. Kinetics
	c. Doppler
	d. Peak to Average Flux Ratio
	16. Heat Transfer
	a. Nucleate Boiling
	b. Departure from Nucleate Boiling
	c. Conduction
	d. Forced Convection
	e. Void Collapse Condensation (inverse flashing)
	17. ECCS spillage (out the break)
	18. ECCS mixing
	19. Shrink or Swell
	20. Instrumentation & Control
	a. Detector Response
	b. Instrumentation Delay
	c. Actuation
	d. Prompt Drop (rate of change of reactivity insertion)
	21. Secondary Saturation Pressure
	22. Primary-Secondary Heat Transfer
	23. Turbine Trip
	24. Main Feedwater Pump Runback
	25. Two-Phase Flow in Hot Leg
	26. Asymmetric Loop Flow
	27. Decay Heat
	28. Upper Head Voiding
	29. Turbine Bypass Demand/Steaming
	30. Rod Drop Time

PHASE 4 PRESSURE STABILIZATION

COMPONENTS	PHENOMENON
1. Break	1. Two-phase Break Flow
2. Emergency Core Cooling System	2. Flashing
3. Core	3. Loss of Subcooling Margin
4. Main & Aux. Feedwater	4. Cold Leg Temperature
5. Reactor Coolant Pumps	5. Cold Leg Pressure
6. Candy Cane	6. Pump Coastdown
7. Steam Generator	7. Two-Phase Pump Degradation
8. Operator	8. Neutronics
9. Downcomer & Lower Plenum	a. Peak to Average Flux Ratio
10. Upper Plenum & Hot Leg	9. Heat Transfer
11. Balance of Plant	a. Nucleate Boiling
12. Integrated Control System	b. Departure from Nucleate Boiling
	c. Forced Convection
	d. Void Collapse Condensation (inverse flashing)
	e. Wall to Coolant
	10. ECCS spillage (out the break)
	11. ECCS mixing
	12. Secondary Saturation Pressure
	13. Primary-Secondary Heat Transfer
	14. Secondary Level
	15. Two-Phase Flow in Hot Leg
	16. Decay Heat
	17. Turbine Bypass Demand / Steaming
	18. Upper Plenum Void
	19. Core Inventory
	20. Natural Circulation Transport Time
	21. Candy Cane Void
	22. Internal Vessel Circulation

PHASE 5 LOSS OF NATURAL CIRCULATION

COMPONENTS	PHENOMENON
1. Break	1. Critical Break Flow
2. Emergency Core Cooling System	2. Steam Flow Through Break
3. Core	3. Flashing
4. Main & Aux. Feedwater	4. Loss of Subcooling Margin
5. Reactor Coolant Pumps	5. Cold Leg Temperature
6. Candy Cane	6. Cold Leg Pressure
7. Steam Generator	7. Pump Coastdown
8. Operator	8. Two-Phase Pump Degradation
9. Downcomer & Lower Plenum	9. Neutronics
10. Upper Plenum & Hot Leg	a. Peak to Average Flux Ratio
11. Balance of Plant	10. Heat Transfer
12. Reactor Vessel Vent Valves	a. Nucleate Boiling
13. Pressurizer	b. Departure from Nucleate Boiling
	c. Forced Convection
	d. Void Collapse Condensation (inverse flashing)
	e. Wall to Coolant
	11. ECCS spillage (out the break)
	12. ECCS mixing
	13. Secondary Saturation Pressure
	14. Primary-Secondary Heat Transfer
	15. Secondary Level
	16. Two-Phase Flow in Hot Leg
	17. Decay Heat
	18. Upper Plenum Voiding
	19. Core Inventory
	20. Candy Cane Voiding
	21. Internal Vessel Circulation
	22. Water Hammer
	23. Thermal Stratification

PHASE 6 REFLUX & BOILING CONDENSING

COMPONENTS	PHENOMENON
1. Break	1. Critical Break Flow
2. Emergency Core Cooling System	2. Steam Flow Through Break
3. Core	3. Flashing
4. Main & Aux. Feedwater	4. Subcooling Margin
5. Reactor Coolant Pumps	5. Cold Leg Temperature
6. Candy Cane	6. Cold Leg Pressure
7. Steam Generator	7. Pump Coastdown
8. Operator	8. Neutronics
9. Downcomer & Lower Plenum	a. Peak to Average Flux Ratio
10. Upper Plenum & Hot Leg	9. Heat Transfer
11. Balance of Plant	a. Nucleate Boiling
12. Reactor Vessel Vent Valves	b. Departure from Nucleate Boiling
13. Pressurizer	c. Condensation (void compression)
	e. Wall to Coolant
	10. ECCS spillage (out the break)
	11. ECCS mixing
	12. Secondary Saturation Pressure
	13. Primary-Secondary Heat Transfer
	14. Secondary Level
	15. Two-Phase Flow in Hot Leg
	16. Decay Heat
	17. Turbine Bypass Demand / Steaming
	18. Upper Plenum Voiding
	19. Core Inventory
	20. Internal Vessel Circulation
	21. Thermal Stratification

PHASE 7 REFILL / REPRESSURIZATION

COMPONENTS	PHENOMENON
1. Break	1. Critical Break Flow
2. Emergency Core Cooling System	2. Subcooling Margin
3. Core	3. Cold Leg Pressure
4. Balance of Plant & Feedwater	4. Cold Leg Temperature
5. Hot Path	5. Pressurizer Refill
6. Cold Path	6. Neutronics
7. Steam Generator	a. Peak to Average Flux Ratio
8. Operator & Reactor Coolant Pumps	7. Heat Transfer
9. Pressurizer	a. Nucleate Boiling
	b. Departure from Nucleate Boiling
	c. Condensation (void compression)
	d. Wall to Coolant
	8. ECCS spillage (out the break)
	9. ECCS mixing
	10. Secondary Saturation Pressure
	11. Primary-Secondary Heat Transfer
	12. Secondary Level
	13. Two-Phase Flow in Hot Leg
	14. Decay Heat
	15. Turbine Bypass Demand / Steaming
	16. Core Inventory
	17. Natural Circulation Transport Time
	18. Internal Vessel Circulation
	19. Thermal Stratification
	20. Upper Head Refill
	21. Upper Plenum Refill
	22. Hot Path Refill

PHASE 8 LEAK FLOW = INJECTION FLOW

COMPONENTS	PHENOMENON
1. Break	1. Critical Break Flow
2. Emergency Core Cooling System	2. Subcooling Margin
3. Core	3. Cold Leg Pressure
4. Balance of Plant & Feedwater	4. Cold Leg Temperature
5. Hot Path	5. Pressurizer Refill
6. Cold Path	6. Neutronics
7. Steam Generator	a. Peak to Average Flux Ratio
8. Operator & Reactor Coolant Pumps	7. Heat Transfer
9. Pressurizer	a. Conduction
	b. Departure from Nucleate Boiling
	c. Condensation (void compression)
	d. Wall to Coolant
	8. ECCS spillage (out the break)
	9. ECCS mixing
	10. Secondary Saturation Pressure
	11. Primary-Secondary Heat Transfer
	12. Secondary Level
	13. Shrink or Swell
	14. Decay Heat
	15. Turbine Bypass Demand / Steaming
	16. Core Inventory
	17. Natural Circulation Transport Time
	18. Internal Vessel Circulation
	19. Thermal Stratification
	20. Upper Head Refill
	21. Upper Plenum Refill
	22. Hot Path Refill

PHASE 9a NATURAL CIRCULATION REESTABLISHED

COMPONENTS	PHENOMENON
1. Break	1. Critical Break Flow
2. Emergency Core Cooling System	2. Subcooling Margin
3. Core	3. Cold Leg Pressure
4. Balance of Plant & Feedwater	4. Cold Leg Temperature
5. Hot Path	5. Pressurizer Refill
6. Cold Path	6. Neutronics
7. Steam Generator	a. Peak to Average Flux Ratio
8. Operator & Reactor Coolant Pumps	7. Heat Transfer
9. Pressurizer	a. Conduction
	b. Condensation (void compression)
	c. Void Collapse Condensation (inverse flashing)
	d. Wall to Coolant
	8. ECCS spillage (out the break)
	9. ECCS mixing
	10. Secondary Saturation Pressure
	11. Primary-Secondary Heat Transfer
	12. Secondary Level
	13. Decay Heat
	14. Turbine Bypass Demand / Steaming
	15. Internal Vessel Circulation
	16. Thermal Stratification
	17. Upper Head Void

PHASE 9b FEED AND BLEED

COMPONENTS	PHENOMENON
1. Break	1. Critical Break Flow
2. Emergency Core Cooling System	2. Two-Phase Break Flow
3. Core	3. Subcooling Margin
4. Balance of Plant & Feedwater	4. Cold Leg Pressure
5. Hot Path	5. Cold Leg Temperature
6. Cold Path	6. Pressurizer Refill
7. Steam Generator	7. Pressurizer Pressure
8. Operator & Reactor Coolant Pumps	8. Neutronics
9. Pressurizer	a. Peak to Average Flux Ratio
	9. Heat Transfer
	a. Conduction
	b. Condensation (void
	compression)
	c. Void Collapse Condensation
	(inverse flashing)
	d. Wall to Coolant
	10. ECCS spillage (out the
	break)
	11. ECCS mixing
	12. Shrink or Swell
	13. Decay Heat
	14. Internal Vessel Circulation
	15. Thermal Stratification
	16. Upper Head Void

PHASE 1 COMPONENT RANK BY INEL

PAIR-WISE RANKS							SYS
	BRK	RCP	RCS	PZR	COR	CVC	RANK
BRK	1	3	3	2	3	3	9
RCP		1	1/2	1/3	1	1/2	1
RCS			1	1/2	1	1/2	2
PZR				1	2	1	4
COR					1	1/2	1
CVC						1	4

Dist

**NRR COMMENT ON
SCOPE AND SCHEDULE OF REVIEW OF
W BE ECCS/LOCA MODEL**

**PRESENTED TO:
ACRS T/H SUBCOMMITTEE
BETHESDA, MD
DECEMBER 7, 1989**

**PRESENTED BY:
Y. GENE HSII
NRR/DST/SRXB
492-0887**

REVIEW SCOPE

- **REVIEW WCOBRA/TRAC CODE QUALIFICATION DOCUMENT**
 - **CAPABILITY TO PREDICT IMPORTANT PHENOMENA IDENTIFIED BY CSAU**
 - **SCALING CAPABILITY**
 - **CODE ASSESSMENT**

- **REVIEW UNCERTAINTY QUANTIFICATION**
 - **CSAU ELEMENTS**
 - **PROPAGATION OF UNCERTAINTY BLOWDOWN PEAK TO REFLOOD PEAK**
 - **OVERALL UNCERTAINTY QUANTIFICATION**

- **REVIEW PLANT APPLICATION**
 - **PLANT MODEL**
 - **PLANT PARAMETERS**

REVIEW SCHEDULE

- REVIEW TO BE COMPLETED APPROXIMATELY ONE YEAR AFTER SUBMITTAL**
- PERIODIC MEETINGS WITH ACRS TO INFORM PROGRESS OF REVIEW**
- WILL HAVE NATIONAL LABORATORY TO HELP REVIEW**

Arce



**STATUS
SBLOCA CSAU**

**GARY E. WILSON
MARCOS G. ORTIZ**

**ACRS SUBCOMMITTEE ON
T/H PHENOMENA**

DECEMBER 1989



**THE MAJOR TOPICS WHICH WILL BE ADDRESSED IN THE
PRESENTATION ARE:**

- o CSAU METHODOLOGY OVERVIEW (WILSON)**

- o RESULTS OF WORK-TO-DATE (ORTIZ)**

- o FUTURE ACTIVITIES (WILSON)**

THE CSAU METHODOLOGY CONSISTS OF THREE BASIC ELEMENTS

- REQUIREMENTS & CODE CAPABILITIES (STEPS 1-6)
- ASSESSMENT & RANGING OF PARAMETERS (STEPS 7-10)
- SENSITIVITY & UNCERTAINTY ANALYSIS (STEPS 11-14)





FIGURE 1 CODE SCALING, APPLICABILITY AND UNCERTAINTY EVALUATION METHODOLOGY


THE STEPS IN THE FIRST ELEMENT COMPARE THE MODELING REQUIREMENTS WITH THE BASIC CODE CAPABILITIES

- IDENTIFY PLAUSIBLE PHENOMENA/PROCESSES
- DETERMINE DOMINANT PHENOMENA/PROCESSES
- EVALUATE CODE MODELS IN CONTEXT OF IMPORTANT PHENOMENA
- DEFINE BASIC CODE APPLICABILITY




THE STEPS IN ELEMENT 2 ESTABLISH THE KEY CODE PARAMETERS, & THEIR VARIABILITY

- WORK BASED ON DEFINED ASSESSMENT MATRIX
- STANDARD NODALIZATION REMOVES IT AS AN UNCERTAINTY SOURCE
- INDIVIDUAL PARAMETER VARIABILITY STATED IN TERMS OF PROBABILITY (PREFERRED), OR BOUNDING BIAS



THE STEPS IN ELEMENT 3 QUANTIFY THE UNCERTAINTIES IN INDIVIDUAL IMPORTANT KEY PARAMETERS IN THE CONTEXT OF THE PRIMARY SAFETY CRITERIA, & THEIR COMBINED EFFECT

- SENSITIVITY ANALYSIS USED TO CONVERT VARIABILITY IN INDIVIDUAL KEY CODE PARAMETERS INTO THEIR INDIVIDUAL REFLECTIONS IN SAFETY CRITERIA
- INDIVIDUAL UNCERTAINTIES IN SAFETY CRITERIA ARE COMBINED TO DEFINE TOTAL CODE UNCERTAINTY



Insert

CSAU for PWR SBLOCA

**presented to the
Advisory Committee on Reactor Safeguards
T/H Phenomena Subcommittee
December 7, 1989
Bethesda, Maryland**

by

**Richard Lee
Reactor & Plant Systems Branch
Division of Systems Research
Office of Nuclear Regulatory Research**

CSAU for PWR SBLOCA

Objective:

To determine the CSAU for RELAP5/MOD3 when applied to small break LOCA for PWR

Program Structure:

Similar to LBLOCA CSAU effort. A Technical Program Group (TPG) was organized to guide and coordinate the effort of INEL.

Program Structure (continued)

NRC: Richard Lee, Program Monitor

INEL: Integrating Contractor

**Marcos Ortiz - Principal
Investigator**

**Gary Wilson - Program
Manager**

TPG Members:

Richard Lee, David Bessette (NRC)

Brent Boyack (LANL)

Peter Griffith (MIT)

Y-Y Hsu (UM)

Mamoru Ishii (Purdue)

Gerald Lellouche (S. Levy, Inc.)

Gary Wilson, Marcos Ortiz (INEL)

ACRS Oversight:

V. Schrock (UCB)

Program Status:

- * Initiated in June 89. Scheduled for completion in FY91.**
- * 1st TPG meeting:
September 19-20, 1989.**
- * 2nd TPG meeting:
December 5-6, 1989.**

Insert

NRR STAFF PRESENTATION TO THE ACRS

SUBJECT: ISLOCA PROGRAM OVERVIEW

DATE: DECEMBER 7, 1989

PRESENTER: RICHARD J. BARRETT

PRESENTER'S TITLE/BRANCH/DIV: CHIEF, RISK APPLICATIONS BRANCH
DIVISION OF RADIATION PROTECTION
AND EMERGENCY PREPAREDNESS

PRESENTER'S NRC TEL. NO.: 492-1089

SUBCOMMITTEE: ACRS T/H

CONSEQUENCES OF AN ISLOCA

- o LOSS OF REACTOR PRESSURE BOUNDARY AND CONTAINMENT
(Two out of three fission product barriers)
- o POTENTIAL FOR EARLY CORE DAMAGE
- o POTENTIAL FOR HIGH OFFSITE DOSES
- o LIMITED TIME FOR OFFSITE PROTECTIVE ACTIONS

PWR ISLOCA BACKGROUND

- o WASH-1400 (10/75)
- o EVENT V ORDERS (4/81)
- o GI-105
- o INPO SOER 86-3
- o BULLETIN 89-02

CURRENT PRA RESULTS

- o ISLOCA ANALYZED AS A VALVE LEAKAGE/FAILURE PROBLEM
- o RELATIVELY LITTLE ANALYSIS OF HUMAN ELEMENT
- o LITTLE OR NO CREDIT FOR ACCIDENT MANAGEMENT
- o CORE DAMAGE FREQUENCY $\sim 1E-6$
- o ISLOCA A MAJOR CONTRIBUTOR TO EARLY FATALITIES

OPERATING EXPERIENCE


- o HUMAN ERRORS
- o VALVE FAILURES
- o UNANTICIPATED FAILURE PATHS (e.g., CCW)

ISLOCA PROJECT GOAL

- o HIGH CONFIDENCE THAT A HIGH CONSEQUENCE ISLOCA WILL NOT OCCUR IN THE CURRENT GENERATION OF U.S. PLANTS

ISLOCA AREAS OF EXAMINATION

- o LIKELIHOOD THAT AN ISLOCA WILL OCCUR
- o IN THE EVENT OF AN ISLOCA, LIKELIHOOD THAT PROCEDURES AND EQUIPMENT ARE IN PLACE TO DELAY SIGNIFICANTLY OR PREVENT CORE DAMAGE
- o EFFECTIVENESS OF EQUIPMENT AND PROCEDURES IN MINIMIZING OFFSITE RADIOLOGICAL CONSEQUENCES OF AN ISLOCA



ACRS BRIEFINGS ON ISLOCA

o APRIL 1989

**Tom Murley informed Full Committee
of existence of ISLOCA Project**

o DECEMBER 1989

**Staff briefing of Thermohydraulic
Subcommittee regarding goals,
structure and elements of project**

o SPRING 1989

**Subcommittee briefing on preliminary
technical results**

o FUTURE BRIEFINGS

At appropriate intervals

NRR STAFF PRESENTATION TO THE ACRS

SUBJECT: NRR COORDINATION OF ISLOCA RESOLUTION ISSUE

DATE: DECEMBER 7, 1989

PRESENTER: SAMMY S. DIAB

PRESENTER'S TITLE/BRANCH/DIV: RELIABILITY AND RISK ANALYST
RISK APPLICATIONS BRANCH
DIVISION OF RADIATION PROTECTION
AND EMERGENCY PREPAREDNESS

PRESENTER'S NRC TEL. NO.: 492-1075


SUBCOMMITTEE: ACRS T/H

PROJECT OVERVIEW

- o OPERATIONAL DATA ASSESSMENT
SEARCH FOR PRECURSORS (ROOT CAUSES & FAILURE MECHANISMS).

- o INSPECTION PROGRAM
AUDIT SELECTED PLANTS TO GAUGE CURRENT STATUS REGARDING PROJECT AREAS OF EXAMINATION
 - MAINTENANCE & OPERATOR ERRORS
 - VALVE TESTING/SURVEILLANCE
 - OPERATOR RESPONSE/ACCIDENT MANAGEMENT

- o ANALYSIS PROGRAM
FOCUSED PRA EFFORT TO ASSESS POSSIBLE ISLOCA SCENARIOS.
 - HUMAN RELIABILITY
 - THERMOHYDRAULIC/STRESS ANALYSIS



AREAS OF EXAMINATION

- o LIKELIHOOD THAT AN ISLOCA WILL NOT OCCUR FOR THE CURRENT GENERATION OF REACTORS
- o IN THE EVENT OF AN ISLOCA, LIKELIHOOD THAT PROCEDURES AND EQUIPMENT ARE IN PLACE TO DELAY SIGNIFICANTLY OR PREVENT CORE DAMAGE
- o EFFECTIVENESS OF EQUIPMENT AND PROCEDURES IN MINIMIZING OFFSITE RADIOLOGICAL CONSEQUENCES OF AN ISLOCA

RELEVANT PLANT ATTRIBUTES

AREA 1: LIKELIHOOD THAT AN ISLOCA WILL OCCUR

- o VALVE INTEGRITY
 - TESTING/MAINTENANCE
 - INTERLOCKS

- o PIPE/SEAL INTEGRITY
 - TH/STRUCTURAL

- o HUMAN PERFORMANCE
 - PROCEDURES
 - TRAINING
 - MAN/MACHINE INTERFACE
 - PERFORMANCE SHAPING FACTORS

- o EARLY BREAK ISOLATION
 - PROCEDURES
 - DIAGNOSIS

RELEVANT PLANT ATTRIBUTES (Continued)

AREA 2: ASSURANCE FOR DELAY OR PREVENTION OF CORE DAMAGE

- o INSTRUMENTATION/DIAGNOSIS AND ISOLATION**

- o ECCS (SHORT TERM)**
 - INJECTION PATH**
 - NPSH**
 - SYSTEM INTERACTIONS (PROTECTION OF EQUIPMENT FROM FLOODING, STEAM, ETC.)**

- o ECCS (LONG TERM)**
 - RWST REFILL**
 - CONSERVATION OF BORATED WATER**

- o HUMAN PERFORMANCE**
 - PROCEDURES**
 - TRAINING**
 - MAN/MACHINE INTERFACE**
 - PERFORMANCE SHAPING FACTORS**

RELEVANT PLANT ATTRIBUTES (Continued)

AREA 3: MINIMIZATION OF OFFSITE CONSEQUENCES

- o **DELAY/MINIMIZE F.P. RELEASE**
 - **RCS DEPRESSURIZATION**
 - **FLOODING OF BREAK LOCATION**
 - **ACTIVATION OF FIRE SPRAYS**
 - **SECONDARY BUILDING CHARACTERISTICS**

Insert

**RES STAFF PRESENTATION TO THE
ACRS**

SUBJECT: ISLOCA RESEARCH PROGRAM (NEAR-TERM)

DATE: DECEMBER 7, 1989


PRESENTER: GARY BURDICK

**PRESENTER'S TITLE/BRANCH/DIV.:
SPECIAL ASSISTANT
DIVISION OF SYSTEMS RESEARCH
OFFICE OF NUCLEAR REGULATORY RESEARCH**

PRESENTER'S NRC. TEL. NO.: 49-23509

ISLOCA RESEARCH PROGRAM NEAR-TERM OBJECTIVES

- 0 EVALUATE LOW PRESSURE SYSTEMS FRAGILITIES UNDER HIGH PRESSURES/TEMPERATURES TO IDENTIFY LIKELY FAILURE LOCATIONS.
- 0 IDENTIFY SPECIFIC HUMAN ACTIONS AND ROOT CAUSES IMPORTANT TO ISLOCA FOR RECOMMENDING RISK REDUCTION ACTIONS.
- 0 DETERMINE ISLOCA SEQUENCE TIMING, FLOW RATES, ACCIDENT MANAGEMENT STRATEGIES, AND ISLOCA EFFECTS ON OTHER EQUIPMENT.
- 0 DEVELOP A PRA FRAMEWORK TO EVALUATE HUMAN AND HARDWARE CONTRIBUTIONS TO ISLOCA.
- 0 ESTIMATE ISLOCA CONSEQUENCES AND IMPORTANT FACTORS FOR CONSEQUENCE REDUCTION.



RES ISLOCA PROGRAM FLOW CHART

BRIEF TASK DESCRIPTIONS

1. CONFIGURATION REVIEW

- IDENTIFY "REPRESENTATIVE" SYSTEMS FOR ANALYSIS IN SIX PLANTS

2. DATA ANALYSIS

- REVIEW OPERATING HISTORY FOR ISLOCA EVENTS
- ESTIMATE PRA PARAMETERS
- IDENTIFY IMPORTANT HUMAN ACTIONS

3. ENGINEERING ANALYSIS

FOR THE SYSTEMS IDENTIFIED IN
TASK 1:

- CALCULATE COMPONENT FRAGILITIES W.R.T. PRESSURE AND TEMPERATURE
- ESTIMATE LIKELIHOODS OF FAILURES AT SPECIFIC SYSTEM LOCATIONS
- ESTIMATE FLOW RATES AND TIMINGS

BRIEF TASK DESCRIPTIONS (CONT'D)

4. HUMAN FACTORS

- ANALYZE HUMAN ACTIONS FROM TASK 2 FOR PERFORMANCE SHAPING FACTORS
- COLLECT ADDITIONAL DATA FROM PLANTS IDENTIFIED IN TASK 1
- RETROSPECTIVELY REVIEW AUDIT PROCEDURES IN LIGHT OF CURRENT PROGRAM RESULTS
- RECOMMEND AUDIT PROCEDURE REVISIONS
- DEVELOP FINAL PERFORMANCE SHAPING FACTORS FOR ESTIMATION OF HUMAN ERROR CONTRIBUTION TO ISLOCA

5. ANALYSIS METHOD DEV.

- DEVELOP PROCEDURES TO INTEGRATE ANALYSES AND RESULTS (TASKS 1-4) INTO ISLOCA PLANT EVALUATION METHOD

BRIEF TASK DESCRIPTIONS (CONT'D)

6. EVALUATION METHOD APPLICATION

APPLY PROCEDURES OF TASK 5 TO SYSTEMS AND PLANTS IDENTIFIED IN TASK 1.

7. PROGRAM MANAGEMENT

- IDENTIFY CRITICAL PATH ITEMS
- ENSURE COORDINATION AMONG TASKS

8. ISLOCA EVALUATION GUIDE DEVELOPMENT

- PRODUCE A LIBRARY OF SYSTEM MODELS FOR USE IN ISLOCA EVALUATIONS
- PROVIDE GUIDELINES FOR ASSESSMENT OF DESIGNS, PROCEDURES, RECOVERY ACTIONS, ETC. TO EVALUATE ISLOCA FREQUENCY AND RISK.

PROGRAM STATUS

TASK

1. CONFIGURATION REVIEW (COMPLETED)
2. DATA ANALYSIS (COMPLETED)
3. ENGINEERING ANALYSIS
(DAVIS-BESSE UNDERWAY)
4. HUMAN FACTORS (UNDERWAY)
5. ANALYSIS METHOD DEV.
(UNDERWAY)
6. METHOD APPLICATION (DAVIS-BESSE)
7. PROGRAM MANAGEMENT (UNDERWAY)
8. ISLOCA EVALUATION GUIDE AND SYSTEMS
ANALYSES
(DELIVERY IN LATE FY1990)

Int

FUTURE WORKSCOPE AND SCHEDULE INCLUDE THE FOLLOWING MILESTONES

RESOLVE TPG & INEL PIRT DIFFERENCES . . . JAN 1990
COMPLETE ASSESSMENT MATRIX (DRAFT) . . . FEB 1990
DETERMINE KEY CODE PARAMETERS & . . . FEB 1990
RANGE
DETERMINE CODE APPLICABILITY (DRAFT) . . . MAR 1990
SBLOCA CASU WORKSHOP MAR 1990
DOCUMENT PIRT (FINAL) APR 1990
COMPLETE SENSITIVITY CALCULATIONS . . . OCT 1990
DETERMINE CODE UNCERTAINTY (DRAFT RPT) . MAR 1991
ISSUE NUREG/CR JUN 1991