PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-89-72 Date 12-8-89

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this data.

| FACILITY: | SACRAMENTO MUNICIPAL UTILITY<br>RANCHO SECO UNIT 1 | DISTRICT | Emergency Classification<br>Notification of Unusual Event |
|-----------|--|----------|---|
|           | DOCKET NO. 50-312<br>HERALD, CA                    |          | General Emergency<br>X Not Applicable                     |

## SUBJECT: RANCHO SECO DEFUELING STATUS

The licensee completed defueling the reactor on December 8, 1989. The Spent Fuel Pool (SFP) now contains 493 fuel assemblies. The SFP has the capacity to hold 1080 assemblies. Other major work activities that the licensee is presently focusing on include: efforts to locate and correct a minor SFP leak (maximum leak rate - 1 gallon per hour); placing plant systems in a long term layup condition; and preparing licensing submittals to support moving to decommissioning.

Media interest has occurred regarding the defueling activities.

This information is current as of 11:00 a.m., December 8, 1989.

CONTACT: S. Richards (FTS 463-3853)

| Date Time     | 9     |      |
|---------------|-------|------|
| Chairman Carr | EDO   | RI   |
| Comm. Curtis  | AEOD  | RII  |
| Comm. Roberts | PAO   | RIII |
| Comm. Rogers  | SLITP | RIV  |
| Comm. Remick  | RES   |      |
| OCA           | NRR   |      |
| OGC           | NMSS  |      |
| OE            | IRM   |      |
| ACRS          | OIG   |      |
| GPA           | ASLAP |      |
| RES           |       |      |

FAX TO: Date \_\_\_\_\_\_Time\_\_\_\_\_ INPO NSAC LICENSEE ESIDENT INSPECTOR HQS. CPERATIONS OFFICER PDR (202)634-3343

MAIL TO: DC3 (Original) DOT:(Trans. Only, Applicable State)

IE34 110

8912190198 891203 PDR 1&E PNO-V-89-072 PDC