



**Florida
Power**
CORPORATION

December 13, 1989
3F1289-07

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Monthly Operating Report

Dear Sir:

Attached is the Crystal River Unit 3 November 1989 Monthly Operating Report. This report is submitted in accordance with Technical Specification 6.9.1.6.

Sincerely,

Rolf C. Widell, Director
Nuclear Operations Site Support

/wla

Attachment

xc: Regional Administrator, Region II
Senior Resident Inspector

8912200186 891130
PDR ADOCK 05000302
R PDC

TE 2A
11

OPERATING DATA REPORT

DOCKET NO. 50-302
 DATE 12-5-89
 COMPLETED BY J. Binkowski
 TELEPHONE (904)563-4485

OPERATING STATUS

1. UNIT NAME: CRYSTAL RIVER UNIT 3
2. REPORTING PERIOD: November 1-30, 1989
3. LICENSED THERMAL POWER (MWt): 2544
4. NAMEPLATE RATING (GROSS MWe): 890
5. DESIGN ELECTRICAL RATING (Net MWe): 825
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 860
7. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 821
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:

NOTES:

N/A

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWe): 516 MWe
10. REASONS FOR RESTRICTIONS, IF ANY: Control Rod 3-2 became unlatched and inserted into the core causing an automatic runback to 60% power.

	T/IS MONTH	YR. TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	<u>720.0</u>	<u>8016.0</u>	<u>117,504.0</u>
12. NUMBER OF HOURS REACTOR WAS CRITICAL	<u>720.0</u>	<u>3581.1</u>	<u>70,364.4</u>
13. REACTOR RESERVE SHUTDOWN HOURS	<u>0.0</u>	<u>0.0</u>	<u>1,280.6</u>
14. HOURS GENERATOR ON-LINE	<u>713.3</u>	<u>3508.7</u>	<u>68,902.1</u>
15. UNIT RESERVE SHUTDOWN HOURS	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. GROSS THERMAL ENERGY GENERATED (MWH)	<u>1,801,896</u>	<u>7,672,951.0</u>	<u>155,189,915.0</u>
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>580,930.0</u>	<u>2,589,802.0</u>	<u>53,327,577.0</u>
18. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>552,530.0</u>	<u>2,456,750.0</u>	<u>50,358,387.0</u>
19. UNIT SERVICE FACTOR	<u>99.1%</u>	<u>43.8%</u>	<u>61.8%</u>
20. UNIT AVAILABILITY FACTOR	<u>99.1%</u>	<u>43.8%</u>	<u>61.8%</u>
21. UNIT CAPACITY FACTOR (Using MDC net)	<u>93.5%</u>	<u>37.3%</u>	<u>56.2%</u>
22. UNIT CAPACITY FACTOR (Using DER net)	<u>93.0%</u>	<u>37.1%</u>	<u>54.7%</u>
23. UNIT FORCED OUTAGE RATE	<u>0.9%</u>	<u>32.1%</u>	<u>21.7%</u>

24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (Type, Date, and Duration of Each):

Refueling Outage VII; start 3/14/89, duration of 74 days.

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: 11/1/89
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):

	FORECAST	ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-302
 UNIT FLCRP-3
 DATE 12-5-89
 COMPLETED BY J. Binkowski
 TELEPHONE (904) 563-4485

MONTH NOVEMBER

DAY	AVERAGE DAILY POWER LEVEL (MWE-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>327</u>	17	<u>803</u>
2	<u>752</u>	18	<u>786</u>
3	<u>803</u>	19	<u>786</u>
4	<u>800</u>	20	<u>833</u>
5	<u>814</u>	21	<u>785</u>
6	<u>795</u>	22	<u>834</u>
7	<u>805</u>	23	<u>779</u>
8	<u>811</u>	24	<u>809</u>
9	<u>808</u>	25	<u>782</u>
10	<u>784</u>	26	<u>590</u>
11	<u>801</u>	27	<u>679</u>
12	<u>803</u>	28	<u>810</u>
13	<u>808</u>	29	<u>799</u>
14	<u>807</u>	30	<u>626</u>
15	<u>796</u>	31	<u> </u>
16	<u>806</u>		

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE 12-5-89
COMPLETED BY Scot Stewart
TELEPHONE (904) 795-6486

REPORT MONTH NOVEMBER

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
89-11	891027	F	6.7	D	4	89-037-00	JD	INSTRU	The plant was taken off-line to replace instrumentation in the High Pressure Injection Cooling System following concerns regarding the Emergency Core Cooling System.
89-12	891125	F	0.0	A	5	N/A	HC	HTEXCH	Reduced load to approximately 72% power to locate and repair three leaking tubes in the main condenser.
89-13	891130	F	0.0	A	5	N/A	RB	CRDRVE	Automatic run back to less than 60% power per Technical Specifications when control rod 3-2 became unlatched and inserted into the core.

¹
 F- Forced
 S- Scheduled

²
Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
Method
 1-Manual
 2-Manual Scram
 3-Auto Scram
 4-Continued
 5-Reduced load
 9-Other

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

MONTHLY OPERATIONAL SUMMARY STATEMENT

DOCKET NO.	<u>50-302</u>
UNIT	<u>FLCRP-3</u>
DATE	<u>12-5-89</u>
COMPLETED BY	<u>J. Binkowski</u>
TELEPHONE	<u>(904) 563-4485</u>

MONTH NOVEMBER

SUMMARY STATEMENT:

The plant returned to service at 06:40 on November 1, 1989 ending the High Pressure Injection Flow Indicator outage. The unit reduced load during the month to repair a condenser salt leak and repair a feedwater leak on the Feedwater Heater 5B. On November 30, 1989 the plant experienced an automatic runback to less than 60% power when a control rod was inserted into the core.