



CHARLES CENTER • P.O. BOX 1475 • BALTIMORE, MARYLAND 21203

LEON B. RUSSELL

MANAGER
CALVERT CLIFFS NUCLEAR POWER PLANT DEPARTMENT

December 12, 1989

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Technical Specification 3.7.11.1.c. Special Report

On December 11, 1989 at 1400 hours it was discovered that fire protection valves 653 and 413 had not been included in Surveillance STP M-693-0 which satisfies Technical Specification Requirement 4.7.11.1.1.e. As a result it could not be shown that all valves in the flow path were operable as required by Technical Specification 3.7.11.1.c. Valve 653 was tested and found operable by performing a complete cycle test at 1420 hours on December 11, 1989. Valve 413 was tested and found operable by performing a complete cycle test at 1250 hours on December 12, 1989. Both valves were found in the open position. There was no effect on plant operation. A 24-hour telephone report was made per Technical Specification 3.7.11.1, Action Statement b. This is the follow-up letter within one business day required by Action Statement b.2.b.

Should you have any further questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

LBR/WPM/dmb

Attachment

cc: D. A. Brune, Esquire
J. E. Silberg, Esquire
R. A. Capra, NRC
S. A. McNeil, NRC
W. T. Russell, NRC
J. E. Beall, NRC
T. Magette, DNR

8912200237 891212
PDR ADOCK 05000317
S PNU

JE22
1/0