



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VERMONT YANKEE NUCLEAR POWER CORPORATION

DOCKET NO. 50-271

VERMONT YANKEE NUCLEAR POWER STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 117
License No. DPR-28

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Vermont Yankee Nuclear Power Corporation (the licensee) dated October 16, 1989 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-28 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 117 are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Richard H. Wessman
Richard H. Wessman, Director
Project Directorate I-3
Division of Reactor Projects I/11
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 8, 1989

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

15/
Richard H. Wessman, Director
Project Directorate I-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 8, 1989

OFC	: PDI-3/PA	: PDI-3/LA	: OGC	: PDI-3/PA	:	:	:
NAME	: MBairtile	: MRushbrook	:	: RHWessman	:	:	:
DATE	: 11/2/89	: 11/2/89	: 11/14/89	: 11/2/89	:	:	:

OFFICIAL RECORD COPY

AMENDMENT NO. 117 TO DPR-38 VERMONT YANKEE NUCLEAR POWER STATION DATED December 8, 1999

DISTRIBUTION:

Docket File 50-271

NRC PDP

Local PDR

PDI-3 Reading

S. Varga

B. Boger

M. Rushbrook

M. Fairtile

R. Wessman

OGC

Dennis Hagan

E. Jordan

B. Grimes

G. Hill (4)

Wanda Jones - P-522 Phillips Building

J. Calvo

ACRS (10)

GPA/PA - 2G5 OWFN

ARM/LFMB

J. Johnson, Region 3

C. McCracken

D. P. Notley

ATTACHMENT TO LICENSE AMENDMENT NO. 17

FACILITY OPERATING LICENSE NO. DPR-28

DOCKET NO. 50-271

Replace the following page of the Appendix A Technical Specifications with the attached page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

Remove

187-g

Insert

187-o

3.13 LIMITING CONDITIONS FOR OPERATION

2. From and after the date that the CO₂ system in the cable vault or a switchgear room is inoperable, within one hour a fire watch shall be established to inspect the location at least once every hour, provided that the fire detection system is operable in accordance with 3.13.A. If the fire detection system is also inoperable, within one hour a continuous fire watch shall be established with backup fire suppression equipment. Restore the CO₂ system to operable status within 14 days or submit a report within the next 30 days to the Commission as specified in 6.7.C.2 outlining the cause of inoperability and the plans for restoring the CO₂ system to operable status.
3. From and after the date that the CO₂ system in the diesel fire pump day tank room is inoperable, within one hour a fire watch shall be established to inspect the location at least once every hour. Restore the system to operable status within 14 days or submit a report within the next 30 days to the Commission as specified in 6.7.C.2 outlining the cause of inoperability and the plans for restoring the system to operable status.

E. Vital Fire Barrier Penetration Fire Seals

1. Except as specified in Specification 3.13.E.2 below, vital fire barrier penetration seals protecting the Reactor Building, Control Room Building, and Diesel Generator Rooms shall be intact.
2. From and after the date a vital fire barrier penetration fire seal is not intact, a continuous fire watch shall be established on at least one side of the affected penetration within 1 hour.

F. Sprinkler Systems

1. Except as specified in Specification 3.13.F.2 below, those sprinkler systems listed in Table 3.13.F.1 shall be operable whenever equipment in the area protected by those sprinklers is required to be operable.

4.13 SURVEILLANCE REQUIREMENTS

- b. At least once per 18 months be verifying that the system, including associated ventilation dampers, will actuate automatically to a simulated actuation signal.
- c. At least once per operating cycle a flow path test shall be performed to verify flow through each nozzle.

E. Vital Fire Barrier Penetration Fire Seals

1. Vital fire barrier penetration seals shall be verified to be functional by visual inspection at least once per operating cycle and following any repair.

F. Sprinkler Systems

1. Each of the sprinkler systems specified in Table 3.13.F.1 shall be demonstrated operable:
 - a. At least once per 12 months by cycling each testable valve in the flow path through at least one complete cycle of full travel.
 - b. At least once each month by verifying each valve in the flow path is in its correct position. (For electrically supervised valves, adequate verification is a visual check of electrical indication.)