

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, October 2, 2019

Work Order No.: NRC-0619

Pages 1-37

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

667TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

WEDNESDAY

OCTOBER 2, 2019

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2D10, 11545 Rockville Pike, at 1:00 p.m., Peter  
Riccardella, Chairman, presiding.

COMMITTEE MEMBERS:

PETER RICCARDELLA, Chairman

DENNIS BLEY, Member

CHARLES H. BROWN, JR., Member

WALTER L. KIRCHNER, Member

JOSE MARCH-LEUBA, Member

DAVID PETTI, Member

JOY L. REMPE, Member

1 DESIGNATED FEDERAL OFFICIAL:

2 QUYNH NGUYEN

3 ZENA ABDULLAHI

4

5 ALSO PRESENT:

6 JAMES (ALAN) BEARD, GEH

7 YOUSEF FARAWILA, Framatome

8 JANE MARSHALL, NRR

9 JASON PAIGE, NRR

10 WALTER (SKIP) SCHUMITSCH, GEH

11 JAMES SHEA, NRO

12 ASHLEY SMITH, NRR\*

13 DANIEL TINKLER, Framatome

14

15 \*Present via telephone

16

17

18

19

20

21

22

23

24

25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CONTENTS

Page

|   |    |
|---|----|
| Opening Remarks by the ACRS             | 4  |
| Advanced Boiling Water Reactor (ABWR)   | 6  |
| Design Certification Renewal            |    |
| Framatome's Topical Report, RAMONA5 for | 34 |
| Anticipated Transient without SCRAM     |    |

## P R O C E E D I N G S

(1:03 p.m.)

CHAIRMAN RICCARDELLA: This meeting will now come to order. This is the first day of the 667th meeting of the Advisory Committee on Reactor Safeguards. I'm Pete Riccardella, Chairman of the ACRS. The ACRS was established by the Atomic Energy Act and is governed by the Federal Advisory Committee Act, FACA.

The ACRS section of the U.S. NRC public website provides information about the history of the ACRS and provides FACA-related documents, such as charter, bylaws, Federal Register notices for meetings, letter reports, and transcripts of all full and subcommittee meetings, including all slides presented at the meetings.

The Committee provides its advice on safety matters to the Commission through its publicly available letter reports. The Federal Register notice announcing this meeting was published on September 18, 2019, and provided an agenda and instructions for interested parties to provide written documents or request opportunities to address the committee, as required by FACA. In accordance with FACA, there is a designated federal official for today's meeting.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 The DFO for this meeting is Mr. Quyhn Nguyen.

2 During today's meeting, the Committee will  
3 consider the following: advanced boiling water reactor  
4 design certification renewal and Framatone's topical  
5 report, RAMONA5 for anticipated transient without  
6 SCRAM, and, three, preparation of ACRS reports.

7 There is a phone bridge line. To preclude  
8 interruption of the meeting, the phone will be placed  
9 in a listen-only mode during the presentations and  
10 committee discussions. We have received no written  
11 comments or requests to make oral statements from  
12 members of the public regarding today's session.

13 There will be an opportunity for public  
14 comment, as we have set aside ten minutes in the  
15 agenda for comments from members of the public  
16 attending or listening to our meeting. Written  
17 comments may be forwarded to Mr. Quyhn Nguyen, the  
18 designated federal official.

19 A transcript of open portions of the  
20 meeting is being kept, and it is requested that all  
21 speakers use one of the microphones, identify  
22 themselves, and speak with sufficient clarity and  
23 volume so that they can readily be heard. Also,  
24 please silence any phones or other devices to avoid  
25 interruption of the meeting. We're somewhat

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 short-handed this week, as we have two members  
2 overseas, one sick, and one not attending, but we'll  
3 have adequate coverage of the topics based on the  
4 members who are in attendance.

5 Also, I'd like to acknowledge the passing  
6 of a former ACRS member and chairman, Dr. Mario  
7 Bonaca. He served with the Committee until 2014. The  
8 first topic at the meeting is ABWR, advanced boiling  
9 water reactor design certification renewal.

10 This is the -- we've done many design  
11 certifications, but this is the first one to come up  
12 for renewal. With that, I will turn the meeting over  
13 to Jason Page, who is acting branch chief of Licensing  
14 Branch 3 in NRO. Jason.

15 MR. PAGE: Thank you. I'm just going to  
16 introduce myself again. My name is Jason Page, acting  
17 branch chief in the office of new reactors. I'll turn  
18 it over to Jim Shea. He's the PM of this activity.

19 MR. SHEA: Thanks, Jason. Again, I'm Jim  
20 Shea. Good afternoon, everyone. I appreciate the  
21 opportunity for us to present our staff review of the  
22 ABWR D.C. renewal. GEH will go first, and then the  
23 staff will follow. It will be an abbreviation of what  
24 we did before for the subcommittee. Thanks. I would  
25 like to turn it back over the Chairman.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. BEARD: Good afternoon. My name is  
2 Alan Beard. I'm with GE-Hitachi Nuclear Energy. With  
3 me is Walter "Skip" Schumitsch. He's the program  
4 manager for this effort to renew our certification for  
5 the ABWR.

6 We're just going to very quickly go over  
7 what we've done as part of the renewal process. Just  
8 a quick overview of what the ABWR is, for those of you  
9 who are not real familiar with it, a brief discussion  
10 of the timeline that we've been through through the  
11 renewal effort, the scope of what we did during that  
12 renewal effort, and then just a real quick talk about  
13 some of the major design changes that we made as part  
14 of that process.

15 ABWR was first built and operated in  
16 Japan, at the Kashiwazaki-Kariwa site. Units 6 and 7  
17 are both -- were in operation, are currently suspended  
18 in operation because of the events of the tsunami, but  
19 there are plans to bring those back online. Japan has  
20 three additional ABWRs that were operating prior to  
21 the tsunami. As far as we know, there are plans to  
22 bring those back online. Additional two are under  
23 construction in Japan, and then two under construction  
24 in Taiwan, although the Taiwan construction effort is  
25 currently suspended. ABWR is licensed in Japan and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Taiwan, certified in the U.S., and underwent the  
2 approval process, GDA approval process in the United  
3 Kingdom, so it's had a lot of review.

4 CHAIRMAN RICCARDELLA: Did the plants at  
5 KK, did they operate before the tsunami?

6 MR. BEARD: Oh, yes, they had about 25  
7 years of operation between the two of them.

8 CHAIRMAN RICCARDELLA: Twenty-five years.

9 MR. BEARD: Yes. I would also note that  
10 the ABWR, at least in our opinion, is the first of the  
11 Generation 3 reactors that has been in operation.

12 MEMBER REMPE: Out of curiosity, because  
13 I missed your subcommittee meeting in -- educate me.  
14 The ones in Japan and other ones that are up and were  
15 running, do they operate in the MELLLA+ region or  
16 MELLLA region? Do they just use control rods for  
17 power changes, or do they use flow, also?

18 CHAIRMAN RICCARDELLA: Do you know?

19 MR. SCHUMITSCH: I do not -- sorry, this  
20 is Skip Schumitsch. I'm sorry; I do not know the  
21 answer to that, either.

22 MEMBER REMPE: It's probably not relevant.  
23 I just was curious. Do you know, Jose, from your work  
24 on it?

25 MEMBER MARCH-LEUBA: From the original

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 reviews of ABWR, they do use flow for power control,  
2 yes.

3 MEMBER REMPE: So they never have gone to  
4 any sort of expanded operating domain, then?

5 MEMBER MARCH-LEUBA: I suspect it's the  
6 same with ABWRs and BWRs -- I don't know -- that they  
7 have such high power density that there's no need to  
8 go to MELLLA+. They're already a DPU when they were  
9 licensed.

10 MEMBER REMPE: Okay, thank you.

11 MR. BEARD: Would also like to note --  
12 it's not on this slide, but the ABWR --

13 MR. SCHUMITSCH: I'm sorry; we got a text  
14 from somebody that's listening. The answer is not  
15 MELLLA+. Thank you, David.

16 MR. BEARD: -- to note that the ABWR was  
17 the first plant that underwent the Part 52 process and  
18 was issued the No. 1 certification, Appendix A of Part  
19 52. That was back in May of 1997. I will note,  
20 there's a picture over on the wall there. Our initial  
21 meetings with the ACRS during that ABWR certification  
22 were actually held down in the green building, off of  
23 Norfolk Avenue, in Bethesda, when the ACRS was still  
24 meeting down there. There are names on the table  
25 there of people that were actually part of the review

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 initially. Then one other note, just kind of a  
2 historical interest.

3 We actually submitted the ABWR under Part  
4 50, originally, seeking a standard safety analysis  
5 report, then Part 52 became promulgated, became a  
6 regulation, and we chose to take advantage of that, so  
7 we switched our application over to a Part 52  
8 application.

9 Just like to note that the ABWR was a  
10 collaborative effort. It was developed in between the  
11 efforts of GE, Tokyo Electric Power Company, Hitachi,  
12 and Toshiba. As I noted before, the first plants that  
13 were built and operated, Kashiwazaki-Kariwa Units 6  
14 and 7.

15 We'll note that both of those plants were  
16 built on time and ahead of schedule and under budget.  
17 It can be done. The Japanese have a very good way of  
18 doing that. Hopefully, we can learn some lessons from  
19 them. Primary drivers for the ABWR, at least from  
20 GEH's perspective, were we wanted to enhance the  
21 safety, and we wanted to improve the constructability  
22 and maintainability, as well. Some of the major  
23 design enhancements we made, we have an improved  
24 containment design. We went to pretty much a right  
25 cylinder design that's kind of a combination of our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Mark II and our Mark III pressure suppression  
2 containments.

3 It also is a reinforced concrete  
4 containment vessel with a steel leakage liner. It is  
5 a relatively compact reactor building. The emergency  
6 diesel generators are actually in the reactor  
7 building, so they moved a lot of equipment into a  
8 pretty small footprint.

9 We'll note that with the inclusion of the  
10 reactor internal pumps and the removal of our external  
11 recirculation loops, we were able to show, for all our  
12 design basis accidents, that we never have core  
13 uncovering.

14 So there's always water over the core,  
15 very little heat up when you do go into a transient  
16 situation. Although our reference design was based on  
17 the Japanese design at K6 and K7, our probabilistic  
18 risk assessment people led us to include some  
19 additional items in the design. Here's a list of  
20 several of those that we did. The reason I'm noting  
21 this is we do believe that these are -- if they hadn't  
22 been in the design, probably would have been added to  
23 address the post-Fukushima tsunami event. I'd like to  
24 point out that we were being proactive. We were  
25 looking at the design to identify some safety

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 enhancements. This is a list of those.

2 The first of those is we have an  
3 air-cooled combustion turbine generator that serves as  
4 an alternate AC power source. For the certification,  
5 the ABWR is classified as an alternate AC power plant  
6 for the station blackout rule. Having said that, we  
7 do have a reactor core isolation cooling pump, which  
8 also provides us with an AC independent means of  
9 cooling the core in the event of a station blackout.

10 We have what we call the AC independent  
11 water addition system, ACIWA. Very fancy way of  
12 saying we tied the fire water into several of our  
13 safety-related systems so that if we don't have other  
14 means of injecting water, we can use the fire water  
15 storage tanks and the fire water pumps to pump water  
16 into the reactor pressure vessel, into the  
17 containment, and into the spent fuel pool.

18 We also had a means of passively  
19 addressing cooling of core debris that would have  
20 melted through the bottom of the vessel in the event  
21 of a severe accident. This used thermally-actuated  
22 valves, kind of like what you have in the overhead  
23 here. What they did was they opened up and they  
24 allowed water from the suppression pool to float over  
25 to the debris that would have relocated down to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 bottom of the drywall.

2 Then finally, containment overpressure  
3 protection system, we did engineer in a leakage path  
4 or a vent path. That is from the suppression pool air  
5 space, so that we do credit scrubbing of any release.  
6 I believe we had a decontamination factor of ten that  
7 we credited for gasses and about 100 for particulate  
8 matter. That just allows that excess pressure to vent  
9 out to the atmosphere.

10 MEMBER REMPE: Is it a multi-unit  
11 application?

12 MR. BEARD: No.

13 MEMBER REMPE: It's just a single --

14 MR. BEARD: Following the EPRI guidance,  
15 it was designed as a single-unit standalone plant.

16 MEMBER REMPE: Okay.

17 MR. BEARD: So there's no sharing of  
18 systems.

19 MEMBER REMPE: I was going to ask about  
20 the standby gas treatment system, but I suppose, then,  
21 that doesn't come up in the application.

22 MR. BEARD: Quickly, the reactor core  
23 power of 3,926, that is kind of an edifice from Japan.  
24 They license on electrical output. The electrical  
25 output, when they backed it out, we got 3,926

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 megawatts of thermal. Eight hundred and seventy-two  
2 fuel bundles, very similar to our operating fleet,  
3 using the latest and greatest technology, 12 feet in  
4 length, 3.7 meters in length.

5 We characterize it as a moderate power  
6 density, 51 kilowatts per liter. To control that, we  
7 have 205 control blades. We did introduce -- one of  
8 the other major design enhancements with the ABWR is  
9 what we call our fine motion control rod drive. Prior  
10 to that, we actually had what we called a locking  
11 piston.

12 It was purely hydraulic insertion and  
13 withdrawal of the control blades, six-inch increments.  
14 With the fine motion control rod drives, we went to an  
15 electric motor that drives the lead screw. We now get  
16 five eighths of an inch increments for each notch  
17 position.

18 We also maintained the ability to  
19 hydraulically SCRAM. We actually have diverse means  
20 of inserting control blades. We can do it either  
21 hydraulically, which is the preferred safety-related  
22 means, or if that should fail for whatever means, we  
23 can also drive them in electrically.

24 MEMBER BLEY: How long does that take?

25 MR. BEARD: Hydraulic --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER BLEY: No, the --

2 MR. BEARD: To put this in perspective,  
3 the hydraulic SCRAM, less than two seconds, the  
4 electric drive in is a little less than two minutes  
5 from full out.

6 MEMBER MARCH-LEUBA: Since we are curious,  
7 on the control room, do you still use the CO248  
8 display for control rod, or do you use inches?

9 MR. BEARD: I actually don't know. I have  
10 not been in the control room.

11 MEMBER MARCH-LEUBA: It's likely you used  
12 the CO248.

13 MR. BEARD: Yes. I'm sure we're going to  
14 get an answer. This is just an overall flow chart of  
15 the ABWR. I won't spend a lot of time talking about  
16 it, but given the power rating, a single high-pressure  
17 turbine, followed by three low-pressure turbines in  
18 series, so pretty standard conventional side of the  
19 plant. On the nuclear side, you see a pressure  
20 suppression containment denoted there, and then I'll  
21 talk about a little bit of the safety-related systems  
22 on the next slide. The approach for the ABWR was we  
23 had three divisions of safety related equipment.

24 They were operated by four divisions of  
25 instrumentation and control logic that was making the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 decisions, but each of those three divisions has both  
2 a high-pressure injection capability, as well as a  
3 low-pressure injection capability.

4 One of those high-pressure injection  
5 capabilities is the reactor core isolation cooling  
6 turbine and pump that I spoke of, which provides us  
7 with an AC independent means. The three high-pressure  
8 systems are sufficient to inject enough cooling water  
9 to maintain the core cool in the event of -- should we  
10 have an isolation event.

11 Then the low-pressure systems inject  
12 plenty of water to handle all the break scenarios. As  
13 I said before, design basis accident point, we never  
14 have core uncovering. In the event that we go beyond  
15 design basis and we only have a single pump injecting,  
16 any one of our five motor-driven pumps is sufficient  
17 to keep enough water into the core to maintain  
18 adequate cooling.

19 CHAIRMAN RICCARDELLA: No recirculation,  
20 though, internal pumps.

21 MR. BEARD: Yes, reactor internal pumps.  
22 That's these yellow cans hanging down here. There are  
23 ten of them. They're about 700 kW each. Excuse me --  
24 yes, 700 kW each. The next picture's just that of an  
25 artist's rendering of what this plant looks like. You

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 can see that the turbine structure is orientated  
2 perpendicular to the reactor building.

3 Somewhat interesting is the control  
4 building is located in between our reactor building  
5 and the turbine building here. The vast majority of  
6 the control building is actually below grade,  
7 including the main control room, itself. Timeline, I  
8 don't need to read this to you. It's there for your  
9 information.

10 It has been a relatively long and lengthy  
11 process. We've gotten through it, and we're glad to  
12 be at this final stage and hope to get good report out  
13 from the Committee today. In our original submittal  
14 to the NRC, as part of our renewal request, these are  
15 some of the items we addressed, aircraft impact,  
16 obviously a post-9/11 requirement. We did have some  
17 containment re-analysis we had to do based on some  
18 knowledge we gained from further projects. We did  
19 some selected design updates, and we also corrected a  
20 couple of errors that had been identified by GEH,  
21 again, in some of the construction projects we had  
22 going on. In addition to that, the NRC developed a  
23 list of 28 topics that they sent to us in a letter.

24 That list actually grew to 39 by the end  
25 of the renewal process, but we've worked our way

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 through all those. Anticipating the question, out of  
2 those 28 topics, there were several that GE proposed  
3 not be addressed. An example of that would be  
4 upgrading of the digital instrumentation control  
5 system.

6 As we mentioned last time we were here,  
7 because of the speed that technology continues to  
8 evolve, we felt that wasn't a worthwhile investment at  
9 this time because we did not know when our next  
10 potential customer would be and that we would upgrade  
11 at that time as part of the license application.

12 MEMBER REMPE: I apologize if this was  
13 brought up during the subcommittee meeting, but with  
14 the errors identified by GEH, did you look to  
15 understand why those errors occurred and provide  
16 yourself some sort of assurance that there wouldn't be  
17 other errors?

18 MR. BEARD: Yes. Following all the GE  
19 practices, we go through a corrective action program  
20 that we look at what are the root causes for these  
21 things. An example of that, that I talk about here  
22 later -- I'll go ahead and do it now -- is for the  
23 containment overpressure protection system, we did not  
24 have exact pipe routing at the time we were submitting  
25 this design.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           We had some design assumptions on what the  
2 pressure losses would be in that system. When we  
3 finally got around to designing one of those for one  
4 of our projects, we determined that we were  
5 non-conservative with some of our design assumptions  
6 for that, so went back and corrected it, indicated  
7 what prior diameters were needed and how many elbows  
8 and flow restrictions we had in there in order to  
9 maintain the assumptions we had for the safety  
10 analysis.

11           MEMBER REMPE: You looked for any other  
12 possible situations similar to that and didn't find  
13 any.

14           MR. BEARD: Correct.

15           MEMBER REMPE: Sounds good. Thanks.

16           MR. BEARD: I keep forgetting I have to  
17 drive myself. Some of the significant design changes  
18 that we did incorporate listed here. Post-Fukushima  
19 1, we did add two safety-related wide-range spent fuel  
20 level monitors. That gives a time to main  
21 reflectometry concept. We did enhance our ECCS  
22 suction strainers to address continuing concerns about  
23 plugging the strainers in the event of a LOCA event.

24           We had a new fuel vault in the original  
25 design, just a big hole in the operating floor on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 refuel floor, where we would put -- initial concept,  
2 when you brought the new fuel on site, inspected it,  
3 you would put it in there and store it. Most  
4 utilities, I think maybe all utilities, have stopped  
5 doing that.

6 They pull the fuel out; they inspect it;  
7 and they go ahead and put a channel on it and put it  
8 in the spent fuel pool, so it is ready for that, which  
9 eliminates a handling step and the potential to damage  
10 the fuel while doing that.

11 We did address the NRC Bulletin 2012-01  
12 dealing with the out-of-phase current issues that were  
13 identified at -- I know it was an Exelon site in the  
14 Midwest, but I can't remember the exact site. We did  
15 some design changes to our electrical distribution  
16 system to monitor and to detect an out-of-phase  
17 condition, and then to isolate the out-of-phase  
18 condition and allow the diesel generators to come on  
19 and support the necessary safety functions.

20 MEMBER BLEY: That solution's in the  
21 design cert.

22 MR. BEARD: That solution is in the  
23 renewal design cert. I would point out that we did  
24 have commitments in the initial design that one of our  
25 three safety-related divisions was to actually be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 powered from a different offsite source. We had  
2 requirements for two offsite sources.

3 We had a commitment that at least one of  
4 the three had to be on the auxiliary site. Fukushima  
5 Recommendation 4.2 mitigation strategies. We included  
6 several items to do that. We enhanced our fire  
7 protection system connections. We originally only had  
8 one external connection. We added a second external  
9 connection on a different face of the building, just  
10 to address the possibility that debris might have  
11 blocked access to the original thing. We did that.

12 MEMBER BLEY: A couple years ago, we had  
13 a presentation from NEI and the owners' group on the  
14 PWR strategies for using FLEX and other systems. Is  
15 that part of the design cert, or is that going to be  
16 -- the procedures for using all of that going to be  
17 done later?

18 MR. BEARD: Anything that was  
19 administrative or procedural in nature was deferred  
20 until we had an applicant for license.

21 MEMBER BLEY: Makes sense. Okay.

22 MR. BEARD: The change to the containment  
23 overprotection system I talked about already. Then we  
24 included some other changes to enhance the capability  
25 to implement the FLEX strategy, as outlined by NEI.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 That completes our prepared comments. I'm prepared to  
2 answer any other questions.

3 MEMBER KIRCHNER: This is, perhaps, a  
4 late-in-the-game detailed question. Where are your  
5 FLEX connections to the fire mains and such?

6 MR. BEARD: Let me see.

7 MEMBER KIRCHNER: Are they between the  
8 control room and the reactor building? It's a leading  
9 question because I'm looking at your layout and I just  
10 noticed -- the control room's in the middle.

11 MR. BEARD: The control room's here, yes.

12 MEMBER KIRCHNER: It's in a hardened  
13 building, right?

14 MR. BEARD: It's in a reinforced concrete  
15 --

16 MEMBER KIRCHNER: But you've got your  
17 steam lines running right over, right?

18 MR. BEARD: Yes.

19 MEMBER KIRCHNER: And feedwater lines.

20 MR. BEARD: Mm-hmm.

21 MEMBER KIRCHNER: Are the FLEX connections  
22 into between those two buildings, or are they  
23 somewhere else?

24 MR. BEARD: We have two sets of FLEX  
25 connections. There's one over on what I call the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 south wall.

2 MEMBER KIRCHNER: Okay, you answered my  
3 question.

4 MR. BEARD: Then there's another one over  
5 on this wall.

6 PARTICIPANT: Which wall?

7 MR. BEARD: This east wall. North is this  
8 side of the building right here, east, south, west.

9 PARTICIPANT: Thank you.

10 MR. BEARD: Mm-hm.

11 MEMBER MARCH-LEUBA: You mentioned there  
12 was a connection to add water for a very long-term --

13 MR. BEARD: Yes.

14 MEMBER MARCH-LEUBA: Where would that come  
15 from?

16 MR. BEARD: We'd use the fire water  
17 system. We have two 500,000-gallon tanks.

18 (Simultaneous speaking.)

19 MEMBER MARCH-LEUBA: So you just refill  
20 the fire tanks outside the containment, and then use  
21 that piping to come in?

22 MR. BEARD: We use the fire water system  
23 to connect to the residual heat removal system, and  
24 then the pipes within the residual heat removal system  
25 give us the capability to flow water either to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 containment, whether that be the dry well or the wet  
2 well, into the pressure vessel, itself, or into the  
3 spent fuel pool.

4 MEMBER BLEY: Did you build in any special  
5 filtering for that water or just --

6 MR. BEARD: No, we figured, at that point,  
7 that --

8 PARTICIPANT: Water's water.

9 MR. BEARD: Water's water. It's not  
10 salted water. It's clean water, but it's not --

11 MEMBER MARCH-LEUBA: You never know what.

12 MR. BEARD: It's not demineralized or  
13 anything like that. The answer back to the question  
14 about rod position indication, it's 0 to 200.

15 MEMBER MARCH-LEUBA: Two hundred.

16 PARTICIPANT: Two hundred steps.

17 MEMBER MARCH-LEUBA: You have to have some  
18 additional training for operators. I would have gone  
19 to 100 percent, maybe.

20 MR. BEARD: Any additional questions? If  
21 not, we thank you for your time and interest.

22 CHAIRMAN RICCARDELLA: Okay, with that,  
23 we'll bring up the staff for their presentation.

24 MR. SHEA: Good afternoon. My name is  
25 James Shea. I'm the staff project manager for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ABWR DC renewal. Today, the staff will present an  
2 overview of the GEH design certification renewal  
3 review, and we'll review the ABWR DC renewal upcoming  
4 schedule activities and rulemaking.

5 As mentioned before, the ABWR is the only  
6 Generation 3 nuclear plant in operation today, not in  
7 the United States, at least yet, anyway. The ABWR was  
8 initially certified in 10 CFR Part 52, Appendix A, on  
9 May 12, 1997. The ABWR DC renewal application was  
10 submitted on December 7, 2010. In a July 20, 2012  
11 letter, the NRC staff identified proposed DCD design  
12 changes that the staff believes should be considered  
13 for renewal. GEH provided, Revision 6 of the DCD of  
14 the ABWR, on February 19, 2016, in response to the  
15 staff-requested design changes, and then the staff  
16 completed its supplemental SER at the end of June of  
17 this year. GEH submitted the ABWR DC renewal  
18 application under Subpart B, standard design  
19 certifications of 10 CFR Part 52.

20 Scope of the ABWR DC renewal included a  
21 total of 39 design items proposed by staff or  
22 submitted by GEH. We talked about the 28 -- there was  
23 28 specific staff items that were requested. Out of  
24 those, 22 were accepted by GEH, and six items were --  
25 GEH wrote back to us that they thought they had

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 already covered. We re-reviewed those. Then in a  
2 February 2018 letter, we agreed with that assessment  
3 and wrote an additional assessment from the staff side  
4 in that letter.

5 MEMBER MARCH-LEUBA: How many of those  
6 were related to the aircraft impact analysis, just the  
7 main major analysis?

8 MR. SHEA: None of those. You mean of the  
9 28 design items?

10 MEMBER MARCH-LEUBA: Mm-hm.

11 MR. SHEA: Actually, aircraft impact was  
12 submitted originally. That's one of the -- if you  
13 look at that 11 additional design items, it was  
14 actually submitted with the initial renewal.

15 MEMBER MARCH-LEUBA: Okay, so it wasn't  
16 additional.

17 MR. SHEA: As part of the rule of Part 52,  
18 it required AIA, if it wasn't already completed,  
19 which, in this case, prior to its original  
20 certification, the AIA rule had not been promulgated;  
21 therefore, as part of this rule, it is required to  
22 submit an AIA.

23 MEMBER MARCH-LEUBA: I understand from the  
24 subcommittee that was one of the main efforts.

25 MR. SHEA: That was, yes. It was one of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the main efforts. That's why I wanted -- my one  
2 particular staff member who worked on that, that was  
3 probably the most significant item that was addressed  
4 as part of the renewal.

5 Some of the other key significant renewal  
6 design changes included ECCS suction strainers,  
7 Fukushima design enhancements that GEH talked about.  
8 That included -- they talked about the AC independent  
9 water addition, and also connections to enable offsite  
10 sources to come in and connect to a fire truck or  
11 other water sources, in order to -- for a COL  
12 applicant, essentially, to meet the mitty bitty rule  
13 (phonetic), included AC connections offsite -- again,  
14 offsite, non-safety-related electrical generator could  
15 be brought onsite and connected to safety-related 1E  
16 electrical components, in order to mitigate a beyond  
17 design basis event, and EP enhancements mostly related  
18 to staffing, and also fuel pool instrumentation.

19 We just talked about two sets of fuel pool  
20 safety-related instrumentation, redundant. I think we  
21 mentioned it at the subcommittee meeting. They're  
22 backed by the AC and DC batteries that are backup,  
23 those two safety-related instruments. The ABWR AIA,  
24 mentioned that. That was submitted with the original  
25 renewal.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The PCT modification, that came up very  
2 late in the game, actually, probably toward the end of  
3 our review, when the staff noticed that PCT should  
4 have been updated for the renewal. Then GEH went back  
5 and did some changes based on 50.46 reporting  
6 requirements and made some adjustments to their  
7 evaluation model, and then resubmitted. Finally, a  
8 containment overpressure protection system, which they  
9 talked about, also, as being -- that came in, again,  
10 from GEH, originally, because they found an error in  
11 their analysis. Just as an example, we used the AIA  
12 as an example of the 39 items that we addressed, in  
13 this particular case, the SER Supplement, Chapter 19,  
14 Section 19.5, Aircraft Impact Assessment.

15           GEH submitted its assessment, again,  
16 initially, with the renewal. Changes included  
17 enhanced fire protection design features and ITAAC  
18 that ensures penetrations are not installed on the  
19 control building roof without an AIA cognizant  
20 engineer review.

21           In short, GE didn't change any parameters,  
22 as far as the design, the walls, the locations, the  
23 buildings, essentially took the NEI template for doing  
24 AIA and applied it and verified that the aircraft  
25 impact would not adversely impact the plant or meet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the parameters for ensuring safety of the plant.

2 Next, what we have is scheduled -- after  
3 this meeting, we do have our rulemaking that we'll --  
4 we already had some preliminary rulemaking meetings.  
5 We'll kick that off, essentially, after this Phase 3  
6 of the ACRS review. That schedule would include about  
7 a year to 14 months for rulemaking. That will go in  
8 parallel with the final SER that the staff will work  
9 on and have published for the rule effort, which would  
10 be Phase 4, FSER, with no open items. With that, I  
11 just want to summarize everything. The staff  
12 evaluated the GEH-proposed design updates to the ABWR  
13 and validated the findings in NUREG-1503 and  
14 NUREG-1503, Supplement 1.

15 This ABWR DC renewal safety evaluation  
16 report, Supplement 2 to the NUREG-1503, documents the  
17 NRC staff's review of GEH's application to renew the  
18 ABWR DC. Except as modified the supplement, the  
19 findings made in NUREG-1503 and its Supplement 1  
20 remain in full effect.

21 The NRC staff made its safety  
22 determinations on specific modifications and  
23 amendments proposed by GEH as part of the DC renewal  
24 application. These modifications and amendments were  
25 found to meet the applicable regulatory requirements

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and are therefore accepted. That ends the staff  
2 presentation, unless there's any questions.

3 CHAIRMAN RICCARDELLA: Thank you. Are  
4 there any --

5 MEMBER KIRCHNER: I'm sorry, go ahead.

6 CHAIRMAN RICCARDELLA: Are there any  
7 further questions from the Committee?

8 MEMBER KIRCHNER: Yes, Jim, just for the  
9 record, what is the expected time for the staff to  
10 complete a rulemaking on something like a DC renewal?

11 MR. SHEA: I think the goal that we have  
12 -- currently, we are planning to have a direct final  
13 rule, so it won't go out for the normal rulemaking  
14 process. That should shorten the process. What we  
15 have in planning phases, right now, is expected about  
16 12 to 14 months.

17 MEMBER KIRCHNER: Why does it take so  
18 long? It's not a safety question; it's a process  
19 question.

20 MR. SHEA: Part of the fact that we still  
21 have Phase 4, the FSER. Step 1 is GEH will submit us  
22 their Revision 7 to the DCD, which they haven't done  
23 yet. They're still going through their final  
24 validation process on that. Once they submit that to  
25 us, we use that as the basis to go back and look at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 all the SERs that we completed that were based on  
2 markups of Rev. 6.

3 For example, AIA, we had some RAIs  
4 following the Revision 6 to the DCD that were then  
5 addressed and included markups, which will now be  
6 incorporated into Revision 7. At that point, the  
7 staff -- we will verify all those changes were made in  
8 Revision 7. That's going to take some time, probably  
9 until the end of the year. Right now, the schedule  
10 has us completing the FSER in -- I think we have it in  
11 March 2020.

12 MEMBER KIRCHNER: Yes, that's what you  
13 have on Slide 9.

14 MR. SHEA: That all will depend on when we  
15 get the DCD. It should only take us -- in this  
16 particular case, it should only take us a few months  
17 to complete the FSER process. You need the FSER and  
18 the final DCD to actually submit it as a rule. We've  
19 got to have those two main administrative pieces done  
20 before we can actually go to final rule.

21 MEMBER KIRCHNER: I should have framed my  
22 question differently. When you get done with the  
23 final SER with no open items in March of next year,  
24 which is your target, how much time, then, is  
25 allocated for the rulemaking, itself?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SHEA: Like I said, that can be done  
2 -- we should be kicking the rule off within a month or  
3 so. That would take us, from that point, 12 to 14  
4 months. That includes, in parallel, us completing the  
5 FSER. That's part of that process. It wouldn't be in  
6 addition.

7 MEMBER KIRCHNER: Thank you.

8 MR. SHEA: Like I said, if we can get the  
9 DCD back to us even before -- I think we're scheduled  
10 to get it before the end of this year, the final DCD,  
11 we can then validate. Then this process could take  
12 shorter than our goal. That's what we would strive to  
13 do.

14 CHAIRMAN RICCARDELLA: Any other questions  
15 from members? Let's check for members of the public.  
16 Is there anybody in the room from the public who would  
17 like to make a comment on this?

18 Not seeing any, we will open the phone  
19 line and accept questions from anybody who happens to  
20 be on the line. Are there any members of the public  
21 out there who would like to make a comment on the ABWR  
22 design certification renewal? If so, please state  
23 your name and make your comments.

24 Not hearing any, we'll proceed. I think  
25 -- we're finished with the presentations. We do have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a draft letter, which --

2 MR. NGUYEN: Chairman, I guess I recommend  
3 a break, so I can make copies while we have the  
4 licensee here.

5 CHAIRMAN RICCARDELLA: Okay, we'll take a  
6 break until 2:00 p.m., 15 minutes, and then we will --  
7 okay, we're off the record until the next topic, which  
8 is at 2:30.

9 (Whereupon, the above-entitled matter went  
10 off the record at 1:43 p.m. and resumed at 2:30 p.m.)

11 CHAIRMAN RICCARDELLA: Next topic on the  
12 agenda is Framatome's topical report on RAMONA5 for  
13 anticipated transient without SCRAM. A portion of  
14 this meeting will be open, and then we will close the  
15 meeting for a closed session. With that, I'll ask,  
16 Jane, do you want to make a comment?

17 MS. MARSHALL: Yes, I'll make a couple of  
18 quick opening remarks. I know the ACRS subcommittee  
19 had an opportunity to review this a month or so ago.  
20 Framatome has generalized this methodology, so it can  
21 now be used at -- they generalized it to a form that  
22 can be used at any BWR currently operating in the U.S.  
23 The methodology is directly applicable to Brunswick  
24 ATRIUM-11.

25 That's scheduled to be presented to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ACRS subcommittee in November, since Brunswick  
2 proposed to use an identical analysis. The NRC staff,  
3 our contractor from Oak Ridge National Lab, and  
4 Framatome staff have demonstrated a -- have been very  
5 responsive to each other's needs. We've had an  
6 efficient and, we think, satisfactory completion of  
7 this complex review, without any challenges or delays.  
8 Thanks.

9 MEMBER MARCH-LEUBA: Framatome, you want  
10 to do some introductory remarks on the open session?  
11 Don't use any proprietary slides until we close.

12 MR. TINKLER: I guess we'll start with  
13 some introductions, here. My name is Dan Tinkler.  
14 I've been with Framatome, now, for 17 years. Fourteen  
15 of that has been working various stability methodology  
16 development projects, starting with our long-term  
17 stability solution methodology, RAMONA5 based, going  
18 up through various plant specifics, and now here,  
19 today, moving into the generic ATWS-I.

20 With me is Dr. Farawila. He has many  
21 decades of stability experience working various items,  
22 such as testing, methods development, pretty much  
23 spanning the gamut when it comes to the stability  
24 field.

25 MEMBER MARCH-LEUBA: Do you want to say

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 something on the topic of representation in open  
2 session?

3 MR. TINKLER: The generic ATWS-I  
4 methodology we're really going to present today is  
5 kind of -- it's not a new methodology. It's kind of  
6 the culmination of some plant-specific work and  
7 previous work we've done on the long-term stability  
8 solution. That's really kind of what we're going to  
9 present to you today.

10 MEMBER MARCH-LEUBA: Thank you. Mr.  
11 Chairman, at this point, I propose that we close the  
12 open session.

13 CHAIRMAN RICCARDELLA: Okay, the open  
14 session is closed. We'll now go into closed session.

15 MEMBER KIRCHNER: Jose, are we going to go  
16 closed, and then open again?

17 MEMBER MARCH-LEUBA: No, this is --

18 MEMBER KIRCHNER: Then something's  
19 missing, I would suggest. The public needs to know  
20 what's the answer. What I mean by that is has the  
21 staff review approved the topical? That should be  
22 part of the record.

23 MEMBER MARCH-LEUBA: It should. Let me  
24 give a summary. The staff has issued an SER.

25 MEMBER REMPE: Just slow down. First of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 all, are we still in the open session, or did we close  
2 it? I thought I heard the gavel bang. Are we in the  
3 open session -- the transcriber's going to have to  
4 answer this -- or are we in the closed session?

5 COURT REPORTER: We're still in open.

6 MEMBER REMPE: In addition to this, we  
7 need to allow for public comments. That's good.  
8 Sorry to interrupt.

9 MEMBER KIRCHNER: The public can't really  
10 comment until they know what the answer is. We need  
11 a summary of what was presented and what was approved.

12 MEMBER MARCH-LEUBA: The staff has  
13 reviewed the proposed methodology to calculate ATWS-I  
14 transients in BWRs, on a generic basis, and found it  
15 acceptable. That's what their SER says.

16 CHAIRMAN RICCARDELLA: With that, before  
17 we go into the closed session, we'll ask are there any  
18 members of the public in the room that would like to  
19 make a comment?

20 (No response.)

21 CHAIRMAN RICCARDELLA: Are there any  
22 members of the public on the phone line? Which I  
23 guess is open now, because Ashley's on the line.  
24 Ashley, are you there?

25 MS. SMITH: Yes, I'm still here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RICCARDELLA: Is there anybody  
2 else on the line, besides Ashley?

3 Hearing none, I assume there's nobody from  
4 the public who would like to make a comment. Is it  
5 okay for Ashley to be on the open line? What if  
6 someone else --

7 MEMBER MARCH-LEUBA: This is the closed  
8 line, right?

9 MS. MARSHALL: She'll use the closed line.  
10 She has that number now, but she's not on it yet.

11 MS. SMITH: Yes, thank you. I'll call  
12 back in.

13 CHAIRMAN RICCARDELLA: All right, very  
14 good, thank you. With that, we can close the open  
15 phone line, the public line.

16 (Whereupon, the above-entitled matter went  
17 off the record at 2:37 p.m.)

18

19

20

21

22

23

24

25



**U.S. NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

**Presentation to the ACRS Full  
Committee**

**Staff Safety Review of  
ABWR DC Renewal**

**October 2, 2019**



# **ABWR DC RENEWAL**


## **Agenda**

- ❖ Overview of the General Electric Hitachi (GEH) Advanced Boiling Water Reactor (ABWR) Design, Certification and Renewal.
  
- ❖ ABWR Design Certification (DC) Renewal Application
  - Regulatory Basis for DC Renewal
  - Design Change Items Proposed and Reviewed
  - Key Significant Design Changes
  - Staff Conclusions
  
- ❖ Schedule for the ABWR DC Renewal Activities



## Overview of the ABWR Design

- ❖ Generation III Reactor with enhanced safety features
- ❖ ABWR is a single-cycle, forced-circulation, boiling-water reactor (BWR), with a rated power of 3926 MWt
- ❖ Reactor recirculation system applying internal pumps
- ❖ Advanced Fine Motion Control Rod Drive (CRD) System
- ❖ Main Control Room (MCR) with full digital system
- ❖ Reinforced concrete containment vessel



Source- GEH "ABWR"

## ABWR DC Renewal Application Summary

- ❖ **May 1997:** Staff FSER NUREG-1503 Supplement 1 based on ABWR design control document (DCD) Revision 4.
- ❖ **May 12, 1997:** Initial ABWR DC Rule (Appendix A to Title 10, Part 52)
- ❖ **December 7, 2010:** GEH ABWR DC Renewal Application DCD Revision 5
- ❖ **July 20, 2012:** NRC staff Identified proposed changes including Fukushima Near Term Task Force Recommendations (NTTF) from SECY-12-0025
- ❖ **February 19, 2016:** GEH provided ABWR DCD Revision 6 in response to staff requested changes with GEH responses to those requests
- ❖ **June 28, 2019:** NRC staff completed Advanced Supplemental SER with no open items



## **DC Renewal Regulatory Basis**

- ❖ Regulatory Requirements for DC Renewal Applications
  - 10 CFR 52.57, Application for renewal
  - 10 CFR 52.59, Criteria for renewal
  
- ❖ GEH submitted the ABWR DC renewal application under Subpart B, "Standard Design Certifications," of 10 CFR Part 52
  - Application included the ABWR DCD and an environmental report (ER).





## ABWR DC Renewal Design Items

- ❖ **28 Design Items** Proposed by the staff for Consideration:
  - GEH accepted the changes proposed by the staff for 22 items and included the changes in the February 2016 DCD Revision 6.
  - 6 items not incorporated in revised ABWR DCD.
  
- ❖ **11 additional design items** identified at time of Renewal or during the review of the application.
  
- ❖ **39 Total Design Items Reviewed and Approved** in Supplemental SERs to NUREG-1503 or closed by letter.

# ABWR DC RENEWAL

## Key Significant Renewal Design Changes

- ECCS Suction Strainers
- Fukushima Design Enhancements
- ABWR Aircraft Impact Assessment
- PCT Modification
- COPS



- ❖ **Issue 29 -AIA Aircraft Impact Assessment:**
- ❖ **Design Change Type - Modification**

SER Supplement Chapter 19 Section 19.5 Aircraft Impact Assessment:

Submitted as part of the DC Renewal (DCD Revision 5) - ABWR DCD Tier 2, Section 19G, Revision 6, GEH "Aircraft Impact Assessment," and proposed changes to Revision 6 of the ABWR DCD.

- ✓ Enhanced Fire Protection Design Features.
- ✓ Control Building (C/B) penetrations are not installed on the C/B roof without an AIA cognizant engineer review.

The NRC staff also finds that the applicant adequately described the key design features and functional capabilities identified and credited to meet 10 CFR 50.150(b), including how the key design features meet the acceptance criteria in 10 CFR 50.150(a)(1).

## Schedule – Letter Dated 5/31/19

| Key Milestones  | Completion Date<br>Actual - A<br>Target - T |
|---|---|
| <i>Application</i>  |   |
| Received Design Certification Renewal Application   | 12/07/10 - A                                |
| <i>Acceptance Review</i>  |   |
| NRC to issue Acceptance Review Determination Letter   | 02/14/11 - A                                |
| <i>Safety Review</i>  |   |
| Phase 1 - Preliminary Supplemental Safety Evaluation Report (SER) and Requests for Additional Information | 01/21/19 - A                                |
| Phase 2 - Advanced Supplemental SER with No Open Items  | 06/28/19 - A                                |
| Phase 3 - ACRS Review of SER with No Open Items   | 10/19 - T                                   |
| Phase 4 - Final SER with No Open Items  | 03/20 - T                                   |
| <i>Rulemaking</i>   |   |
| Issue final rule  | TBD   |



## ABWR DC Renewal NRC Staff Conclusions

- ❖ The NRC staff evaluated the GEH proposed design updates to the ABWR and validated the findings in NUREG–1503 and NUREG–1503 supplement 1.
- ❖ This ABWR DC Renewal Safety Evaluation report, Supplement 2 to NUREG–1503, documents the NRC staff's review of GEH's application to renew the ABWR DC. Except as modified by this Supplement, the findings made in NUREG-1503 and its Supplement 1 remain in full effect.
- ❖ The NRC staff made safety determinations on the specific Modifications and Amendments proposed by GEH as part of its DC Renewal Application.
- ❖ These Modifications and Amendments were found to meet the applicable regulatory requirements and are therefore acceptable.
- ❖ Thank You!



# Backup Slides



# ABWR DC Renewal

## List of Abbreviations Used

- ❖ ABWR – Advanced Boiling Water Reactor
- ❖ ac – Alternating Current
- ❖ ACS – Atmospheric Control System
- ❖ ACRS – Advisory Committee on Reactor Safeguards
- ❖ ACIWA - Alternating Current (ac) Independent Water Addition System
- ❖ AIA – Aircraft Impact Assessment
- ❖ ATWS – Anticipated Transient Without Scram
- ❖ BWR – Boiling Water Reactor
- ❖ C/B – Control Building
- ❖ COL – Combined License
- ❖ COPS- Containment Overpressure Protection System
- ❖ CRD- Control Rod Drive
- ❖ DBA – Design Basis Accident
- ❖ DC – Design Certification
- ❖ DCD – Design Control Document
- ❖ ECCS – Emergency Core Cooling Systems
- ❖ EP – Emergency Planning
- ❖ ER – Environmental Report
- ❖ GEH- General Electric Hitachi
- ❖ I&C – Instrument and Control
- ❖ IEEE – Institute of Electrical and Electronics Engineers
- ❖ ITAAC - Inspections, Tests, Analyses, and Acceptance Criteria
- ❖ MBDBE- Mitigation of Beyond Design Basis Events
- ❖ MCR – Main Control Room
- ❖ NPSH – Net Positive Suction Head
- ❖ NTTF - Fukushima Near Term Task Force Recommendations
- ❖ NRC – US Nuclear Regulatory Commission
- ❖ RAI – Request for Additional Information
- ❖ RB – Reactor Building
- ❖ RG – Regulatory Guide
- ❖ RHR – Residual Heat Removal System
- ❖ RSP – Remote Shutdown Panel
- ❖ SER – Safety Evaluation Report
- ❖ SFP – Spent Fuel Pool
- ❖ SR – Safety Related
- ❖ SRP – Standard Review Plan
- ❖ SSC – Structure, Systems, and Components
- ❖ TS – Technical Specifications
- ❖ TSC – Technical Support Center

# ABWR DC RENEWAL

| Item No. | Description   | Type         |
|----------|---|--------------|
| 1        | SER Supplement Chapter 2.0 Section 2.5 Geological, Seismological and Geotechnical Engineering | Modification |
| 2        | SER Supplement Chapter 2.3 Section 2.3.1, Regional climatology                                | Modification |
| 2        | SER Supplement Chapter 3 Section 3.3, Wind and Tornado Loadings                               | Modification |
| 2        | SER Supplement Chapter 3 Section 3.5.1.4.1 Missiles Generated by Natural Phenomena            | Modification |
| 3        | SER Supplement Chapter 2.0 Section 2.6.8 ABWR Site Acceptability                              | Modification |
| 4        | SER Supplement Chapter 2.0 Section 2.6.2 Water Level (Flood) Design Site Parameters           | Modification |
| 5        | SER Supplement Chapter 12 Section 12.3 Radiation Protection Design Features                   | Amendment    |
| 6        | SER Supplement Chapter 12 Section 12.2 Radiation Sources (SER covers Issues 6&7)              | Modification |
| 7        | SER Supplement Chapter 12 Section 12.2 Radiation Sources (SER covers Issues 6&7)              | Modification |
| 8        | SER Supplement Chapter 11 Section 11.4 Solid Waste Management System                          | Modification |
| 9        | SER Supplement Chapter 6 Section 6.2.1.9 Containment Debris Protection for ECCS Strainers     | Amendment    |
| 10       | SER Supplement Chapter 5.0 Section 5.4.8 Reactor Water Cleanup System.                        | Amendment    |
| 11       | SER Supplement Chapter 9 Section 9.5.1 Fire Protection System                                 | Modification |

# ABWR DC RENEWAL

| Item No. | Description   | Type                |
|----------|---|---------------------|
| 12       | SER Supplement Chapter 5.0 Section 5.2.5 Reactor Coolant Pressure Boundary Leakage Detection.   | <b>Amendment</b>    |
| 13       | SER Supplement Chapter 9.0 Section 9.1.1 New Fuel Storage   | <b>Amendment</b>    |
| 13       | SER Supplement Chapter 9.0 Section 9.1.4 Light Load Handling System (Related to Refueling)  | <b>Amendment</b>    |
| 13       | SER Supplement Chapter 9.0 Section 9.1.5 Overhead Heavy Load Handling Systems   | <b>Amendment</b>    |
| 14       | Update the Level 1 and 2 full-power probabilistic risk assessment (PRA) for the ABWR, including its description and results in Chapter 19 of the DCD. | <b>Issue Closed</b> |
| 15       | Complete a Level 1 and 2 shutdown PRA for the ABWR, including its description and results in Chapter 19 of the DCD.                                   | <b>Issue Closed</b> |
| 16       | Update Appendix 19K to develop a comprehensive list of risk-significant SSCs.   | <b>Issue Closed</b> |
| 17       | SER Supplement Chapter 13 Section 13.5 Plant Procedures   | <b>Amendment</b>    |
| 18a      | SER Supplement Chapter 4 Section 4.2 Fuel System Design   | <b>Modification</b> |
| 18b      | SER Supplement Chapter 9 Section 9.1.2.1 Fuel Racks   | <b>Modification</b> |
| 19       | SER Supplement Chapter 9 Section 9.1.2 New and Spent Fuel Storage (SER covers Issues 19&20)   | <b>Modification</b> |
| 20       | SER Supplement Chapter 9 Section 9.1.2 New and Spent Fuel Storage (SER covers Issues 19&20)   | <b>Modification</b> |

# ABWR DC RENEWAL

| Item No. | Description  | Type         |
|----------|--|--------------|
| 21       | Replace obsolete (I&C) and data communication technology. The replacement design should conform to current instrumentation and control related regulations, industry standards, and regulatory guidance. | Issue Closed |
| 22       | SER Supplement Chapter 7.0 Section 7.7.1.2.1 Control Rod Ganged Withdrawal Sequence Restrictions   | Modification |
| 23       | SER Supplement Chapter 3.0 Section 3.7.3, Seismic Subsystem Analysis   | Modification |
| 24       | Apply the guidance from Regulatory Issue Summary 2008-05, Revision 1, to the existing ITAAC and submit revised ITAAC.  | Issue Closed |
| 25       | Provide a control room design that reflects state-of-the-art human factor principles in accordance with 10 CFR 50.34(f)(2)(iii).   | Issue Closed |
| 26       | SER Supplement Chapter 22 Sections 5.4.7 RHR, 5.4.7.1.1.10 ACIWA, 7.4.1.4.4 RSP, 8.3.4.4 1E Buses Chapter 16 TS  | Amendment    |
| 27       | SER Supplement Chapter 22 Sections 3.2.3 Safety Classifications, 7.5.2.1 Post Accident Monitoring System, 9.1.3 Fuel Pool Cooling  | Amendment    |
| 28       | SER Supplement Chapter 13 Section 13.3 Emergency Planning (SER Covers Issue 28&31)   | Modification |
| 29       | SER Supplement Chapter 19 Section 19.5 Aircraft Impact Assessment  | Modification |
| 30       | SER Supplement Chapter 6 Section 6.2.1.3 Short-Term Pressure Response  | Amendment    |

# ABWR DC RENEWAL

| Item No. | Description   | Type         |
|----------|---|--------------|
| 31       | SER Supplement Chapter 13 Section 13.3<br>Emergency Planning (SER Covers Issue 28 & 31)                       | Modification |
| 32       | SER Supplement Chapter 19 Section 19.2.3.3.4<br>ABWR Containment Vent Design                                  | Modification |
| 33       | SER Supplement Chapter 8 Section 8.2.5 NRC<br>Bulletin 2012-01 Design Vulnerability                           | Modification |
| 34       | SER Supplement Chapter 6 Section 6.2.1.6<br>Suppression Pool Dynamic Loads                                    | Modification |
| 35       | SER Supplement Chapter 14 Section 14.3.2.3.6<br>Structural Task Group Review                                  | Modification |
| 36       | SER Supplement Chapter 1 Operating<br>Experience Review (Chapter 1 SER Covers<br>Issues 36 & 37)              | N/A          |
| 37       | SER Supplement Chapter 1 Alternate<br>Vendor/Changes to Chapter 1 SE (Chapter 1<br>SER Covers Issues 36 & 37) | N/A          |
| 38       | SER Supplement Chapter 6 Section 6.3<br>Emergency Core Cooling Systems  | Modification |
| 39       | Supplement Chapter 19 PRA to discuss effect of<br>design changes on PRA.                                      | N/A          |

GE Hitachi Nuclear Energy

# ABWR Design Certification Renewal

ACRS Committee meeting 2 October 2019



**HITACHI**



# GEH Presentation

- ABWR Overview
- U.S. Design Certification Renewal Timeline
- Renewal Scope
- Significant Design Changes



**HITACHI**

# ABWR Overview

- GEH's first ABWR began commercial operation at Kashiwazaki-Kariwa (K/K) in Japan, in 1996.
- Three additional ABWRs operational in Japan
- Two more under construction in Japan, and two in Taiwan.
- The ABWR is licensed in Japan and Taiwan, certified in the U.S., and approved in the UK (GDA)



**HITACHI**

# ABWR Overview (cont.)

The ABWR was developed as a collaborative effort between GE, TEPCO, Hitachi and Toshiba

- First Plants were built at the K/K site as units 6 and 7

Primary Drivers were enhanced safety and improved constructability and maintainability

- Improved Primary Containment design
  - Combines features of the Mark II and III containments
  - Reinforced Concrete Containment Vessel (RCCV) with steel leakage liner
- Compact Reactor Building of primarily reinforced concrete
- No Core Uncovery during a Design Basis Accident (DBA)
- Reactor Internal Pumps (RIPs)



**HITACHI**

# ABWR Overview (cont.)

The U.S. NRC certified design incorporated additional features:

- Combustion Turbine Generator as an Alternate AC power source (air-cooled)
- AC Independent Water Addition (ACIWA) System using Fire Protection as diverse water source
- Lower Drywell Flooder utilizing passive thermally activated valves to flood the Lower Drywell in the event of an ex-vessel core melt
- Containment Overpressure Protection System (COPS)
  - Passive rupture disc venting from Suppression Pool Airspace



**HITACHI**

# ABWR Overview (cont.)

## Reactor Specification


3926 Rated MWt

872 Fuel Bundles

- ✓ N- Lattice (symmetric water gap)
- ✓ Active Fuel Length (3.66 m; 12 ft)
- ✓ Moderate Power Density (51 kw/liter)

205 Control Blades


- ✓ Fine Motion Control Rod Drives (FMCRDs)
  - Reduced Fuel Duty
  - Fast Hydraulic Scram



**HITACHI**

# ABWR Overview (cont.)



## Overall Flow Chart



**HITACHI**


# ABWR Overview (cont.)

## Emergency Core Cooling Systems



**HITACHI**

# ABWR Overview (cont.)



**HITACHI**



# U.S. Design Certification Renewal Timeline

- Renewal Application Submitted (ABWR DCD rev 5) Dec 2010
- Application Docketed by NRC Feb 2011
- Initial Application Review Meeting Mar 2011
- NRC Letter – Proposed Changes (28 items) Jul 2012
- GEH response to NRC Letter Sep 2012
- ABWR DCD revision 6 Feb 2016
- Final GEH response (PCT) Jan 2019
- ACRS ABWR Subcommittee meeting Aug 2019



**HITACHI**

# Renewal Scope

## Original Submittal

- ✓ Aircraft Impact Assessment
- ✓ Containment Re-analysis
- ✓ Selected design updates
- ✓ Corrected errors identified by GEH

## NRC identified

- ✓ NRC originally identified 28 topics
- ✓ Final list was 39 items



**HITACHI**


# Significant Design Changes

- ABWR added two safety-related wide range spent fuel pool level
- Enhanced ECCS Suction Strainers
- Deletion of new fuel vault
- Addressed NRC bulletin 2012-01
- ABWR DCD Fukushima Recommendation 4.2 - Mitigation Strategies
- ABWR DCD COPS Size Corrections
- Included changes needed to enhance FLEX



**HITACHI**

Questions?





**HITACHI**