

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HIX YOKO WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

September 15, 1980

Docket Nos. 50-213
50-245
50-336
50-423
A01160

Mr. Boyce H. Grier, Director
Region 1
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

- References:
- (1) B. H. Grier letter to W. G. Council dated July 31, 1980 transmitting I&E Bulletin No. 80-20, (Docket No. 50-213).
 - (2) B. H. Grier letter to W. G. Council dated July 31, 1980 transmitting I&E Bulletin No. 80-20, (Docket Nos. 50-245, 50-336, and 50-423).


Gentlemen:

Haddam Neck Plant
Millstone Nuclear Power Station, Unit Nos. 1, 2, and 3
Response to I&E Bulletin No. 80-20

In References (1) and (2), Connecticut Yankee Atomic Power Company (CYAPCO) and Northeast Nuclear Energy Company (NNECO), respectively, were requested to determine if the Haddam Neck Plant or Millstone Unit Nos. 1, 2, and 3 used Westinghouse (W) Type W-2 control switches with spring return to neutral position, in safety-related applications.

NNECO has determined that Millstone Unit Nos. 1, 2, and 3 do not use W Type W-2 control switches.

CYAPCO has determined that W Type W-2 control switches are used in the following safety-related applications:



| <u>Component</u> | <u>No. of Switches</u> |
|--------------------------------------|------------------------|
| Containment Air Recirculation Fans | 4 |
| Service Water Pumps | 4 |
| High Pressure Safety Injection Pumps | 2 |
| Low Pressure Safety Injection Pumps | 2 |
| Charging Pumps | 2 |
| Emergency Diesel Generators | 2 |
| Primary Water Transfer Pumps | <u>2</u> |
| Total | 18 |

Items (2) and (3) of the subject Bulletin required interim testing of these switches and longer-term modifications as depicted by Figure 1 of the Bulletin. CYAPCO performed the required longer-term modifications as recommended in W's report to Mr. Victor Stello, Jr., of the Office of Inspection and Enforcement, dated June 18, 1980, prior to issuance of the Bulletin. The testing required in Bulletin Item (2) was, therefore, unnecessary.

CYAPCO and NNECO have, thus, concluded that the requirements of I&E Bulletin No. 80-20 have been met for the Haddam Neck Plant and Millstone Unit Nos. 1, 2, and 3. We trust the Staff will concur.

Very truly yours,

CONNECTICUT YANKEE ATOMIC POWER COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Council

W. G. Council
Senior Vice President

By: *W. F. Fee*

W. F. Fee
Executive Vice President