

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M | T | R | R | P | I | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | d | o | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5

7 8 9 14 15 25 26 30 37 CAT 38

CON'T

01 | R | E | P | O | R | T | S | O | U | R | C | E | 6 | L | 6 | 0 | 1 | 5 | 1 | 0 | - | 0 | 1 | 5 | 1 | 5 | 7 | 0 | 1 | 9 | 1 | 1 | 9 | 8 | 1 | 0 | 9 | 1 | 1 | 0 | 1 | 7 | 8 | 1 | 0 | 9

7 8 9 14 15 25 26 30 37 CAT 38

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During routine annual leak rate and operability checks per Tech Spec

03 | 3.7.(b) of containment isolation valve CV4027 in the reactor and fuel

04 | pit drain line, minor through seat leakage in excess of Tech Spec limits

05 | was observed. The back-up valve CV4117 in series was found to be accept-

06 | able and has been tagged and disabled in the closed condition until repairs

07 | can be made during a future shutdown. No hazard to the public occurred.

08 | _____

7 8 9

09 _____ 7 8 9	SYSTEM CODE S D 11	CAUSE CODE E 12	CAUSE SUBCODE B 13	COMPONENT CODE V A L V E X 14	COMP. SUBCODE F 15	VALVE SUBCODE D 16
17 LER/RO REPORT NUMBER 8 0 21	EVENT YEAR 8 0 21	SEQUENTIAL REPORT NO. 0 3 0 24	OCCURRENCE CODE 0 3 28	REPORT TYPE L 30	REVISION NO. 0 32	
ACTION TAKEN X 18	FUTURE ACTION A 19	EFFECT ON PLANT Z 20	SHUTDOWN METHOD Z 21	HOURS 0 0 0 0 22	ATTACHMENT SUBMITTED N 23	NPR-4 FORM SUB. N 24
PRIME COMP SUPPLIER A 25	COMPONENT MANUFACTURER B 2 9 0 26					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Investigation to determine the exact cause is planned during a future

11 | shutdown but as outlined in similar event RO 79-23, the valve seat is

12 | scheduled for replacement due to previous indication of wear. Report-

13 | ability is based on Tech Spec 6.9.2b (2).

14 | _____

7 8 9

15 FACILITY STATUS E 28	% POWER 0 7 7 29	OTHER STATUS N/A 30	METHOD OF DISCOVERY B 31	DISCOVERY DESCRIPTION Routine Test Observation 32
16 ACTIVITY CONTENT Z 33	AMOUNT OF ACTIVITY NA 35	LOCATION OF RELEASE NA 36		
17 PERSONNEL EXPOSURES NUMBER 0 0 0 37	TYPE Z 38	DESCRIPTION NA 39		
18 PERSONNEL INJURIES NUMBER 0 0 0 40	DESCRIPTION NA 41			
19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42	DESCRIPTION NA 43			
20 PUBLICITY ISSUED DESCRIPTION N 44	DESCRIPTION NA 45			

NRC USE ONLY

68 69 80