

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

September 26, 1980

Docket No. 50-245
B10085

Mr. Boyce H. Grier, Director
Region 1
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Reference: (1) Letter, W. G. Council to B. H. Grier dated
September 19, 1980.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 1
Scram Discharge Volume Monitoring

This letter responds to a verbal request from the NRC office of Enforcement and Inspection on September 26, 1980, concerning ultrasonic test monitoring of the scram discharge volumes. Specifically, Northeast Nuclear Energy Company (NNECO) was verbally requested to clarify the intent in Reference (1), to install a permanent UT monitoring system on the SDV.

NNECO intends to install the continuous UT monitoring system on the SDV's prior to returning to power operation following the upcoming refueling outage.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Council
Senior Vice President

W. F. Fee
Executive Vice President

8010230/77

P