

POOR ORIGINAL

REGULATORY DOCKET FILE COPY

OCT 14 1980

Docket No. 50-219

MEMORANDUM FOR: Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

FROM: W. A. Paulson, Project Manager
Operating Reactors Branch #5
Division of Licensing

SUBJECT: SUMMARY OF MEETING ON SEPTEMBER 9, 1980 TO DISCUSS
JERSEY CENTRAL POWER AND LIGHT COMPANY'S RESPONSE
TO OUR JULY 10, 1980 LETTER ON SEP TOPIC III-5.B, 1,
PIPE BREAK OUTSIDE OF CONTAINMENT FOR THE OYSTER
CREEK NUCLEAR GENERATING STATION

On September 9, 1980, a meeting was held in Bethesda, Maryland with representatives of Jersey Central Power and Light Company (JCP&L) and their consultants. A list of attendees is enclosed (Enclosure 1). The meeting agenda is listed on Enclosure 2.

In our July 10, 1980 letter to JCP&L, we requested that the licensee provide a schedule for modifications to be installed to provide adequate protection against the effects of postulated pipe breaks in the emergency condenser steam and condensate lines in the reactor building. Schematic diagrams of the system are shown on the meeting handouts (Enclosure 3).

One concern is that the effects of a postulated break could prevent the two isolation valves on the steam supply line from closing. The licensee stated that there is not sufficient room inside containment to install another isolation valve. Barriers would be massive because of the size of the lines. Accordingly, they are going to propose a leak detection system based on the concept that the pipes will leak before they break. JCP&L is considering two concepts: (1) an acoustic system designed by Westinghouse, and (2) a moisture detection system. We indicated that they should also consider including augmented inservice inspection.

We stated that the acceptability of their proposal would, in part, depend on the NRR staff's position regarding "leak before break." A staff paper on this subject related to postulated pipe breaks inside containment, is under review for approval.

8410230322 P

POOR ORIGINAL

With regard to postulated pipe breaks inside containment, JCP&L stated that they would like to have this topic reviewed based on their submittals to date. They do not want to have to postulate additional breaks that might be required in the staff's proposed position.

JCP&L stated that modifications that were made to the plant since the submittal of Amendment No. 75 to the Facility Description and Safety Analysis Report, have resolved our concerns regarding postulated main feed and main steam line breaks in the turbine building mezzanine area.

JCP&L is scheduled to document their responses to our July 10, 1980 letter by October 1, 1980.

W. A. Paulson, Project Manager
Operating Reactors Branch #5
Division of Licensing

Enclosures:
As stated

cc w/enclosures:
See next page

OFFICE	ORB#5					
SURNAME	WAPaulson:dr					
DATE	10/14/80					



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

OCT 14 1980

Docket No. 50-219

MEMORANDUM FOR: Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

FROM: W. A. Paulson, Project Manager
Operating Reactors Branch #5
Division of Licensing

SUBJECT: SUMMARY OF MEETING ON SEPTEMBER 9, 1980 TO DISCUSS
JERSEY CENTRAL POWER AND LIGHT COMPANY'S RESPONSE
TO OUR JULY 10, 1980 LETTER ON SEP TOPIC III-5.B,
PIPE BREAK OUTSIDE OF CONTAINMENT FOR THE OYSTER
CREEK NUCLEAR GENERATING STATION

On September 9, 1980, a meeting was held in Bethesda, Maryland with representatives of Jersey Central Power and Light Company (JCP&L) and their consultants. A list of attendees is enclosed (Enclosure 1). The meeting agenda is listed on Enclosure 2.

In our July 10, 1980 letter to JCP&L, we requested that the licensee provide a schedule for modification to be installed to provide adequate protection against the effects of postulated pipe breaks in the emergency condenser steam and condensate lines in the reactor building. Schematic diagrams of the system are shown on the meeting handouts (Enclosure 3).


One concern is that the effects of a postulated break could prevent the two isolation valves on the steam supply line from closing. The licensee stated that there is not sufficient room inside containment to install another isolation valve. Barriers would be massive because of the size of the lines. Accordingly, they are going to propose a leak detection system based on the concept that the pipes will leak before they break. JCP&L is considering two concepts: (1) an acoustic system designed by Westinghouse, and (2) a moisture detection system. We indicated that they should also consider including augmented inservice inspection.

We stated that the acceptability of their proposal would, in part, depend on the NRR staff's position regarding "leak before break." A staff paper on this subject related to postulated pipe breaks inside containment, is under review for approval.

With regard to postulated pipe breaks inside containment, JCP&L stated that they would like to have this topic reviewed based on their submittals to date. They do not want to have to postulate additional breaks that might be required in the staff's proposed position.

JCP&L stated that modifications that were made to the plant since the submittal of Amendment No. 75 to the Facility Description and Safety Analysis Report, have resolved our concerns regarding postulated main feed and main steam line breaks in the turbine building mezzanine area.

JCP&L is scheduled to document their responses to our July 10, 1980 letter by October 1, 1980.



W. A. Paulson, Project Manager
Operating Reactors Branch #5
Division of Licensing

Enclosures:
As stated

cc w/enclosures:
See next page

Mr. I. R. Finfrock, Jr.

CC
G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

GPU Service Corporation
ATTN: Mr. E. G. Wallace
Licensing Manager
260 Cherry Hill Road
Parsippany, New Jersey 07054

Natural Resources Defense Council
917 15th Street, N. W.
Washington, D. C. 20006

Steven P. Russo, Esquire
248 Washington Street
P. O. Box 1060
Toms River, New Jersey 08753

Joseph W. Ferraro, Jr., Esquire
Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
1100 Raymond Boulevard
Newark, New Jersey 07012

Ocean County Library
Brick Township Branch
401 Chambers Bridge Road
Brick Town, New Jersey 08723

Mayor
Lacey Township
P. O. Box 475
Forked River, New Jersey 08731

Commissioner
Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, New Jersey 07102

Gene Fisher
Bureau Chief
Bureau of Radiation Protection
380 Scotts Road
Trenton, New Jersey 08628

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Plant Superintendent
Oyster Creek Nuclear Generating
Station
P. O. Box 388
Forked River, New Jersey 08731

Resident Inspector
c/o U. S. NRC
P. O. Box 128
Forked River, New Jersey 08731

Director, Technical Assessment Div.
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection
Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection
Agency
Region II Office
ATTN: EIS COORDINATOR
26 Federal Plaza
New York, New York 10007


ATTENDANCE LIST

September 9, 1980 meeting with NRC and Jersey Central Power and Light Co.

<u>Name</u>	<u>Affiliation</u>
W. Paulson	NRC
J. Knubel	JCP&L
S. Chan	JCP&L
J. Johnson	MPR
W. Schmidt	MPR
H. L. Brammer	NRC/DE/MEB
Y.C. Li	NRC/DE/MEB
T. M. Cheng	NRC/DL/SEPB
D. P. Allison	NRC/DL/SEPB

AGENDA


- I. INTRODUCTION - J. KNUBEL
- II. NRC STAFF POSITIONS - J. JOHNSON MPR
 - EMERGENCY CONDENSER
 - TURBINE MEZANINE
- III. NRC REQUEST FOR INFORMATION - J. JOHNSON
 - CABLE SPREADING ROOM FLOODING
 - CABLE TRAY 13A
 - COMPARISON WITH B.2.C of BTP ASB 3-1
 - COMPARISON WITH B.1.b of BTP MEB 3-1
- IV. STATUS OF HIGH ENERGY LINE BREAK INSIDE
CONTAINMENT - (DISCUSSION)



NOTE: Only One of Two Systems Shown.


SCHEMATIC DIAGRAM
EMERGENCY CONDENSER SYSTEM

FIGURE 1




CONTAINMENT PENETRATION
EMERGENCY CONDENSER SYSTEM

FIGURE 2




PLAN VIEW
EMERGENCY CONDENSER PIPING

FIGURE 3




MOISTURE SENSING ELEMENT

FIGURE 4




PLAN VIEW
MAIN STEAM PIPING

FIGURE 6




PLAN VIEW
FEEDWATER PIPING

FIGURE 7




CONTAINMENT PENETRATION MAIN STEAM



CONTAINMENT PENETRATION EMERGENCY CONDENSER

FIGURE 2



CONTAINMENT PENETRATION (TYP)
 REACTOR WATER CLEANUP

FIGURE 3

MEETING SUMMARY DISTRIBUTION

[REDACTED]
NRC PDR
Local PDR
ORB Reading
NRR Reading
HRDenton
EGCAsa
DEisenhut
RPurple
JRowe
TNovak
Rtedesco
GLainas
GZech
JHeltemes, AEOD
SVArga
RReid
Tippolito
RClark
DCrutchfield
WPaulson
OELD
OI&E (3)
HSmith
ACRS (16)
NRC Participants
NSIC
TERA

cc: short list