

APPENDIX A

Sacramento Municipal Utility District
P. O. Box 15830
Sacramento, California 95813

Docket No. 50-312
License No. DPR-54

NOTICE OF VIOLATION

Based on the results of the NRC inspection conducted on August 18-22, 1980, it appears that one of your activities was not in full compliance with the conditions of your license, as indicated below:

Facility Technical Specification 6.5.2.8 states in part: "Audits of facility activities shall be performed under the cognizance of the MSRC. These audits shall encompass:

- a. The conformance of facility operation to all provisions contained within the Technical Specifications...at least once a year."

Contrary to the above, audits had not been performed on an annual or other periodic basis for at least two years prior to the inspection, to determine if the facility was operating in conformance with the "Limiting Safety System Settings", "Limiting Conditions for Operation", and "Environmental Protection Conditions" sections of the Technical Specifications.

This is an infraction.