

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

NUCLEAR REGULATORY COMMISSION

ORIGINAL

T-φ782

In the Matter of:

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

245TH MEETING

NRC PDR

DATE: September 4, 1980 PAGES: 1 thru 308

AT: Washington, D. C.

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8009080385

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

- - -
245TH MEETING
- - -

Nuclear Regulatory Commission
1717 H Street, N.W.
Room 1046
Washington, D.C.

Thursday, September 4, 1980

The 245th meeting of the Advisory Committee was
convened, pursuant to notice, at 8:30 a.m.

MEMBERS PRESENT:

- M. PLESSET, Chairman, presiding
- J. C. MARK, Vice chairman
- C. P. SISS
- S. LAWROSKI
- M. BENDER
- D. W. MOELLER
- W. KERR
- N. CARSON
- H. ETHERINGTON
- W. M. MATHIS
- J. C. EBERSOLE
- F. W. LEWIS
- P. G. SHEWMON
- D. OKRENT
- J. J. RAY

DESIGNATED FEDERAL EMPLOYEE:

R. F. FRALEY, Executive Director

ALSO PRESENT:

J. M. JACOBS, Secretary

P R O C E E D I N G S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. FLESSET: The meeting will come to order.

This is the 245th meeting of the Advisory Committee on Reactor Safeguards. During this meeting the Committee will hold discussions on the following: BWR scram systems, quantitative risk criteria, Sequoyah Nuclear Power Plant, Units 1 and 2, hydrogen control, NRC regulatory requirements and reevaluation of operating nuclear plants, and revised clad swelling and rupture model.

We shall also discuss other topics as well. The specific items on the agenda today include the BWR scram systems, a brief session on quantitative risk criteria, and the Sequoyah Nuclear Plant.

The meeting is being conducted in accordance with the Federal Advisory Committee Act and the Government in the Sunshine Act. Mr. Raymond Fraley is the designated Federal employee for this portion of the meeting.

A transcript of the meeting is being kept, and it is requested that each speaker first identify himself and speak with sufficient clarity and volume so that he or she can be readily heard.

We have received no request for statements from members of the public for this meeting.

(The Chairman's report follows.)

1 MR. PLESSET: We will go into open session.

2 I would like to ask you to look at Tab 1.2. We
3 are going to discuss the BWR hydraulic scram system.

4 As you know, we had one brief discussion of this
5 already to the full committee which was not very
6 informative, although it is a rather complicated problem.
7 It is not clear yet just what all went wrong on Brown's
8 Ferry. There are certainly some hydraulic problems, but
9 there are other problems, as well.

10 There was a subcommittee meeting on August 19 and
11 20 on this question, and we had a rather lengthy discussion
12 of the whole problem. It is quite remarkable, the asymmetry
13 in the scram systems, as you will recall.

14 MR. SIESS: At Brown's Ferry?

15 MR. PLESSET: All of them.

16 MR. SIESS: I thought some of them had separate --

17 MR. PLESSET: Do they? Some of the very new ones?

18 MR. SIESS: Peach Bottom.

19 MR. PLESSET: I thought they all -- aren't they
20 all -- they have separate -- some of them have long lines,
21 don't they? Some of them have very long lines from one
22 point to the other in the reactor. There is a lot of
23 variability. This is something that is an example of the
24 complications you get into when it is a balance of plant
25 question, even though this is an extremely important safety

1 system.

2 The so-called hockey stick has been mentioned.
3 There are problems with the vent valves and the drain valves
4 in the systems, and presumably the severe hydraulic water
5 hammer could be experienced as a result of the behavior of
6 the drain valves. And you will hear about that, so let me,
7 unless there are some general questions, to go the agenda
8 that we have in that tab.

9 I should say that our presentation that Gary Young
10 made and Ms. Zukor made were excellent. You will get an
11 abbreviated version today. So let me call on -- Gary
12 begins. I see. Okay. Gentlemen first.

13 MR. YOUNG: I would like to describe briefly, with
14 the help of Dorothy Zukor, the report that the ACPS staff
15 fellows prepared on the recent malfunctions of the BWR scram
16 systems. What we tried to do in this report was present
17 briefly a description of the scram systems and kind of in a
18 generic way how they operate, and then go through each one
19 of the events that occurred at Brown's Ferry, at Hatch and
20 at Brunswick, as well as some of the other occurrences that
21 were found during the test program following the Brown's
22 Ferry event.

23 We also had a discussion of the NRC Office of
24 Analysis and Evaluation of Operational Data Report on the
25 Brown's Ferry event. They went through and visited the

1 Brown's Ferry site and made some recommendations. Also we
2 did a comparison with WASH-1400 what they listed as some
3 possible causes of failure of the scram system, and we
4 compared that with what actually happened.

5 So, first I would like to start by showing some
6 slides.

7 (Slide)

8 This is the scram system, and I will briefly go
9 through how it is supposed to work and what happened, the
10 reason it did not work at Brown's Ferry.

11 MR. PLESSET: Can you raise it up a little bit,
12 Gary? Fine. That is good.

13 MR. YOUNG: This is a schematic drawing of a
14 control rod drive mechanism, and this is the drive piston
15 that pushes the control rod into the fuel assembly area.
16 The way it is supposed to work is the high pressure water is
17 applied to this side of the line, which exerts force on the
18 bottom of the drive piston, pushing it up into the vessel,
19 and then the back side of the drive piston, this area here,
20 is vented via this line to the scram discharge volume, and
21 this is essentially an atmosphere pressure, and this is
22 approximately 1500 psi. So it is a differential system that
23 drives the rod into the core.

24 (Slide)

25 This is a schematic of the hydraulic system used

1 to push the control rod into the core. This is the scram
2 accumulator. That is the safety grade water supply that
3 that 1500 psi is used to exert the pressure on the drive
4 piston. It is normally charged during power operation, and
5 it is charged by this drive water pump here.

6 That is in operation all the time to supply water
7 for normal drive motion and for cooling water.

8 These are the scram valves here. They are
9 normally closed and held closed by air pressure maintained
10 on the valves.

11 The back side of the drive piston is vented via
12 this path to the scram discharge volume, and then the scram
13 discharge volume has an instrument volume attached to it.
14 At Browns Ferry, this was a two-inch pipe that connected it
15 to an independent tank. At Brunswick the instrument volume
16 is an integral part of the scram discharge volume.

17 Normally the scram discharge volume and instrument
18 volume are vented and drained. These valves are opened such
19 that any water that might accumulate during normal operation
20 would flow right on through. During a scram these valves
21 close to bottle up that scram discharge volume, and these
22 valves open during a scram.

23 So the design numbers that are given by G.E. in
24 designing the system, the scram discharge volume is sized to
25 have a capacity of 3.3 gallons per rod. There are 185

1 control rods in each of the plants, and this is 3.3 gallons
2 capacity for each one of the rods.

3 So at Browns Ferry they had a total of about 750
4 gallons capacity, which was in excess of this number. This
5 number comes from the volume on the back side of the piston
6 when it goes from its fully withdrawn to its fully inserted
7 position. It displaces about 3/4 of a gallon of water.
8 Then in addition to that, there is an allowance for seal
9 leakage from this side over to the back side of the piston
10 of 10 gallons per minute, lasting for 10 seconds, and that
11 is where they come up with this number.

12 There is also some conservatism in there because
13 those two numbers add up to less than 3.3 gallons.

14 MR. LEWIS: I am sure I am the only one who does
15 not understand the plumbing, but just to be quite sure, this
16 picture is a little bit different from the previous one in
17 that in the previous one the discharge water comes down the
18 center of the piston tube and exits from the bottom, whereas
19 this shows it exiting from above the piston.

20 Is the first one right and this one wrong?

21 MR. YOUNG: This is to show schematically how it
22 works. Although the other one is also schematic, it has a
23 little bit better view of the flow pattern.

24 MR. LEWIS: Better schematic.

25 MR. PLESSET: Before you take the slide away, do

1 you want to make any comment about Michaelson's question
2 regarding the loss of air and what it would do to the scram
3 inlet and outlet valve? Do you want to make a comment on
4 that?

5 MR. YOUNG: Okay. This is the air supply that
6 holds these valves shut during normal operation, and the
7 AEOD group wrote a letter, Mr. Michaelson wrote a letter
8 that said that if this air supply were gradually cut off,
9 your normal mechanism is to rapidly vent this air supply so
10 that these valves fly open very quickly.

11 He said that if this air supply was gradually lost
12 due to some failure in the air system which is non safety
13 grade, that this valves would drift open very slowly, and
14 with this drifting you would get water leakage from the
15 control rod drive system into the scram discharge volume.
16 His concern was that this volume could quickly fill up with
17 water before the operator would initiate a scram, a manual
18 scram signal.

19 So basically, it is based on an event that
20 happened at Browns Ferry just recently where they had an air
21 compressor fail and it was a catastrophic failure, so the
22 air supply bled off rather quickly and the operator noted
23 that some of his rods were drifting into the core.

24 The reason for that is that this valve was
25 drifting open. He had high pressure water here and it was

1 causing the rods to drift in. If he had not initiated the
2 scram -- at the same time the water was going to the scram
3 discharge volume filling it up.

4 .o his concern is there is a possibility that your
5 scram discharge volume will fill with water before you
6 initiate a scram, and then when you try to initiate a scram,
7 you cannot do it, because you have to have a vent path to
8 vent this water off before the rods will go into the core.

9 MR. EBERSOLE: There is some follow on to that.
10 The monitoring at Browns Ferry was said to be continuous;
11 however, when one went into questioning and detail, it turns
12 out it was continuously recorded but only periodically read,
13 which led to a case of looking at, I think, it 1 minute
14 every 30 minutes, so you had 29 minutes out of 30 for this
15 to presumably start filling.

16 You are exposed for that tremendously large
17 fraction of time. I understand that that has been fixed.

18 MR. PLESSET: Yes.

19 MR. EBERSOLE: There is another aspect of this
20 that came up just the other day, and that is, of course this
21 failure of the service system not to perform abruptly as it
22 was designed to do but progressively as it should not do
23 applies generically to pressure and air and AC and DC
24 systems and all over the place; but I think in this case it
25 may also affect the STV vents and drains in a manner to

1 cause them to open slowly as well.

2 So what one has is an open system; however, it is
3 inadequate to drain. So this volume would still fill up.
4 But it leads to a case where if that condition goes on, it
5 appears to offer an open path to the atmosphere, which is a
6 radiation problem which Carl has pointed out, and it may be
7 significant in that it offers a boron leakage path for which
8 you have an ATWS mitigating system, only one shot of boron,
9 with a present zero allowance for any liquid leakage.

10 That is an adjunct matter to be looked at.

11 MR. PLESSET: I think that is a very good point
12 that Carl and you have made. You remember we raised the
13 question about the quality of this whole system. They
14 assured us it was great but they stopped at the valves and
15 they did not think what would happen if these valves did not
16 do what they were supposed to do, as Carl and you are
17 pointing out.

18 So it is a question of how far do they go when
19 they consider the safety features of a system like this.
20 They stopped.

21 MR. BEERSOLE: I think at this time I am going to
22 make just a fragment of that little statement I made at the
23 meeting about the curious rationale on which this is built.
24 You notice that it is built conceptually on the thesis
25 whenever you have a potential for radiation leakage present,

1 by all means close everything up tight.

2 So what this really does, one can argue it takes
3 the primary function, which is get the rods scrammed, and it
4 preconditions the dump volume so it is closed and therefore
5 cannot open except to the extent its volume has been defined
6 and it is loose in the system, whereas it could have been
7 designed to be an open discharge into a sump or into the
8 containment or someplace with subsequent action to take care
9 of the relatively minor problem of radioactive water leakage
10 after you have sealed in and locked the rods in place.

11 So the roots of this rationale here like in a
12 rather vague theory that it is more important to keep a
13 little bit of leakage from occurring than it is to scram the
14 reactor, which I think is inverse logic.

15 MR. BENDER: My intuitive logic says that may be
16 one of the regulatory influences that is adverse to safety.
17 The fact of the matter is we put so much emphasis on not
18 letting any radioactivity get out, that the vendors have
19 chosen this avenue.

20 MR. EBERSOLE: Right.

21 VOICE: Could staff make a clarification on the
22 vent and drain valve?

23 MR. PLESSET: Briefly, yes.

24 VOICE: The vent and drain valves still are closed
25 on loss of air.

1 MR. EBERSOLE: That would act as a seal. So they
2 are different from a scram dump valve.

3 VOICE: That is correct.

4 MR. YOUNG: They are both serviced by the same air
5 supply, and they do act somewhat slower. So I think your
6 point that these could be open, as well as these could exist
7 if you had a slow loss of air pressure, but these do close
8 on loss of air. But if it were a gradual loss, they would
9 gradually close.

10 MR. EBERSOLE: There is a fundamental problem of
11 not looking at the gradual -- it is presumed there are
12 abrupt changes in the barometers. It is a problem
13 everywhere you look.

14 MR. YOUNG: Another point, too, that was in the
15 Michaelson letter is there is an alarm to the operator to
16 tell him that he is losing air pressure. So he is not flying
17 blind. He knows that he is losing air pressure. It is not
18 a safety grade alarm, but it is in the control room.

19 Based on that, I think the recommendation was that
20 as soon as he sees he is losing air pressure, he will scram
21 to prevent filling this with water. So he has a period of
22 time between the alarm and the time these valves start
23 drifting open to take his action.

24 MR. EBERSOLE: Again pointing to the fact that the
25 operator looks at an indicator and thinks he is looking at

1 the barometers. He is looking at a general air pressure but
2 may not be looking at this leg of the system. He may be
3 losing air but not know it.

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. YOUNG: To talk about the features of the
2 scram system and how they are related, the scram discharge
3 volume's purpose is to allow scram to progress to depletion
4 and then to isolate the water leakage from the reactor
5 vessel following the scram.

6 The instrument volume is there to alert the
7 operator to the fact that he has water in the scram system
8 prior to a scram, so the instruments here are to tell him he
9 is getting water in there that should not be there and that
10 he needs to take some action -- either initiate a scram or
11 get the water out of there by some method.

12 (Slide.)

13 This next slide shows a little closer view of the
14 Browns Ferry design on the instrument volume. This again is
15 just a schematic, but the way the system is set up, the
16 operator's first indication is he gets an alarm there is
17 water in the bottom of his instrument volume, because again,
18 the drain line is open during normal operation. So if water
19 were to build up, he would get an alarm.

20 As water builds up higher, if he does not take any
21 action, he gets a rod block level which prevents him from
22 withdrawing the rods from the core any more than they
23 already are. And then if the water level continues to build
24 up, at this point he gets an automatic scram signal. And
25 the purpose of this is as water gets to this elevation, it

1 is starting to get up into a point where it can get into the
2 scram discharge volume, the 3.3 gallon capacity; so this
3 scrams him when he still has plenty of capacity to allow a
4 scram.

5 MR. SHEWMON: At Browns Ferry none of these alarms
6 alarmed.

7 MR. YOUNG: At Browns Ferry none of these came in.

8 MR. MOELLER: Excuse me. Was this system not at
9 Browns Ferry?

10 MR. YOUNG: This is Browns Ferry.

11 MR. MOELLER: But it failed to alarm.

12 MR. YOUNG: I will show you. They were operating,
13 the instruments were operating, but I will show you a little
14 later why they did not work.

15 (Slide.)

16 Now, I would like to go into the Browns Ferry
17 event. This happened on June 28 this year, and the
18 operators were bringing Unit 3 down for a scheduled
19 maintenance, and as part of the procedure for bringing the
20 plant down they initiated a manual scram at approximately 30
21 percent power to shut it completely down.

22 When the operator did this, he got indication that
23 all of his scram inlet and outlet valves had opened because
24 he has position indicators in the control room; but he noted
25 on his rod position indicators that the rods had not all

1 inserted, and they had stopped moving. And this is a
2 picture of the rod pattern --

3 MR. MOELLER: Excuse me a moment. You were at 30
4 percent power when he started this. When had he brought it
5 from presumably 100 percent down to 30 percent, and had
6 everything worked all right then?

7 MR. YOUNG: Yes. It was a normal, routine
8 shutdown.

9 MR. MOELLER: And how far previously?

10 MR. SIESS: Not a scram.

11 MR. YOUNG: It was not a scram. It was a manual
12 decrease in power using the rods.

13 MR. MOELLER: Okay. Then how much prior to the
14 problem had this been done?

15 MR. YOUNG: It was a consecutive thing. He was
16 just bringing the plant gradually down, and when he reached
17 the 30 percent power level he initiated --

18 MR. SHEWMON: Over a period of minutes, hours, or
19 days?

20 MR. YOUNG: Minutes.

21 MR. MOELLER: Thank you.

22 MR. YOUNG: Okay. This was at 1:30 in the
23 morning. Also, it was on Saturday morning when it
24 occurred. All of the zero positions shown here indicate
25 that the rods were fully inserted into the core. The 48

1 position indicate the rods were fully withdrawn from the
2 core, and this is a view of the west side of the core.
3 There are 92 rods on the west side, and on the east side
4 there are 93 rods.

5 This was the pattern that they recorded. On the
6 west side there was one rod that did not fully insert, but
7 it was at the 02 position, which from a neutron absorption
8 viewpoint is essentially full in. But one of those 76 rods
9 was on the west side. All of the others were on the east
10 side. And there was one rod up here that was at the 46
11 position.

12 As I mentioned before, the 48 position is fully
13 withdrawn, so it barely went in at all. The ones I have
14 marked here in blue can be counted as being essentially in
15 because they were far enough in that they had all of their
16 neutron absorption capabilities. So if you count the rods
17 that were effectively not inserted, there were only about 70
18 rods that did not go in.

19 You will notice here the strange rod pattern on
20 the east side. The rods started to insert and then suddenly
21 stopped, and they stopped at different positions. GE and
22 TVA have done some analysis and have been able to confirm
23 that the amount of position change that occurred during this
24 first scram is directly related to the scram speed that they
25 got during tests.

1 And what that means is that, for example, this rod
2 up here had a very slow scram speed when they ran the test,
3 indicating that it had some seal leakage in excess of some
4 of the other rods or a little more friction, and therefore,
5 it had a slow scram time relative to the others. So it
6 moved for a little while and then stopped in this position,
7 whereas other rods moved considerably further; and that was
8 based on rods that had very quick scram times during their
9 test program prior to this event.

10 MR. LEWIS: So the inference is they all stopped
11 at the same time.

12 MR. YOUNG: They all started at the same time or
13 they all stopped at the same time. The difference in
14 movement was based on friction and other losses.

15 MR. EBERSOLE: Something that happened here is
16 where they are pointing out that is the operator's
17 response. He was doing two things. One, he was faced with
18 a half-ATWS, or he thought he was, so he was going to try to
19 get the rods in, which he did, but he did another thing, but
20 not intentionally or obviously intentionally but by instinct
21 or prior training. He did not intercept the steam flow path.

22 Had he done that then the course of events would
23 have been somewhat different. He would have collapsed the
24 voids. We would have had a spike in power to some
25 magnitude. But from prior experience he thoughtfully

1 allowed steam to continue to flow. Therefore, he did not
2 have any real power spiking problem, but he could have had
3 if he had reacted erroneously and closed the turbine valves,
4 but he did not do it.

5 MR. PLESSET: Yes, Max.

6 MR. CARBON: Gary, what was the power level of the
7 reactor after this much rod insertion? Was the left side
8 still critical?

9 MR. YOUNG: The indication that the operator had,
10 he had a power range monitor still watching the core, and it
11 indicated less than two percent power. That monitor, the
12 down-scale is two percent power, so he only knew he was less
13 than two percent power. He did not have the instruments
14 inserted to measure the low power levels, so he only knew
15 that he had gone from 30 percent power to less than two
16 percent power. And at this point all of the reports simply
17 say that. They do not say that he was subcritical, but they
18 imply that he probably was.

19 MR. KERR: Decay heat would be one or two percent
20 power at this point, wouldn't it?

21 MR. YOUNG: The two percent was neutron power.

22 MR. PLESSET: This would be above --

23 MR. BENDER: Gary, I guess I was not clear on the
24 decision process that occurred. He had reduced the power to
25 30 percent, and then the decision was made to shut down

1 completely.

2 MR. YOUNG: Yes. That is the routine.

3 MR. KERR: That was probably achieved by asserting
4 recirc flow, wasn't it?

5 MR. YOUNG: Yes.

6 MR. BENDER: At 30 percent the normal procedure is
7 just to scram the reactor by pressing the scram button?

8 MR. YOUNG: For TVA at Browns Ferry that was their
9 normal procedure.

10 MR. BENDER: Okay. And at that point all the rods
11 on one side went in, and they observed evidently the rods
12 weren't going in on the other side.

13 MR. YOUNG: Right.

14 MR. BENDER: Did you look at the procedures enough
15 to know what instructions the operator has during this part
16 of the operation? What is he supposed to be doing? Is he
17 supposed to be looking at the rod action or what?

18 MR. YOUNG: Yes, yes. He verifies that all of the
19 scram valves operate and that the rods are fully inserted.

20 MR. BENDER: What do the procedures tell him to do
21 if the rods are not going fully in? Were you able to find
22 out?

23 MR. YOUNG: I think the NFC staff has that
24 information. I do not directly know.

25 MR. BENDER: I think it would be interesting to

1 know whether there is some kind of procedures.

2 MR. YOUNG: There are procedures, but I could not
3 tell you exactly what they are.

4 MR. BENDER: Jesse's point, whether the steam
5 valves should have been closed or not closed and whether
6 that was done by intuitive judgment or not is an interesting
7 part of the whole operational planning question.

8 MR. YOUNG: TVA mentioned at an earlier meeting
9 that it was intentionally -- it was the operator's intention
10 to continue steam flow simply because he has to make sure he
11 has a heat sink.

12 Now, if anything had gone wrong, any other events
13 had occurred, he could very easily have lost that steam
14 flow, but he does routinely maintain steam flow just because
15 he needs that heat sink.

16 MR. BENDER: I guess I was interested in knowing
17 just what his training instincts would tell him to do.

18 MR. YOUNG: Right.

19 MR. LEWIS: One of the other questions that I just
20 --

21 MR. PLESSET: Could you use the mike, Hal?

22 MR. LEWIS: One of the other questions to which I
23 never knew the answer was what do the calculations show the
24 power level would have been if this had happened from full
25 power instead of 30 percent?

1 MR. PLESSET: We are going to get to that.

2 MR. LEWIS: Forgive me.

3 MR. YOUNG: This was the configuration after the
4 first manual scram, and in addition, the operator noted that
5 the instrumentation on the instrument volume, the scram
6 discharge instrument volume, gave him an alarm or gave him
7 an automatic scram signal at 19 seconds into the event.

8 The normal fill time for that scram discharge
9 volume takes between 45 to 60 seconds to fill up and give
10 him this alarm. It took only 19 seconds, so that was an
11 indication that there was water already in the scram
12 discharge volume that he did not know about prior to the
13 scram event.

14 MR. BENDER: Is he conscious of that incremental
15 time? It seems to me that is expecting an operator to know
16 a lot, to be able to judge the difference between 19 seconds
17 and 45 seconds or whatever.

18 MR. YOUNG: I don't know if that was a later
19 finding or if the operator knew it right at the instant. It
20 was recorded that way.

21 MR. BENDER: Thank you.

22 MR. OKRENT: I would guess he does not normally
23 look at that. Were these rod positions on the computer?

24 MR. YOUNG: Yes.

25 The next action taken by the operator was to clear

1 the scram signal to put the mode switch in shutdown which
2 allows him to bypass the automatic scram signal he has from
3 the instrument volume. By doing that he can reset the scram
4 signal, allow the scram volume to start to drain, and then
5 six minutes after the first scram he initiated a second
6 manual scram.

7 (Slide.)

8 This was the rod configuration after the second
9 manual scram. Again, the rods moved in slightly. Each rod
10 moved in a little bit more than it was before, but it did
11 not go all the way. It moved and stopped.

12 All of the rods on the west side were now in. The
13 ones circled in blue were effectively pulled in.

14 Okay. Again, he reset the scram signal. He
15 allowed a little bit of time for the scram volume to drain,
16 and two minutes later he initiated the third manual scram.

17 (Slide.)

18 And this was the rod configuration after the third
19 one. There were 36 rods out and of those 36 several of them
20 were effectively full in. He at this point again reset the
21 scram signal, allowed some drain time on the scram volume,
22 and at this point he took the bypass switch on the automatic
23 scram signal coming from the level instrumentation, took it
24 back to the automatic position which is, as I understand it,
25 is a routine thing to do.

1 When he did that there was still water in the
2 instrument volume, and that initiated the final automatic
3 scram; and this was six minutes after the third scram. At
4 that point all the rods went completely into the core, and
5 based on some looks back at the situation, it did not really
6 matter whether it was an automatic or a manual scram at this
7 point.

8 There was enough space available in the scram
9 discharge volume to allow the full scram, so it is really
10 incidental that it was an automatic scram rather than a
11 manual scram.

12 MR. EBERSOLE: That sounds as though he knew what
13 was happening, and he was draining as he knew that that was
14 what the problem was.

15 MR. YOUNG: He had indication that that was a
16 problem. He had indication that each time he allowed it to
17 drain, he got the rods a little further in. So the final
18 complete scram occurred 14 minutes after the first scram.

19 (Slide.)

20 Based on the studies that were done later, they
21 determined that the scram discharge volume did have water in
22 it on the east side, and that is what prevented the rods
23 from fully inserting on the east side.

24 (Slide.)

25 To understand why that occurred a little better,

1 you need to look at the layout, and I have a drawing here of
2 Peach Bottom, but it is very, very similar for Browns
3 Ferry. This is a plan view looking down from above the
4 reactor vessel, and off to the side here are the hydraulic
5 control units for each one of the rods.

6 They basically split it up so that 92 of the
7 hydraulic systems are serviced by a hydraulic control unit
8 on the west side, and then 93 are serviced by control units
9 on the east side.

10 This is the scram discharge volume. It is a
11 six-inch pipe header arrangement. It has in the
12 neighborhood of 300 gallons capacity, somewhat more than 3.3
13 gallons times 92 rods. A similar arrangement on the east
14 side, and then each one has a two-inch drain line connected
15 to the instrument volume which has all the instrumentation
16 to tell the operator he has water in the scram volume.

17 MR. PLESSET: About how long is that line?

18 MR. YOUNG: About 150 feet on the east and on the
19 west side about 20 feet long. So there was a considerable
20 difference in the drain line.

21 I have an isometric view of the Browns Ferry
22 layout.

23 (Slide.)

24 These are the headers for the scram discharge
25 volume on the west side and the east side, and these are the

1 two-inch drain lines that connect to the instrument volume
2 here. And you will notice that this one is 150 feet long,
3 this is only 20 feet long, and this is the expansion loop.

4 MR. SIESS: This is Browns Ferry?

5 MR. YOUNG: Yes. Browns Ferry Unit 3. This is
6 the expansion loop that a lot of people thought was the
7 problem originally. It turned out probably it was not. It
8 is a horizontal expansion. Earlier it was reported it might
9 have acted as a trap and prevented water from draining, but
10 it is horizontal, and it would not act as a trap.

11 (Slide.)

12 Another view of Browns Ferry design is this one.
13 It shows an elevation view, and these are the volumes, the
14 header arrangement here and here. This is the instrument
15 volume, and these are the hydraulic control units that have
16 the accumulator, and all the scram valves, and everything
17 associated with the scram system.

18 It is interesting to note here that GE is a design
19 member for the slope of the drain lines in the system of an
20 eighth of an inch per foot. And you can see here that on
21 the west side they had approximately a one inch per foot
22 slope down to the instrument volume, but on the east side
23 they had about a .13 inch per foot, so they just met the
24 one-eighth inch per foot slope on this side. It is 150
25 versus 20.

1 You will notice here that the vent lines off of
2 the scram discharge volume tie into a drain header right
3 here, and they rely on air being in this vent header for
4 their vent capability. The drain line off the instrument
5 volume also ties into a common drain header, and this feeds
6 into a sump, and the pipe is under water at this point.

7 This is a very large header system, and there are
8 a lot of open drains in this system, so you would expect air
9 to be in that header system, but not necessarily so.

10 Another point is that from this valve on and from
11 this valve on down is a non-safety grade part of the
12 system. That piping is not seismically qualified, and
13 necessarily it does not need all of the specifications of a
14 safety-grade system. And of course this drain header --

15 MR. KERR: Beginning where does it not meet safety
16 --

17 MR. YOUNG: From this drain valve down and from
18 this vent valve down. All of the instrument volume and the
19 header arrangement up here are safety grade up to the first
20 valve, which is here.

21 MR. KERR: But if you did -- let's see. If you
22 had an incident that would open it, it would not prevent
23 function; but if you had an incident that blocked it, it
24 would be serious.

25 MR. YOUNG: That is true, because the safety

1 function of these valves is to close, so if you --

2 MR. KERR: The safety function is to close, but if
3 you have them open it does not prevent scram, does it? It
4 just prevents containing the water.

5 MR. EBERSOLE: Safety function in the context of
6 stopping radiation leakage. If they were open and delayed
7 in closing, then the rods would have drifted in without
8 closing, not at the desired rate, but they would have gone
9 in.

10 MR. YOUNG: Right. If it was caused by the air
11 supply which connected that with the scram valves.

12 MR. EBERSOLE: If you left them open until you
13 ascertained scram, they would have gone in but not very fast.

14 MR. BENDER: What is it that is non-safety grade
15 about it?

16 MR. YOUNG: The piping is not analyzed
17 seismically, supported seismically not necessarily. That
18 does not exclude them from doing that, but they do not have
19 to do that. And the only other thing is the certification
20 of the pipe material, which is really not that relevant. It
21 is usually the same pipe, but it has a little more
22 documentation on it.

23 MR. BENDER: If one looked at it in terms of pipe
24 break, that would not prevent the scram system from working.

25 MR. YOUNG: The pipe would not have any effect on

1 this. The problem is that simply prior to a scram you
2 assume that this system is draining completely because this
3 valve is open and this valve is open; but since this is
4 non-safety grade or even if it were safety-grade, it does
5 not matter.

6 If this were plugged by water, trash, whatever, it
7 can prevent this from draining into the instrument volume,
8 and therefore defeat a safety function.

9 MR. KERR: What is the pressure buildup in that
10 system if you do not have drainage? Can the pressure build
11 up to 1500 psi?

12 MR. YOUNG: Prior to a scram?

13 MR. KERR: During an effort to scram.

14 MR. YOUNG: During a scram these valves close.
15 The water comes into the system, and it does pressurize to
16 full primary system pressure. That is its design.

17 MR. KERR: It will only go to primary system
18 pressure, or will it go to the 1500 psi that is indicated?

19 MR. YOUNG: The 1500 psi is the accumulator
20 pressure. If you let the scram valves completely open, that
21 water, that 1500 psi water would bypass the seals and go
22 into the reactor vessel, so that pressure would have to
23 pressurize the vessel as well as this to get the 1500.

24 MR. KERR: But you can go to vessel pressure.

25 MR. YOUNG: Yes.

1 MR. BENDER: Gary, would deformation of the header
2 have the indication of perhaps preventing the system from
3 draining properly and be a way of --

4 MR. YOUNG: Yes, sir. If this pipe were crimped
5 or bent or whatever, or this pipe, you could prevent
6 drainage.

7 MR. BENDER: Thank you.

8 MR. EBERSOLE: Successive scrams after a first
9 attempt are done by non-safety grade evolutions, because if
10 there has been some sort of stoppage of if these non-safety
11 grade valves have stopped so they cannot be opened, then you
12 do not have the privilege of a safety-grade second or third
13 or any other shot at the scram. It is designed for a
14 one-shot scram, not for successive scrams in the context of
15 having safety evolutions to permit secondary scrams after
16 the first attempt.

17 So this whole shutdown was accomplished on
18 non-safety grade evolutions, evolutions of non-safety grade
19 equipment which was cyclically opening these valves which
20 have no particular pedigree. You were not entitled to that
21 second drain.

22 Of course, you would not be if you crimped it.
23 You would never get it, even if the valves would not work.

24 MR. SHEWMON: You have to bend the pipe a fair
25 ways to completely shut it off.

1 MR. BENDER: I guess what I had in mind, it would
2 have to be pretty substantial displacement of the header
3 system. It is going to put its force right on that small
4 line. Just by bending it a little bit you can restrict it,
5 so the flow would be somewhat limited; and I can see that as
6 a way of eliminating the effectiveness of the whole drain
7 system.

8 MR. YOUNG: The way the system is set up, it was
9 intended to be set up if anything occurred that prevented
10 draining, the instrumentation in this would catch the water
11 buildup and cause a scram before that situation was a
12 problem.

13 But what happened at Browns Ferry simply was that
14 this header filled with water, and as it ran into the
15 instrument volume it was not picked up by the instruments
16 because -- well, I will show you. I have another drawing
17 that shows that a little better.

18

19

20

21

22

23

24

25

1 (Slide)

2 The design was there to prevent that problem, but
3 it did not work at Browns Ferry. This was a test after the
4 event to find out what could have caused the problem. They
5 filled the east header with water to simulate a blocked vent
6 line condition, and then they closed the drain valve here so
7 they could measure the water accumulation to measure flow
8 rate.

9 Based on that test, they found that this header
10 drained at the rate of .6 gallon per minute into the
11 instrument volume, which was good because that indicated
12 this thing is self-venting. If you close the vent, it still
13 will drain but it is a very slow drain.

14 (Slide)

15 They ran another test on the west side, and got
16 again a self-venting condition. But it drained at 3.2
17 gallons per minute with this vent valve closed, which was
18 much better but still not very good.

19 (Slide)

20 MR. SHEWMON: If I have a bottle of Coca-Cola and
21 pour it out, is that self-venting?

22 MR. YOUNG: Yes.

23 MR. SHEWMON: Thank you.

24 MR. YOUNG: This is a test to simulate both vent
25 valves closed or plugged, and both headers will fill with

1 water, and they got a combined flow rate this time of about
2 .6 gallons per minute. Then a final test was done to
3 simulate the normal condition.

4 (Slide)

5 This is the condition that would exist after a
6 scram normally. Everything is filled with water, and you
7 open the vents and the drain, and using some ultrasonic
8 indicators on these headers, they measure the amount of time
9 it took to empty them. They took 9.5 minutes to empty the
10 west side, 25 minutes to empty the east side, and the
11 instrument volume was completely clear.

12 The level alarm was cleared in 11.5 minutes, so
13 this indicated the problem, which is that at Browns Ferry
14 when this header empties it is draining at about 34 gallons
15 per minute. This level just continues to drop in the
16 instrument volume because it has a flow rate of 36 gallons
17 per minute.

18 Therefore, the water coming in from the east
19 header comes in at 11 gallons per minute normally. So it
20 just runs right through the instrument volume and the
21 instruments do not pick up anything, and yet there is still
22 water up here in this header.

23 Now, if you blocked this at all, this drain line
24 or the vent line, you will not get 11.6; you will get
25 something approaching .6 gallons per minute. So that

1 explains how the water was held up in this volume simply by
2 the fact that some -- they don't know how it got there.
3 There are several possible mechanisms for getting the water
4 in there.

5 The normal leakage from the scram discharge
6 valves, they leak a little bit. It is very small. They
7 measure a .03 gallon per minute leakage from all 185 valves
8 after the Browns Ferry event. It is a small leakage rate,
9 but if this were not draining properly, that would
10 eventually fill up this header and the operator would get no
11 indication over here.

12 MR. LEWIS: I did not understand one thing. When
13 they did the simulated test with both the east and west
14 header vents blocked, the flow rate was .6 gallons per
15 minute. But that was much less than the west alone was.
16 Why did blockage of the east one slow down the burbling of
17 the west one?

18 MR. YOUNG: I wondered that, too.

19 MR. LEWIS: I see. Thank you.

20 MR. YOUNG: When they filled both headers, it
21 allowed them to drain into the instrument volume. It
22 settled down to about a .6 gallon per minute drain rate.

23 MR. LEWIS: Is there any common section of pipe
24 between those two 2-inch lines before they go into the
25 instrument volume?

1 MR. YOUNG: No, there was not. They separately go
2 into the --

3 MR. LEWIS: They obviously interact somehow.

4 MR. EBERSOLE: Isn't there some -- the air flow
5 path --

6 MR. YOUNG: That may be. That may be.

7 MR. MOELLER: In the test you say they blocked the
8 vents from each side. Why did they do that? Did they have a
9 reason to believe the vents had been blocked?

10 MR. YOUNG: They suspected there was inadequate
11 venting that caused the problem, so they closed the vent
12 valves to simulate that condition. They had attached a
13 vacuum pump just after the event to the vent headers, and at
14 one point they were able to pull a slight vacuum with that
15 pump on the east side. They were never able to repeat that
16 experiment, but it implied there may have been some type of
17 blockage.

18 So that is the description of the Browns Ferry
19 event.

20 MR. LAWROSKI: Are the other Browns Ferry units
21 different from this?

22 MR. YOUNG: They are similar to this. There is
23 just minor piping variations.

24 MR. FRALEY: Maybe you ought to recap what the
25 staff has told the utility to do as a result of this.

1 MR. YOUNG: Okay. Right after the event, some
2 other problems occurred and they came up with a
3 recommendation on how to allow continued operation, and that
4 was to install some ultrasonic level indicators on these
5 headers directly rather than relying on this instrument
6 volume to tell the operator that he has water in the header.

7 In addition to that, they had they open this vent
8 line here to the atmosphere in the building so that when
9 this valve is opened, it is directly open to the building
10 atmosphere rather than relying on the string header
11 arrangement. So those were the two things that they
12 primarily did to allow continued operation.

13 MR. BENDER: There has not been any proposal to
14 subdivide those string headers further.

15 MR. YOUNG: Yes. The final solution that is being
16 recommended by G.E., and the utility is basically going
17 along, is to eliminate that drain line. I think Dot will
18 show in her presentation that the Brunswick design does
19 eliminate that drain line and it is a better arrangement.

20 MR. BENDER: I had in mind to have more separate
21 drain lines. This thing is divided into two halves, and one
22 might want to divide it into quarters or even a greater
23 subdivision than that.

24 MR. YOUNG: I see. I don't --

25 MR. BENDER: Commonality continues to be a matter

1 of concern, and as long as G.E. is going to make the
2 argument that they have independence within their scram
3 units, I think they ought to make damn sure they are really
4 independent.

5 MR. PLESSET: Well, does that finish your
6 presentation?

7 MR. CARBON: I have a question. It was my
8 impression from what you said that the problem perhaps
9 stemmed in part from plugged vents. From what you say, the
10 staff had those vents opened to the atmosphere to bypass
11 part of the line.

12 Did they do anything in terms of the valves, the
13 vents themselves?

14 MR. YOUNG: They have done some testing to make
15 sure the valves are operating properly, and they have done
16 some tests to make sure the system is venting properly when
17 the valves do open. The valves themselves have not been
18 changed. They are the same valves.

19 MR. PLESSET: Thank you, Gary.

20 Is there another question?

21 MR. LEWIS: A trivial question. In the real
22 world, the header pipes each have 90-odd T's in them, each
23 for the separate rod discharges, or do the rod discharges
24 come together before they go to the header or what?

25 MR. YOUNG: They are separate. They have 185

1 separate hydraulic lines that go from the rod drive
2 mechanism all the way and tie into the header.

3 MR. LEWIS: There are 95 T's in these pipes.

4 MR. YOUNG: Yes. These are small pipes and they
5 come up here into the header. This shows one of the 185
6 hydraulic control units. You have two banks on each side.

7 MR. LEWIS: Okay, thank you.

8 MR. PLESSET: Thank you, Gary.

9 I think Dorothy is next.

10 MR. YOUNG: Yes. She will talk about the
11 Brunswick and Hatch events.

12 (Slide)

13 MS. ZUKOR: What I am going to cover are the Hatch
14 and Brunswick events. I will go through the Brunswick event
15 first, mainly because I have more information.

16 I would like to preface this with the fact that we
17 are still gathering information and that any conclusions are
18 not necessarily final. There is information coming in, and
19 our conjectures and judgments on what has happened and what
20 may have to be done will probably change as more information
21 becomes available.

22 On October 19, 1979, the Brunswick unit underwent
23 a scram from full power. Following that scram, they noticed
24 damaged pipe supports along the drain line below the scram
25 discharge and instrument volume.

1 Now, this is a portion of the scram discharge
2 volume. This is the instrument volume at Brunswick. Notice
3 that there is no small two-inch line connecting the two.
4 Brunswick is one of the new BWPs and that line has been
5 eliminated in the BWP-6 design.

6 The pipe was damaged primarily on the south side,
7 although the north side did undergo some damage and some of
8 the switches. Essentially, the rod block and the high level
9 alarm switch were damaged on Brunswick. This damage is
10 believed to have been the result of a water hammer.

11 Now, this water hammer is not your classic steam
12 or steam collapse water hammer. It is mainly a hydraulic
13 event which we believe occurred when the system went solid
14 and the vent valve and drain valve failed to close in a
15 reasonable amount of time. These valves were normally
16 closing between 25 and 35 seconds, and at this particular
17 time the solenoid which controls both of those valves --
18 there is only one solenoid -- failed to close these valves
19 in a reasonable amount of time. So it was taking about 5
20 minutes for these valves to close.

21 At this point this entire system could have gone
22 solid and been that way when those vent and drain valves
23 failed to close. After the event, the licensee sent an LER
24 to NRC, and the NRC suggested that the licensee examine the
25 switches because the damage to the drain line was of such an

1 extent that it pulled some of the piping right out of the
2 wall.

3 So they suspected that maybe the switches had
4 undergone some damage. Now, the licensee had inspected the
5 switches, but from a visual inspection, not an inspection
6 where these switches were disassembled and radiographed. So
7 while a new valve or new solenoid was ordered, the plant
8 resumed operation with the vent and drain valve closed.

9 The idea behind this was that if it took too long
10 for the vent and drain valve to close and that was an unsafe
11 condition, then a very safe condition would be to have them
12 close from the beginning so you would not have to worry
13 about that problem. The idea was to open the drain and
14 drain the system every hour.

15 Well, the drain valve happens to be in an
16 extremely inaccessible place, so the operators decided that
17 they would wait for the high level alarm switch, and when
18 this switch came on, then they would drain the system. This
19 proceeded until November 14th, where a scram was obtained on
20 the high level scram switches, and none of the lower level
21 switches had alarmed.

22 Neither the high level alarm switch had sent any
23 indication nor the rod block switch. Upon investigation it
24 was found that both of those switches were damaged to such
25 an extent that they were inoperable.

1 (Slide)

2 Now, at this point since you still have fresh in
3 your mind what Browns Ferry looks like, I would like to go
4 through and show you the difference between the instrument
5 volume on these two plants. Notice that the scram level
6 switches come off, the scram level and the rod block level,
7 come off the instrument volume itself. The alarm level is
8 connected to the drain line.

9 This differs slightly from Browns Ferry where all
10 of the switches are in line and all are connected to the
11 drain line. We are not sure whether this is really a
12 significant point or not, but it is something to watch out
13 for. It is possible that the connection to the drain line
14 may be a source of some of these problems.

15 (Slide)

16 This is a partial isometric of the Brunswick
17 system. Notice that this is the alarm switch, this is the
18 rod block withdrawal switch, and these are the scram
19 switches. Again, this is the portion that is significantly
20 different from Browns Ferry.

21 MR. LAWROSKI: Do you know when those switches
22 were damaged?

23 MS. ZUKOR: We think it was October 19th. I don't
24 think anyone would want to swear to that because they had
25 not been disassembled and inspected to verify that they were

1 undamaged previous to that.

2 (Slide)

3 Notice the difference between Browns Ferry and
4 Brunswick. This is the long line. This line is completely
5 missing in Brunswick. Also, Browns Ferry only has one
6 instrument volume. Brunswick has one on each header.

7 (Slide)

8 This slide simply shows the initial configuration
9 before scram so that your vent and drain valves are open,
10 your system is empty, assuming it is draining properly.

11 (Slide)

12 At scram your vent and drain valves will close.
13 The system will fill with water. Now, this is the portion
14 that we believe caused the problem for Brunswick. In other
15 words, these valves should have closed much more rapidly
16 than they did.

17 In closing, on the order of 5 minutes it allowed
18 this entire system to fill up. Now, this water in here is
19 now at reactor pressure, so these valves when they finally
20 do close are closing against full reactor pressure, which
21 can create a transient that could go back and damage these
22 switches.

23 MR. EBERSOLE: I am under the impression that the
24 Browns Ferry valves closed instantaneously, more or less.
25 Is that correct?

1 MS. ZUKOR: They closed, I believe, in about 15
2 seconds.

3 MR. EBERSOLE: They are deliberately time
4 delayed. Is that correct?

5 MS. ZUKOR: I don't think so.

6 MR. EBERSOLE: They are accidently time delayed.

7 MS. ZUKOR: Yes. It takes that long for the air
8 to bleed off the valves.

9 MR. EBERSOLE: That is a variable you can control
10 any way you want.

11 MS. ZUKOR: And in some cases you cannot control
12 it.

13 (Slide)

14 These are the switches that were damaged, and this
15 is just a slight schematic that indicates roughly how they
16 were damaged. These switches are hydraulically tested before
17 they bleed the plant or their place of manufacture to 1625
18 psi. But this is a static test, basically. It is not done
19 under dynamic conditions.

20 Again, notice that although there were no damaged
21 switches on the south side, the rod block switch and the
22 high level switch are not present on the south side. That
23 is not to say that if they had been there, they would not
24 have been damaged.

25 (Slide)

1 Upon investigation it was found that neither the
2 drain piping nor the vent piping had been analyzed for any
3 type of load. As a result of that, the systems had to be
4 strengthened.

5 What I would like to show you now are some slides
6 that indicate how those systems really look and how they are
7 oriented and what are some of the adjustments that have been
8 made in light of this event. What you see here is the
9 header that comes down from the scram discharge volume into
10 the instrument volume. Notice that the scram discharge
11 volume and the instrument volume are basically one pipe
12 which is simply increased in diameter as it goes into the
13 instrument volume.

14 There is no clearcut cutoff between the scram
15 discharge volume and the instrument volume. What you see
16 off to the right here is one of the two scram switches.

17 (Slide)

18 This is the other scram switch. Some of this
19 instrumentation is the instrumentation that was on the
20 switches to do the NRC test to make sure that they were
21 operating properly. This is the rod block withdrawal
22 switch. This line will go into the scram discharge
23 instrument volume.

24 (Slide)

25 Again, this is the rod block withdrawal switch

1 going into the instrument volume and also connected to the
2 alarm switch which is off the drain line.

3 (Slide)

4 This is the drain line coming out of the scram
5 discharge instrument volume. No, this is the line which
6 underwent some of the damage and which had pipe supports
7 pulled off the walls.

8 (Slide)

9 This is what the floats looked like that had been
10 taken out of the rod block withdrawal and the alarm switch.
11 I cannot tell you which one, but they were equally
12 destroyed. So I don't believe it makes a whole lot of
13 difference.

14 (Slide)

15 As you can see, there is a rod that goes into the
16 ball and it is welded at the ball. These balls are 34'
17 stainless steel. There is no damage on the bottom or on the
18 sides to indicate that there was any other event other than
19 pushing the rod into the ball that damaged these floats.

20 (Slide)

21 Again, you can see that the float was damaged, and
22 in some cases it was damaged enough to rip the float itself.

23 (Slide)

24 Now, I have seen some pictures of floats from
25 Hatch, and they look very similar to this. They were

1 damaged in essentially the same way.

2 (Slide)

3 This is a picture of a vent valve. Now, this line
4 goes back into the vent header, which is one of the lines
5 that Gary spoke about, which is a vent and a drain line.
6 You can expect water to be in the line. You would not expect
7 it to be full. This is where it ties in.

8 (Slide)

9 This goes to the reactor equipment drain tank.

10 (Slide)

11 This is a picture of pipe supports. This is where
12 one of the previous pipe supports came out of the wall.
13 This is a picture of the new pipe support. It is difficult
14 to see because it is the same color, but I have another
15 picture which will make it more clear.

16 (Slide)

17 Here is a picture of them side by side. Notice
18 that the base plate is the primary change between the pipe
19 supports. The licensee has sent the NRC a memo and
20 indicated that should additional strengthening be required
21 because of further analysis, they will perform that
22 additional strengthening.

23 (Slide)

24 What I would like to do is go through the Hatch
25 event a little bit. There is much less information. It is

1 mostly data.

2 MR. BENDER: Before you go on, could you recap a
3 couple of things? I guess I was not too clear on how the
4 water hammer was initiated in the first place. Could you
5 clear that up?

6 MS. ZUKOR: This is not cast in stone. This is how
7 we believe it was initiated. The vent and the drain valve
8 delayed open, so that normally you would expect to have in
9 this system when this vent and drain valve closed. By
10 delaying the opening of these two valves, it allowed this
11 entire system to fill with water before this vent and drain
12 valve slammed shut.

13 When it finally did shut, they were closing
14 against not air but water that was at reactor pressure. So
15 it is possible that by closing against that force, it
16 created an impulse back into the system.

17 MR. BENDER: How many times has the opportunity
18 for that event to occur occurred? Is there any feeling for
19 that?

20 MS. ZUKOR: I cannot give you a number, but it has
21 occurred more frequently than we originally suspected
22 because upon looking back into the computer printouts and
23 some of the LERs, we found that these vent and drain valves
24 had failed on different occasions to fail in their expected
25 time, and there have been damaged floats found.

1 MR. BENDER: Is it several times a year or several
2 times a month or what?

3 MS. ZUKOR: Not even that. It is on the order of
4 four events in the LERs that we have managed to look at so
5 far.

6 Are there any other questions on Brunswick?

7 MR. EBERSOLE: Concerning the closing mode, what
8 you suggest is these things approach closure and then they
9 rather suddenly snap shut; they do not progressively close
10 and thus diminish or break the acceleration of the water; is
11 that correct?

12 MS. ZUKOR: We have not been able to get the
13 complete characteristics of the valve yet, but we believe
14 that is what it does.

15 MR. EBERSOLE: Thank you.

16 MR. LEWIS: Is there obvious rationale for not
17 having a high level switch on the south instruments?

18 MS. ZUKOR: Not that I can find, no.

19 MR. LEWIS: I see.

20 MR. FRALEY: I think that is considered an alarm
21 and not a safety function, so they don't duplicate it.

22 MR. LEWIS: From the north but not from the south.

23 MR. FRALEY: That is correct.

24 MS. ZUKOR: The alarms are for the convenience of
25 the operator rather than for safety.

1 (Slide)

2 In Hatch-2 -- I am sorry, Hatch-1, on June 13th
3 the Hatch-1 plant was shut down for refueling. At that
4 time, two out of four scram switches were found to be
5 inoperable, and this inoperability was believed to be due to
6 an adjustment and maintenance which was done on the switches
7 earlier.

8 Up until this time the switches had been operating
9 properly and they had passed all their surveillance
10 testing. However, when the LERs were examined and the
11 events that involved the vent and drain valves, it had been
12 found that on the 5th of May in 1980, the vent and drain
13 valves had failed to close on trip and the damage was found
14 on the vent line in May. So there are events -- these are
15 not related because the shutdown was mainly for refueling,
16 and Brunswick, as you know, underwent a scram and that is
17 why they noted they effects.

18 But there are more events than originally thought
19 of occurring on this particular system.

20 Now, I am not going to make any conjectures about
21 Unit 1 having a drain system that looks like this because I
22 found out that every one is different and the best thing you
23 can do is not assume anything about them until you see the
24 drawings.

25 MR. EBERSOLE: Could you throw the previous slide

1 up for just a minute?

2 MR. PLESSET: Use your mike, Jesse.

3 MR. EBERSOLE: The one that shows the signal
4 circuitry.

5 (Slide)

6 The question was asked about having only on one
7 leg the annunciator. I think there is a generic thing here
8 that ought to be called out. This is a classic example of
9 the fact that operator information fed to the operator is
10 single track and non safety grade, and a low grade in
11 general, not in a class with automatic safety functions,
12 which you notice in the scram systems are duplicated.

13 There is the one shot pitch to the operator that
14 this level exists. The other case is duplicated, and that
15 is typical of most all information fed to operators on which
16 they base their safety actions, which is one of the generic
17 problems we have.

18

19

20

21

22

23

24

25

1 Heretofore, we have always considered operator
2 information non-safety grade in character. This is just an
3 example of that.

4 (Slide.)

5 MS. ZUKOR: Now, Hatch-2 has undergone similar
6 damage to Brunswick. I have seen pictures of the floats and
7 they are partially collapsed. In fact, they look very
8 similar to the Brunswick floats that were damaged.

9 However, the damage that occurred sort of
10 precludes the assumption that it is all connected with the
11 drain line, because one of the floats that was damaged was
12 on the north bank and one was on the south bank; and these
13 were the scram switches, as opposed to the rod block
14 withdrawal or the alarm switches. So as of yet, we are
15 still not sure exactly what the mechanism is that is
16 damaging these plates.

17 MR. SHEWMON: Normally, one of the two should see
18 the same pressure there.

19 MS. ZUKOR: Correct.

20 MR. BENDER: This was learned by physical
21 inspection as opposed to symptomatic indications?

22 MS. ZUKOR: The float damage?

23 MR. BENDER: Yes.

24 MS. ZUKOR: Yes, because the floats are in a
25 housing. As you saw, you cannot see any of the floats from

1 the outside. You have to either disassemble the system or
2 radiograph it, and I get the impression that even
3 radiography does not show it. You almost have to
4 disassemble them to see that they are okay.

5 MR. BENDER: And this was learned as a result of
6 the NRC all points bulletin or whatever it was?

7 MS. ZUKOR: Correct.

8 MR. BENDER: Correct.

9 MR. FRALEY: Which scram switch was damaged?

10 MS. ZUKOR: I don't know precisely which one. One
11 on this side and one on this side.

12 MR. FRALEY: One on each side.

13 MS. ZUKOR: And right now that is all the
14 information we have available to us on Hatch, and more
15 information is expected to come in.

16 MR. SIESS: Dot, near the beginning you said
17 something about the design, with the two scram discharge
18 instrument volumes, that GE had had a new design for
19 BWR-6's, and I think that was the term you used.

20 MS. ZUKOR: Gary is going to go through that.

21 MR. SIESS: I got the impression earlier that
22 these systems really were not designed by GE; that they just
23 specified volume and it was up to the AE or subcontractor.
24 Does that mean that GE is telling people what they want?

25 MS. ZUKOR: Yes. They have a suggested design.

1 They cannot require their licensees to use the suggested
2 design.

3 MR. SIESS: Did they have one before?

4 MS. ZUKOR: I do not believe so. As a result,
5 they had a subcontractor --

6 MR. SIESS: It would be interesting to know why
7 they have now suggested something that is good, where before
8 they did not suggest anything, including what was not good.

9 MR. PLESSET: There was one outfit which designed
10 these.

11 MR. SIESS: I know that. But Dot says GE now has
12 a suggested design, and I got the impression that previously
13 they did not even have a suggested design. They just said,
14 you want 3.3 gallons, they said, that is right. I wondered
15 what they learned or what happened to cause them to change
16 their policy and suggest a design which is a good design, it
17 looks like, in terms of the volumes and the hydraulics.

18 MS. ZUKOR: I do not think they had a suggested
19 design. The scram discharge volumes themselves are very
20 similar. Where they tend to differentiate is below the
21 scram discharge volume into the instrument volume.

22 MR. EBERSOLE: I think they found that general
23 criteria and specifications were insufficient.

24 MR. SIESS: If that were true, this would be
25 reportable, because it would be a safety deficiency on all

1 the previous plants, wouldn't it? I am not a lawyer. Is
2 there one present? They seem to decide those things.

3 MR. BENDER: I recall a generic item that referred
4 to interfacial relationships between balance of plant and
5 the primary -- the nuclear system. And we took it out
6 because the regulatory staff said they had now established a
7 requirement for checking those interfaces.

8 MR. SIESS: We only got concerned about interfaces
9 with standard plants, and I don't think any of these are
10 standard designs. These are all just so-called "custom
11 designs." Custom designs are made by different people. We
12 never talked about interfaces on custom designs.

13 MR. FRALEY: Apparently, somehow GE did get the
14 word, as history moved forward, to put in the hockey stick
15 versus the drain line and to put in DP cells versus the
16 floats, which were evolutions in this system design, which
17 did get passed on to the AE's, but we are not quite sure
18 how. Because you can see this evolution over the years.

19 MR. SIESS: What I am interested in is what -- did
20 something happen that made them realize this was an
21 improvement or did somebody just sit down and think of it
22 and say, gee, this is an improvement? I don't think anybody
23 has found any previous incidents of flow blockage.

24 MS. ZUKOR: No, no.

25 MR. SIESS: And did they occur and not be --

1 MS. ZUKOR: I believe that question was asked of
2 GE and there was no real response that said why they changed.

3 MR. SIESS: Here we have some bad systems and some
4 good systems. There was a reason for the good systems.
5 Apparently they were not completely accidental. And I would
6 sort of like to know why we get good things sometimes, as
7 well as why we get bad ones.

8 MR. PLESSET: Thank you, Dot.

9 Let's go back to Gary

10 MR. YOUNG: Okay. I would like to briefly go to
11 the recommendations that were made by the NRC Office of
12 Analysis and Evaluation of Operating Data. They reviewed
13 the Browns Ferry 3 event specifically and came to some --
14 had some findings and some recommendations. The findings
15 are listed in the handout. I will not go through those.
16 But the final recommendations are shown here.

17 (Slide).

18 And the first recommendation is that the
19 operability of the instrument volume high-level trip or
20 scram system should be independent of venting and draining
21 requirements. And this goes back to the fact that at Browns
22 Ferry the drain problem presented in the instrument volume
23 from seeing the water and initiating a scram when they have
24 water there.

25 So he is recommending that the operability of this

1 system be independent of venting and draining. I will show
2 later how that can be accomplished.

3 They recommend that the instrument volume
4 instruments be redundant and diverse. And the reason for
5 that is obviously that there are problems with the
6 instrumentation, such as was found at Brunswick and Hatch,
7 and that you cannot always rely on this instrumentation, on
8 these floats, to work properly. So they are recommending
9 that they be -- they already are redundant, but they are not
10 diverse.

11 MR. BENDER: Gary, if you satisfy one, is two
12 important?

13 MR. YOUNG: Yes.

14 MR. BENDER: Why?

15 MR. YOUNG: Because the instruments -- if you just
16 satisfy one, if you made a system where the instruments will
17 see the water if there is water there, but if they are
18 unreliable they may not cause a scram and, number two, make
19 sure that they are reliable, diverse, and redundant, they
20 will initiate a scram if water is present. So they really
21 are directly connected.

22 MR. BENDER: Thank you.

23 MR. YOUNG: The third item is that all the vent
24 and drain paths from the scram discharge volume should be
25 redundant automatic isolation valves. Right now there is

1 one vent valve on each of the headers and one drain valve on
2 the instrument volume.

3 The concern there was the single failure of any
4 one of those valves would result in a leakage of primary
5 system water following a scram. So they are recommending
6 that they become redundant valves instead of just a single
7 valve that they have now. And this is to assure that the
8 system is bottled up following a scram.

9 The fourth item concerns operating procedures to
10 be followed during the complete or partial scram failure.
11 Apparently, at Browns Ferry 3 there was concern that the
12 operator did not initiate the standby liquid control system
13 or the boron injection system, and he would have needed some
14 upper management approval to do so, when in fact the
15 decision probably should have been made much quicker.

16 So this is not true at all plants, but apparently
17 at Browns Ferry that was a problem.

18 And then the fifth item is a recommendation -- it
19 is not really safety-related. It says: Consider modifying
20 the vent drain arrangement to improve drain reliability. It
21 goes back to the problem of having a vent drain tied into a
22 drain system that might not be able to adequately vent.

23 So this was more, as I said -- as I say, consider
24 it. It is not a necessity if you do all the other things.

25 GE has made a recommendation, preliminary '

1 recommendation, on a configuration that would meet all of
2 the items that I just discussed.

3 (Slide).

4 This is the hockey stick arrangement that exists
5 on the newer plants. This is the scram volume, and then the
6 instrument volume is an integral part. It has no drain line
7 between the two. Therefore, any water that gets in the
8 system, because it is slow, will drain into the instrument
9 volume and therefore you cannot have the situation where
10 there is water up here and not down here.

11 And that would be independent of a vent or a drain
12 on the system. It would not matter if the vent drain
13 worked; water would still fall to the lowest point, and then
14 the instrumentation they showed here has been slightly
15 modified to not connect with the drain line any more. It
16 connects directly with the instrument volume.

17 And this was, I think, an attempt to correct the
18 water hammer problems at Brunswick and Hatch. It is not a
19 definite solution because no one really knows what caused
20 the problem at this point.

21 MR. BENDER: Was this possibility considered in
22 regard to --

23 MR. YOUNG: I believe the NRC staff is looking
24 into -- this is just a recommendation that they -- that GE
25 has made. And I believe during their presentation the staff

1 will discuss some of that, the other possibilities.

2 MR. BENDER: Thank you.

3 MR. PLESSET: I have to make a remark. We let
4 Gary pass over pretty easily the remark about the operator
5 needing upper management approval for boron injection. It
6 depends on what kind of situation you are in as to whether
7 one can do it or not without management intercession.

8 MR. SHEWMON: Is management the SRC on duty or do
9 they have to call up the front office or something?

10 MR. YOUNG: It is the on-plant management, the
11 shift supervisor.

12 MR. SHEWMON: But that person is not necessarily
13 in the control room. He is available someplace, hopefully,
14 in the plant.

15 MR. YOUNG: Yes, he is definitely in the plant.
16 And I think normally he would be very close to the control
17 room.

18 MR. EBERSOLE: It requires twice as many
19 instruments to accomplish the same function as the old
20 design did. Therefore, it is half as reliable.

21 MR. YOUNG: It requires twice as many instruments,
22 but I believe -- for example, if water got into this header,
23 it would scram the plant. So it is really kind of
24 redundant.

25 MR. EBERSOLE: Wait a minute. These have to be

1 coincident on both sides.

2 MR. YOUNG: No, sir. Any water in either header
3 would scram the plant.

4 MR. EBERSOLE: They have rigged it for A and B
5 channels?

6 MR. YOUNG: It is similar to the design that
7 already exists at Brunswick. It is really the same type of
8 configuration.

9 MR. EBERSOLE: You will still get scram?

10 MR. YOUNG: I don't believe that is true. I
11 believe you've got water in just one of these headers; then
12 you would scram the plant.

13 MR. KERR: Can't we find out that -- don't you get
14 scram, supposedly, while you still have enough volume left
15 to produce scram?

16 MR. EBERSOLE: If you have scram and you fill it
17 up, then you don't have a second option.

18 MR. YOUNG: The half-scram does not cause a rod --
19 the rods don't move at all on a half-scram.

20 MR. EBERSOLE: I mean a half-stroke.

21 MR. YOUNG: A half-stroke, I see, okay.

22 If there are not any more questions, Dot Zukor
23 will talk a little bit about the WASH-1400 comparisons of
24 these events.

25 (Slide).

1 MS. ZUKOR: As a result of analyzing the scram
2 systems, we have more or less generally concluded that the
3 BWR scram systems are not as reliable as originally expected
4 and thought.

5 (Laughter).

6 And as a result, some of the calculations done in
7 WASH-1400 are a little bit overly conservative that the
8 system will work. Now, what I have here is a fault tree for
9 the analysis done for a failure to complete a successful
10 scram for Peach Bottom. This is similar to the Browns Ferry
11 plant in that it has that two-inch drain line. At least now
12 it does. Soon it will be changed. But it still has the
13 two-inch drain line.

14 Now, previously this was the only mechanism
15 thought of that would block the system, and you usually have
16 water entering the header, as Gary mentioned, because you
17 have some leakage into the system. Once that satisfies that
18 end gate, it can continue to go up to the top, where you
19 have a failure to successfully scram.

20 This number here is on the order of 10^{-7} , which
21 is extremely small, which you would usually expect for a
22 dead leg pipe that is basically a passive component.

23 (Slide).

24 Now, what I have done with this system is to
25 include the fact that if this header fails to drain -- and

1 it can fail to drain for more than one reason, not
2 necessarily that particular two-inch line. It can fail to
3 drain for a number of reasons:

4 One is if the scram discharge instrument volume
5 fails to drain, and that can be because the drain valve
6 fails to operate or the level instruments fail to function,
7 which has been found to be not an uncommon occurrence.

8 (Slide).

9 The trip header vent line can fail to vent, again
10 for a similar reason. You have your vent valve failing to
11 operate.

12 Now, what this would do for a plant like Browns
13 Ferry is simply slow the rate of drainage down. But it may
14 be significant enough to prevent the system from draining
15 properly, or your vent line itself is plugged. Again, you
16 have the original vent which was on the original WASH-1400
17 fault tree, which says, okay, the drain line is blocked.

18 Now, what reduces this probability of failure --
19 and you have it on your handouts; I did not write it on the
20 transparency -- is that the vent valve and the drain valve,
21 because of their active compatibility, have a much higher
22 probability of failing than, say, this class of component
23 here.

24 So your trip header failing to drain becomes
25 something on the order of 10^{-3} or 10^{-4} rather than

-7

1 10 . Notice, however, that at Browns Ferry there is the
2 possibility that that was precisely what happened, even
3 though it is a very low probability event. It could have
4 been that that system was drained.

5 Now, after the event, the whole scram discharge
6 instrument volume at Browns Ferry was cleaned very
7 completely. So it is possible that we will not find out
8 where that plug was, or if in fact there was one.

9 MR. SHEWON: Did they analyze what came out of it
10 besides water?

11 MS. ZUKOR: Yes. They found some crud, but
12 nothing that was significant to make them think it would
13 have blocked the system. And at places where there were
14 bends and turns, they cut the turns out and checked the
15 system to make sure that there were no plugs in there. And
16 they were not able to find any.

17 MR. FRALEY: There was one other thing. Do did
18 not include in here the probability of a design deficiency
19 which would increase the probability of such a failure, and
20 that in effect is what they have concluded happened at
21 Browns Ferry. This long run of pipe that would not drain,
22 you know, that let the SDIV drain faster than the scram
23 discharge volume, which was really a design deficiency,
24 which would have been another leg to this fault tree.

25 MR. LEWIS: I don't entirely understand the

1 definition of "probability" here, Dot, because 10 to the
2 minus -- normally, the probability is that when you call on
3 something it will not perform, whereas here a blockage or a
4 filling of a header can be a long-term affair. So the
5 probability is that when you look for a scram, you will find
6 that it actually was blocked. That depends on how often you
7 look for a scram.

8 MS. ZUKOR: Yes.

9 If there are no more questions, I have completed
10 my presentation.

11 MR. PLESSET: Any other questions?

12 MR. LEWIS: I would like the record to show that
13 the Chairman promised me the answer to a question earlier.

14 MR. PLESSET: We will still get that answer for
15 you. Don't worry. Just stick around.

16 MR. LEWIS: Is that the price I have to pay?

17 MR. PLESSET: That is the price.

18 Well, I want to thank both Gary and Dot for their
19 presentations, which I think were rather models of clarity.
20 And the Committee rarely has that kind of an opportunity to
21 be exposed to clarity. Let me put it that way.

22 Well, let's take a ten-minute recess.

23 (Recess.)

24

25

1 MR. PLESSET: Let's reconvene.

2 It would be moderately appropriate since Gary is
3 an ex-ACRS fellow and Dot is still an ACRS fellow, to
4 introduce new ones to the committee, and maybe I can ask
5 them to appear.

6 Stu Biehl, would you stand up? The new ACRS
7 fellow. Thank you. And Bill Baldowitz up there. Thank you.

8 So now the committee members will be getting onto
9 you pretty quick for all kinds of interesting tasks.

10 Well, let's go on -- we are running a little late
11 -- the staff presentation. And I think that Mr. Speis is
12 going to take over. Would you go ahead?

13 MR. SPEIS: Thank you, Mr. Chairman.

14 I am Thomas Speis of the Office of Nuclear Reactor
15 Regulation. Before I make some opening remarks I would like
16 to congratulate the fellows for doing such an outstanding
17 job, and our people will attempt to be as clear as possible.

18 We have a number of items to go over today, but we
19 also have in mind to go through the description of the event
20 and the description of the design, but that part of the
21 presentation will be abbreviated since it has been given
22 already by the -- by your fellows.

23 We will concentrate basically on the actions that
24 the NRC has taken since the events, of both short-term
25 actions taken and short-term actions underway, as well as

1 longer term actions. Also, we will cover analyses covering
2 "what if" type of questions, assuming -- superimposed -- if
3 you had some limiting transients. And also we will say a
4 few things about the implications for the ATWS position.

5 I would like to ask you if you think -- by the
6 way, our presentation is probably an hour and a half with a
7 moderate amount of questions. Mr. Thadani will be making
8 the presentation on the implications of ATWS, but he has to
9 leave here about ten after 12:00 to go to a Commission
10 meeting. So if you think our presentations will go beyond a
11 quarter after 12:00, we would like to get him after Mr.
12 Mills makes his initial presentation.

13 MR. PLESSET: That is fine. Let's do that.

14 Now, you remember we promised Mr. Lewis some --

15 MR. SPEIS: Is this the analysis of the event?

16 MR. PLESSET: Yes.

17 MR. SPEIS: This will be presented today also. We
18 have a number of staff members, and they will be introducing
19 themselves as they make their presentations. In addition to
20 myself, there is Ed Jordan from the Office of Inspection.
21 He will help orchestrate the staff's presentation.

22 So with no further remarks, Mr. Mills will start
23 the presentations.

24 MR. PLESSET: Thank you.

25 MR. MILLS: My name is Bill Mills. I am a member

1 of the IE staff.

2 (Slide.)

3 Since Gary and Dorothy have discussed the partial
4 scram at Browns Ferry-3 and the Hatch and Brunswick events,
5 I will briefly summarize those and primarily discuss the
6 concerns of the Browns Ferry-3 event as raised within the
7 staff, the short-term actions we have taken through Bulletin
8 80-17 and related ongoing short-term actions, and our
9 conclusions on the Browns Ferry-3 event.

10 (Slide.)

11 This slide shows a simplified diagram of the scram
12 discharge volume at Browns Ferry, and as previously stated
13 this morning, the function of the -- the function of the
14 scram discharge volume is to receive exhaust water from the
15 control rod drives during reactor scram.

16 During normal operation prior to scram, scram
17 discharge volume is empty, the vent and drain valves are
18 open, and leakage into the system drains into the instrument
19 volume of the drain line. Level switches are provided on
20 the instrument volume to detect an accumulation of water.

21 In the Browns Ferry-3 partial scram event, an
22 accumulation of water in the east scram discharge volume
23 caused a failure of the rods to scram. Even though the
24 exact cause for that accumulation of water is not known, the
25 basic problem with the system is the poor communication

1 between the scram discharge volume and the instrument volume.

2 These two volumes are connected, as previously
3 stated, by approximately 150 feet of two-inch piping. This
4 makes it possible under certain conditions to accumulate
5 water in the scram discharge volume without detection in the
6 instrument volume.

7 As I will discuss later, we have taken corrective
8 actions to ensure that this does not happen again. I will
9 discuss them in more detail later. But briefly, we have
10 required that the vent and drain valves be operable, and
11 that has to be verified, and verification that the vent
12 lines are free of obstruction, that this system is free to
13 drain. And also we require direct monitoring of the scram
14 discharge volume, besides the normal instrumentation
15 provided here.

16 We have also required that following each scram,
17 all of these level switches be functionally tested with the
18 injection of water to make sure that they are operable.
19 This is the result of the Hatch and the Brunswick concerns
20 with the damaged lines.

21 MR. BENDER: Why are you insisting on the
22 operability of the vents?

23 MR. MILLS: If you have an ineffective vent, then
24 the draining of the scram discharge volume will be degraded.

25 MR. BENDER: Will it be ineffective?

1 MR. MILLS: It can be, yes. It depends on the
2 leak rate into the scram discharge volume, and there are two
3 cases. One would be following a scram in which you started
4 with the system full, and you would get a slow draining
5 rate. But during normal operation with the system empty you
6 would get a better draining rate even if the vent were
7 plugged.

8 MR. CARBON: How sensitive are your devices on the
9 scram discharge volume? Will they pick up the thing half
10 full, ten percent full?

11 MR. MILLS: Within about one inch.

12 MR. CARBON: How big is the volume?

13 MR. MILLS: The pipe size varies from plant to
14 plant, and they can take measurements on various places.
15 Usually they take it right near the reducer from the
16 six-inch pipe to the two-inch pipe.

17 At Browns Ferry currently they have a UT monitor
18 there. They believe that the accuracy of that is within, it
19 is either a quarter or a half inch, so that would be out of
20 a six-inch pipe, a quarter or a half inch, so it is less
21 than an inch.

22 MR. JORDAN: We can add to that that that volume
23 is also sloped, so we are looking at the accumulation in the
24 sloped end of it.

25 (Slide.)

1 MR. CARBON: One more question. Are those devices
2 required before the plants can return to operation, or what
3 is the schedule?

4 MR. MILLS: Yes, it is required following scram
5 before return to operation that each of those switches be
6 operable and functionally tested.

7 The Browns Ferry-3 event caused the staff to
8 question the reliability of the scram function, and our
9 understanding of the as-built scram discharge volume
10 configuration.

11 We determined that short-term corrective actions
12 were needed to justify continued operation, and that
13 long-term corrective actions were needed to provide a new
14 scram discharge volume design, improved reliability, and
15 that implementation of ATWS-related procedures and not
16 applications were necessary.

17 MR. EBERSOLE: All events related to BWRs, isn't
18 there also an implication here that there are subtleties in
19 design detail that may well be present at the PWR design
20 analogous to this one into which we have never looked, such
21 as undervoltage relay functions which may present a problem?

22 MR. MILLS: That is correct, and I think that is a
23 good point; and that is part of what the NRR task force will
24 consider in their longterm actions.

25 MR. MOELLER: In terms of the first item, the

1 reliability of the scram function, I am looking at this
2 memorandum of August 22 from Denwood Ross to Harold Denton
3 with an attachment, and it says that "The PAS group conclude
4 that the Browns Ferry experience does not negate the
5 validity of prior probabilistic estimates set forth in
6 WASH-1400."

7 And then the next paragraph says that "It is clear
8 that the occurrence has created considerable concern
9 regarding the reliability of the GE scram system, and that
10 the failure rate or failure estimate has been revised."

11 Are those two statements compatible, and could you
12 explain them in relation to what -- to this aspect of the
13 problem?

14 MR. PLESSET: I think Speis wants to make a
15 response.

16 MR. SPEIS: What are you reading from?

17 MR. MOELLER: I am reading from the attachment to
18 this memorandum of August 22, 1980. I can show it to you.

19 MR. PLESSET: That is a memo from Denny Ross.

20 MR. MOELLER: Page 3, item 5 and 6.

21 MR. SPEIS: We will address it later on.

22 MR. PLESSET: Okay, fine. Why don't you go on
23 then?

24 (Slide.)

25 MR. MILLS: The staff took immediate corrective

1 action following the Browns Ferry-3 event to ensure that an
2 event of that type did not reoccur. Actions were taken both
3 through an 80-17 -- the requirements of that bulletin are
4 listed here.

5 For all BWRs it was required that within three
6 days they verify that the scram discharge volume is empty
7 and operable. By "operable" we mean that the vent and drain
8 valves are operable, that the vent line is free from
9 obstruction, and that the system is empty and draining --
10 and will drain.

11 We also required scram tests to be performed to
12 confirm that no significant problems existed and to provide
13 data on the operation of the scram discharge volume and its
14 draining characteristics.

15 We required that the scram discharge volume be
16 verified empty after the scram tests and after all other
17 scrams that occurred. We also required procedures for
18 monitoring the scram discharge volume daily for an
19 accumulation of water.

20 They were required to have emergency operating
21 procedures to ensure that operator actions were adequate for
22 an event of the Browns Ferry-3 type.

23 In addition, actions were specified in the
24 bulletin to be taken to mitigate the consequences of an ATWS
25 event.

1 (Slide.)

2 After issuance of the original bulletin 80-17,
3 Supplement 1 was issued. This supplement was issued
4 following further staff review, and the information that was
5 received on as-built configurations.

6 Supplement 1 required continuous monitoring of the
7 scram discharge volume to be installed by September 1 or
8 additional actions had to be taken. A design review of the
9 vent system to find ways to improve the venting of the scram
10 discharge volume. Procedural controls for the use of
11 standby liquid control, we required that the key be
12 maintained in the control room, and the operator be provided
13 with procedures and criteria such that he could make the
14 decision without management approval, that he could initiate
15 standby liquid control if it were deemed necessary.

16 We also required a verification of as-built
17 drawings for the scram discharge volume, and in particular,
18 interties with the vents and drains to identify any
19 deficiencies.

20 MR. EBERSOLE: We asked TVA in the L.A. meeting
21 about the continuous monitoring. Subsequently we found out
22 there was a control that ran by every thirty minutes that
23 looked at a continuously monitored signal but was viewed by
24 operators only once every half hour, so this left a vast
25 exposure.

1 If an accidental fill takes place in the 29
2 minutes that the operator was not looking at it -- was that
3 not subsequently corrected?

4 MR. MILLS: I will be discussing that.

5 MR. EBERSOLE: Okay.

6 MR. MILLS: You are correct. They have a
7 continuous monitor there, and they have one individual who is
8 assigned to go from one unit to the other and look at those;
9 but I will get into that a little later.

10 MR. BENDER: I heard some words like requiring the
11 key, I think you said key to the standby liquid control
12 system, the actuator, I guess, be in the control room.

13 MR. MILLS: Correct.

14 MR. BENDER: That tells me something that I guess
15 I was not aware of. Is there the possibility that some guy
16 could take the key and walk out and there would be no way to
17 actuate the liquid control system because it is locked up?

18 MR. MILLS: I do not think that that is a
19 realistic possibility for a couple of reasons. They also
20 require it be in a designated location.

21 MR. BENDER: I don't care about the key. If the
22 key is not there, can you actuate the liquid control system?

23 MR. MILLS: No. You need a key in the switch in
24 order to actuate. It has to be a deliberate action.

25 MR. EBERSOLE: This will bring up a fundamental

1 issue.

2 MR. BENDER: Well, we can think about that some.

3 MR. EBERSOLE: I think it is a good time to bring
4 up a fundamental issue, and that is whether one should use
5 keys or frangible seals like lead-sealed wires. And in my
6 own view, a key is infinitely worse than a frangible seal,
7 which is clearly indicative of having been pre -- is a clear
8 preventative for any inadvertent action.

9 I wish we would get rid of the keys and put in
10 frangible seals.

11 MR. MILLS: As you are aware, we have positions
12 for installation of equipment to mitigate ATWS, and in there
13 we are looking for automatic initiation of a standby liquid
14 control. So there are actions going on that would eliminate
15 that problem in the future.

16 MR. PLESSET: That might be a long time coming.

17 MR. MILLS: That is true.

18 (Slide.)

19 Supplement 2 to Bulletin 80-17 was issued after
20 testing at Browns Ferry-1 and Dresden-3. It highlighted the
21 importance of the event on a scram discharge volume. This
22 supplement required that for each EWR, the vent for the
23 scram discharge volume rely on no component other than the
24 scram -- excuse me, other than the vent valve, and that the
25 vent must be positive in its function at all times, directly

1 connected to reactor building atmosphere.

2 If the vent configuration did not conform with
3 that requirement, they were to make modifications within 48
4 hours. As a result, approximately 15 plants modified their
5 vent system.

6 (Slide.)

7 MR. LEWIS: What does the term "positive in its
8 function at all times" mean?

9 MR. MILLS: That it be open.

10 MR. LEWIS: It means that there is no valve in --

11 MR. MILLS: There is no closed valve, and no
12 component has to operate to provide the function, and that
13 the line be free and clear to the atmosphere.

14 MR. LEWIS: If there is a valve that can fail, of
15 course -- I'm trying to understand the "at all times" --
16 that means there is literally nothing in the line.

17 MR. MILLS: Right. It is open. It is free to
18 communicate with the atmosphere.

19 MR. LEWIS: Okay.

20 MR. MILLS: Supplement 3 was issued following a
21 concern that was raised by Mr. Michaelson of AEOD that loss
22 of air pressure in the scram discharge volume could result
23 in filling the scram discharge volume prior to reactor scram.

24 The bulletin required procedures to ensure that
25 operator action took place so an event of this type would

1 not occur, and it required immediate manual scram of the
2 reactor on low air pressure or other signals that would be
3 indicative of a loss of air pressure in the CRD system.

4 And I would point out that there are alarms
5 directly on the CRD system downstream of the pressure
6 regulator for the CRD system, so that that pressure is
7 monitored directly to the scram valves.

8 MR. KERR: What does "low" mean?

9 MR. MILLS: In this case it means 10 pounds.
10 There is a margin of 10 pounds above the pressure at which
11 the valves would start to open.

12 We also required that the functional tests of all
13 level switches be performed following each scram and prior
14 to reactor startup because of the problems we have observed
15 with those switches.

16 MR. PLESSET: Have you made any suggestions
17 regarding the kinds of switches they might use?

18 MR. JORDAN: In terms of the level indicating
19 switches?

20 MR. PLESSET: Yes.

21 MR. JORDAN: The next fix or the measurement on
22 the volume after September 1 is generally going to be a
23 UT-type level fix.

24 MR. PLESSET: That is general now. I knew TVA was
25 going to do that. Now you are making that a general.

1 MR. JORDAN: We did not specify. We were not
2 prescriptive as to what type switch. We were looking for
3 diversity between these ball-type float switches and the
4 utilities in general, and through GE selected the UT level
5 measurement.

6 MR. PLESSET: Okay. Thank you.

7 MR. MILLS: Our status so far, all plants have
8 responded to both 80-17 through Supplement 2. Scram tests
9 have been completed on all plants except Brunswick-2 which
10 is currently shut down for an outage.

11 Our review of the responses is ongoing. However,
12 our screening and information so far has identified some
13 scram deficiencies which I will discuss in a minute.

14 Responses to 80-17 through Supplement 2 have been
15 satisfactory for all plants. They have implemented
16 procedure changes, modification to the vent as necessary,
17 and in general the requirements in the bulletin.

18 There is one exception and as we have discussed,
19 we required continuous monitoring be installed by September
20 1 on the scram discharge volume for an accumulation of water
21 or that additional actions had to be taken.

22 In the responses we found out that most plants
23 will not have the continuous monitoring installed by
24 September 1. By "continuous" we mean continuously recorded
25 in the control room and alarmed in the control room.

1 So getting back to your point, the current Browns
2 Ferry configuration would not satisfy this requirement.

3 MR. EBERSOLE: How long will that be allowed to
4 persist?

5 MR. MILLS: I will cover that in just a minute.

6 The additional actions that were required in the
7 bulletin were that if they could not have it in by September
8 1, give us a detailed explanation as to why it could not be
9 in, provide a firm schedule for installation of the
10 continuous monitoring, and increase the frequency at which
11 it is monitored.

12 Right now it is on a daily frequency, and we were
13 looking for something shorter between the tests.

14 (Slide.)

15 This slide shows the scram system deficiencies
16 which have turned up so far. You notice the first two and
17 the last one are concerned with the float damage that has
18 been observed at Brunswick and Hatch.

19 I would like to point out that our involvement
20 with the float damage at Hatch and Brunswick and prior to
21 the Browns Ferry-3 event, the Operational Events Evaluation
22 Branch was established in I&E after the Three Mile Island
23 event. However, it was established after the Brunswick and
24 the Hatch events had occurred.

25 But during our review of operating experience,

1 besides keeping up with the current operational problems, we
2 went back into past problems as time permitted. That is
3 when we uncovered these events, recognized the significance
4 of the events, had discussions with NRR that resulted in the
5 issuance of Bulletin 80-14 prior to the Browns Ferry-3 event.

6 The other scram deficiencies identified here, I do
7 not plan on going through each one. These have been
8 discussed briefly in the bulletin or one of the supplements
9 previously, except for the Fitzpatrick problem which was
10 found most recently when they returned from a refueling
11 outage and did their 80-17 scram tests. They found they had
12 a small loop seal in the drain piping from the discharge
13 volume to the instrument volume.

14 The system did drain properly except a small
15 amount of water was retained in that loop seal.

16 MR. MOELLER: You were not going to discuss them,
17 but can you give us a rough date for the Hatch-2 event?

18 MR. MILLS: I can give you an exact date.

19 MR. ZUKOR: I think it was June the 26th.

20 MR. MOELLER: I wanted to mention that because the
21 emphasis in the presentation has been on Bulletin 80-17. On
22 June the 12th they issued Bulletin 80-14, and you had had
23 failure in Hatch-1, and this was issued then on June the
24 12th. And if on June the 26th, then two weeks later,
25 Hatch-2 has a problem, I am surprised somewhat.

1 What did Bulletin 80-14 accomplish? Here we have
2 not only the same utility but the same station in presumably
3 a duplicate unit having a problem that had occurred in the
4 other unit and which was the subject of a bulletin.

5 MR. MILLS: The failures at Hatch-2 were
6 discovered by July 26th.

7 MR. MOELLER: July, that is even worse. So it is
8 six weeks.

9 MR. MILLS: And they were found as a result of
10 testing from Bulletin 80-17, not Bulletin 80-14.

11 MR. MOELLER: What did Bulletin 80-14 accomplish
12 then? What was its intent?

13 MR. MILLS: This particular unit right here was
14 the only unit that was not injecting water directly into the
15 float chamber to test the operation of the float. They were
16 doing their functional testing just by manually actuating
17 the electrical portion of the switch, and when they
18 responded to Bulletin 80-14, they did not recognize that
19 that is how they were doing their tests. So as a result,
20 their failures went undetected, and it was subsequent in the
21 80-17 testing that they realized the problem that they had.

22

23

24

25

1 MR. MOELLER: That helps some. Thank you.

2 MR. EBERSOLE: Did they just take the panel off
3 and move the panel up and down?

4 MR. MILLS: I think all they did was actuate the
5 contacts on the switch, close them, and saw that they got
6 the proper response in the protective system.

7 MR. ETHERINGTON: Was that a reasonable
8 misunderstanding or should they have understood what was
9 intended?

10 MR. MILLS: The reason that they did that is that
11 they have the standard tech spec, versus other plants which
12 have the older form of tech spec. And it was the new tech
13 spec that led them to do this type of test the way the
14 functional test is described in the standard tech spec. The
15 frequency of the functional test was increased at Hatch-2 by
16 the standard tech spec. It was moved from quarterly to
17 monthly, so they did it more often. But they did not do it
18 with the injection of water.

19 MR. JORDAN: I will answer that. It was a very
20 unreasonable response on their part, based on the intent of
21 the bulletin.

22 MR. KERR: I cannot understand the response of the
23 presenter, because he seemed to imply that they did a test
24 specified by tech specs, and you are saying --

25 MR. JORDAN: I would like to separate the bulletin

1 from the tech specs, and say that the bullet was identifying
2 a problem to them and they clearly should have responded to
3 that particular problem, that there was damage occurring to
4 the floats, and they should test them in a direct manner,
5 not an indirect.

6 MR. KERR: I don't understand the tech spec
7 comment. What was it meant to be?

8 MR. JORDAN: That was the licensee's excuse, not
9 the staff's position at all.

10 MR. KERR: I guess I do not understand the
11 comment. What was his comment meant to tell us?

12 MR. MILLS: The plant definitely made a mistake,
13 and they did respond when they found their mistake and
14 reported that they had made an error in their response to
15 Bulletin 80-14.

16 MR. KERR: What did the standard tech spec versus
17 a non-standard tech spec have to do with it? I am curious.
18 I still do not understand.

19 MR. THATCHER: The standard tech specs have
20 defined channel functional tests, and they defined it for
21 both an analogue channel, where you are using some device,
22 like the transmitter, that puts out an analogue signal and
23 from that you get an actuation signal; and they also define
24 a channel function test for what they call a bistable
25 channel.

1 But there is potential for someone reading those
2 and misinterpreting exactly what is being said. The words
3 in those definitions are to the effect that one should
4 inject a signal as close to the monitored parameter as
5 possible. So if someone chose to, they could misinterpret
6 those words and change the tests, which as I understood,
7 they did start out with a channel test, channel functional
8 test, that included adding water. Is that right, at
9 Hatch-2? At Hatch-1 they were doing that.

10 MR. MILLS: I am not sure on Hatch-2.

11 MR. ETHERINGTON: I think they chose to
12 misunderstand. I think that is what you are saying.

13 MR. THATCHER: I think if you read documents like
14 IEEE 279 and so forth, I don't think you could misinterpret
15 those statements. However, the words in the tech specs are
16 not --

17 MR. KERR: Has any thought been given to the
18 possibility that maybe the wording in the tech specs could
19 be changed so they could not be misinterpreted?

20 MR. THATCHER: I personally don't know if they are
21 thinking about doing that.

22 MR. MILLS: The tech specs --

23 MR. KERR: Since these are standard tech specs --

24 MR. MILLS: There were previously deficiencies in
25 the tech specs, and we required that the tech specs be

1 modified to have functional tests that directly inject water
2 into those float chambers.

3 MR. KERR: Okay. So the tech specs now could not
4 be misunderstood, even deliberately.

5 (Laughter).

6 MR. THATCHER: No, I would not say that.

7 MR. OKRENT: Let's see --

8 MR. MILLS: The requirements --

9 MR. OKRENT: Are you suggesting they be
10 prescriptive?

11 (Laughter).

12 MR. KERR: I don't see how one avoids being
13 prescriptive in tech specs. That is what they are meant to
14 do.

15 MR. OKRENT: Well, but I think it would still
16 follow the same idea, that what you are trying to have the
17 licensee do is test the things in an adequate fashion, at a
18 certain frequency. And that would in principle say, we are
19 now not being prescriptive; we are telling the licensee that
20 there is a certain period in which he should test and --

21 MR. KERR: I am suggesting they be as unambiguous
22 as possible, then.

23 MR. OKRENT: I would say unambiguous, but not
24 prescriptive.

25 MR. KERR: It prescribes -- well, I agree with

1 you.

2 MR. SIESS: Would you buy that standardized tech
3 specs have to be prescriptive?

4 MR. OKRENT: We frequently pick on the staff
5 because they are too prescriptive, and --

6 MR. KERR: Tech specs by definition tell one
7 specifically the operating conditions. They give things
8 like power level, temperatures, and they use numbers. And
9 they in that sense have to be prescriptive.

10 MR. MILLS: I would like to point out that our
11 bulletin was very non-ambiguous as to what they had to do
12 with those switches; that they had to inject water and test
13 them with the use of water; and also that the tech specs had
14 to reflect that. And sample tech specs were sent out and
15 new tech specs will be coming in to reflect the bulletio.

16 (Slide).

17 Our short-term actions are ongoing. We are
18 reviewing responses to 80-17. We have an ongoing review to
19 identify the need for improvement in other areas of the
20 control rod drive system. And we are considering further
21 actions to require installation of continuous monitoring of
22 the scram discharge volume by December of 1980, monitoring
23 once per shift in the interim.

24 MR. EBERSOLE: How do you arrive at the adequacy
25 of a once per shift, rather than once every three days or

1 once every five minutes or once every ten seconds? What is
2 the basis of your decision?

3 MR. MILLS: I personally feel that once per day,
4 as currently required, would detect the accumulation of
5 water in the scram discharge volume.

6 MR. EBERSOLE: At what rate of introduction, and
7 what is the basis for that?

8 MR. MILLS: The basis is that if it were to come
9 in -- if it were to come in at a rate faster, such that it
10 would fill up in less than 24 hours, we would get
11 indications either from rod drift, rod temperature alarm, or
12 low air pressure, and that action would be taken from those
13 other considerations.

14 MR. EBERSOLE: Has that relationship been
15 established by calculation?

16 MR. MILLS: I am not sure what kind of
17 calculations you are referring to.

18 MR. EBERSOLE: The degree of leakage per unit
19 time, according to the condition of valves or the condition
20 of the air pressure or whatever. I mean, it seems to be a
21 quantitative problem.

22 MR. MILLS: It is, and I think all the mechanisms
23 that we have identified so far for getting water into the
24 scram discharge valve we feel are -- we feel that it is
25 appropriate for those leak rates that could exist into the

1 volume and out of the discharge volume, as well as not being
2 able to detect it in the instrument volume.

3 MR. EBERSOLE: That would include a stuck rod
4 valve, rod dump valve?

5 MR. MILLS: Yes, because if it were partially
6 stuck open, if the value were low enough that it did not
7 give an indication on the temperature alarm or a rod drift,
8 and it was just one of them, then that would be a low enough
9 volume that the scram discharge volume would not fill up
10 within the 24 hours.

11 MR. ETHERINGTON: Couldn't you get leakage from
12 the cooling water without actuating the temperature alarm?

13 MR. EBERSOLE: The water coming in is from the
14 cool water side. There is no mixing. It progresses up from
15 the bottom to the top.

16 MR. MILLS: There is a low enough value at which
17 you could get, let's say, less than .1 gpm; you could get
18 leakage out of that drive such that you did not actuate the
19 temperature alarm. But for the drive the way it is
20 constructed, if the leakage gets to approximately .1 gpm you
21 will get a temperature alarm.

22 MR. BENDER: Who is responsible for the second
23 item up there?

24 MR. MILLS: This is independent of the long-term
25 effort that is going on in NRR. This is part of an I&E

1 review that we do of operational events and BWR operating
2 experience.

3 MR. BENDER: I am not really clear on what was
4 meant by that. I would presume that somebody is looking at
5 the need for alterations in the design of some sort. Is
6 anything intended more than an LER review?

7 MR. JORDAN: Not for that item. That was on the
8 short-term actions, and so we were talking about, you know,
9 immediately related to this event. We are still looking at
10 this event and the facets of it that could contribute
11 further. We are still talking short-term. So the design
12 changes you are talking about are long-term and they will be
13 discussed separately.

14 MR. BENDER: Okay. How many LERs exist that
15 relate to this item right now?

16 MR. JORDAN: I don't know off the top of my head.

17 MR. BENDER: Is there any group looking at the
18 LERs?

19 MR. PLESSET: Dorothy confided in me that she
20 thinks there are something like 12.

21 MR. BENDER: I understand Dorothy's review.
22 Dorothy is on the ACRS staff. I want to know what the NRC
23 regulatory staff is doing.

24 MR. JORDAN: There are two groups that are doing
25 it, both AEOD and NPR, you know, that are doing systematic

1 reviews of that data now.

2 I will say that the I&E review group is more on
3 real time, the events of today, and we are only looking back
4 a very short time. So we are not doing a constant review of
5 all LERs in a systematic way. We are looking at the current
6 events, their relationship to recollected events, and then
7 the short-term actions. So that's how our office is
8 interacting.

9 MR. BENDER: I heard what you said. But why
10 aren't the LERs being looked at in a systematic way?

11 MR. JORDAN: They are, but not by I&E.

12 MR. BENDER: Who is doing it?

13 MR. JORDAN: AEOD and NRR. That was my first
14 answer.

15 MR. BENDER: Is there a name?

16 MR. SPEIS: It is the NRR responsibility to review
17 LERs.

18 MR. BENDER: If I wanted the guy's telephone
19 number, what would it be?

20 MR. SPEIS: Excuse me?

21 MR. BENDER: What man would I call?

22 MR. LEWIS: Looking at LERs means looking at all
23 LERs that relate to scram systems, to the entire reactor
24 protective system. Is that what the job is?

25 MR. SPEIS: The job is to review all the LERs for

1 all reactors.

2 MR. LEWIS: All LERs, everything?

3 MR. SPEIS: Yes.

4 MR. LEWIS: Oh. Thank you.

5 MR. EBERSOLE: May I have a clarification on some
6 relationships? There was an instruction to provide
7 continuous monitoring, which was refused by the applicants
8 and has been set aside until December, I believe.

9 MR. MILLS: It will be installed on a schedule --
10 some plants will have it in earlier because of availability
11 of equipment. We are looking for the last one to be in in
12 December.

13 MR. EBERSOLE: So four months from now we are
14 going to be dependent upon two parameters that determine we
15 are not filling the scram volume, that is, rod drift and
16 temperature; is that correct?

17 MR. MILLS: Those alarms, the daily monitoring.
18 We still would have that. The daily --

19 MR. EBERSOLE: I am not counting that as being
20 worth anything, because of the possible flow rates. If the
21 rod drift and the temperature monitoring are unreliable --
22 if I declare they are unreliable arbitrarily, then I can
23 easily fill up in far less than a day with some leakage.
24 Now, then I am going to get back to my credibility of rod
25 drift and temperature.

1 Following Mr. Etherington's question, I don't yet
2 see how you cannot have cool water emerging from the rod
3 drive system and flowing up into the rod and thence through
4 a leaky valve to fill the volume in a time far shorter than
5 the periodic interval of inspection. I don't think
6 temperature will show. I am not sure about drift.

7 In any case, both drift and temperature are
8 non-safety grade systems.

9 MR. MILLS: They are non-safety grade systems, and
10 I don't think I said that we would not have relatively cool
11 water. I think what I said, to the best of my
12 understanding, it is correct that, for the drive, the way it
13 is constructed and operated, if the valve does leak when you
14 do get to around .1 gpm, the temperature alarm will come in
15 if it works.

16 And if you question the operation of the
17 temperature alarms and the drift alarms, yes, I have to
18 agree then that you could get water in the discharge volume
19 without alerting the operator. I think the likelihood of
20 that is quite low, that you are going to have a significant
21 sudden degradation of those scram valves without getting
22 some annunciation to the operator.

23 MR. EBERSOLE: This .1 gpm to the valve, is that
24 not made up from water from the drive system, not water from
25 the reactor?

1 MR. MILLS: I see it has been a combination,
2 because it goes into -- it is a very small amount, on the
3 order of .1 to .2 gpm per rod; and it goes into the drive
4 and it mixes with reactor water that is already in the drive.

5 MR. ETHERINGTON: It should not mix; it should
6 drive the reactor water out. The pressure is 25 psi above
7 the reactor pressure.

8 MR. MILLS: Right. But I think it has to mix in
9 the drive as it flows up along --

10 MR. ETHERINGTON: It will mix if it is full of
11 reactor water to begin with.

12 MR. EBERSOLE: The credibility of temperature is
13 worth a re-examination. Evidently, that is all we are
14 riding on, since you do not seem to mention drift.

15 MR. MILLS: We can look at it in more detail and
16 we will in response to your comment. But my understanding
17 is it cannot get directly from the cooling water into the
18 drive -- to the scram outlet, without a flow path through
19 the drive.

20 MR. PLESSET: I think GE told us in Los Angeles
21 that the leakage was not the coolant water, but the reactor
22 water.

23 MR. EBERSOLE: That was due to a peculiarit,
24 the system.

25 MR. PLESSET: Right.

1 MR. EBERSOLE: How reliable that peculiarity is I
2 don't have a feel for.

3 MR. JORDAN: Dr. Ebersole, when the scram
4 discharge valve begins to leak, then the 25 psi differential
5 you have is decreased in that drive. The drives were
6 manifolded separately, so that when you do get an increasing
7 amount of reactor water that is coming through the seals and
8 going back out --

9 MR. EBERSOLE: What you are riding on, in addition
10 to this, is a full control mechanism that pinches off the
11 cold water flow.

12 MR. JORDAN: If you have the scram discharge valve
13 open, you no longer have the 25 psi on that particular drive
14 as being a differential. You are dropping the pressure.

15 MR. EBERSOLE: I see. Okay. Thank you.

16 MR. OKRENT: I wonder if the staff has a response
17 to this question, the one Dr. Moeller raised earlier about
18 the seeming discrepancy between the analysis of the PAS
19 staff and then the succeeding statement. And also, is there
20 something in writing which documents the analysis of the PAS
21 staff?

22 MR. SPEIS: Yes, there is something in writing.
23 There is an internal memo.

24 MR. OKRENT: I would like to request that I
25 obtain a copy of it; if I can do it this way, unless you are

1 going to make me use the Freedom of Information Act.

2 MR. SPEIS: No.

3 MR. OKRENT: Thank you. But could you tell us a
4 little bit about that seeming discrepancy? Do you have any
5 comments?

6 MR. SPEIS: Donnie will discuss it.

7 MR. OKRENT: Yesterday in a Subcommittee meeting
8 on a range of questions, we were talking to Mr. Stello and
9 Mr. Denton, and we were trying to ascertain how the staff
10 decided that after the partial failure to scram had
11 occurred, it was or was not okay for all the BWRs or some of
12 the BWRs to continue to operate. And I would say we got a
13 sort of judgmental answer.

14 Now, I think one thing we did here was that there
15 was an estimate made by Mr. Thadani or somebody that you
16 take the BWRs as a class and they just put this piece of
17 information in. The scram unreliability was on the order of
18 -- unreliability, one in ten per demand, and that is not
19 radically different, as I recall, from what the ACRS fellows
20 got by looking at fault trees, that it is a factor of ten,
21 that sort of thing.

22 So I am wondering if in fact staff thought the
23 unreliability was on the order of one in ten at that point.
24 And now, let me think in terms of the points that do not
25 have recirc pump trips; how it was decided that this was an

1 acceptable mode for continued operation. I am trying to see
2 for myself, when the staff decides something needs to be
3 done in a day or a month or a year or just, we will study
4 it, and so forth. And this seems to me to provide a test
5 case.

6 Can we get any comment from I&E?

7 MR. JORDAN: Dr. Okrent, that was an I&E, NRR
8 concern, that we did not have the reliability in those
9 systems that we understood or had previously understood.
10 The basis for continued operations was that the actions we
11 were prescribing in this case for the licensees we felt
12 would return those systems back to that level, let's say, of
13 reliability which we previously understood they had.

14 And so those were essentially immediate actions we
15 took with the affected licensees.

16 MR. OKRENT: It is not clear to me that you knew
17 enough shortly after this occurred about the designs of each
18 system, in fact, to know where there might be weak spots or
19 single failure points or whatever; that from a fault tree
20 analysis, in addition to just, you know, an empirical look
21 at the data, it might indicate that the unreliability was
22 pretty low.

23 It is also not clear to me that at the time that
24 you indicated, if the licensee should do certain tests,
25 there was any basis for knowing that these would really

1 remedy the situation.

2 So I hear you, but I really question that you had
3 the same depth of knowledge, let's say, that we have today.
4 So I am trying to understand this and you know, compared to
5 other things, like what was done after Three Mile Island to
6 certain B&W plants. Let me suggest that had this event been
7 a full ATWS at full power and the pressure pool had gotten
8 very hot, your actions may have been different, although it
9 would not have changed the unreliability of all the other
10 BWR systems. They would be where they were.

11 Do I make the point? I am trying to understand
12 the rationale. I think in fact the staff does exercise
13 judgment in situations these days where the estimated
14 probability of an event is thought to be substantial,
15 whatever that means, and I become increasingly interested in
16 knowing how and on what basis you do it.

17 You know, you do not have quantitative criteria.
18 There is nothing in fact -- they are decisions made that end
19 up having quantitative applications.

20 MR. JORDAN: It was clearly a judgment based on
21 the knowledge that the staff had, and I don't think I can go
22 further than that, based on the discussions you had
23 yesterday already.

24

25

1 MR. LEWIS: I want to associate myself with the
2 point Dave is making because I agree that the general
3 pattern one perceives is that the squeaky axle gets the
4 grease, and the amount of grease depends upon the loudness
5 of the squeak rather than the implications of the need for
6 grease. That is a very important point.

7 But on another point closely related -- and I also
8 would like to see the PAS analysis that shows that WASH-1400
9 was vindicated because I thought that there was no part of
10 WASH-1400 more discredited than the calculation of the
11 probability to scram for a BWR. I thought that was
12 something we had put behind us a long time ago, and that
13 seems not to have been the case.

14 So under your Freedom of Information Act request,
15 I want to look at the same thing.

16 There is one other point, if I may, Mr. Chairman,
17 and that is that obviously this Browns Ferry event and Hatch
18 and Brunswick before are going to raise a whole host of deep
19 philosophical problems about the reliability of scram. As I
20 look at the WASH-1400 diagram that I guess Dot passed out,
21 there is a left side, which is electrical, and a right side,
22 which is hydraulic.

23 All our conversation has been on the hydraulic
24 side. But my memory, such as it is, was that G.E. always
25 estimated that the prime vulnerabilities were on the

1 electric side, which we seem not to talk about. Again,
2 squeaky axle.

3 I wonder if as we reassess the implications of the
4 event we might take a somewhat broader view than just
5 blockages in two-inch lines.

6 MR. PLESSET: I am very glad you made your
7 comments because it reminds me of another point. I am going
8 to ask you and Dave to give me some paragraphs for our
9 letter on this thing. Since you have spoken so eloquently, I
10 expect these paragraphs both from you and Dave to be
11 eloquent.

12 MR. LEWIS: I will write the even words if you
13 write the odd ones.

14 (Laughter.)

15 MR. EBERSOLE: Since he got into the electrical
16 area, he does not need to bother with the hydraulic area.

17 MR. PLESSET: We are going to ask you also, Jesse,
18 to give us some paragraphs.

19 (Laughter.)

20 MR. PLESSET: And Harold has not said much, but we
21 are going to ask Harold to contribute.

22 I wonder if you have much more, because we do want
23 to get Mr. Thadani up here as soon as possible because he
24 has to leave early.

25 MR. MILLS: This is the last slide I have here.

1 Our conclusion on Browns Ferry 3 is that the
2 corrective actions being taken ensure that the scram
3 discharge volume is empty during power operation. If the
4 discharge volume is empty, the scram will work when called
5 upon. These corrective actions are necessary and they are
6 sufficient to justify continued operation.

7 If the scram discharge volume is empty, the scram
8 function will work. Long-term corrective action is
9 necessary and is under way. This is headed up by the Task
10 Force, which will be discussed later.

11 MR. PLESSET: Okay. Now, we will certainly
12 remember the requests that were made by Lewis and Okrent. I
13 am sure we will not forget.

14 Yes.

15 MR. MOELLER: Just a quick question without even
16 the answer now. But I have been asking what was the purpose
17 and objectives of this Bulletin 80-14. I notice in the same
18 memo that I referenced earlier, it says in response to
19 Bulletin 80-14, "some BWRs were performing SDV level
20 instrument functional tests after every scram."

21 You see, that leaves me confused. Were they doing
22 it out of the goodness of their heart or were they doing it
23 because they chose to interpret Bulletin 80-14 in a manner
24 so as to require such tests? I would hope that someone later
25 this morning could clarify that for me.

1 MR. PLESSET: All right. Let's come back to that
2 question after, unless you have a yes or no quick answer,
3 because I do want to get --

4 MR. SPEIS: I would like to make two points before
5 Mr. Thadani speaks. First of all, we have not excluded for
6 the long term problems associated with the electrical part
7 of the system. I would like to make that clear
8 immediately. We did focus on the electrical part and we got
9 some satisfaction. I cannot quantify that. We should pay
10 more attention to the hydraulic part but we have not
11 excluded the electrical for the long term.

12 Also I would like to make the point that in answer
13 to Dr. Okrent's point -- we were concerned with these
14 plants, and one of the questions we raised with licensees in
15 Bulletin 80-17 was to perform analysis without RPT showing
16 us what kind of degrading had to be performed in order not
17 to exceed their pressure and temperature limits -- the
18 pressure limits.

19 MR. OKRENT: I am familiar with the fact that you
20 asked for this and there was at least one response that I
21 have seen, but that is only part of the decision-making
22 process. At the moment I am not saying that what you did
23 was right or wrong. I am interested in understanding the
24 decision process in some depth because, as I say, I think we
25 are getting involved in decisions that are on the borderline

1 of which way to go.

2 I think the auxiliary feed-water systems which are
3 not seismically qualified is another example of one which in
4 my mind is not on the borderline. It is not sitting clearly
5 in a situation where everything is all right for the
6 indefinite future, or let's say we cannot run another
7 minute, so if we are encountering such, I think we had
8 better start understanding it.

9 I do not think the answer "it was our best
10 judgment" can continue to be an adequate approach even if
11 that is all you can do on Saturday. Maybe by the following
12 Saturday you ought to have reevaluated it and decided yes,
13 this is why it still remains our best judgment, and we can
14 tell you.

15 MR. PLESSET: Let me come back to Jesse and to
16 Paul after Thadani. His time is rapidly disappearing.

17 MR. SHEWMON: Let me ask a short question of the
18 last speaker. If one Duane Arnold finds an SDV drain valve
19 installed backwards, does that get reported as an LER?

20 MR. MILLS: It would now because of our
21 requirements on the vent drain valves previously. It would
22 not necessarily have been reported.

23 MR. SHEWMON: Thank you.

24 MR. PLESSET: We will come back to you Jesse, I
25 promise.

1 MR. THADANI: I am a member of the NRR staff. In
2 at least partial response to your question, it is a
3 difficult question in terms of the type of considerations
4 one goes through in making any decision. Indeed, when we put
5 together some of the requirements for licensees in Bulletin
6 80-17, some thought was given to those plants which do not
7 yet have ATWS-related recirculation pumping solved.

8 The rationale was to try to assess what could be
9 done at these plants to minimize the risk from such events
10 while we were still trying to find out what had actually
11 happened at Browns Ferry, and what, if anything, could be
12 done to improve the situation.

13 If you remember, at an earlier meeting we had
14 given you a schedule of implementation of recirculation pump
15 trip in all plants. My understanding is that unless things
16 have changed, that all operating boiling water reactors were
17 to have recirculation pump trip implemented by the end of
18 this year, and this is the ATWS-related recirculation pump
19 trip and not the end-of-cycle recirculation pump trip.

20 I do believe in the decisions that were made
21 following the Browns Ferry event. This was taken into
22 account, as well as the actions that were being taken.

23 As you know, we have had the ATWS issue for many
24 years, and we have at least taken the position that the risk
25 from an ATWS event, if for a moment we leave Browns Ferry

1 aside, risk from ATWS events, while it is high, it is not so
2 high so as to shut the plants down; that improvements have
3 to be implemented at some schedule, hopefully a fairly rapid
4 schedule.

5 I think the same kind of thinking was involved in
6 the decisions that were made following the Browns Ferry
7 event. As you remember, back in March of this year we had a
8 meeting with the ACRS at which we discussed our
9 recommendations on this issue, the alternatives that we had
10 considered. In April we received your letter giving us your
11 advice as to which way to proceed, and the care we were to
12 apply in implementing significant design modifications in
13 terms of schedules that were proposed in our earlier report.

14 We were taking into consideration your letter as
15 well as the industry comments in preparing what we called
16 Commission Policy Paper on this issue when the Browns Ferry
17 event occurred. As soon as the event occurred or soon after
18 that, we sat back and said what does it mean in terms of
19 what we have been doing in this paper that we are writing
20 for Commission consideration? What lessons had we learned,
21 if any?

22 The first lesson, I think, that we learned was
23 indeed the reliability of the scram system is not as high as
24 had been planned by certain sectors of industry. Indeed,
25 the overemphasis -- what I would call overemphasis on the

1 electrical portions might have been the reason for having
2 missed the seriousness of the type of Browns Ferry scenario,
3 the concern that certain failures are difficult to
4 recognize, especially for highly reliable systems, or that
5 if a failure is recognized, sometimes there might be a
6 tendency, based on some sort of judgment, to say the
7 likelihood of this kind of a failure mode is very low.

8 Indeed, that is what happened in terms of the type
9 of failure we saw at Browns Ferry and earlier industry
10 approaches, especially as they related to boiling water
11 reactors.

12 Another important lesson I think we learned was
13 the recommendation that we had made that was termed
14 Alternative 2A in our report, improvements in the reactor
15 scram system to reduce its likelihood of failure. If they
16 had been implemented, they would not have prevented the
17 Browns Ferry event at all, because again, the concentrated
18 effort in terms of improvements was in the electrical
19 portion.

20 The proposed diversity was to be incorporated in
21 the logic portion, and the sensors in the instrument
22 portion. You have heard a lot of discussions in terms of
23 the problems that these sensors have experienced, and that
24 was one of the reasons for our insisting that we ought to
25 provide some diverse means of detecting the amount of water

1 in the instrument volume.

2 But that would not have done anything in terms of
3 the water in the scram discharge volume. So it is my belief
4 that the proposed modifications would not have prevented the
5 Browns Ferry-3 event.

6 On the other hand, perhaps another important
7 lesson we learned was that mitigation, again, might be the
8 most appropriate means of taking care of types of failures
9 which have very low likelihood of occurrence, ones that are
10 difficult to predict. It has reemphasized, in my opinion,
11 the need to do, obviously, as good a job as one can do in
12 terms of design of the system, sit back and learn from these
13 experiences.

14 We are bound to make mistakes. We are bound to
15 miss certain aspects of the systems, and subject to the
16 consequences from those potential scenarios, one ought to
17 seriously consider ways that would be diverse and would,
18 indeed, mitigate the consequences of both events. We had,
19 as you know, taken the course over the last few years.

20 In my opinion, the Browns Ferry event further
21 emphasized that that was the way to go. I took a very quick
22 look to see how we might impact the frequencies and so forth
23 of ATWS events that we have discussed with you over the last
24 few months, at least. You, as well as we, recognize the
25 uncertainties and so on in these estimates.

1 I did what I would call a conservative assessment,
2 assuming that the Browns Ferry event is indeed a legitimate
3 failure to scram event -- and I believe Marvin is going to
4 discuss with you the potential consequences of the Browns
5 Ferry event if it had occurred at 100 percent power along
6 with an anticipated transient, or, for that matter, if you
7 had half a scram at 100 percent power along with an
8 anticipated transient.

9 (Slide)

10 If you will just accept for the moment that for
11 those scenarios subject to certain operator action fairly
12 early in the event -- when I talk about early, I am talking
13 about very, very, very few minutes -- the consequences
14 certainly would be quite serious.

15 Just to summarize some of the things we have done
16 in the past, the first row, which says Prior to Browns
17 Ferry-3, the estimated frequency of a severe ATWS event was
18 on the order of 2×10^{-4} , and I am only addressing
19 boiling water reactors now. If we assess that if the type of
20 modifications described under what we called Alternative 3A
21 had been implemented, this frequency of severe ATWS events
22 would be further reduced on the order of 10^{-5} per reactor
23 year.

24 The types of changes under Alternative 3A were
25 recirculation, pump trip, automating the standby liquid

1 control system, as well as making sure that the poison
2 system would inject simultaneously. Currently most of the
3 plants cannot do that because of piping design limitations.

4 Alternative 4A basically went further and said we
5 ought to also be able to handle a single failure in any of
6 the mitigating systems. And for what it is worth, I am not
7 going to try to justify the 10^{-6} number, but rather to
8 point out if you go to the event tree approach and for the
9 moment accept that there is not a common mode failure that
10 would disable scram as well as the mitigating system, which
11 has a frequency higher than 10^{-6} , indeed that is what you
12 would come up with roughly.

13 Now, the Browns Ferry event occurred, and what
14 does that mean? We took a look at the experience in terms
15 of the total number of scrams that have occurred at boiling
16 water reactors. It is approximately, I believe, on the
17 order of 5000 or so. And a fairly simple point estimate
18 would indicate that failure to scram probability would be on
19 the order of 10^{-4} , combined with the recurrence frequency
20 of anticipated transients.

21 The estimate of ATWS frequency would be on the
22 order of 10^{-3} .

23 MR. KERR: Do you have a confidence level
24 associated with that?

25 MR. THADANI: No. It is a point estimate. It is

1 basically 50 percent.

2 MR. KERR: Okay.

3 MR. THADANI: Having said that, certainly most of
4 us recognize that as a result of this event, certain actions
5 have been taken. All these actions are directed towards
6 reducing the likelihood of this kind of an event. My belief
7 is that the true frequency today would be lower than 10^{-3}
8 per reactor here. And whether it is 2 times 10^{-4} or
9 10^{-3} per reactor year, I do not know.

10 I tend to think that as a result of the actions
11 taken, the system is better than it was, and we believe in
12 making these rough estimates in terms of frequency of
13 events, I would expect the frequency of an ATWS in the
14 revised system would probably be closer to 2 times 10^{-4}
15 than 10^{-3} . But again, this is a very subjective personal
16 opinion.

17
18
19
20
21
22
23
24
25

1 I do think improvements have been made to reduce
2 the occurrence rate of this kind of a failure mode. So what
3 that meant -- basically there is a difference of a factor of
4 5 between considering this event or excluding this event
5 from consideration. You can translate this factor of 5 all
6 the way across, depending on whatever alternatives are being
7 considered.

8 Another approach was to say this is yet another
9 example of the type of failures that are likely to occur
10 that for whatever reasons we are not going to be able to
11 predict, and that there are certain recurrence frequencies
12 for these types of failures.

13 Instead of looking at this in isolation, if you
14 will, in terms of just being applicable to boiling water
15 reactors, maybe we ought to sit back and say, okay, what if
16 we were to say that this is representative of a frequency,
17 if you will, of a failure which could disable part or all of
18 the scram system?

19 What might be the impact on PWRs as well as BWRs?
20 Again, it is a fairly simple approach. You see the
21 difference once you account for pressurized water reactors.
22 The numbers are not significantly different. There is an
23 increase in frequency estimate by a factor of 2 to 3. Again,
24 as I said earlier, because of the improvements, I think
25 there are certain elements of rectification.

1 I use that term "rectification" with some fear
2 because of the type of reaction I might get, but I think
3 there has been a certain amount of rectification. I agree
4 with the statement that Dr. Kerr made yesterday that this
5 does not preclude recurrence of this failure mode but rather
6 reduces the likelihood of this type of failure.

7 MR. SHEWMON: Would you tell me where in there the
8 reactor pump trip comes in in this framework?

9 MR. THADANI: Okay. Basically, if you have
10 alternative 3A implemented, that includes recirculation pump
11 trip, includes the improvement in scram systems, again, only
12 in the electrical portion, and it includes alternating
13 standby liquid control systems.

14 MR. KERR: Mr. Thadani, I think if you strictly
15 refer to ATWS frequency, then pump trip does not come in at
16 all because pump trip does not prevent an ATWS. What it
17 does is mitigate it.

18 MR. THADANI: That is right.

19 MR. KERR: So what you have there is a frequency
20 of ATWS whose consequences are unacceptable, I think.

21 MR. THADANI: That is exactly correct. I noticed
22 that on the slide. That is why when I started out, I so
23 characterized this slide. Estimated ATWS frequency is
24 somewhat higher, but this is an estimate of ATWS frequency
25 which could result in severe consequences.

1 MR. BENDER: My recollection of some of these
2 numbers is a little vague, but in developing those numbers,
3 especially when G.E. did it, they took the position that
4 there was a lot of mechanical independence between the
5 drives, and the commonality, if it existed, was in the
6 electrical part of the system.

7 Now, I don't recall any discussion of commonality
8 relationships that might exist in the hydraulics. How are
9 they expressed up there in those numbers?

10 MR. THADANI: Well, if I may characterize G.E.
11 analysis, they did have fault-tree analysis of the scram
12 system. The failure mode was indeed there. It was
13 characterized as -- you have to have multiple failures. You
14 have to have plugging of the system as well as failure of
15 the sensors in the instrument volume, and the combination
16 was thought to be for very, very low probability.

17 If I can quote numbers, it was on the order of
18 ⁻⁸ 10 . I would say the mode was recognized, but how you
19 got there in terms of likelihood and so on was certainly
20 underestimated.

21 MR. BENDER: Is that mode in those numbers up
22 there -- those are not G.E.'s numbers. Those are yours.

23 MR. THADANI: These are our numbers, and these
24 numbers are based on what we call a systems model. It is
25 basically an exponential model which says we have had so

1 many reactor years of experience, we have such and such
2 frequency of testing, we have had so many failures, and I
3 can make an assessment of the likelihood of this kind of an
4 event without going to the so-called fault tree approach,
5 which fault tree, as well as synthesis models which have
6 indeed been used in the past, both by the industry as well
7 as WASH-1400 --

8 MR. BENDER: There are only a couple of events, as
9 I recall, that represented experience.

10 MR. KERR: Let me comment on that. The first
11 number, 2×10^{-4} , I think comes from a consideration of
12 experience and some estimate of reactor years in which there
13 is either one or zero failures, depending on interpretation,
14 and is calculated about at a 95 or 90 percent confidence
15 level.

16 MR. THADANI: No, I am sorry, Dr. Kerr. The first
17 number, the mechanism is correct, indeed, but it is based on
18 single failure. We through out the N-reactor because we felt
19 it was not applicable to commercial designs. We looked at
20 the reactor years of experience, looked at the frequency of
21 testing, recognized the true testing frequency was somewhat
22 higher than that required by the technical specifications,
23 and that some credit was given for the concept of
24 rectification.

25 MR. KERR: But the basic number which you took and

1 then modified by giving credit for testing was a number
2 based on experience.

3 MR. THADANI: It is based on experience but it is
4 not a 90 to 95 percent confidence number. It is a 50
5 percent confidence number.

6 MR. KERR: You get about 10^{-4} if you use the raw
7 data, with somewhere around 90 to 95 percent confidence, as
8 I remember. You get another factor of 10 by putting in
9 testing and rectification. So you get 10^{-4} or 10^{-5} and
10 then you put in the rate of anticipated transients, which is
11 about ten per year, and that is the way you get to 10^{-4} .

12 MR. THADANI: I can tell you, I recollect some
13 of the numbers, the exact numbers come out at 95 percent
14 confidence. Sometime back it was 1.1×10^{-4} for failure
15 to scram. That, when combined with a recurrence frequency
16 of transients, will give you on the order of 10^{-3} and not
17 2×10^{-4} .

18 MR. KERR: If you have put in your rectification
19 and testing, you get to the 10^{-4} .

20 MR. THADANI: Even if I assume zero failures, I go
21 to 95 percent confidence and I would come up with a number
22 like this, zero failures.

23 MR. LEWIS: I don't understand how zero failures
24 can give you anything but an upper limit.

25 MR. THADANI: Right.

1 MR. LEWIS: There is no 95 percent confidence
2 associated with an upper limit.

3 MR. THADANI: I can go to the upper limit and that
4 upper limit would be this kind of a number if I throw out
5 that failure that at least we think was a failure.

6 MR. LEWIS: Which one?

7 MR. THADANI: The call.

8 MR. BENDER: Let me see if I can pursue the
9 question I was trying to develop. Given that those numbers
10 are based on what amounts to the operational experience and
11 now I want to crank in the observation that there were a
12 number of hydraulic faults in the systems that have been
13 investigated as a result of this one event, which might have
14 suggested that those systems would not have scrambled either,
15 how might they influence those numbers up there?

16 MR. THADANI: Mr. Bender, would you go through
17 that one more time?

18 MR. BENDER: We found out that Hatch had some
19 problems and Brunswick had some problems. As a matter of
20 fact, I suspect most of the BWR systems had some problems
21 and they were all on the hydraulic side of the system. With
22 my limited knowledge I would have to suspect that some
23 fraction of those would have experienced the same kind
24 circumstances as Browns Ferry if they had been called upon
25 to work.

1 How would I go about interpreting those numbers
2 that you have up there in light of the observation about the
3 faults in those systems.

4 MR. THADANI: One way would be to go back and look
5 at fault trees and recognize, possibly, that one could have
6 failure of half the system by possible plugging of the vent
7 line. There would be some other factors involved in terms
8 of timing, what can drain out and so on. But it seems to me
9 that one could go to data and make an estimate as to the
10 contribution.

11 MR. KERR: It seems to me that number in the upper
12 left is based on experience. Then you cannot attribute
13 anything to that number on the basis of what has been found
14 out because you simply would use data, and the data, in a
15 sense, took into account --

16 MR. BENDER: Except --

17 MR. KERR: It does not have anything to do with --

18 MR. THADANI: No, no. I think Dr. Kerr said it
19 quite correctly. Implicit in this are two failures that we
20 have experienced, Browns Ferry and Call (phonetic), the last
21 two rows, basically. The judgment that we ought not to pay
22 as much attention to synthesis models in terms of trying to
23 show how unlikely the failure rate was was arrived at on the
24 basis of our having seen some of the partial failures in, as
25 you point out, the hydraulic system.

1 But this did not include quantification. It is
2 very difficult to quantify when you have had only partial
3 failures and move on and try to come to a conclusion as to
4 how likely it is for certain combinations of failures to
5 occur.

6 MR. KERR: It may be a very fine point, but if one
7 is really interpreting these numbers, the left-hand column,
8 at least the modification due to Browns Ferry 3, does not
9 refer to an anticipated transient without acceptable
10 consequences, fortunately. So that is a modification which
11 really deals with the probability of scram failure and your
12 interpretation as to what effect that might have on the
13 other number.

14 MR. THADANI: You are quite right. It impacts only
15 one-half or at least the failure to scram portion. We had
16 made an assumption that anticipated transient as well as
17 failure to scram are independent events. I think at least
18 in my opinion, Browns Ferry raises a concern as to whether
19 that is a fair assumption, especially if possible failure of
20 the scram system as related to the demand which might --
21 here is a scenario, if you will.

22 I have a scram today. Whatever reason the scram
23 took place, I got a lot of water in my discharge volume and
24 I have another anticipated transient tomorrow, and I have
25 not drained my system. I think it raises a question in my

1 mind and it is a fair assumption to say that the two events
2 are independent. I don't think they are quite independent.
3 That is an assumption in the estimates that you see up there.

4 MR. PLESSET: Is that all?

5 MR. THADANI: I am sorry that Dr. Moeller is not
6 here. I would have been glad to have addressed -- I hope I
7 have addressed his question. I tried to in the way I
8 discussed this. I did not address part of what he said,
9 which was reference to the PAS and the conclusion that there
10 is no significant change in terms of conclusions in
11 WASH-1400.

12 I think that was intended to mean not ATWS-related
13 differences but overall core melt probabilities. I do not
14 want to speak for PAS, but at least I have talked to PAS in
15 terms of frequency, if you will, of the likelihood of
16 failure to scram on demand. Until changes are made, they
17 are in agreement that the failure probability is on the
18 order of 10^{-4} , and the reduction in terms of improvements
19 we just don't know.

20 But that would then imply that with the kinds of
21 transient frequencies that we see in these plants, that ATWS
22 frequency is somewhat higher than what we had stated earlier.

23 MR. LEWIS: We have the PAS note here, and it does
24 what it says. In effect, there is nothing in the experience
25 of failure to scram to negate the WASH-1400 numbers for

1 failure to scram, however ill-derived they were. It does
2 not have that last phrase in it, of course.

3 May I ask just one trivial question? Why in
4 September of 1980 are there still BWRs that do not have RCP
5 trip?

6 MR. THADANI: There is a commitment to implement
7 that by the end of the year.

8 MR. LEWIS: By the end of this year. I will ask
9 the same question January 1st.

10 (Laughter.)

11 MR. THADANI: I hope the answer is they all have
12 recirculation pump trip.

13 If you will excuse me, Dr. Okrent, you said you
14 have a copy of a memorandum. Was that a memorandum from Jim
15 Pittman?

16 MR. LEWIS: Yes.

17 MR. THADANI: Let me make a correction. On the
18 second page of that it talks about 5×10^{-4} per reactor
19 year based on 2000 scrams and so on. It is the last page, I
20 am sorry. That should be per demand. If you take that per
21 demand and include the transient frequency, you would come
22 up with numbers which are pretty close to what I am saying.

23 MR. LEWIS: This is a very rudimentary calculation.

24 MR. THADANI: It is.

25 MR. OKRENT: Before you leave, I wonder if you

1 could tell me whether there are any problems or conflicts of
2 information requirements or procedural requirements in
3 implementing Alternative 3A. As you know, we sent some
4 questions to the staff and the people who were at the
5 subcommittee meeting did not answer them, and they said Mr.
6 Thadani would be your source of wisdom here.

7 I am afraid our source is going to run upstairs
8 before I know whether Alternative 3A has practical problems
9 or not.

10 MR. THADANI: Let me give you a quick answer to
11 that. If you would like a longer discussion, I can come
12 back later in the afternoon. I think that the concern you
13 had related to ADS. You quite correctly pointed out ADS is
14 actuated on high -- there are a combination of signals that
15 have to be present for ADS actuation. Indeed that is true.

16 One of the concerns we had was the G.E analyses
17 showed that for full ATWS events, you do not get to the
18 point where ADS would be actuated. I suspect, and I have
19 asked G.E. this question and I have not really gotten an
20 answer, but I suspect the main reason is because of the
21 timer, the two minute timer in the ADS actuation. I think
22 this is why they do not actuate ADS.

23 Your thought that ADS could make consequences for
24 ATWS worse is indeed correct, I believe. It could cause
25 more problems. But current analyses do not challenge ADS.

1 The recommended change in NUREG 0626 that you referred to in
2 fact would help because it says that you go to ADS only if a
3 high pressure core spray or the reactor core isolation
4 cooling system fails.

5 Under Alternative 3A the implicit assumption is
6 that basically all systems are available, including high
7 pressure core spray or high pressure coolant injection. So,
8 if that system is available, I think it would give me more
9 confidence that ADS would not be actuated in the event of an
10 ATWS.

11 MR. OKRENT: Well, I guess it is very hard to
12 discuss the topic in this particular forum, so I don't know
13 whether the chairman is going to be able to put something in
14 on ATWS later today. I have a feeling he is going to need
15 all the time he has on Sequoyah. If sometime at this
16 meeting, even if it means Saturday morning, that we get Mr.
17 Thadani or whatever, I think it could be useful because
18 there is also the question Mr. Ebersole has that I have not
19 really heard answered about can you lose the boron under
20 some circumstances, and a few things that are not
21 unimportant in connection with this.

22 Let me just leave that as a scheduling question.

23 MR. MARK: Let me introduce the situation to the
24 chairman. There is a question which relates to this current
25 status of implementing the ATWS proposal, certain features

1 which Thadani thinks require more discussion than he could
2 give to it now. He said he could come back this afternoon
3 if we would like to go back to ATWS this afternoon.

4 MR. PLESSET: I don't think we can. We will have
5 to have a less rushed discussion of this.

6 MR. OKRENT: This is what I suggested.

7 MR. PLESSET: This afternoon would be too --

8 MR. OKRENT: I said maybe Saturday morning or
9 something, unless we can find time on Friday.

10 MR. PLESSET: Saturday morning would be all right.

11 MR. THADANI: I might make one comment.

12 (Laughter.)

13 MR. PLESSET: Maybe we should plan it for Saturday
14 morning. How does that fit your schedule?

15 MR. THADANI: It will have to fit my schedule.

16 (Laughter.)

17 MR. PLESSET: I have a question. I would like you
18 to explain one thing to me. There is this note from Georgia
19 Power. Have you seen that?

20 MR. THADANI: I don't know. I may have seen it.

21 MR. PLESSET: It says -- we all have a copy --
22 that the operation of standby liquid control system with
23 both pumps -- it is a question regarding that. And their
24 evaluation indicates that the system as designed cannot be
25 operated safely with both pumps running and the reactor at

1 maximum ATWS pressure of 1297 psi.

2 Tell me what that means.

3 MR. THADANI: I don't know.

4 MR. PLESSET: Okay. Then Saturday morning you
5 will tell me.

6 MR. OKRENT: I think it is relevant.

7 MR. PLESSET: Oh, yes, I think so too, Dave.

8 MR. EBERSOLE: A related question. Mr. Thadani
9 has mentioned the RPT as a system of some importance in this
10 and the boron injection. This is part of a somewhat larger
11 problem. The RPT system is like getting out of an airplane
12 that is burning, and then there is a long way to the ground,
13 and starting the boron injection system is like pulling the
14 ripcord. There are lots of things that still have to happen.

15 One of these is the reliability of the HPCI
16 system, which now must face a pressure transient, and it
17 always tries to overspeed trip anyway. And now it is faced
18 with an initiating pressure substantially higher than the
19 ordinary pressure at which we use it and test it. I would
20 be inclined to guess that the first thing it will be is
21 overspeed and lockout.

22 Another thing is, having gotten the boron system
23 running, if you can, in fact, the ECCS systems are
24 exuberantly trying to flush all the water out of the
25 systems. There are various valves which might be stuck

1 open. The operator must, if he gets the boron in, keep it
2 there because he has only a one shot opportunity and there
3 is hardly enough to leak any of it whatsoever.

4 MR. THADANI: Well, the first part, certainly I
5 completely agree with you in terms of the reliability of
6 high pressure coolant injection system. In theory the later
7 plants are supposed to have better systems, the high
8 pressure core injection systems. That was one of the big
9 differences between what I call Alternate 3A and Alternate
10 4A.

11 We were concerned about just that aspect of high
12 pressure coolant injection systems, and we felt quite
13 strongly that total reliance on that system seemed
14 inappropriate. I am sorry I can't discuss what we are
15 recommending to the Commission in an open meeting, but I can
16 point to the suggestion that we have to include the
17 reliability of that system as to its potential for failure
18 under high pressure conditions.

19 I have to go by my memory. I think that the data
20 dump seemed to indicate that.

21 MR. KERR: Mr. Thadani, we had one of our fellows
22 look at this to some extent, and I believe some of the
23 experiences seem to indicate that although there is a
24 considerable failure to start for those high pressure
25 injection pumps, that it is not difficult to restart them.

1 I don't know.

2 It is not a failure in the sense that they are
3 automatically unavailable once you get a failure to start.
4 They may start and trip out, but they can be started again
5 fairly readily. So I am not sure -- I mean it certainly
6 would be preferable that they not have this feature. But I
7 think the experience has to be interpreted in the light of
8 the use that you have for them.

9 MR. THADANI: I could not -- pardon me. I
10 certainly agree with you, Dr. Kerr, that it has to be. On
11 the other hand, ATWS is, relatively speaking, a fairly fast
12 transient, a fast accident. You need high pressure coolant
13 injection systems fairly quickly, and turbine-driven pumps
14 and controls associated with those systems and the types of
15 failures that have been experienced.

16 One has to then go back and determine how likely
17 is it that the operator is going to indeed notice that the
18 system did not work and fix it in time and so on

19 MR. OKRENT: You would be requiring the operator
20 to look at a very excited control room panel.

21 MR. KERR: My impression also is that there had
22 been some fixes for some of these. But I think you are quite
23 right. It is a problem that has to be looked at.

24 MR. EBERSOLE: One other comment. You
25 characterized the unmitigated accident as having severe

1 proportions. I think that is very optimistic. It carries
2 with it the connotations -- I think that is hardly an
3 appropriate word, "severe," which connotes something that is
4 fairly manageable and we can cope with the emergency
5 preparedness systems and so forth.

6 MR. THADANI: Sometimes one gets accused of going
7 overboard. I certainly have been accused. I have chosen
8 the word "severe" for one major reason. Some substates of
9 these events were perceived -- at least I am fairly sure in
10 my own mind not all of them will proceed to core melt.

11 There are some events where you may have a
12 condenser available to you, and if you have a recirculation
13 pump trip, if you have a very smart operator and if you have
14 an event which occurred at fairly low power level -- it has
15 to be fairly low -- then there is a chance that he can
16 protect the plant. Because this frequency includes events
17 like that, I characterize it that way.

18 MR. EBERSOLE: You are weighting the presence of
19 the condenser in a manner which rather obscures the worst
20 end of the spectrum. If you weighed it another way, it
21 looks worse.

22 MR. THADANI: I did not mean to obscure it. In
23 past discussions I have gone into some detail as to why we
24 think these events will proceed to core melt, and then one
25 can go to WASH-1400 and determine how quickly one could get

1 into serious trouble. Indeed, this is considered by PAS as
2 the most significant contributor to risk in boiling water
3 reactors.

4 MR. PLESSET: Let me ask, Mr. Thadani. You have
5 to leave at 12:30, is that correct?

6 MR. THADANI: I have to be there at 1 o'clock.

7 MR. PLESSET: There is no rush. I misunderstood.

8 MR. THADANI: I was going to grab a bite, but I
9 have no problems. Let me just touch on the second part of
10 the question.

11 MR. OKRENT: Before he goes on, I think sometime
12 at this meeting, in closed session, if necessary, we should
13 hear what it is the staff is going to tell the Commission
14 unless when they tell it it will be in open session, and
15 after that they can tell it to us in open session. I think
16 we ought to hear what the new staff position is in this
17 meeting unless we are not going to write something.

18 MR. PLESSET: We are going to try to. I was going
19 to ask Mr. Thadani and the Committee how they felt about
20 having him come back at 9:30 Saturday.

21 MR. THADANI: I will be here.

22 MR. PLESSET: Should we plan a closed session at
23 that time? That is what Dr. Okrent was suggesting.

24 MR. THADANI: I would hope that it is a closed
25 session because then I would feel more comfortable telling

1 you what steps we have taken.

2 MR. PLESSET: Can we do that?

3 MR. FRALEY: I will check and see if we can or not.

4 MR. PLESSET: Let's plan on that unless we get
5 some contrary indication.

6 MR. BENDER: Are you planning to discuss the
7 matter with the Commissioners in closed session?

8 MR. THADANI: No. I understand and ELD tells me
9 that a document becomes public on the day of the briefing to
10 the Commission. And tentatively, as you heard yesterday
11 Harold Denton describe, in the middle of this month -- I
12 have my doubts. I think it will be later.

13 MR. BENDER: You have answered all I wanted to
14 know.

15 MR. PLESSET: Go ahead. I am sorry. I just
16 wanted to settle that. You were discussing. And then
17 Okrent has a question.

18 MR. KERR: I don't think we can hold a closed
19 session on this subject.

20 MR. PLESSET: Well, Ray is going to find out.

21 MR. FRALEY: I will look into it.

22 MR. PLESSET: If not, we will have him in open
23 session, and that will limit the discussion, presumably.

24 MR. FRALEY: I think Mr. Thadani could talk to us
25 about current staff thinking without talking about the staff

1 paper and not violate any confidences.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. THADANI: In terms of the considerations for a
2 standby liquid control system, or poison, if you will, yes,
3 that is a concern. We did the usual kind of calculations
4 quite some time ago for normal leakage and so on, and we
5 found that there were several days available -- several days
6 available before one would worry about possible power going
7 off. But that is really, at this stage, it is very
8 difficult to answer that question, whether it is today or
9 Saturday, simply because I think it is very plant specific.

10 In some cases you might need 28 percent of the
11 volume of the standby liquid control system. In another
12 case you might need 35 percent and so on. So there may be
13 some differences in terms of how much leakage.

14 One of the requirements that we would place on
15 this would be to address that issue, and I think at this
16 stage that is really all we can do. I just don't see how in
17 a generic sort of way we can resolve that problem. That
18 might give away something of what I think the paper is going
19 to do, but I don't believe there are certain parts that can
20 be handled generically.

21 MR. EBERSOLE: That's just the high pressure,
22 pre-borated feedwater system.

23 MR. THADANI: There was a suggestion that we made
24 a few years ago for high pressure standby backup feedwater
25 systems and so on.

1 MR. EBERSOLE: Borated.

2 MR. THADANI: Unfortunately, the cost associated
3 with it was so high that we looked around for alternate ways
4 to get high reliability where the cost would also be
5 reduced. And the alternate that was proposed was to make
6 the standby liquid control system a much bigger system so
7 that it has a certain amount of redundancy, it is indeed
8 automatic, that it serves two functions. Not only does it
9 serve the function of reducing power by inserting negative
10 reactivity as well as keeping the -- at least contributing
11 to keeping the core covered along with other systems, even
12 if we assume high pressure coolant injection or high
13 pressure core spray fails. And that was the thinking that
14 was reflected in alternative 4A.

15 MR. PLESSET: Dave.

16 MR. OKRENT: I was just going to add a comment to
17 a point Ebersole was mentioning earlier; that for one class
18 of ATWS in PWRs we don't have very much time. That is again
19 the plants without recirc pump trip. And I must say when I
20 look at a number like 10 to the -3 as a possible number,
21 best estimate or whatever, I don't know, and if I couple
22 this -- I don't really care whether it is that or 10 to the
23 -4 -- with an event that is a quick release event,
24 overpressurizing the primary system, and if I see a possible
25 avenue, for example, by reducing power to 80 percent until

1 you put in a recirc pump trip, that seems to avert possibly
2 some of the concerns in the short timeframe and put you into
3 the compression pool overheating scheme.

4 It would seem to me that that is a decisionmaking
5 process that should be consciously one through, and I would
6 not lump all the BWRs into one group in that decisionmaking
7 process. That is what I am saying.

8 Now, what we heard is they did a study -- the
9 applicant did a study on the point whether pressure was
10 below an awkward pressure. Well, I just wanted to put this
11 on the table.

12 MR. KERR: How many do we have that do not now
13 have operating pump trips?

14 MR. THADANI: Eight I think is the number.

15 MR. KERR: Eight out of?

16 MR. THADANI: Eight out of 26.

17 Again, Dr. Okrent, just to comment that 10 to the
18 -3, as I hopefully characterized the things that have been
19 done, whether the real number is still 10 to the -3 or
20 higher or lower I do not know. But if you look at the
21 difference, we are talking about a difference of a factor of
22 three or four between five -- between our earlier estimate
23 and our current estimate, with the Browns Ferry event --

24 MR. OKRENT: Let me put it this way. As you may
25 have guessed, I think the plants have been running without

1 recirculation pump trip for too long.

2 MR. PLESSET: You are not alone in that, Dave.

3 MR. OKRENT: And maybe with a larger number you
4 might well have considered whether because of the nature of
5 the event and how it differs from the longer overheating
6 one, something that is past due. But I would say the recent
7 experience makes the interest more acute.

8 MR. THADANI: I think I agree with you. The
9 seriousness certainly has increased.

10 MR. PLESSET: Well, yes?

11 MR. LAWROSKI: The 80 percent figure that you
12 gave, does that take care of all of them?

13 MR. THADANI: I beg your pardon.

14 MR. OKRENT: I saw an analysis for one, Quad
15 Cities or Dresden. I suspect it is roughly the range. It
16 may have been 85 percent. I don't remember. In that
17 ballpark.

18 What it does is reduce the peak pressure, but it
19 still leaves you in an overheating situation. But you would
20 have more time.

21 MR. THADANI: I might just make a comment that
22 that would probably be very plant specific, because as you
23 know, different plants have different safety relief
24 capacities and -- as well as the containment pressure
25 considerations now becoming more acute, I think, because the

1 energy you are going to dump is going to be somewhat higher
2 than the current calculations would show.

3 MR. KERR: Does each of these eight plants have an
4 approved system that has been analyzed and approved by the
5 staff, or is there still some approval process that would
6 have to be gone through?

7 MR. THADANI: I cannot answer that. Perhaps Tom
8 Toledo can.

9 MR. KERR: Does each of the eight plants that does
10 not yet have a pump trip installed have an approved system?
11 Have they proposed a system and had it approved by the staff
12 so that the only thing left to do is to install it?

13 MR. TOLEDO: That is correct and that is by
14 Commission order. In other words, these eight plants must
15 have an RPT --

16 MR. KERR: My question is have they submitted and
17 had approved by you a pump trip scheme which they only now
18 to install?

19 MR. TOLEDO: I was about to tell you that the
20 order that went out said you have two designs which are
21 acceptable to the staff. If you put in one of the two
22 designs, you need not come to us for approval.

23 MR. KERR: Okay.

24 MR. TOLEDO: And these must be installed this
25 year. They cannot operate in 1981 without an RPT installed.

1 Some will be installed in September, some in October. I
2 think three plants are due to put them in in December.

3 MR. OKRENT: I would say it is not unlike dropping
4 the water level in a dam when you get nervous about it.

5 (Laughter.)

6 MR. PLESSET: Well, can we let Mr. Thadani go
7 until Saturday morning? I think he would appreciate a
8 little break at this time, right?

9 MR. THADANI: I certainly could use one. I've got
10 twenty minutes still.

11 MR. PLESSET: Well, let's continue then, because I
12 think we have a relatively short --

13 MR. SPEIS: I think we can finish by 1:00.

14 MR. PLESSET: Why don't we go ahead? I hope it is
15 not too troublesome Saturday morning.

16 MR. MENDANCA: The first question which is
17 generally asked is what kind of power levels would be
18 expected if you were to have a scram failure similar to the
19 one at Browns Ferry. For a case where you would have a
20 scram failure approximating that of Browns Ferry with the
21 recirculation pump trip, your equilibrium power after your
22 first spike would be around 10 percent. For the bounding
23 case where you would have half rods in and half rods out,
24 that number goes to around 20 percent. That is still with
25 an RPT.

1 In the case where you do not have the RPT and you
2 still have the rods out on one half side of the core, your
3 terminal power is 40 percent.

4 MR. EBERSOLE: Before you go further --

5 MR. CARBON: Excuse me. Let me ask do we have a
6 handout of that, because I could not see that.

7 MR. MENDANCA: You do not. I will give it to the
8 appropriate people.

9 MR. CARBON: Then after Mr. Ebersole would you
10 mind repeating what you said because I was hunting for the
11 paper.

12 MR. EBERSOLE: You qualified that only as an RPT.
13 Is this for a full closure?

14 MR. MENDANCA: This is just the terminal power
15 that would be achieved. This is equilibrium power. This is
16 a physics calculation

17 MR. EBERSOLE: Is it under the conditions that the
18 MSIV is closed?

19 MR. MENDANCA: Yes.

20 MR. EBERSOLE: That means you are at the pressure
21 of the relief set valves.

22 MR. MENDANCA: I believe so.

23 MR. EBERSOLE: So the voids are collapsed, the
24 voids are collapsed.

25 MR. MENDANCA: Partly. To repeat again, the

1 terminal power is the parameter that this vu-graph is trying
2 to show, and it is trying to show it from 100 percent rod
3 configuration for conditions where you would have scram
4 similar to that of Browns Ferry.

5 MR. CARBON: From 100 percent power.

6 MR. MENDANCA: From 100 percent power, yes, sir.

7 The first figure of 10 percent is for a rod motion
8 pattern in one-half the core similar to what was observed at
9 Browns Ferry, trying to approximate that negative reactivity
10 insertion.

11 MR. EBERSOLE: You're sure the reactor is at
12 safety set pressure? I think that is an important aspect.

13 MR. MENDANCA: I believe so. I believe these
14 numbers come from the calculation from the MSIV closure.

15 MR. KERR: This includes the injection of the
16 standby liquid control?

17 MR. MENDANCA: No, sir. This is just the power
18 level that would be reached after your initial transient.

19 MR. KERR: Within minutes, seconds?

20 MR. MENDANCA: Forty seconds. That number comes
21 to mind.

22 MR. PLESSET: Jesse, we asked for the calculation
23 with MSIV closure. I presume that is what they did, because
24 we were very explicit about that as I recall.

25 MR. MENDANCA: It is. The second figure of 20

1 percent power is for the limiting case of the possible rod
2 insertion from the scram discharge phenomena that was
3 observed at Browns Ferry. That is where you have half the
4 rods on one side of your core sticking out. And that is
5 again with the recirculation pump trip with the RPT, and
6 that number was 20 percent.

7 The final number is for the case similar but
8 without the RPT, and that was a number of 40 percent.

9 Now, there are two criteria that we generally look
10 at in ATWS mitigation, and that is to make sure that you
11 have a pressure boundary and to make sure that you can
12 remove your heat from your core, your generated heat under
13 ATWS situations.

14 We asked immediately or in one of our bulletins, I
15 believe -- we asked for a calculation of what would be the
16 effect of a half scram on vessel boundary criteria, what
17 would your peak pressure be. We asked this of the plants
18 with no recirculation pump trip, and that is because they
19 are the most limited in that feature.

20 They did perform a generic calculation, and came
21 up with a figure for a half scram; that is, with one side of
22 the core not inserting, one half of the rods not inserting
23 on one half, a max pressure of 1460 psig.

24 As Dr. Okrent and others have already alluded to,
25 we did also ask for further calculations for full ATWS; that

1 is, no scram. And they did show that in order to meet the
2 emergency pressure level, 1500 psig criteria, you would have
3 to restrict power to somewhere around 80 percent. I think
4 it was 81.5 in their generic calculation, to be specific.

5 MR. ETHERINGTON: Do you have a figure for 100
6 percent?

7 MR. MENDANCA: What the pressure would have been
8 for 100 percent? I don't believe we have that calculation.
9 We have an extrapolated curve.

10 MR. EBERSOLE: Exponential upward?

11 MR. MENDANCA: In the curve I saw it seemed to be
12 linear.

13 MR. EBERSOLE: I don't think it is.

14 MR. ETHERINGTON: As long as plants are operating
15 at 100 percent, I think we should have that number.

16 MR. MENDANCA: Yes. The calculations that we
17 asked for or that we received are for the half scram. That
18 answered the immediate question of the scram discharge
19 volume. Perhaps you are correct.

20 The second criteria which we generally look at in
21 ATWS mitigation is the heat removal capability, and that is
22 generally limited by your suppression pool temperature. We
23 have various calculations in that area.

24 The first preliminary results which we received
25 informally from General Electric and are specific to Browns

1 Ferry, the first calculation at this point is again for MSIV
2 closure from 100 percent power, and this is for the plants
3 with the RPT.

4 MR. ETHERINGTON: Is there a steam bypass there
5 open?

6 MR. MENDANCA: No, sir. This is for suppression
7 pool temperature. The assumptions here are the 1 RHR at 30
8 minutes and standby liquid control at 30 minutes, and a
9 temperature of 190 degrees Fahrenheit in the suppression pool.

10 The second calculation was for the half rods out,
11 half rods in configuration. It is a bit different
12 assumption, and it shows you have to initiate the standby
13 liquid control system at an earlier time in order to meet
14 the 200 degree limit which is applicable when you have
15 quenchers.

16 MR. OKREN: How many have quenchers, by the way?

17 MR. MENDANCA: I don't believe any do. There may
18 be one that does, but I am not certain on that right now.

19 MR. OKRENT: They are currently running without
20 quenchers.

21 MR. MENDANCA: That is correct.

22 MR. EBERSOLE: There is something missing from
23 that that I think is most important, and that is aux
24 feedwater slow or HPCI or RCS, one or all. It is not there.

25 MR. MENDANCA: It is assumed to work on its

1 automatic signals. I know, I think it would be informative
2 to have it, and the requirements on it.

3 The final list under the generic BWR calculations
4 are the ones we have received formerly from General
5 Electric. The first is a Browns Ferry-3 type scram, and it
6 assumes actuation of your emergency systems in ten minutes,
7 which is more in line with our current licensing basis type
8 assumptions, I would say.

9 Your temperature maximum there is 153 degrees
10 Farenheit. If one postulates, which we did require, that
11 General Electric postulate a longer time in initiating their
12 standby liquid control than 30 minute initiation, you come
13 to the next calculation which indicates somewhere around 190
14 degrees, 186 degrees Farenheit.

15 These are for scrams similar to the Browns Ferry.
16 That is approximating the Browns Ferry type scram. For
17 conditions where you have half the rods not going in, again
18 the limiting case from our observation of the phenomena at
19 Browns Ferry-3 and initiating your RHR at 10 minutes, you
20 would require that you would initiate your standby liquid
21 control system at a fairly early time, about five minutes.

22 GE feels this is an adequate time, and they
23 indicated so in their letter to me, less than 200 degrees.

24 I wanted to present these consequences. They are
25 important in our evaluation of what needs to be done and

1 what has been done.

2 I think I would like to have Vince answer --

3 MR. PLESSET: When are the installations supposed
4 to be completed? Is there a schedule?

5 MR. TOLEDO: I think we will be going before the
6 Commission with a proposed Action Plan, and I think either
7 this week or next week. That is about the closest we can
8 come to it. I cannot tell you what the thinking is, because
9 we have not presented it to the Commission yet. It will be
10 some time.

11 MR. SPEIS: We will attempt to provide this
12 information via Thadani.

13 MR. EBERSOLE: Four thousand pounds at 100
14 percent. That is just a hand estimate. It may be a little
15 higher.

16 MR. PLESSET: Any other question?

17 Well, back to you.

18 MR. SPEIS: I think in ten more minutes we can
19 finish our presentation. Vince Panciena will talk about the
20 long-term implications.

21 MR. PANCIENA: About the middle of July a review
22 group was formed within the Division of System Integration
23 to develop a plan of action to resolve this problem. About
24 that same time within the staff there became a concern that
25 we were not sure what the as-built condition configuration

1 of the plants, the operating plants were.

2 As a result of that, we set up a series of NRC
3 regional meetings. These meetings took place the third --
4 the last week of July. The meetings were held at Chicago,
5 Atlanta, and Philadelphia. During these meetings -- the
6 objective of the meetings was to obtain an in depth
7 understanding of the as-built condition of the scram
8 discharge volume, the instrumented volume, and the
9 interconnecting piping, vent and drain systems.

10 The general areas covered during these meetings
11 were we looked at the general layout of the plant, looked at
12 the general layout of the systems. We actually received
13 from most of the licensees as-built drawings showing the
14 as-built conditions of the systems.

15 We discussed system design requirements, the
16 system interties, primarily the vent and drain systems, what
17 systems intertie into those systems. We discussed the
18 NSSS-AE interface, because we were not quite sure just what
19 kind of interfaces existed.

20 We also discussed recent tests involving valve
21 opening and closing tests on the vent and drain valves, and
22 the drain tests themselves. These tests were simulated
23 tests where they -- where the licensee filed the headers and
24 then timed the amount of time it would take to drain the
25 system.

1 Lastly, we discussed emergency procedures
2 primarily dealing with verification that the operator did
3 have authority to actuate standby liquid level control.

4 MR. MOELLER: These were, as you say, regional
5 meetings. What was the purpose of doing it regionally?

6 MR. PANCIENA: The purpose was to, in a short
7 period of time, get an understanding of just what the system
8 configuration looked like, because there was some concern
9 that developed that we found problems where valves were
10 installed backwards; we found problems where there was some
11 concern that there were slopes, that the lines leading from
12 the scram discharge volume to the instrument volume were not
13 sloped correctly.

14 And so the purpose of the meeting was to quickly
15 get out there and have a face-to-face shiftsleeve meeting
16 with each licensee and to obtain that information quickly.

17 MR. MOELLER: You did it regionally and covered
18 the plants in that region only.

19 MR. PANCIENA: In Region III we did cover some of
20 the plants that were in the regions further west. We did
21 not cover Humboldt Bay, because Humboldt Bay is in cold
22 shutdown.

23 To gain a little bit of perspective, I would like
24 to discuss some general results that we obtained from these
25 regional meetings.

1 (Slide.)

2 Basically there are two basic configurations. The
3 first configuration, we have a single instrumented volume.
4 In the second configuration we have an instrument volume of
5 each scram discharge header. I have shown these
6 schematically as such.

7 (Slide.)

8 At the same time I would like to discuss the vent
9 and drain configurations that go along with this general
10 layout.

11 All plants, with the exception of the newer plants
12 -- Brunswick, Hatch, and Duane Arnold -- have this kind of
13 configuration where you have two headers, usually an east
14 and west or north and south scram discharge volume header,
15 both feeding to an instrumented volume.

16 In all cases the line connecting the scram
17 discharge volume to the instrumented volume is two-inch
18 pipe. Similarly, the drain line coming off the instrumented
19 volume is also two-inch pipe.

20 All plants have a vent system composed of one-inch
21 pipe connected to a vent valve. In this kind of
22 configuration where you have one instrumented volume, there
23 is one plant, Nine Mile Point, that has a vent configuration
24 where there is only one vent valve for both instrumented
25 volumes.

1 The second configuration is found on the newer
2 plants.

3 (Slide.)

4 And in this case here you have the scram discharge
5 volume. You have a large connecting eight-inch pipe that
6 connects into the ten-inch instrumented volume. You have
7 the drain line from each instrumented volume going into a
8 single "T," this being two inches, this also being two
9 inches, going into a two-inch drain valve.

10 Similarly, most plants have a single vent valve of
11 each scram discharge volume header. There are two plants,
12 Duane Arnold and Brunswick, that have the single valve
13 configuration.

14 I'd like to say something about what we found as
15 far as the vent systems themselves. We found a wide
16 spectrum of configurations. We found some plants -- for
17 example, Monticello -- that had both a dedicated vent and a
18 dedicated drain system.

19 By "dedicated" I mean that they only serve that
20 one purpose. We found most plants had interties where they
21 intertied with other systems. In the extreme case -- and I
22 think one of the extreme cases being Browns Ferry -- there
23 was something like on the order of -- it went into a common
24 clean rad waste header, and there was something like over 16
25 interties.

1 We also found in some cases where the vent systems
2 actually went down -- and I think this was pointed out this
3 morning by the fellows -- they went down and actually tie
4 into a drain system.

5 (Slide.)

6 I would like to spend a little bit of time on
7 design interfaces, because I think there was some confusion
8 in our mind, and I think the regional meetings helped us to
9 understand the situation.

10 This system was -- in one case where GE was the
11 turnkey contractor, this system was procured by General
12 Electric Company. However, the General Electric Company
13 supplied the major components -- the vent valve, the drain
14 valve instrumented -- the float instruments.

15 GE in turn then subcontracted this work to an
16 outfit called Reactor Controls located in California.
17 Reactor Controls did all of the design work and provided the
18 fabrication and built the system. So that was one
19 situation. GE acting as a prime contractor subcontracted
20 this work.

21 In the other situation where GE did not have a
22 turnkey contract, a very similar path was followed in that
23 GE provided a functional specification for the system, which
24 included such things as slopes of lines, size of the volume
25 to be provided in the scram discharge volume. And GE

1 provided that specification to the licensee. The licensee
2 in turn either subcontracted the work to Reactor Controls
3 themselves -- Reactor Controls directly or through the
4 licensee's AE.

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 So basically this system was basically designed by
2 one outfit, Reactor Controls, under a subcontract, with
3 major controls such as the vent and drain valves being
4 supplied by General Electric.

5 MR. SIESS: Did they design any other systems?

6 MR. PANCIENA: I don't know that.

7 MR. SIESS: Has anybody tried to find out? It
8 seems to me that after Three Mile Island, we discovered that
9 auxiliary feedwater systems have a great variety of designs,
10 and consequently a great number of reliabilities. I think
11 that another system has the great deal of design
12 reliability.

13 Which is going to be the next one? Can we think
14 about it and maybe find it out before it happens this time?

15 MR. PANCIENA: I think that is a good point.

16 MR. LEWIS: We won't do anything if we do.

17 MR. ERERSOLE: What is the basis here? Is it
18 inadequacy in the degrees of specification in detail, this
19 horrible thing we call specificity, or is it prescriptive?
20 Is it inadequate prescriptiveness, inadequate
21 specifications? Surely the generic aspects of getting a
22 product like this out of narrative instructions has got to
23 be looked at.

24 MR. PANCIENA: Yes, sir. My general feeling is
25 that this system was relegated to a secondary position.

1 MR. EBERSOLE: It moves into the field of what
2 should be a standard requirement which would avoid these
3 things occurring.

4 MR. PANCIENA: We also found -- I will go back to
5 this.

6 (Slide)

7 We find varying lengths here. The long side could
8 vary up to -- the longest the found was about 180 feet, down
9 to something like 100 feet. The short side would be more
10 like 20 feet. So we found variations in the piping
11 dimensions, both in the vent drain and in the piping
12 connecting the scram discharge volume with the instrument
13 volume.

14 So basically we found nothing that really
15 approached even the standard design.

16 MR. ETHERINGTON: Are these systems designed for
17 reactor pressure over 15 psi?

18 MR. PANCIENA: They are designed for reactor
19 pressure, I know that.

20 MR. BENDER: These systems that you mentioned
21 being designed by Reactor Controls Corporation or whoever
22 they were, that was under subcontract to G.E.?

23 MR. PANCIENA: Subcontracted to G.E., in the case
24 where G.E. was a turnkey contractor.

25 MR. BENDER: I see.

1 MR. PANCIENA: In the case where G.E. was not a
2 turnkey contractor, then this system was subcontracted by
3 the AE to Reactor Controls or by the licensee directly.

4 MR. BENDER: When G.E. was a turnkey contractor,
5 did they review these designs?

6 MR. PANCIENA: That I am just not sure of.

7 MR. BENDER: Are you looking into that aspect?

8 MR. PANCIENA: We are trying to look into that
9 aspect.

10 MR. BENDER: Thank you, sir.

11 MR. EBERSOLE: Are you aware of a case where an
12 architect engineer did the balance of plant but Control
13 Engineering did this part?

14 MR. PANCIENA: Yes, sir.

15 MR. EBERSOLE: You would not call that a turnkey.

16 MR. PANCIENA: The difference between turnkey and
17 nonturnkey is that G.E. was the turnkey in those major
18 contracts. Let me get on to long-term actions. We are in
19 the process of reviewing the responses to the bulletins.
20 We have started on the responses to 80-14, I&E Bulletin
21 80-14, and we are starting a review of the responses to at
22 least supplements 1 and 2 to I&E 80-17.

23 So we hope to complete this in a very short period
24 of time because I think we really have to understand what we
25 are being told by the licensee to do, this adequate job of

1 long-term corrective action. We are reviewing the as-built
2 systems as a result of the I&E bulletins and the information
3 we got during our regional meetings.

4 We have started to develop a matrix that tries to
5 lay out what are the basic characteristics of the system. I
6 think the key to the long-term actions, though, is we have
7 encouraged the owner group participation, and we have
8 encouraged the owners to organize a subgroup to develop
9 design and performance criteria for the scram system. I
10 would like to maybe generalize this a little bit more.

11 It is not just the SDV, but it is going to include
12 more of the hydraulic systems and possibly some of the
13 auxiliary systems, so it is just not going to be limited to
14 the scram discharge volume. I would like to show this flow
15 chart.

16 (Slide)

17 Our plan is to get the owners group to develop or
18 to propose design and performance criteria. We will take
19 into consideration the Michaelson effort as well as comments
20 we received from the ACRS, our bulletin response and review
21 of the as-built drawings.

22 We are in the process of coming up with what I
23 feel is at least a minimum acceptable list of requirements.
24 We intend to work with the owners to develop or to
25 understand what is needed in the way of criteria. Our plan

1 is that we will meet with the owners as needed in a short
2 period of time to come up with agreed upon criteria which
3 would allow the owners then to implement on a plant-specific
4 basis those changes that are necessary for each plant to
5 meet the criteria.

6 Mention was made this morning about the G.E.
7 recommendations which have been developed. These G.E.
8 recommendations will be factored into the effort that we are
9 currently undergoing. At the present time a subgroup has
10 been formed. The chairman of that subgroup is a man by the
11 name of Tom Dente, who is from Northeast Utilities, and they
12 are currently meeting.

13 They met yesterday and they met today to at least
14 start this work going.

15 (Slide)

16 The upcoming action at the present time. As I
17 mentioned, there is a meeting with the owners subgroup today
18 and yesterday. We expect to receive the results next
19 Monday. Now, I do not know how final these will be. I
20 presume they will be preliminary results. The staff will
21 have a meeting with the subgroup during the week of the
22 15th.

23 I expect that by the third week in October we will
24 have approved design and performance criteria in place.
25 That is the kind of time frame we are working on. We are

1 asking each licensee to provide schedules for plant-specific
2 modifications by December 15. That is my letter. That
3 concludes my presentation.

4 MR. PLESSET: Any other point?

5 Denny?

6 MR. ROSS: I had two remarks. First, within both
7 I&E and NRR, this problem -- and it is a problem -- has
8 fairly high priority. We have several men assigned to it,
9 senior staff, and it is their number one assignment.

10 The other thing is the Committee will be seeing
11 this again. It is the first OL matter, which will be
12 LaSalle. It is on the Committee's agenda this fall sometime,
13 so in addition to whatever comments you might want to make
14 on operating reactors, you will get another bite on this
15 subject on the next OL.

16 MR. PLESSET: Okay, thank you.

17 MR. EBERSOLE: One way to look at this event is
18 the more general context than just boilers. This should be
19 a precursor as to what you find when you look at a system
20 more deeply. I presume certainly it will be considered as
21 such a precursor to the extent that we look at what might be
22 the equivalent of a scram dump volume in the PWR field.

23 MR. PLESSET: Any other comment?

24 If not, we will recess for lunch and return in one
25 hour.

1 (Whereupon, at 1:15 p.m., the Committee recessed,
2 to reconvene at 2:15 p.m. the same day.

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 AFTERNOON SESSION

2 (2:15 p.m.)

3 MR. PLESSET: Let's reconvene and go to our next
4 item on the agenda, the report of the ACRS Subcommittee on
5 Quantitative Risk Criteria.

6 Dave.

7 MR. OKRENT: Yesterday, if you noticed it when you
8 were picking up your folders, there was a package of three
9 memoranda which you should have received, in white, relating
10 to the subject of quantitative risk assessment criteria.
11 Today while you were having lunch --

12 MR. KERR: What is your confidence level that we
13 received that?

14 MR. PLESSET: It is very high.

15 MR. OKRENT: I don't know that you have it because
16 --

17 MR. KERR: I don't think I have it. Are there any
18 more?

19 MR. QUITTSCHREIBER: This was passed out last
20 night about 6 o'clock.

21 MR. OKRENT: If you do not have the three
22 memoranda, one of which is marked Part I, one of which is
23 marked Part II, and the third of which is not marked Part
24 III but is by Johnson and Kastenberg, tell Gary
25 Quittschreiber and he will know what you need.

1 Then this noon while you were at lunch you were
2 given a short green draft letter. Let me, then, having
3 mentioned that, summarize where we are and where we are
4 supposed to go.

5 You will recall in May 1979 we recommended that
6 the Commission work on development of quantitative risk
7 goals for safety, and a couple of months later Chairman
8 Ahearn asked could we provide some specific input into this,
9 and we said we would in about a year. We are just about a
10 month behind our year right now.

11 More recently, in some of the stuff being written
12 by the Office of Policy Evaluation -- I think that is the
13 name -- they are sort of casting into concrete that we are
14 going to try to provide something in about a year. They are
15 going to try to get something up to the Commission.

16 So the Subcommittee on Reliability and
17 Probabilistic Assessment or whatever its name is has been
18 working in the area, and we had a briefing on the general
19 subject at a full committee meeting some time ago trying to
20 give you an idea of the kind of approach we had in mind.
21 Last month we sort of had a freewheeling discussion with
22 knowledgeable people, let's say, from the outside coming in,
23 and speaking, if you remember.

24 The approach we have taken is to prepare three
25 memoranda. The first one is intended to serve as a review

1 of some of the proposals which had previously been made for
2 quantitative safety goals, not exclusively as applied to
3 nuclear power reactors. Many were, but not exclusively. It
4 was not intended to include all that had been made, but what
5 we thought were an interesting selection. And that was
6 called Part I.

7 My guess is that that document is in fairly good
8 shape. I hope we find it that way. I suspect it is not a
9 particularly controversial kind of a document since what we
10 tried to do is reflect what other people have proposed.
11 But you will have to read it if you have not.

12 Then the second document, Part II, is entitled
13 Rulemaking on -- it is a specific proposal prepared by ACRS
14 fellow Peismeyer (phonetic) and myself, trying to take
15 advantage of the inputs we had in the subcommittee meetings
16 with consultants and so forth, and would, in effect,
17 represent what you might call the new proposal that exists
18 in this packet of information. I hope it is in reasonably
19 good shape. I will have to wait until I hear what you have
20 to say.

21 This, in my opinion, is certainly the document on
22 which you should focus primary attention. The third
23 document, which is by Kastenberg and Johnson, which is
24 entitled A Study of the Application of Risk Assessment
25 Criteria, is an effort to look at a few technologies in

1 terms of risk assessment criteria, somewhat like what is in
2 the second document, but they did not have the second
3 document. They had to work with a previous draft, so it is
4 not -- there is not now a one-to-one correspondence -- we
5 can make it that but there is not such a one -- and to see
6 what would happen for a limited number of technologies and
7 technological situations.

8 Just to give one a little bit of a feeling, that
9 document has one or two areas where we know we want to
10 modify it somewhat. For example, in L&G, there is a
11 numerical difference between what they obtained versus
12 something that is in the report, and we don't know whose
13 arithmetic was right.

14 And we have one more technology which we always
15 intended to try to include, which we weren't able to pick
16 up, which one of our new ACRS fellows is going to try to do
17 on an accelerated time scale, and it may or may not be -- on
18 dams -- and we are going to try to see there if we can look
19 at empirical information on dams and devise certain kinds of
20 risk numbers and then do a risk study kind of thing on dams
21 and see how they look, and then how both of these compare
22 against the criteria.

23 MR. PLESSET: You had better put that in.

24 MR. OKRENT: That will be in Part III.

25 So, by way of introduction, that is what these

1 three memoranda are. Again I want to repeat my firm opinion
2 is the most important one to look at is Part II. After that,
3 I would say, is the summary in Part III, but there are
4 several appendices in Part III which, hopefully, are
5 accurately reflected in the executive summary.

6 My guess is that Part I represents an area that is
7 the least controversial.

8 Now, the way we have in mind trying to proceed, as
9 you have probably noticed, is that tomorrow morning there is
10 a block of time, roughly 3-1/2 hours, for the Committee
11 discussion of this. Actually, four hours is shown. I think
12 it is intended that a half-hour of that be used by Mr. Stegy
13 to tell us what the Commission has in mind from the point of
14 view of proceeding on development of quantitative safety
15 goals.

16 They made recommendations to the Commission for a
17 program aimed at developing something on a fairly short time
18 scale. I am not sure whether he will be on first in the
19 morning or last, but my preference would be that he be
20 last. He would be sort of the dessert, something to look
21 forward to if you are good boys and finish in time.

22 If you look at the letter hurriedly, you will see
23 that the first page is boilerplate and the second page is
24 boilerplate, until about the last paragraph, which says that
25 the Committee hopes that this set of memoranda will

1 contribute to the process of the development of quantitative
2 criteria. And up on the top it says that this is expected
3 only to be a first step in an interim process.

4 So the intent is not that this is -- whatever it
5 is the Committee sends, if it sends something, it is not
6 supposed to be the be all and the end all, but one specific
7 thing that people might talk about and criticize. So it is
8 intended not that this be something that the Committee
9 thinks is the way to go, but it is in good enough shape to
10 serve as something to discuss.

11 Now, I can see three or four possible ends of what
12 we do this month and/or next month. We might decide it is
13 not ready to go anywhere, so back to the drawing board. We
14 might talk about it at this time and get subsequent comments
15 that you want included by next month, and hopefully we can
16 finish it by next month.

17 We might look at it and say, well, it seems pretty
18 good, leave it to the subcommittee chairmen and the fellows
19 to work on editorial parts and members would give specific
20 editorial recommendations or so forth as to where they think
21 there should be changes, but there is nothing that looks
22 like it just has to be changed, an important number or
23 concept or whatever it is.

24 In other words, the Committee might say we are
25 happy as of this month, but clean up the editorial part and

1 get it out by October, but we don't have to have it back on
2 the agenda. And you can probably think of one or two other
3 variants on that. I am not going to try to guess in advance
4 where we are likely to end up.

5 Now, my request, and it is a firm request for the
6 discussion tomorrow, is as a minimum you have carefully read
7 Part II, that you have made your comments and you have them
8 well articulated, if you can, written out or whatever. If
9 you have editorial kinds of comments, write them into the
10 copy. That is the easiest way to handle it.

11 You should not try to handle anything that is even
12 semi-editorial, semi-technical. I think we ought to at
13 least initially see what are the important questions, and
14 then I hope we could look at what I call the summary of Part
15 III. We can also talk about Part I and that would be good,
16 but, you know, you ought to know what is in Part I and Part
17 III so you know what is the subject of discussion.

18 But Part II is where there is a specific proposal,
19 and it is somewhat different than what you heard a couple of
20 months ago because this is a version that Reismeyer and I
21 prepared on Labor Day. I want you to know ACRS fellows work
22 even on Labor Day.

23 That is by way of introduction. I don't know what
24 further discussion you would like now or whether members
25 have some specific questions.

1 MR. PLESSET: There may be some questions. I
2 think Paul had a question.

3 MR. SHEWMON: I think I would be very
4 unenthusiastic about trying to get a letter out at this
5 meeting. Some people read fast and late at night. I don't
6 read well late at night or particularly fast. I think to say
7 all comments must be in writing by tomorrow so we can write
8 a letter on Saturday is just rushing.

9 MR. PLESSET: Comment, Dave?

10 MR. OKRENT: I had assumed myself we would need
11 October. I said --

12 MR. PLESSET: That is what I thought, too.

13 MR. OKRENT: But I did not want to preempt the
14 Committee from the possibility of throwing up its hands 00
15 (Laughter.)

16 MR. PLESSET: Do you mean washing its hands?

17 MR. OKRENT: Or whatever. But let me say I think,
18 though, nevertheless, whether Paul reads slow or fast, he
19 should stay up long enough to read Part II.

20 (Laughter.)

21 MR. PLESSET: Okay. I think that helps Paul. It
22 certainly clarifies the point.

23 Any other question of Dave? Yes, Mike?

24 MR. BENDER: I only had a chance to skim the
25 document, Dave, so I am really not trying to comment on it

1 in any substantive way, but it seems to emphasize primarily
2 reactors. Is that the charter which you envisioned?

3 MR. OKRENT: Well, the Committee recommended that
4 the NRC develop quantitative goals for reactors. We did say
5 in our original letter that the NRC should advise the
6 Congress of this and ask the Congress for its opinion in a
7 broader context. In fact, the draft letter mentions this.
8 But nevertheless, Part II is in terms of reactors. In Part
9 III, as I indicated, a look is taken at what this same set
10 of criteria, though, would mean for some other system.

11 So it is there. But Part III is not an exhaustive
12 look. There just is not time.

13 MR. BENDER: I had in mind addressing the whole
14 fuel cycle.

15 MR. OKRENT: I am sorry. Again, we did not look
16 at the rest of the fuel cycle here.

17 Now, EPA in effect has gotten some criteria for
18 the whole fuel cycle and so forth, but you are correct. The
19 original proposal was for quantitative safety goals for
20 nuclear power reactors.

21 MR. PLESSET: Any other question of Dave now that
22 you know your evening reading is prescribed?

23

24

25

1 MR. OKRENT: I should note one other thing. There
2 were a few typographical errors in Part 2. We will have,
3 rather than read them to you actually --

4 MR. SHEWMON: Let us find them for ourselves.

5 (Laughter.)

6 MR. OKRENT: I'll let you find others, but the
7 secretary did a remarkable job considering she had to type
8 from Reismeyer's scrawl and mine superimposed on his in
9 single space writing.

10 (Laughter.)

11 In fact, some of the things were not even her
12 fault. We will have a new Part 2 for you before the end of
13 the day. And will it be green?

14 MR. REISMEYER: Yes.

15 MR. OKRENT: So you should get one Part 2 in
16 green, and we will have not a large number of corrections,
17 but some of them are important.

18 MR. PLESSET: Thank you, Dave.

19 MR. OKRENT: We missed the reactor scam. How did
20 that happen?

21 MR. PLESSET: Anyway -- well, I appreciate your
22 brevity, Dave, I really do, because it has helped us a lot
23 in our schedule. And I think we will proceed to our next
24 item regarding the Sequoyah Nuclear Power Plant.

25 And before I call on the subcommittee chairmen to

1 report, I was told before our recess for lunch that they had
2 brought a model of the containment and of the globe
3 igniters, is that correct?

4 They were going to put them on the table, but we
5 thought that somebody might come in and take them out. So
6 any time you want to wander over there, take a look, without
7 disrupting the meeting too much. Feel free to do so.

8 MR. LEWIS: Are they going to inflate them and we
9 find out what the pressure limit is?

10 (Laughter.)

11 MR. BENDER: We used to get some zinc batteries
12 and hydrochloric acid to fill balloons with. Could we try
13 that technique today and see what happens?

14 (Laughter.)

15 MR. PLESSET: I don't know whether we want to. I
16 will take it under advisement, Mike.

17 Now, the items that should be pertinent to our
18 discussion were given to you mostly separately, right?

19 MR. QUITTSCHREIBER: Separate bundle.

20 MR. PLESSET: In the front of your notebook. So
21 you might want to make sure you have those in hand. And as
22 I mentioned to you, we had two subcommittee meetings on this
23 topic, and we should first get reports from them. And even
24 before that I think that the Sequoyah subcommittee chairman,
25 Dr. Mark, wants to make a brief comment regarding some of

1 the specific features of Sequoyah and results of the
2 augmented low power tests. So let's do that before we go to
3 the subcommittee reports.

4 Carson, would you go ahead?

5 MR. MARK: I would hope I could have my little say
6 here.

7 You will remember in July the committee wrote what
8 it thought was its letter on Sequoyah. Commissioner
9 Gilinsky was interested in the question of hydrogen
10 control. He sent back a letter on August 7th asking for
11 further clarification of the committee's position on
12 hydrogen control. He had two reasonably simply stated
13 questions.

14 I don't have the letter in front of me. One had
15 to do with -- does anyone have that letter? Do you have the
16 questions? It is in my bundle somewhere.

17 The questions I am thinking of are the ones of the
18 date August 7. "Does the committee believe that additional
19 hydrogen control measures are necessary for ice condenser
20 containments" is one question; and the other, "Is the
21 committee reasonably persuaded of the effectiveness of
22 distributed igniters in ice condenser containments? Can
23 they be counted on to keep pressure increases caused by
24 hydrogen burn at suitably low levels, which I would define
25 as design pressures, during accident sequences involving

1 TMI-like quantities of hydrogen?"

2 He goes on to say that, "We are not talking of
3 dealing with remotely hypothetical events, but protecting
4 against what was experienced last year."

5 I think in one form today's discussion is supposed
6 to provide the basis for answers or comments on those
7 questions. In a different form the Commission is going to
8 be reviewing the staff's current -- yesterday's proposal
9 that a full power operating license be issued for Sequoyah
10 tomorrow afternoon; and they very much want comments from
11 the committee on, I believe, the general subject that
12 touches things most particularly related to those questions.

13 Going back just for a moment, you have in your
14 hands an SER and the staff's submission to the Commission in
15 connection with the license that just came up. The low
16 power tests have been completed. I think there will be some
17 discussion of them in the course of the presentations made
18 today. I won't say anything on that.

19 Last time we talked about a question as to whether
20 significant information had been withheld. It may come out
21 today, but I believe the situation is now at the point that
22 I&E has concluded there was no intent of that sort on the
23 part of the TVA.

24 The general status of Sequoyah is that all non-TMI
25 and I guess even TMI-related issues other than hydrogen

1 control are either resolved or a solution has been either
2 implemented or scheduled, and assumes further questions are
3 a formality.

4 Maybe the staff or TVA will want to comment on
5 that situation.

6 TVA thinks of itself as ready to start its power
7 ascension progress as soon as they should receive a
8 license. And I believe that is all I have to report except
9 for the fact that the two subcommittees are much more
10 pertinent to today's discussion -- the Class 9 subcommittee
11 and the Subcommittee on Structural Features, which met
12 yesterday or the day before. Those are not Sequoyah
13 subcommittees, but they have everything to do with what is
14 up for discussion on Sequoyah at this stage and --

15 MR. PLESSET: I think that Carson described the
16 situation. Let me amplify or repeat. The hope of the
17 Commission is that we will have a fairly finalized version
18 of our comments on the questions raised by Commissioner
19 Gilinsky, namely the question of hydrogen generation and
20 control, which was examined in detail by Dr. Kerr's
21 subcommittee, and then there were some differences in the
22 evaluation of the containment capability, which was examined
23 by Dr. Siess' subcommittee.

24 These were two questions that were raised and
25 which we have looked into in some depth through these two

1 subcommittees. So I would like you to keep in mind our need
2 to get some formulation for a letter. This will be to the
3 Commission -- that is, Chairman Ahearne -- on this whole
4 matter.

5 So in order to get on with this, let me first call
6 on Bill Kerr. Would you want to give us your subcommittee
7 report?

8 MR. KERR: You have a one-page memorandum which
9 attempts to summarize that part of the meeting that was
10 relevant to Sequoyah. We saw results of calculations which
11 had to do with assumptions about hydrogen generation that
12 were deemed appropriate to the kind of incident that
13 occurred at TMI-2.

14 And the consensus of these calculations, using the
15 MARCH code and TVA -- I guess it was a
16 Westinghouse-developed code that TVA used -- is that one
17 can, by using an appropriate ignition system, keep the
18 containment pressure below about 30 psia absolute by
19 operating the igniter system to burn hydrogen in the
20 containment air up to an amount of hydrogen equal to about
21 70 percent of that, which would be produced by a total
22 zirconium-water reaction of all the zirconium available.

23 This assumption does not involve any detailed look
24 at the way in which the igniters operate. It is an
25 assumption which is based on putting into the computer the

1 fact that the igniters begin burning at a certain
2 concentration of hydrogen, and that the burning continued to
3 the point at which one expected burning to stop. Given a
4 concentration of hydrogen and that given this evolution rate
5 of hydrogen, burning starts again.

6 But it does not model in any detail the
7 performance of the individual igniters. So TVA and the NRC
8 staff independently are carrying out experiments which they
9 expect will give additional information on the performance
10 of igniters in systems involving air, hydrogen, and steam of
11 appropriate concentrations.

12 The committee also heard a short presentation by
13 Dr. Hubbard of R&D Associates, since R&D had made some
14 comments on hydrogen handling in the Sequoyah containment.
15 Dr. Hubbard emphasized that their treatment had been brief
16 and not very involved and not very detailed.

17 He did recommend inerting. Their recommendation
18 was not based on any detailed consideration of the problems
19 that might be associated with inerting, but rather on the
20 fact that they did not, on the basis of their analysis, have
21 any indication that the igniters would necessarily work.
22 Appropriately and hence were recommending some other
23 approach be used, because they thought it would be more
24 nearly appropriate.

25 This deals with part of the Sequoyah problem.

1 Even if one assumes that the igniter system will work and
2 will keep the containment pressure below some number such
3 that the containment will indeed contain, there is a further
4 question of what to do about operation of Sequoyah between
5 now and the time at which the igniter system will be
6 sufficiently developed and sufficient experimental evidence
7 will exist so that the staff and TVA will agree that it
8 should be operated.

9 The subcommittee and the consultants I believe
10 reached a consensus, with the exception of one consultant,
11 that probably the igniter system looked promising, and
12 subject to further information was an appropriate at least
13 interim approach to handling the hydrogen.

14 There was one consultant who had some questions
15 about it based on the fact that it was relatively untried
16 and also on some information that was provided in a
17 Brookhaven report, copies of which I think you have. This
18 had to do primarily with the effect of hydrogen burn on some
19 of the components of the ice condenser.

20 I did not urge the subcommittee members there
21 present or the consultants to try to pass on the question of
22 what should occur between now and the time of igniter
23 operation. That I think is something that -- with which the
24 committee needs to deal, and it has to be based on taking
25 into account a number of considerations.

1 I have in the memorandum given my personal
2 recommendation. That is all I have to say.

3 MR. PLESSET: Thank you, Bill.

4 I don't know if you want to comment on a point
5 that came up about detonations. I know that you and other
6 members of the subcommittee did consider this problem with
7 some care.

8 Do you want to comment on that?

9 MR. KEBB: Well, I think much of the consideration
10 of that question has been done by Carson, and unless Carson
11 is unwilling, I would ask him to comment on it.

12 MR. PLESSET: All right. Do you want to do that,
13 Carson, briefly?

14 MR. MARK: Let me say just a word or two then. In
15 the subcommittee meeting that Bill is referring to, Dr.
16 Hubbard had in particular -- he was not the only one, I
17 think -- raised the subject of detonation in quite alarmist
18 terms, that the distribution of hydrogen in the containment
19 might not be even, and there might be detonable pockets.
20 And if one of those got ignited, there might be a
21 detonation. And left it to the reader to assume that that
22 is the end of Sequoyah.

23 That raises a question as to whether it is really
24 true or not. As you know, in WASH-1400 for a large dry
25 containment, the argument is gone through at considerable

1 length that a hydrogen detonation in contact with the wall
2 will not disturb the wall.

3 I had a question then as to whether that situation
4 might not also apply to Sequoyah. And with the help of Paul
5 Shewmon in particular, my own conviction that you may have a
6 hydrogen detonation in the Sequoyah plant without doing
7 damage to the wall. The consideration will be how much
8 hydrogen is involved and what will be the quasi-equilibrium
9 pressure afterwards for which the containment capability --
10 Chet will comment on that, I think -- becomes the only
11 important consideration.

12 There is a draft of a possible letter to Gilinsky
13 which I think will be easier to discuss after we have had
14 the presentations. Attached to that is the argument that
15 Paul put together on this subject. There are also in here
16 references to a study by TVA which brings them to the same
17 conclusion; but I think it is nothing as good as Paul's
18 discussion is that --

19 MR. PLESSET: Fine. I have not seen the TVA one,
20 but I am familiar with Paul's. I know it is here.

21 MR. MARK: You won't see it by the time you finish
22 this, but they did it, or the staff says they did it.

23 MR. PLESSET: Do you want to comment, Paul?

24 MR. SHEWMON: No. I had a question.

25 MR. PLESSET: Let me make a comment on the thing

1 that you and Carson did. I thought it was very nice. I
2 think it is on the conservative side myself. I think you
3 overestimate the load a little bit. You would not want to
4 argue with me about that, would you?

5 MR. SHEWMON: Ten percent of the yield? I do not
6 care.

7 MR. PLESSET: Okay. Go ahead with your question.

8 MR. SHEWMON: Bill, will we -- the question of
9 mixing, the degree to which that came in, whether it is bad
10 or good and what happens comes up in your summary. And
11 perhaps you are getting to this in the presentations, but
12 the other is whether or not the igniter system will work,
13 and what is meant by work I guess is something I would like
14 to hear more about.

15 Will that also come up in the discussions?

16 MR. KERR: I would hope that both of these come up
17 in discussion. The assumption is that mixing is fairly good.

18 MR. SHEWMON: It is relatively complete or
19 relatively beneficial.

20 MR. KERR: That it is relatively complete and that
21 one does not get significant amounts of pocketing. The
22 pocketing question has not been looked at in detail as far
23 as I know.

24 Your second question was will the igniters work,
25 and I would say that further experimental evidence will add

1 to our knowledge of that question. I don't know with what
2 confidence one can finally demonstrate that they will or
3 will not work. I would doubt if it would be with 100
4 percent confidence, but there will be experiments in an
5 attempt to simulate the conditions that one might expect in
6 containment, and the igniters will be in place and will
7 attempt to ignite.

8 Both Livermore and a laboratory which TVA is
9 working with will run experiments which are expected to give
10 information about this. I think some comments will be made
11 about that during the presentations.

12 MR. SHEWMON: And it is basically whether they
13 will ignite mixtures which are ignitable, is that right?

14 MR. KERR: I think one could put it that way. One
15 also might say that they will attempt to find out what
16 mixtures are ignitable.

17 MR. PLESSET: Any other question of Dr. Kerr? If
18 not, I would like to call on Dr. Siess to give a report of
19 his Structural Engineering Subcommittee.

20 MR. SIESS: I would like to report in two parts.
21 I would like to make a brief report at this point and then
22 when the time comes for presentations by the staff and
23 consultants, etcetera, later on, I would like to have a few
24 minutes to give some introductory material in the hope that
25 it will keep them from each repeating the same introductory

1 material.

2 The committee met on Tuesday. We reviewed the
3 various analyses that had been made of the capacity of the
4 containment to resist uniform static pressure. We did not
5 take into account the dynamic effects.

6 We heard from six people, I guess, with seven
7 different analyses based on different assumptions. This is
8 summarized to some extent in the written committee report
9 which is in that same package as the other stuff with a
10 rubber band around it, which I suggest you read at your
11 leisure.

12 We arrived at a committee recommendation, a
13 committee judgment as to the pressure. It is not one
14 number. We will give you several to choose from.

15 Thirty-pounds per square inch we consider a
16 conservative lower bound based on neglecting the effects of
17 the stiffening longitudinal members. A reasonable value for
18 a first yielding other than very local bending we considered
19 to be somewhere in the neighborhood of 46 pounds per square
20 inch. A reasonable lower bound or limit capacity based on
21 general yielding but still at very limited deformations,
22 less than an inch or so, we considered to be about 50 pounds
23 per square inch. And then a best estimate of a limit
24 capacity, and I would express that as what I would expect to
25 see if we actually made a test, is somewhere around 55

1 pounds per square inch.

2 Now, in all of those numbers I can put a plus or
3 minus 10 percent on them.

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 We have a range of values from a very conservative
2 lower bound to a best estimate. We will have more
3 information on that and the other assumptions which those
4 are based on later on.

5 MR. SHEWMON: Is the limit somewhat related to
6 where you think the rupture might occur?

7 MR. SIESS: There's a general yielding. Rupture
8 is ruled out. Rupture would involve such large deformation,
9 they cannot even be considered. The limit here really comes
10 from elasto-plastic analysis, the real strength hardening
11 material. There would be some higher capacity. *

12 MR. SHEWMON: What is the definition of "limit"?

13 MR. SIESS: Just what I said. From elasto-plastic
14 analysis, it is the best you can get, beyond which you
15 cannot go.

16 MR. SHEWMON: It blows up like a balloon.

17 MR. SIESS: Yes. 20 percent strain, this would
18 look a lot like a balloon in this region, if you go out that
19 far. But those are very small deformations, probably less
20 than one percent strain anywhere, except local bending.

21 Later on I can give you a little more introduction
22 as to how we got here. You will not hear all seven analyses.

23 MR. PLESSET: You can spare us that.

24 MR. SIESS: It was narrowed down. In the
25 meantime, I would like you to read the report, because it

1 lists eight assumptions that were made to get here. You
2 might want to question some of them.

3 MR. PLESSET: Any other question of Chet before we
4 go forward? I guess not. Thank you, Chet.

5 I think we will now go to the staff. I think
6 that, Carl, will you be --

7 MR. STAHL: Yes. My name is Carl Stahl. I am the
8 project manager for the NRC in the Sequoyah plant. My
9 status is brief here. We have provided you two packages,
10 the first of which is the package that has been submitted to
11 the Commissioners, and it contains all the pertinent
12 information for licensing the Sequoyah Plant Unit No. 1 for
13 full power operations.

14 Of particular interest to you is supplement number
15 2, which covers all the non-TMI and TMI issues that have
16 been previously discussed with you at the July sessions, and
17 including others before that. Included in the package is
18 supplement number 3. That is a draft version which we will
19 publish shortly. That contains a great deal more
20 information on the hydrogen control issue.

21 Included in that supplement 3 is the current
22 information on the testing of igniters, that I think will be
23 of particular interest to you. I also want to report that I
24 have received a letter from Region II dated September 3.
25 They have concluded that no further items of significance

1 require resolution prior to issuance of a full power license
2 on Unit No. 1. From their point of view, the plant is ready
3 for power ascension and full power operations.

4 I wish to point out one additional item that has
5 not been discussed with the Committee or the Subcommitte
6 members, that quite recently, within the past two to three
7 weeks, a member of the Brookhaven National Laboratory staff
8 identified a concern that he had with respect to the
9 insulating material that is inside the Sequoyah
10 containment.

11 This matter is undergoing review with the staff.
12 We have provided you today recent information from TVA that
13 provides a discussion of this matter. It deals with the
14 subject of the flammability of this particular insulation
15 and the possible impact that this may have in the event of
16 hydrogen burn taking place within the containment itself.

17 MR. SHEWMON: Where have you give us that?

18 MR. STAHL: That was distributed, I believe, to
19 you in a separate package.

20 MR. PLESSET: It looks like this, Paul -- oh, it
21 is coming to you right now.

22 MR. STAHL: It is coming to you, sir.

23 MR. SHEWMON: Two classes of citizens.

24 (Laughter).

25 MR. STAHL: That material is quite recent, like

1 today. I apologize for the quality of the reproduced
2 material. This came in by Telefax.

3 TVA is present. If there is any clarity needed,
4 I'm sure they can provide it.

5 This actually concludes my brief status report.
6 We can proceed to the agenda item if there are no further
7 questions for me.

8 MR. SHEWMON: Let me ask a simple, non-technical
9 question. Is the composition of this foam significantly
10 different from the foam cup I have in my hand?

11 MR. STAHL: I will let TVA answer the chemical
12 composition. Polyurethane is the material -- an insulating
13 material. That is not polyurethane, I think. It certainly
14 has different flammability characteristics. The
15 characteristics of the material identified in the material
16 we have submitted -- I think that is a better point of
17 reference than my comments.

18 MR. PLESSET: Carl, if there are no more questions
19 on that point, I would like to handle the containment
20 discussion through Dr. Siess. So if you would let him take
21 the show, it would be very acceptable to us.

22 MR. STAHL: Yes, sir.

23 MR. PLESSET: If that is all right with you.

24 MR. STAHL: It certainly is.

25 MR. PLESSET: All right, Chet.

1 MR. SIESS: They will get their chance.

2 MR. PLESSET: Yes. You will get your chance. I
3 am not ruling anybody out. But I think Dr. Siess has been
4 through all these various things and might be able to do it
5 expeditiously, and that is what a Chairman always likes.

6 MR. SIESS: Okay. I'm glad they brought a model.
7 I have a slide I would like to put up there. Can you put
8 that slide up, please. You can look at the model.

9 The Sequoyah containment consists of a steel
10 cylinder 115 feet in diameter. It has a hemispherical dome
11 on the top and it is attached through bolts to about a
12 ten-foot reinforced concrete slab at the bottom. The
13 thickness of the cylindrical shell is an inch and
14 three-eighths at the bottom one one-half inch up at the
15 top. And that is obviously the weak spot up at the top.

16 There are meridional stiffeners running up and
17 down the thing at four-foot spacing; and then there are ring
18 girders going all the way around at nine and a half foot
19 spacing through most of the shell and closer spacing right
20 up around the spring line.

21 The material that this thing is made of us steel
22 SA 516 grade 60, which has a nominal specified yield
23 strength of 32,000 pounds per square inch and a test yield
24 strength of around 40,000. It has an ultimate strength of
25 60,000 nominal and about 65 ultimate. The ultimate strength

1 occurs at about 20 to 25 percent strain.

2 And we ruled out any calculations based on
3 ultimate, since 20 percent strain would mean something like
4 ten-foot increase in the radius. That did not seem very
5 reasonable.

6 In the cylindrical portion of the shell, which is
7 the critical portion, the hoop stress governs. It is about
8 twice the meridional stress. If there is just simply a
9 cylindrical shell, then the calculation of the stress is
10 very straightforward, and the only questions that are
11 involved in determining the capacity is what you equate the
12 stress to.

13 What is the uni-axial strength from tests is one
14 question; what is the bi-axial strength is another
15 question. And that is a fairly straightforward
16 calculation. The stiffeners, however, do affect the
17 capacity, and additional complications are introduced into
18 the calculation.

19 If we only had the ring stiffeners and they are
20 spaced about nine feet apart, they would have little effect
21 upon the capacity, since the region of the shell in between
22 the ring stiffeners would govern. What we have in addition
23 to the ring stiffeners, we have the longitudinal or
24 meridional stiffeners that are spaced about four feet apart
25 around the periphery, and these have a clear strengthening

1 effect.

2 Now, there have been analyses made neglecting the
3 stiffeners. Those are perfectly straightforward. The only
4 thing you have to decide is what is your yield strength and
5 yield criteria.

6 There have been various analyses made trying to
7 take into account the effect of the stiffeners, with quite a
8 range of degrees of sophistication. The Ames Laboratory
9 tests were the first ones made for the staff. R&DA made
10 some analyses, relatively approximate ones, on the behavior
11 with stiffeners. And Dr. Bagchi, Chief of NRC Research,
12 made some back of the envelope calculations taking into
13 account the effect of the stiffeners. These are quite
14 approximate analyses.

15 There have also been some fairly sophisticated
16 analyses made taking into account the stiffeners.

17 All analyses involve some portion of the shell.
18 Ames Laboratory has made some finite element analyses. Dr.
19 Udens has made some, and TVA -- actually, Offshore Power
20 Systems for TVA has made a finite element analysis.

21 The results that I mentioned earlier, the area
22 stress levels, the 38,000 to the square inch, is a simple
23 shell analysis -- no stiffeners -- using a test yield
24 strength and the Von Mises criterion. The others are all
25 analyses involving the stiffeners.

1 The 46 psi basically comes from Dr. Zudans'
2 analysis, which is strictly elastic. It does not go into
3 the inelastic range. The two upper values that come out of
4 the OPS-TVA analysis, which involve elastic-plastic behavior
5 model the panel.

6 What I am proposing that we do here is hear not
7 from everyone -- I don't know whether the staff wants us to
8 hear a presentation from Ames. We decided in the
9 Subcommittee we would not. The staff position is not using
10 the Ames analysis which was made for them. The Ames
11 analysis tends to give somewhat higher values than the TVA
12 analysis, which I think is probably a little more correct.
13 And since it does not really enter into our recommendations,
14 we did not think there was too much point in hearing from
15 them.

16 The analysis by the TVA staff and OPS I do want
17 you to hear, because there is more than one part to it.
18 They have looked at penetrations and hold-down bolts and
19 other things that could affect the strength, and I would
20 like you to see the scope of their review. And that will
21 probably be in two parts: first, the TVA presentation; and
22 then Dick Orr from OPS will make his presentation.

23 Then I would like to ask Dr. Zudans to tell us
24 what he did to sort of evaluate for us. He is our
25 consultant, and he is an expert in his own right here. And

1 then we can ask the staff to present the basis for their
2 position. They had a very, very short presentation at the
3 Subcommittee meeting, but we definitely want to hear that.

4 And then R&D Associates -- I believe Mr. Parry is
5 here -- indicated at the Subcommittee meeting that they felt
6 the final TVA analysis was the direction they thought we
7 should go. And I would like for them to comment on where
8 they -- what they think about what we got.

9 MR. PLESSET: It sounds --

10 MR. SIESS: We will start with TVA, I believe, and
11 then we will have some initial studies. And then -- I think
12 that --

13 (Slide).

14 MR. MOELLER: The vertical, whatever word you use
15 for them, the strengtheners, the stiffeners, do they tie
16 into the dome or do they go on up over the dome and back
17 down?

18 MR. SIESS: TVA, can you answer that?

19 MR. MILLS: I think Mr. Don Denton can answer that
20 as soon as he takes the stand.

21 MR. PLESSET: Let's let him make his presentation,
22 then.

23 MR. MILLS: Dr. Plesset, we will have Don Denton
24 from our engineering design organization make a very brief
25 statement, and we will follow that by Mr. Richard Orr from

1 OPS.

2 MR. DENTON: Would you be kind enough to get my
3 handouts out of my briefcase back there and hand them out to
4 the people, please.

5 I will answer the question about stiffeners. The
6 stiffeners taper down. The vertical stiffeners taper down
7 at this point here, just beyond the top circumferential
8 stiffener.

9 MR. SIESS: I thought the model would have the
10 stiffeners on it. I am disappointed.

11 (Laughter).

12 MR. LEWIS: I will lend you my knife. You can
13 whittle some.

14 (Laughter).

15 MR. PLESSET: Why don't you go ahead.

16 MR. DENTON: This is my first overlay that I
17 wanted to present to you, and I think you have already seen
18 it. It is just a general description of the vessel.
19 Professor Siess has already given you a description, and I
20 will pass this one.

21 (Slide).

22 The next overlay that we have here represents a
23 summary of the evaluation that TVA did in connection with
24 the hydrogen question, and the supportive data backing up
25 these numbers were presented Tuesday to the ACRS

1 Subcommittee on structures.

2 Let me just briefly go through the numbers and
3 comment on them as I go. And then I will turn it over to
4 Mr. Orr of Offshore Power Systems. The things we looked
5 at: of course, we looked at the anchorage. That represents
6 first yield of the anchor bolts. The value there is 68.4
7 psig, the value of the pressure in the containment that it
8 would take to fail.

9 The equipment hatch is a spherical structure that
10 is for equipment, and it has a capacity of 73 psig. This
11 value, the personnel locks, I have 42 psig there. And we
12 had difficulty locating our stress proportion and our
13 material data on that.

14 This represents the point at which the end
15 bulkhead stiffeners would at first experience yield.
16 Examining a little closer as to why that is such a low
17 value, I found from our design folks that did the evaluation
18 they assumed that the stiffeners were simply supported, and
19 then they looked at what would be the simple moment right in
20 the middle there. And whenever the first value went to --
21 when the fiber went to yield, they said, that is 42 psi and
22 that is the strength of the thing.

23 I checked that out, and just a small amount of the
24 end fixative would run this value considerably above that.
25 The span is only 35 inches, and the plate is half-inch

1 material. The stiffener behind it is four inches by a
2 half-inch.

3 Let me assure you that this will not be the
4 limiting load on the vessel.

5 MR. EBERSOLE: Don't you have some very large
6 purge valves?

7 MR. DENTON: Purge valves, I am not --

8 MR. EBERSOLE: These are butterfly valves for
9 purging operations. The reason I remember this sort of
10 thing is there was some difficulty in guaranteeing closure
11 under LOCA pressures.

12 MR. DENTON: To tell you the truth, I am not
13 familiar with the penetration part of that.

14 MR. EBERSOLE: Since you mentioned vacuum relief,
15 that is why I wanted to --

16 MR. DENTON: I am getting that out, yes, sir.
17 There are some isolation valves inboard of the vacuum relief
18 valve, and this value here does represent the ultimate
19 strength of the vacuum relief valve.

20 Those butterfly valves, if that is what you are
21 referring to as purge valves, have a capacity of 150 psi,
22 and they are inboard of it. So that is the qualification.

23 MR. MOELLER: You said that the modifications for
24 the personnel lock would increase the 42 to what? Is it ten
25 percent or would it triple it or what? Could you ballpark

1 the number for us?

2 MR. DENTON: To be honest with you, I think this
3 is simply sharpening our pencils. This will show that the
4 end part there will take substantially more than this. I
5 was just saying that whatever we have to do to raise that
6 value to above the value of the vessel, we will do, even if
7 we have to put another small stiffener in that area.

8 MR. SIESS: What about the vacuum relief valve,
9 that 48, that is below the maximum?

10 MR. DENTON: Since the butterfly valves are
11 inboard of that and they have a capacity of 150 psi, I think
12 the failure of this, since this is the sort of accident that
13 we are dealing with, a Class 9 accident, I guess we are not
14 limiting ourselves to a double failure-proof system at this
15 point.

16 MR. EBERSOLE: When you say "inboard," does this
17 mean that there is a fairly large part that goes inside the
18 containment, into which you insert this valve?

19 MR. SIESS: How large is the pipe? I think Mr.
20 Ebersole is thinking about these 36-inch purge lines.

21 MR. EBERSOLE: Mainly the pipe that you have them
22 tied into and the buckling mode on that.

23 MR. DENTON: I don't have the drawings. I was
24 going to say 20 inches, but --

25 MR. LAU: Those vacuum relief valves are 24 inches

1 in diameter.

2 MR. SIESS: Do you know anything about the
3 buckling capacity of that pipe under external pressure?

4 MR. LAU: No, sir.

5 MR. SIESS: If that pipe failed, you still have
6 the butterfly valves.

7 MR. LAU: Outboard.

8 MR. DENTON: Without having run out the numbers, I
9 think the buckling capacity of a 24-inch valve would be
10 substantially larger than the numbers we are talking about.

11 MR. LAU: The physical arrangement of these valves
12 are that both valves physically are located in the end of
13 this area. The butterfly valves are inboard of the vacuum
14 relief valve.

15

16

17

18

19

20

21

22

23

24

25

1 MR. EBERSOLE: The pipe projection is outside the
2 shell.

3 MR. DENTON: That is right.

4 MR. PLESSET: Go ahead.

5 MR. DENTON: We looked at a number of
6 penetrations. Electrical penetrations were tested to 100
7 psi. The bellows have a yield strength of 109 psi. We have
8 some spare penetrations that we looked at. The bolted head
9 penetrations, 1300, and the weld penetrations are three.
10 There were other things we looked at those, and presented
11 those as being representative of the scope of our review of
12 the containment.

13 Now, the critical section of the vessel -- I am
14 going to skip through this, because Mr. Orr is going to go
15 into a little more detail, but the values you see here
16 representing first yield, the differences in the numbers
17 represent the factors that you apply or the considerations
18 that you include, and as Professor Seuss has already
19 mentioned this, Von Mises versus shear, actual test versus
20 ACI Code minimum, 40 percent. The difference between
21 considering the stringers and not considering the stringers
22 represents approximately 35 percent, so you really step up
23 here, and this value, 50.8, is the value that we feel is the
24 reasonable number for which this vessel should be qualified.

25 This is the best estimate that Professor Siess

1 mentioned.

2 MR. LEWIS: Will I come out of this
3 understanding --

4 MR. SIESS: That is not my best estimate. That is
5 my reasonable limit value.

6 MR. DENTON: I will change my terminology,
7 whatever that means.

8 MR. LEWIS: Will I come out of this understanding
9 why there is any difference between maximum sheer criterion
10 and the Von Mises criterion?

11 MR. SIESS: Maximum shear strain.

12 MR. LEWIS: Is it because it is three-dimensional?

13 MR. SIESS: Maximum shear stress is just the
14 difference between the maximum and minimum principal stress.

15 MR. LEWIS: That is because you can make a
16 rotation.

17 MR. SIESS: The Von Mises is the square root of
18 the difference of the squares.

19 MR. LEWIS: I understand that. They come out the
20 same. We can talk about it later.

21 MR. DENTON: I think this will probably be cleared
22 up in Mr. Orr's presentation, in which he is going to
23 amplify on the source of this value here.

24 At this time, I would like to turn it over to Mr.
25 Orr, if you have no further questions.

1 MR. ETHERINGTON: I am still not clear.

2 MR. SIESS: Harold, this is by axial stress.

3 MR. LEWIS: It is because it is by axial. It is
4 because of that you have two, one, and zero.

5 MR. SIESS: This is for biaxial stress.

6 MR. LEWIS: In two-dimensional stress, it would be
7 the same.

8 MR. SIESS: Yes.

9 MR. LEWIS: Okay, now I understand. Thank you.

10 MR. ETHERINGTON: I am still not clear how we can
11 talk about 38 or 40 psi on the first yield basis for the
12 plate and still have the same number essentially as the
13 ultimate for the vacuum relief valves. We cannot take
14 credit for that high yield of the plate. Can you clarify
15 that for me?

16 MR. DENTON: Wang, could you address the situation
17 in which the butterfly valve --

18 MR. SIESS: No, put your slide back up and I will
19 explain it. In your second column you have indicated for
20 the vacuum relief valve that that is based on ultimate, and
21 Mr. Etherington is wondering how you can utilize ultimate
22 for that analysis and utilizing yield for the other or the
23 comparable values.

24 MR. DENTON: There is a small membrane inside that
25 vacuum relief valve which is the weak link in the valve

1 itself, and if I had a cross-section of that thing, you
2 could see it, but it is a real thin membrane, and it is that
3 thing which has -- that is the ultimate value.

4 MR. ETHERINGTON: I am not disagreeing with your
5 number at all, but I am saying, if this is the number, then
6 we can hardly go up to pressures as high as that with the
7 same factor of safety as you have in the plate. You were
8 talking 26.8, weren't you?

9 MR. DENTON: No, sir.

10 MR. ETHERINGTON: Weren't you? You are talking a
11 50.8 number now?

12 MR. DENTON: That is the number which we would
13 like Mr. Orr to justify by his presentation.

14 MR. ETHERINGTON: If this can be justified on the
15 basis that you are not going to exceed the limit -- you are
16 going to exceed it -- you have a weak link in this vacuum
17 relief valve. You are right up there with no factor of
18 safety.

19 MR. DENTON: I think the answer to that question
20 is, it is more of an operational question than a containment
21 capacity question, and I think that is where I need some
22 help. The butterfly valve, which is the isolation valve, is
23 in board of that, and that thing is closed.

24 MR. SIESS: There are two valves in series.

25 MR. DENTON: Two valves in series, and the first

1 one has a capacity of 150 psi. The second one, which is the
2 vacuum relief, has a capacity of 47.8.

3 MR. SIESS: Why did you choose to use the second
4 valve?

5 MR. DENTON: Well, the thought was that this would
6 be something that everyone would -- a lot of people might
7 have a question about, strength.

8 MR. SIESS: They did.

9 MR. DENTON: So that is the reason. I did not
10 mean to be confusing by including it.

11 MR. ETHERINGTON: The redundancy then --

12 MR. DENTON: That is correct. That is correct.

13 MR. BENDER: Is the relief valve considered to be
14 a backup to the other valve?

15 MR. DENTON: Wang, could you comment on the
16 operation?

17 MR. LAU: As far as containment isolation valve is
18 concerned, it is true. As far as the system operation of
19 the vacuum relief valve is concerned, the butterfly valve is
20 the backup of the vacuum relief valve.

21 MR. ETHERINGTON: We have to assume we have lost
22 our backup.

23 MR. SIESS: You have two valves to meet the
24 general design criterion on containment, right?

25 MR. LAU: Yes, that is correct, but the vacuum

1 relief valve can be in the second boundary.

2 MR. BENDER: In the past, when we have considered
3 these double valve situations, there has always been the
4 question of whether we should always assume the valve facing
5 the worst operating condition is always closed.

6 Many people have said that dual valves are put in
7 because one of those valves may not operate when demanded to
8 operate, and while I am not -- I am not trying to challenge
9 the reliability of the valves, but I think it is well to
10 understand that the primary boundary may be the vacuum
11 relief valve.

12 Mr. Fotherington's question was, I think, is
13 legitimate to assume that that valve is acceptable,
14 measuring it on the basis of ultimate strength, when you are
15 measuring everything else on the basis of yield strength,
16 and my question now is, when that valve reaches ultimate
17 strength in the particular point that it sees that load,
18 what happens to the valve?

19 MR. SIESS: The membrane fails, and it leaks. The
20 membrane in the valve is the governing factor. I am sure
21 this would not be acceptable on a design basis.

22 MR. LAU: The vacuum relief valve is a 24-inch
23 spring-loaded check valve. If I recall correctly, the
24 failure of this membrane would not cause gross failure of
25 the valve.

1 MR. ETHERINGTON: It could cause leakage, though.

2 MR. LAU: That is correct.

3 MR. SIESS: How much leakage?

4 MR. MYERS: We have not studied that at all at
5 this point. Let me point out the reason the vacuum relief
6 valve was studied in some detail was because our nuclear
7 safety review staff identified it as a potential weak link,
8 because of the nature of the valve, and so the detailed
9 studies were made on that early in the game, when we were
10 talking about much lower pressures.

11 If that membrane fails, we do not get gross
12 structural failure that would lead to immediate type
13 releases, but there would be basically a breaching of the
14 containment into the annulus area.

15 MR. SIESS: Would it be more than the annulus
16 could handle?

17 MR. MYERS: The annulus is exhausted by the
18 emergency gas treatment system, and as a minimum, the flow
19 would be at the full capacity of the emergency gas treatment
20 system, so that you would not have negative pressure
21 maintained in that annulus. It might go positive, but the
22 EGTS can handle quite sizeable flow rates.

23 MR. SIESS: I assume if you had an accident in the
24 plant where there was some possibility that you might
25 generate hydrogen and create unusual pressures in the

1 containment, that you would start that emergency gas
2 treatment system and pull your vacuum on the annulus and not
3 wait.

4 MR. MYERS: The annulus it maintained constantly,
5 and the fans start automatically to maintain a negative
6 pressure, and it raises slightly when the well expands due
7 to temperature and pressure, but it is still kept negative
8 through the bulk of the accident.

9 MR. SIESS: We did not try to address how much
10 leakage would actually take to get out, since there is that
11 annulus, but I think it is an interesting question if you
12 start thinking about small leaks. It does not take a very
13 big leak, I think, to overcome that annulus.

14 MR. ETHERINGTON: If the valve would reseal after
15 a momentary high pressure pulse, not much damage would be
16 done, but I don't know if we can assure ourselves if it
17 would reseal. What is your opinion based on the
18 construction of the valve?

19 MR. DENTON: I am sorry, I really cannot answer
20 that question.

21 MR. SIESS: Can anyone?

22 MR. MYERS: No, sir.

23 MR. BENDER: What is the nature of this load? Is
24 it presumed this is a sharp peak type load that will go up
25 for an instant and then fall off quickly?

1 MR. SIESS: We did not. We assumed essentially a
2 static load, or what Dr. Mark referred to as quasi-static.

3 MR. BENDER: For analysis purposes, I am sure you
4 did that, but just from the standpoint of the kind of
5 loading it might be, is it likely to be a sustained load as
6 opposed to -- it does influence --

7 MR. KERR: I think it would show a curve against
8 pressure when measured against time, Mike.



9 MR. LAU: This valve has no structural problem.
10 This valve is open -- this check valve opens inward, so
11 there is a pressure from the inside of containment. It has
12 a tendency to force the things to close.

13 MR. DENTON: I think really to answer these
14 questions we would have to have a cutaway of that thing to
15 explain it, and to be honest with you, I really cannot
16 explain the thing here. We did not consider it to be the
17 cause of the butterfly valve inside. We have 150 on the
18 inside, and -- and I think if this is a weak point we want
19 to look at this thing more carefully.


20 MR. PLESSET: What does the membrane look like?
21 What is its thickness? Can anybody tell us? Do you have
22 any idea, Chet?

23 MR. SIESS: No.



24 MR. DENTON: I saw the picture about two months
25 ago, and -- so I know could not describe it. As some





**IMAGE EVALUATION
TEST TARGET (MT-3)**





MICROCOPY RESOLUTION TEST CHART







**IMAGE EVALUATION
TEST TARGET (MT-3)**



MICROCOPY RESOLUTION TEST CHART



1 mechanical drawings are, they are a little bit confused.
2 However, evaluating the thing, I looked at it and looked at
3 the calculations that accompanied the evaluations.

4 MR. SHEWMON: I thought the TVA man said it was
5 designed for significantly higher pressures than we are
6 talking about. Don't we believe him, or didn't I hear him
7 right?

8 MR. SIESS: Are you confusing the butterfly valve,
9 which is good for 150?

10 MR. PLESSET: It is a different valve, I think,
11 Paul.

12 MR. SIESS: One is a butterfly valve, and the
13 other is the check valve, which is good for only 48.

14 MR. SHEWMON: All right.

15 MR. SIESS: Which is downstream from the butterfly
16 valve.

17 MR. BENDER: Could I ask another question about --

18 MR. SIESS: Which we have now postulated to be
19 open.

20 MR. BENDER: -- about the closures? I suspect
21 that they are all sealed by some kind of rubber gasket of
22 some sort around the perimeter. Is that the general
23 principle on which they are sealed?

24 MR. SIESS: You said closures?

25 MR. BENDER: Hatches and the valves. I guess they

1 are all closed by some kind of a rubber seal. Is that
2 correct?

3 MR. DENTON: Could one of you all answer that?

4 MR. DILWORTH: Mr. Bender, as we have seen here,
5 we do not have the valve expert, unfortunately, with us
6 today.

7 MR. BENDER: Let me just ask my question, without
8 meaning it to be more than a question. Have you looked at
9 the definition under these very high loads to know that the
10 valve -- that the seals themselves will take deformation and
11 then hold when the pressure decays?

12 MR. MYERS: Early in our study, in about the spring
13 of this year, we looked at resilient seating type affairs,
14 and we looked at the O-ring type seals, because that had
15 been raised. At that time we were looking at pressures in
16 the 20 and lower 30-pound range. The preliminary results
17 were that that would not be a problem area, and therefore we
18 did not pursue it at that time any further.

19 As we go through in defining an exact pressure
20 that one might use as a design basis -- I hate that term,
21 but as a basis for this system, we would look at those in
22 detail again.

23 MR. SIESS: Mr. Denton, would you put the first
24 slide back up?

25 As far as the hatches are concerned, they are

1 located in regions of considerably thicker plate, and under
2 these pressures there would probably be no yielding
3 whatsoever. You said deformation.

4 MR. BENDER: I am talking about deformation of the
5 seals, Chet, and although sometimes people find that those
6 seals get overcompressed, they don't respond after the
7 loading, and you may have a seal over only part of the
8 surface, and I think that needs to be looked at. I don't
9 say it is necessarily a problem.

10 MR. ORR: I would like to present to you today
11 some results of a finite element analysis that was performed
12 on the TVA Sequoyah containment to determine its limit
13 capability. Don has been through the critical areas, and
14 the area of shell that is thinnest and is most critical is
15 the one-half inch course immediately below the spring line,
16 and what we looked at in our analysis was a single panel
17 between the hoop stiffener at elevation 788 and the hoop
18 stiffener at elevation 778.5.

19 We did not consider the change in plate thickness
20 of half-inch to five-eighths. We just assumed half-inch
21 throughout.

22 (Slide.)

23 MR. ORR: So, this represents a typical panel that
24 we looked at. This is a half-inch plate, hoop stiffeners
25 top and bottom, nine foot six apart, vertical stringers nine

1 and a half inches by one-half inch, four degrees apart. In
2 order to do the analysis, we assumed that this was one of
3 many panels in a cylinder, and hence we assumed symmetric
4 boundary conditions at each of these rings, also at the
5 center of the panel so that we were able in practice to
6 analyze a quarter of a panel.

7 (Slide.)

8 MR. ORR: The quarter of the panel tends two
9 degrees up at the top and is four foot nine inches high. It
10 has half of a hoop stiffener up at the top, and it has half
11 of an axial stiffener on one side. We developed a finite
12 element model of this quarter panel.

13 (Slide.)

14 MR. ORR: And we analyzed it on the ANSYS computer
15 program. Each of these elements are plastic triangular
16 elements. The panel itself is divided into elements that
17 are about six inches on a side, and there are four elements
18 in one direction and about ten in the vertical direction.
19 The stiffeners are also modeled using finite elements, the
20 hoop stiffener, and the longitudinal stiffener.

21 The boundary conditions, we assumed symmetry on
22 all boundaries, so on the vertical boundaries the tangential
23 displacement is zero. This allows the whole panel to move
24 out radially, and the rotation about the vertical axis is
25 zero, and the rotation about a horizontal tangent is zero.

1 On the boundaries at the top and the bottom, it
2 was assumed again as symmetric boundaries. The vertical
3 displacements were all imposed to be equal, but a force was
4 imposed in the vertical direction to account for the
5 pressure in the vertical direction. Again, two rotations,
6 zero, one being the rotation about the horizontal tangent,
7 the other being the rotation about the vertical axis.

8 We did a check case first of all for an internal
9 pressure on an elastic analysis, and then we extended it to
10 a non-linear large displacement analysis considering elastic
11 plastic behavior. In the plasticity in the yield criteria,
12 the Von Mises yield criterion is used. We assumed no strain
13 hardening, so in other words it is elastic, perfectly
14 plastic, with a yield stress, uni-axial yield stress at
15 45,000 psi.

16 (Slide.)

17 MR. ORR: This next plot shows the results of
18 radial displacement at each of the four quarters of the
19 quarter panel as a function of pressure. What we see is
20 linear results or relatively linear results extending up to
21 46 bsi. In practice, there is some local yield that
22 commences at about 30 to 32 psi, but the gross yield does
23 not start occurring until 46 psi, and then we extended the
24 analysis on up to 48 psi and to 50 psi, and got valid
25 results there.

1 At 52, we could not get results, and we would not
2 expect to get results above a certain pressure, because with
3 an elastic, perfectly plastic analysis, the displacements
4 would be infinite. What the results show is, Points A and B
5 were shown on the original quarter panel.

6 (Slide.)

7 MR. ORR: Points A and B are two points on the
8 hoop stiffener, one at the intersection with the
9 longitudinal stringer, one at mid-span between longitudinal
10 stringers, and these two points move radially outward to
11 reach the same magnitude.

12 Point C and Point D -- C is the center of the
13 panel. D is the mid-span of the longitudinal stringer.

14 What the results show is that early all four
15 points are moving out radially about the same amount at 46
16 psi, and we are talking a displacement of just about one
17 inch. The mid-span of the stringer, which is Point D, moves
18 out a little bit more than the hoop stiffeners, and the
19 mid-point of the panel moves out a little bit more than that.

20 The difference between C and D represents the
21 local deflection of the plate relative to the adjacent
22 stringers and the deflection of D relative to A and B is the
23 mid-span deflection of the stringer relative to the hoop
24 stiffeners.

25 The next vu-graph I will show you summarizes the

1 stresses at certain locations of the shell at 46 psi.

2 (Slide.)

3 MR. ORR: At this stage, all of the stresses in
4 the shell itself in the panel are at or close to yield. The
5 ring has hoop stresses between 37 and 39 ksi. Yield would
6 be at 45, so the ring is getting close to yield, but is not
7 there yet. The axial stringer has much lower stresses, and
8 in this case you can see that it is bending.

9 If you look at mid-span, the longitudinal stress
10 on the inner edge is 47 ksi; on the outer edge 22 ksi. That
11 is the end span at the ring stringer junction. The inner
12 edge is 18 ksi tension, and the outer edge is 10 ksi
13 compression.

14 The conclusion from this is that the mechanism of
15 the limit load is that the ring goes to yield, but the
16 stringer remains elastic, so basically the whole show is
17 going to be moving out radially at the same time. At 50
18 psi, which was the top point that we went to in our
19 analysis, we looked at some of the strains that were shown
20 in the analysis. The maximum strain is about .3 percent.
21 This is about equal to twice the yield strength.

22 So, we are still talking very low magnitudes of
23 stress.

24 MR. SIESS: This was at what level?

25 MR. ORR: This was at 50 psi. The maximum strain,

1 and that is due to both bending and membrane, is just less
2 than three-tenths of 1 percent, and occurs at the location
3 of the mid-span of the longitudinal stiffener.

4 MR. BENDER: How are their stiffeners attached to
5 the shell? Are they full penetration weld?

6 MR. ORR: I believe they are double fillet welds.

7 MR. DENTON: That is correct.

8 MR. ORR: The final vu-graph I would like to show
9 you is just an attempt to summarize some of the simplified
10 analyses and hand-type calculations that people did, and
11 then compare it with the results that we had on the finite
12 element analysis.

13 The initial number is, as Dr. Siess quoted, for
14 half-inch plate using nominal yield, 32 ksi. A pressure
15 that gives that stress is 23.2 ksi. And this is about twice
16 the pressure that the containment was designed for. That
17 factor of two is consistent with ASME requirements.

18 Then, a factor F1 is the ratio of actual yield to
19 nominal yield, in this case based on test reports. It was 45
20 ksi divided by 32 ksi. So, this is a 41 percent increase.
21 Factor 2, if you use Von Mises, which is a continuous curve
22 and typically matches better than the Tresca criteria, the
23 ratio is 1.15, about the maximum, and perhaps 1.1 -- 1.11 is
24 a better number to use. This is the number that Dr. Siess
25 has been using.

1 Then, coming to one of the concerns that came up
2 in the R&D Associates comments, they did not feel that the
3 smearing of the stiffeners was valid. This shows the effect
4 of smearing of the stiffeners, taking the hoop stiffener,
5 which is 16 inches by one and a quarter, the one almost at
6 the spring line, and smearing that over a length of shell,
7 nine foot six and half an inch, it represents a factor of
8 1.35. So, the hoop stiffeners contribute 35 percent.

9 I will skip this line first. The finite element
10 model that I did the analysis on was indeed consistent with
11 this stiffening configuration of two hoop stiffeners, one
12 above -- half at the top and half at the bottom of the nine,
13 six panel.

14 If I take the product of all of these factors,
15 23.2, 1.41 for the 45 ksi yield, 1.15 for the Von Mises,
16 1.35 for the shear values, I come up with 50.8 psi. The
17 analysis I showed you, we have results up to 50. We could
18 not get results to 52.

19 Going back now to this line, the actual
20 configuration of the containment is not perfectly symmetric,
21 and in fact just about the half-inch panel, there is another
22 hoop stiffener three feet six away.

23 (Slide.)

24 MR. ORR: So, if instead of taking a hoop
25 stiffener and smearing it over nine foot six, I take this

1 hoop stiffener and smear it from midway between these hoop
2 stiffeners to midway between these two, then that becomes a
3 six foot six height, and then I can come up with another
4 equivalent smearing. Let me find the right vu-graph.

5 (Slide.)

6 MR. ORR: That gives me an effect of the hoop
7 stiffeners of 1.51 instead of 1.35, and I believe it is
8 fairly representative of the way the shell will actually
9 behave. So, with the panel at the spring line, we say the
10 capability is 23.2 psi times 1.41 for actual yield times
11 1.15 for Von Mises times 1.51 for the smearing, which comes
12 up with 56.8 psi.

13 That concludes my presentation. Any questions?

14 MR. SIESS: This was the last analysis made, or
15 the most recent, and it essentially verifies the first
16 analysis made. Maybe we should stop here.

17 MR. PLESSET: Is that progress, Chet?

18 MR. SIESS: Yes, that is progress. Nobody
19 believed the first one.

20 MR. PLESSET: No questions.

21 MR. SIESS: I would like to call on Dr. Zudans.

22 MR. MOELLER: The original design was at what, 20,
23 15?

24 MR. SIESS: The original design? Twelve psi.

25 MR. MOELLER: Twelve. Okay, thank you.

1 MR. SIESS: Zenon, I would like for you to present
2 not only the results of your analysis, but also to relate
3 them, if you can, to Dick's and to any of the others that
4 you know of, if you would.

5 MR. ZUDANS: I will do that.

6 We had quite a discussion on Tuesday, and I am not
7 going to repeat everything I said. It might not be so
8 easy. But first, to the best I can show so far -- in the
9 subcommittee -- Dick's analysis -- Richard -- he does not
10 like to be called Dick -- is the right way to go, and the
11 only concern I might have with it is that it takes a very
12 small section near the spring line where there are other
13 discontinuities, but I think it is a nice piece of work, and
14 I think it shows how the shell will behave, and it also
15 confirms what I found. Even the numbers are very similar.

16 I did not do inelastic analysis, but since this
17 material has very little strength hardening, inelastic
18 analysis essentially does not have to be carried very far to
19 come up with a final limit load. Now, the other analysis,
20 as was stated before by Chet, that by Ames, used a method of
21 smearing out rings and stiffeners, and it fails to be
22 rigorous, even in a simple sense, except for the calculation
23 of simple membrane, which is PR/T , known to everybody, and
24 that is what the 23.2 psi is in this calculation.

25 Now, one must give the credit in doing a job as

1 they did, because I am told afterwards that they only had
2 been given, say, four days to give an answer. If you give a
3 four-day answer, that is what you get, a four-day answer.
4 You have to give a guy a chance to read his own work, at
5 least, before he puts his name to it.

6 So, I was more critical on Tuesday -- I am not as
7 critical today, because I don't think it concerns anybody
8 any more, because we now have a set of answers that we all
9 can believe in the sense that if anybody did the most
10 precise analysis, they would not find any different answers.

11 The other analysis, the R&D Associates, they are
12 kind of artistic. It is beautiful. However, unfortunately,
13 not to the problem that we are dealing with right now. So,
14 they are only as good as the initial assumptions are. So,
15 to my amazement, though, Mr. Bagchi's calculation, which,
16 unfortunately, I did not read before I wrote my report, came
17 out with a correct answer on a back of the envelope type
18 calculation.

19 The reason for that was, he simply gave it a
20 little bit more thought of how the stringers interact, and
21 drew up equations for it, and got the answer that is very
22 close to the real answer, after all those sophisticated
23 calculations.

24 I was not going to do any analysis. I only was
25 asked to review two reports, but after I reviewed those two

1 reports, it kind of angered me, because I could not write
2 and give Chet any answers as to what to expect, so I
3 performed some analyses myself.

4 First, I analyzed two different locations. One is
5 from -- halfway from this point over two rings, halfway to
6 this point. This was the area where the Ames report claimed
7 the weakest spot was, and the reason they arrived at that
8 conclusion was because the way they smeared out the
9 stiffeners in the rings, it looked like the weakest section.

10 Then, afterwards, finding that this was not really
11 the critical section, I went back to this area where the
12 half-inch plate joins the five-eighths inch plate, and of
13 necessity this is a critical point regardless of what the
14 internal pressure is, because there is a significant
15 discontinuity.

16 First of all, the inside surfaces match exactly.
17 The reference lines or the center lines of these two
18 sections mismatch, and there is a bending introduced into
19 that section. I would like to see locations like that
20 always reinforced, but this is not the case here, so that
21 was a logical candidate for the weakest spot.

22 Here I took a model from this location here, went
23 over one of these rings, over this five-eighths inch plate,
24 over the half-inch plate, over this ring, this piece of
25 plate, this ring, and halfway about the spring line, so I

1 had three rings at several spans.

2 The reason for going that far with the model was
3 because I had the same doubts Richard stated, that these are
4 discontinued in here. It is very difficult to justify
5 symmetry boundary conditions at those points, so if I move
6 from what I call the critical region far away enough and
7 impose the symmetry there by the simple rule of decay of the
8 boundary perturbations towards this section of interest, I
9 could reason that this would be not shadowed over with any
10 false results.

11 Now, the first analysis that I did then addressed
12 the other section, and that is what the revolution model
13 looked like. The problem used here -- from here to there is
14 able to represent the rings as radial plates in linear
15 elasticity. It is exact. It represents the cylinders and
16 the stringers. These are the stringers that are welded to
17 the shell and the rings. They are represented in a smeared
18 out fashion, but in such a way that their bending stiffness
19 and meridinal stiffness are exactly represented.

20 So, what it really does is, it should overstress
21 the stringer a little bit more and understress the shell a
22 little bit more, because they are forced to deflect together.

23 Normally, as you saw already from Richard's model,
24 the center portion of the span will deflect slightly more
25 than the stringer will.

1 Now, to prove some points, in the other analysis,
2 I did one without the stringers, and this is the
3 distribution without the stringers. You see the hoop stress
4 at the rings reduces essentially to zero, and between the
5 rings it reaches the full hoop stress as if the rings were
6 not there. It indicates that without the rings, the
7 analysis resulted in 23.2 psi. It would have been exactly
8 correct.

9 As you introduce the stiffeners, the picture
10 changes completely.

11 (Slide.)

12 MR. ZUDANS: This is the figure that shows how the
13 hoop stress varied in the lower portion of five-eighths inch
14 plate, and you can distinguish the location of rings, but
15 not particularly being too different. In other words, the
16 entire shell tends to be within 10 percent or so one from
17 the other.

18 Now, to make sure that this shell type analysis is
19 justifiable, I also made up a finite element model.

20 (Slide.)

21 MR. ZUDANS: It is in essence similar to what Bob
22 did. However, I put the ring in the middle of the element
23 because I felt that the easiest way to justify symmetry
24 boundary conditions is halfway between the rings and halfway
25 through the rings here. So, this analysis was on exactly

1 the same model as the previous one, and I used the results
2 of these two analyses to gauge the quality of the shell
3 revolution type of analysis.

4 There was a statement, I guess, to show how much
5 in error the statement that the stiffeners carried the same
6 load the entire lengths -- I plotted here the load
7 contribution by the stiffeners. You see, it essentially
8 reduces the load-carrying capability to zero, and increases
9 this value, so the assumption of some uniform load along the
10 stiffener is only good if you can talk about an infinite
11 cylinder that is completely free to expand.

12 Then the solution would be exact.

13 Okay, now the analysis that represents the weakest
14 spot is done on this model, which is the three rings and the
15 span in between.

16 (Slide.)

17 MR. ZUDANS: If you recall, Richard analyzed the
18 space between these two rings, a quarter of it. This
19 carries the analysis beyond to include these two rings that
20 are quite close together and certainly provide significant
21 stiffeners. Here on this model the symmetry boundary
22 conditions are here. This is fixed axially, and, of course,
23 can grow freely in the radial direction. The thickness
24 change takes place here, from five-eighths to half an inch.

25 (Slide.)

1 MR. ZUDANS: The results of this analysis are
2 shown on this slide. This is the physical bound between the
3 two stiffeners. You can see here where the half-inch plate
4 joins the five-eighths inch. There is a significant
5 increase in hoop stress and also a significant jump in the
6 axial stress.

7 Now, this is the extent of the analysis I have
8 done. If I use these results shown in this area, then I
9 come to the conclusion that based on the shell analysis, I
10 would -- and on Von Mises criteria, I could yield this
11 cross-section -- Let me show you.

12 (Slide.)

13 MR. ZUDANS: It is this cross-section here, at 51
14 and a half psi, gauged by the finite element comparison to
15 the shell revolution in the other area. I had to reduce
16 this to about 48.9 psi, so it will fully yield here.

17 But the most interesting thing is that the entire
18 panel is so close to that, if you compute the Von Mises
19 effect, it would be about 17,000 -- 15,000, which really
20 means within about four psi or so the entire panel will
21 yield, and the rings, if this panel is able to continue
22 carrying load without ballooning out, the rings would start
23 going at 61 psi, this ring first, and those would be much
24 higher.

25 This is about 77, so the structure is very, very

1 well balanced in a way. If it starts yielding at 60 psi,
2 you could probably find several panels going, so to speak.

3 That is about all I have to say. Yes, Dave?

4 MR. OKRENT: There is some probability that there
5 are welds in this structure which are imperfect in the sense
6 that they were able to withstand the pressure test that was
7 done, which was a much lower pressure.

8 MR. ZUDANS: Thirteen and a half.

9 MR. OKRENT: But might nevertheless have
10 substantial flaws, and flaws of the type that would, let's
11 say, give at some higher pressure. How would you factor
12 this kind of thing into your thinking about what constitutes
13 a pressure with some degree of confidence that you know one
14 should count on, or whatever are the right set of words?

15 MR. ZUDANS: By the code requirements, all the
16 shell welds, both longitudinal and vertical, have to meet
17 the code, so it is not likely you would find any difference
18 beyond the code size.

19 MR. OKRENT: They are not 100 percent --

20 MR. SIESS: This is -- Is this 100 percent weld
21 inspected?

22 MR. DENTON: The welds are 100 percent
23 radiographed for all pressure boundary welds.

24 MR. ETHERINGTON: That does not include the welds
25 for the stiffeners?

1 MR. DENTON: There is a magnetic particle
2 examination, I believe, on those.

3 MR. OKRENT: Let me again understand what you are
4 telling me. I thought there was some thickness below which
5 only --

6 MR. SIESS: You don't need stress relievers. You
7 are thinking about the concrete containment liners, and they
8 are only partially inspected, because they are not a
9 pressure boundary. They are only a leak boundary.

10 MR. OKRENT: But only a 100 percent weld
11 inspection.

12 MR. SIESS: That is what he says, and that sounds
13 right. This is a pressure boundary.

14 MR. OKRENT: That would, I think, reduce -- not
15 eliminate, but it certainly would reduce the probability of
16 a large flaw.

17 MR. SIESS: It is very ductile material.

18 MR. BENDER: Generally speaking, the welds provide
19 enough stiffness so you can be comfortable that there is no
20 concern there about those giving way under the loading. The
21 fillet welds.

22 MR. SIESS: The fillet welds are not that
23 important, since the plate is on the inside of the rings,
24 the only purpose those fillet welds have is for a little
25 composite stiffening between the ring girder and the plate,

1 you know, shear transfer, and that is not going to be very
2 much of a load or stress.

3 MR. ZUDANS: Your statement is absolutely
4 correct. The shield transfer capacity here is rather
5 minimal. The bending is not significant. So you could say,
6 all of this weld, that and that, are not really significant,
7 but when you come to this weld, it is very significant.
8 These would be very significant, and of course this is
9 extremely significant because it happens to be sitting right
10 where the critical section is, but these continuous fillet
11 welds, the stringer attachment and the ring attachment are
12 not significant. There is very little bending there.

13 MR. SIESS: We did not cover that at the meeting,
14 but I checked on it in between.

15 MR. ZUDANS: I figured you would.

16 (General laughter.)

17 MR. ZUDANS: So what it really means is, the kind
18 of strains you would have about a one-inch deformation.
19 There is not much to go beyond that point.

20 MR. SIESS: I think at this point to get the
21 analyses completed we ought to hear from the staff. They
22 have heard all of this before, and they have a position
23 which I have already indicated earlier, but I see no reason
24 why we should not hear it.

25 MR. STAHL: Dr. Tan will give the presentation.

1 MR. OKRENT: If I could pursue my question just a
2 little bit to Chet and Zenon, how big a flaw would there
3 have to be to bother you at the kinds of pressures you are
4 talking about?

5 MR. ZUDANS: Me?

6 MR. OKRENT: If it is a half-inch thickness flaw,
7 it would not disturb you.

8 MR. ZUDANS: No, not if it is only that long.

9 MR. SIESS: Paul might have some idea.

10 MR. SHEWMON: I have no complaints with that
11 answer.

12 MR. SIESS: The weld material is usually stronger
13 than the plate material.

14 MR. OKRENT: I just wanted to see if I should
15 worry. At that size, I think it is unlikely.

16 MR. SHEWMON: It is not unlike a notch in a piece
17 of copper.

18 MR. TAN: I want summarize the staff's review and
19 evaluation of the various analyses and to present to you our
20 conclusion.

21 Our evaluation consists of the original Ames
22 Laboratory analysis, R&D Associates, and Bagchi's analysis,
23 and OPS, and Dr. Zudans', because after last Tuesday's
24 subcommittee meeting, we feel we have to take all analyses
25 into consideration and to finalize our position.

1 (Slide.)

2 MR. TAN: These are the analyses done by TVA. It
3 shows the various -- various assumptions with respect to the
4 ring stiffeners and the stringers. This is the value
5 reached by TVA, 38, and OPS comes to 50 and 57, just as we
6 sent it by Richard Orr. This is the Ames Laboratory, after
7 the revised analysis. This is R&D Associates' results of
8 analysis. This is Mr. Bagchi's, and that is ours.

9 These are the finite element analyses from Ames
10 Lab. It is as high as 60 psi, and Dr. Zudans is 47. One is
11 at yield, one is at limit. Now, from this we have to -- Dr.
12 Zudans said the Ames Laboratory analysis may not be as good
13 as OPS, but after the revision -- they revise their value,
14 it is comparable to the OPS.

15 Basically, OPS I think also used the smear
16 technique. There is not much difference.

17 Now, as to the value by Bagchi and Zudans, I have
18 more confidence in Dr. Zudans' because he is my former boss.

19 (General laughter.)

20 MR. TAN: And I know he is competent. But Dr.
21 Bagchi's number, you know, if you look very carefully, it
22 can be manipulated. There are many assumptions there. He
23 hit the jackpot. That is all.

24 (General laughter.)

25 MR. TAN: If you look very carefully, you know,

1 his analysis, you know, so this is a number -- so after
2 looking over all the values at the subcommittee meeting, we
3 recommended 33 psi, but after looking over all of these
4 results and hearing the experts' opinion, we finally -- we
5 said, okay, we agree with using the Von Mises criterion,
6 because the original 33 is on the Tresca criterion.

7 MR. MOELLER: Could you refresh me on the factor
8 45 over 32?

9 MR. TAN: This is the actual mill test result.
10 The 32 is the code specified value. Besides TVA, we also
11 used 32.

12 MR. BENDER: That is ultimate strength?

13 MR. TAN: Yield strength. Yield strength. So our
14 conclusion is -- on the basis of results of TVA, staff's
15 consultant, and others, and taking into consideration all
16 the factors, the staff calculated that the value of 38 psi
17 at yield is reasonable and therefore acceptable as the
18 Sequoyah containment limiting static internal pressure.

19 The basic problem we have to remember for
20 containment, it is necessary but not sufficient because of
21 the leakage problem. We feel 38 psi can be used.

22 MR. SIESS: I think you heard Mr. Orr say that
23 this maximum strain was about three-tenths percent, which is
24 just about twice the yield. Are you concerned with an
25 additional -- that much strain?

1 MR. TAN: The problem -- we tested the containment
2 to about 15 psi, so from 15 psi to 38 already we don't know
3 very much how much the leakage would be, but I think we have
4 some confidence, you know, before reaching the yield, that
5 the leakage should not be too much, but after the yield is
6 reached, you know, nobody can say how much the leakage would
7 be.

8 MR. SIESS: So the staff's position is that as
9 long as you stay elastic -- I have to put elastic in quotes,
10 because there is local bending, but essentially membrane
11 elastic, as long as you stay elastic, you feel confident
12 about it.

13 MR. TAN: Yes. Otherwise, if we don't have the
14 leakage problem, we can go to 50 or 60 as our analysis
15 shows. The leakage -- I don't know -- under the seals in
16 the penetrations how they deform, because, you see, if the
17 containment -- the containment penetrations, you can build a
18 very leak-tight structure, but with all the seals and all
19 the penetrations, I am not confident --

20 MR. SIESS: You are saying all these penetrations.
21 Most of the penetrations are down in the thicker plate, and
22 at 50 psi versus 38, I doubt if even the five-eighths inch
23 plate or the next panel down would be yielded.

24 TVA has got -- I checked with them, and they have
25 found one string of penetrations up in the region we are

1 concerned with. There are four in a row backed by an inch
2 and a half plate, I believe. It is a string, right? So,
3 most of the penetrations are not going to be at yield, even
4 at 60 or 70 psi.

5 MR. TAN: Okay. All right. By the personnel lock
6 -- the seals in the personnel lock and the equipment hatch,
7 you would have those. I am not concerned about those seals.

8 MR. SIESS: You are not concerned about overall
9 deformation?

10 MR. TAN: I don't believe there is a problem.

11 MR. SIESS: So you are concerned about the fact
12 that higher stresses might limit -- take some of the
13 penetrations into yield, and the penetration hardware would
14 be at yield?

15 MR. TAN: That is our concern. Otherwise, we can
16 relax.

17 MR. SIESS: I just wanted to --

18 MR. TAN: The 38 is the lower bound. If you want
19 to go higher then it is a matter of judgment how much higher
20 we can go until the seal will not have a leakage problem.

21 MR. PLESSET: Chet, you indicated perhaps RDA
22 might want to make a comment.

23 MR. SIESS: Any further questions for Mr. Tan?

24 (No response.)

25 MR. SIESS: Okay, thank you very much.

1 R&DA was involved in this by reviewing the initial
2 Ames Laboratory Studies, and pointing out some disagreements
3 and deficiencies, and they raised the question of the panel
4 capacity, which I feel quite sure led to some of these other
5 more detailed analyses.

6 I think it is appropriate to ask Mr. Parry from
7 R&DA if he would like to summarize their current feelings
8 about what you have heard and if you have any general
9 feelings about what you think would be an acceptable
10 pressure, we sure would like to hear those.

11 MR. PARRY: Yes, and I have three vu-graphs.

12 MR. SIESS: Okay, fine.

13 (Slide.)

14 MR. PARRY: The presentation that I gave on
15 Tuesday was dated August, 1980. You will notice this one is
16 dated September, 1980.

17 (General laughter.)

18 (Slide.)

19 MR. PARRY: Now, a few general comments. All the
20 prior analyses that we had seen until Tuesday we considered
21 to be limited in scope mainly because of time and funding.
22 We had about four days to do this analysis. Very clearly,
23 all those results were very dependent on the initial
24 assumptions. What were the ring stringer effects? And we
25 very quickly concluded that the precise stiffener plate

1 interactions are a very complex thing, and we sa'd the only
2 true solution requires a detailed finite element code
3 analysis.

4 Fortunately, TVA picked that up and did a very
5 good analysis, and we essentially agree with what TVA and
6 Offshore Power Services say. We tried to establish some
7 bounds, knowing the problem, and also, I might say, having
8 been involved in some things that have gone wrong in simple
9 analysis before we qualified our analysis by that statement
10 requiring a more detailed finite element analysis.

11 I know some of these simple analyses go wrong, and
12 people have been bitten by simple analyses. You are all
13 aware of that. So we looked at it. The encastre plate,
14 suppose the plate section were held rigidly on all sides,
15 and we looked at it as a membrane aircraft fusilage type
16 analysis.

17 We realize our analysis is conservative. We don't
18 have a jaundiced view of the world, and we are looking at
19 something which should be conservative. Our analysis was
20 conservative, and as I say, the offshore power systems
21 analysis was done with realistic results. I suppose I have
22 a slight disagreement with the interpretation of the OPS
23 analysis. I will talk about it in a minute.

24 Now, the other thing that happened was -- and we
25 assumed this. Now everybody was in the same boat. We

1 originally assumed 3½ ksi as the strength tests have shown.
2 It is actually 45 psi. And since we are not setting
3 criteria, we are finding out what pressure this thing should
4 go. We should use the test results. If we are setting
5 criteria, then we have to put some safety factors in, and so
6 forth. That is a different matter.

7 (Slide.)

8 MR. PARRY: Now, very briefly, we believe that the
9 qualitative summary of what happens is something like this.
10 Panel quilting takes place, and this again is well known in
11 aircraft fuselage type analysis, because the panel is,
12 because rings and stringers, it tends to bow, and Richard's
13 analysis clearly shows that.

14 The first big stress point is at the midpoints of
15 the long sides, and as he said, if you take that analysis up
16 and gradually increase the pressure, then fiber yield will
17 be reached at about 31 psi at these points, and eventually
18 as you raise this thing up, then we finally get to our
19 simple analysis of 38 psi.

20 The detailed analysis of TVA shows 46 psi, which
21 we accept. Now, that is where the thing starts going
22 non-linear rapidly and becomes plastic. If you did the
23 smearing analysis, as Richard did, you get 50 psi. So, what
24 this really says is, in the linear portion, and all the
25 stuff that was done before was always linear, nobody until

1 this recent analysis did any non-linear analysis. It says
2 indeed this double stiffening, rings and stiffeners goes
3 two-thirds of the way towards the smear, 50 psi.

4 Well, we accept that because it has been done and
5 now done properly.

6 (Slide.)

7 MR. PARRY: So, to summarize -- you people have
8 been through this before. We said simple analysis was 27,
9 but the 45 ksi, so the 32 ksi raised that to 38. The OPS
10 finite element says 46. There is still something to be
11 gained by going somewhat plastic, so the 46 in our opinion
12 now is a conservative estimate. We still, however, will be
13 concerned about the midpoints of the sides. After all, they
14 are close to welds. If the welds are well inspected, there
15 should be no problem, but after all, on the midpoints of
16 those sides, there are 180 points around that circumference,
17 so they should be well inspected there.

18 There is another saving grace here which has also
19 been alluded to. This 46 psi is based on a complete
20 half-inch panel, and it is not a half-inch panel.
21 Two-thirds of it is half-inch, and one-third is
22 five-eighths, so there is some help from there.

23 So, having requested this analysis, we now accept
24 that result. It is as simple as that.

25 MR. SIESS: Thank you very much.

1 MR. PARRY: I think the staff are now being a
2 little conservative like we were originally.

3 MR. MOELLER: Would you comment again for me on
4 the two values that are much lower than the 38, the boiler
5 code, and the Sandia analysis? How do you evaluate those,
6 or how do you cross them off, so to speak?

7 MR. PARRY: The boiler code analysis uses maximum
8 shear energy. Everybody else is now using the Von Mises,
9 which gives a 15 percent difference, which is more realistic
10 in a practical case. The boiler code is used because it is
11 very simple to use, and it is conservative, and after all,
12 the code has to be conservative.

13 MR. MOELLER: And the Sandia?

14 MR. PARRY: I don't know anything about the Sandia
15 analysis. I have only seen a result.

16 MR. SIESS: It was not Sandia. It was Battelle.

17 MR. PARRY: Our report said Sandia.

18 MR. SIESS: It is not based on actual strength. I
19 don't think it should be in that column.

20 MR. PARRY: Okay.

21 MR. SIESS: It was based on 32,000 yield, so it
22 belongs over in the other.

23 MR. PARRY: It is.

24 MR. SIESS: I see. Yes.

25 MR. PARRY: I have two columns there.

1 MR. SIESS: We know too little about it to know
2 how they got it.

3 MR. MOELLER: But you have reasons not to view it
4 with alarm?

5 MR. SIESS: We have reasons to believe the ones we
6 have seen which agree remarkably --

7 MR. MOELLER: Yes.

8 MR. SIESS: -- I think there have been about four
9 approaches that come within, I would say, plus or minus 10
10 percent of the same value. That is almost unbelievable.

11 MR. PARRY: I think there is pretty general
12 agreement now that the analysis has been done correctly.

13 MR. SIESS: Actually, as I read the Battelle
14 report -- No, I will take that back. I don't know what the
15 figure is.

16 MR. PARRY: The thing I saw, they had two values,
17 24 psi, and I am talking about this 32 ksi yield and 30 psi,
18 and they said, well, it is 27 psi plus or minus three.

19 MR. SIESS: Twenty-four yield and ultimate of 30.

20 MR. PARRY: Yes, and they add them together,
21 divide it by two, and said plus or minus three.

22 MR. SIESS: Yes. I don't trust that.

23 MR. PLESSET: Does that cover it, Chet?

24 MR. PARRY: Mr. Chairman, I would like to say
25 something else. I see that RDA is down in the hydrogen

1 discussion. I believe there is no one here from RDA to
2 discuss that. I am only peripherally involved in that.

3 MR. PLESSET: All right. All right. I guess that
4 completes this part of our discussion. I think we are going
5 to have a discussion from TVA. I would like to suggest a
6 ten-minute recess. In fact, let's take it.

7 (Whereupon, a brief recess was taken.)

8 MR. PLESSET: Let's reconvene and turn the meeting
9 over to representatives from TVA. As I mentioned to you
10 before, they have a model which, among other things, shows
11 the location of the igniters, and it would be worthwhile
12 if the committee members would take a look at it. Maybe
13 they can do it after their presentation is complete, but it
14 will be of some interest for you to do that, so why don't
15 you go ahead with the presentation? We will look at the
16 model later, after you are all finished.

17 MR. MILLS: Yes, sir.

18 We will have Mr. Wang Lau from our engineering
19 design organization to lead off this presentation, and he
20 will be followed by Mr. Dave Gasser from Westinghouse, who
21 will talk some about the vent wall testing that is going on.

22 MR. LAU: I am Wang Lau, TVA.

23 I plan to spend about five minutes to give brief
24 statements on nine items. The statements are supported by
25 the handouts and the documents that we have submitted to the

1 NRC.

2 Item Number One: Based on our original Sequoyah
3 design and the post-TMI modifications we have made on
4 hardware and operating procedures, we believe that the
5 probability of an accident at Sequoyah which will result in
6 a degraded core is no higher than other plants. We believe
7 that no additional hydrogen mitigation system is required
8 for full power operation.

9 Our analysis indicates that with a reasonable
10 design limit of 57 psi gauge for the containment, Sequoyah
11 can take about 700 pounds of hydrogen in an adiabatic burn.
12 This means that Sequoyah can accommodate an event similar to
13 TMI even without the benefit of an ice condenser. The
14 results of calculations including the ice condenser provide
15 significantly more capability.

16 Item Two: We believe that an interim distributed
17 ignition system has good potential for obtaining additional
18 protection. We have not identified any negative effect due
19 to controlled ignition as opposed to uncontrolled ignition.
20 On the other hand, we have seen from my analysis that
21 controlled ignition has a positive effect in mitigating an
22 assumed sequence of accident events.

23 Three, based on our limited research and limited
24 testing at Singleton Lab, we believe that the interim
25 distributed ignition system we have designed and installed

1 show promise in burning up hydrogen at relatively low
2 concentrations. We intend to obtain firsthand knowledge.
3 While testing at Fenwall Lab through Westinghouse, we will
4 perform ignition tests at various hydrogen concentrations,
5 steam flow, and water droplet environments. This will be
6 discussed by Westinghouse later.

7 We have 31 thermal glow igniters in Sequoyah. We
8 use diesel engine glow plugs. These can be seen from the
9 models we have brought here. The containment model has a
10 scale of one-eighth of an inch to one foot. The igniters
11 are spaced with the intent of burning bulk hydrogen. We
12 have decided to delay the use of spot igniters until we are
13 sure of the effects of electromagnetic interference. We are
14 working on it with the help of consultants.

15 Item Five: We have studied in considerable detail
16 all the possibilities such as nitrogen inerting and filtered
17 vented containment. We believe that distributed ignition
18 systems is the preferred interim measure for obtaining
19 additional protection, although there was no absolute need
20 for this or other systems, as I stated earlier.

21 Item Six: We have joined with American Electric
22 Power to contract with Atlantic Research Corporation to do
23 work on halon. Work has started, and we expect the report
24 in about four months.

25 Seven, we have also started our investigation on

1 catalytic converters.

2 Eight, in other areas, TVA's degraded core task
3 force intends to, A, study system transient and accidents to
4 arrive at a fair range of probability for hydrogen
5 generation and identify critical sequences. Operating
6 procedures and maintenance procedures will be examined to
7 determine their contribution to risk. Work is in progress.

8 B, through computer and system analysis, obtain a
9 regional hydrogen generation rate. Work has started.

10 C, obtain the computer code for containment
11 response analysis. This will be similar to the present
12 CLASIX code by Westinghouse, but will include internal heat
13 sink, initial water droplets, et cetera, to remove certain
14 conservatism and obtain more realistic results.

15 C, through a series of tests, determine if the
16 assumptions and parameters used in the present analysis are
17 consistent with the test data. This work is in progress at
18 Fenwall Lab.

19 In summary, A, we believe that Sequoyah is safe to
20 operate at full power. B, we believe that we have
21 reasonable assurance that the interim distributor ignition
22 system will be effective and offer the best potential for
23 obtaining additional protection. C, we are moving on many
24 fronts to study degraded core related subjects.

25 I would be glad to answer your questions.

1 MR. PLESSET: Let me first ask what kind of a
2 schedule do you have on the glow plug study? I mean, there
3 is a program, your own program, right, and the staff has a
4 program at Lawrence Livermore Lab, but you have your own
5 program.

6 MR. LAU: Yes, we have two different programs.
7 One is at Singleton Lab. Basically this will be a quality
8 assurance type sampling test. We have procured about 600
9 different types of igniters. We will just go through the
10 sampling and arrive at some kind of confidence limit type
11 thing.

12 Another type of test we are doing would be covered
13 by Westinghouse later, about the Fenwall tests.

14 MR. BENDER: I believe you mentioned 31 igniters.
15 How did you decide on the number and distribution?

16 MR. LAU: Okay. The igniters are intended to burn
17 up bulk hydrogen. Mr. Myers wants to add additional
18 comments.

19 MR. MYERS: That, of course, was asked of us
20 earlier. In the interim system, the objective is to burn
21 bulk quantities of hydrogen, that is, over long spaces
22 basically, all the upper compartment or lower compartment,
23 and maybe propagation in between. Therefore, as far as
24 number of igniters, what we were after was to ignite or
25 provide reasonable assurance of igniting a concentration if

1 the bulk average in those compartments got high, rather than
2 in some local area.

3 As far as the number, based upon all the studies
4 we have done in the past on subcompartment analysis for LOCA
5 studies and what have you, we have a pretty good
6 understanding of the distribution in the areas. We thought
7 at that time that on the order of 20 to 30 would probably be
8 required.

9 When we got down to the detailed location, which
10 included sticking them near the top, if there were
11 compartments that were relatively wide in comparison to
12 their heights, then we put several in those compartments,
13 more than one. When we got done, we had about 31 igniters
14 located.

15 The critical dimensions, really, of the upper
16 compartment burn to the lower compartment burn is a rough
17 radius or diameter of 75 to 100 feet, and we tried to make
18 sure that the igniters were not located that far apart.

19 MR. BENDER: Are there any compartments that do
20 not have igniters?

21 MR. MYERS: Inside the reactor vessel cavity I do
22 not believe currently has an igniter. There is a chase for
23 the in core instrument tubes that do not have -- does not
24 have an igniter.

25 MR. LAU: But they will be under water.

1 MR. MYERS: The dog houses of the steam generators
2 and pressurizers do not have igniters up in them, but they
3 do have igniters near the entrance.

4 MR. BENDER: Where would the igniter be that is
5 nearest to the vent valve -- is that the word I want to use?

6 MR. MYERS: You are speaking of the reactor system
7 -- vent system to be added.

8 MR. BENDER: Yes.

9 MR. MYERS: The exact location of that vent
10 release has not been set. We are currently reconsidering
11 and looking at that, but there is an igniter in the area of
12 the pressurizer compartment near the ceiling that would be
13 in the plume from those kinds of releases, and also from the
14 pressurizer relief tank.

15 MR. BENDER: How about the vessel downstream. If
16 that igniter did not ignite, and the hydrogen moved to the
17 next point --

18 MR. MYERS: The probable flow path in that lower
19 compartment is up to the ceiling, because it is hot air, and
20 then there are igniters along the ceiling, so the igniters
21 are around the circumference of the ceiling, if you will,
22 and with the ice condenser, of course, it is a reasonably
23 short distance.

24 MR. OKRENT: Were the comments you just made all
25 addressed specifically to hydrogen control, or were they

1 intended to cover other kinds of questions that arise when
2 you think about degraded core or core melt accidents?

3 MR. LAU: Well, we interpret the phrase in the
4 agenda, "additional hydrogen control measures," to be
5 interpreted as over and beyond interim distributed ignition
6 systems. That would include inerting, vented containment,
7 et cetera, halon, catalytic converters.

8 MR. OKRENT: I see. So you are looking, if I
9 understood what you just said correctly, at other kinds of
10 things in addition to hydrogen control with regard to
11 degraded core or core melt accidents.

12 MR. LAU: Yes, sir.

13 MR. OKRENT: What is the staff's position for ice
14 condenser type containments? Is it coming, you know, with
15 regard to the question of, is there something that they
16 think they should look at or licensees should look at for
17 ice condensers?

18 I probably should remember this.

19 MR. BUTLER: Let me try to just clarify. I think
20 there was a little mixup with respect to the understanding
21 on the scope. The understanding with respect to today's
22 agenda in our area here is limited to those measures needed
23 to deal with hydrogen generation. When you go beyond that
24 -- I have the feeling that your question was directed at
25 other measures beyond hydrogen control. Do I understand

1 that correctly?

2 MR. OKRENT: Yes. Well, I thought the man from
3 TVA just said that he had some things like that in mind in
4 what he was just discussing.

5 MR. BUTLER: But he clarified that by saying that
6 the other things he had in mind were things beyond the
7 igniters, such as halon control, halon systems, and fogging
8 systems, not necessarily vented containments or core
9 catchers or things like that.

10 MR. OKRENT: I am not going to try to put words
11 into his mouth, but I want to know -- let me tell you why I
12 think it is relevant to the discussions.

13 Commissioner Gilinsky has posed some specific
14 questions in terms of hydrogen control, but it seems to me
15 if one is going to try to develop an answer to a question,
16 are measures to deal with hydrogen appropriate on some time
17 scale, or prior to something, or whatever is the way it is
18 phrased, and if we are talking about a lot of hydrogen -- I
19 don't mean like in the rulemaking hearing on ECCS -- one
20 might well think about this in a broader context.

21 In other words, that becomes part of a spectrum of
22 accidents, and you ask yourself, is there a reason to stop
23 with hydrogen? That may be. Or should one look at other
24 things? Possibly. If so, why, and on what time scale, and
25 so forth?

1 Now, I am asking now what the staff position is
2 with regard to ice condenser containments, because that is
3 the one we are talking about now. With regard to not only
4 hydrogen control but other things, regarding core melt
5 accidents.

6 MR. ROSS: First, with respect to the hydrogen
7 management, it is the staff's position that the ice
8 condenser owners, like all other PWR owners, should provide
9 some hydrogen control measure analysis information on a time
10 scale somewhat less than a year. We have expressed our
11 position in the interim rule, which the Commission just a
12 few minutes ago authorized us to issue comment.

13 When the rule becomes effective, it would require
14 in this case TVA within six months to file some analysis
15 information on a number of things related to hydrogen
16 control, including scenarios that lead to burning,
17 effectiveness of halon, water fogging, and so on.

18 What we would do with that information is not
19 defined. Presumably, we could become alarmed and decide
20 that something better needs to be done, or that we have
21 become satisfied, and decide everything is real fine. I
22 don't know, but as far as hydrogen control, that is our
23 position, and we have not gone -- we have not done anything
24 that may be idle speculation beyond the seat of the
25 information.

1 Now, with respect to other things -- I am now
2 going beyond the design basis -- there are a number of
3 activities. We talked yesterday about the advance notice
4 for rulemaking, which goes into these more elegant molten
5 core response features, such as filter vented containment
6 core retention devices.

7 I don't know what the Commission is going to do.
8 They were going to have an affirmation session maybe today,
9 and authorize issuance of that Federal Register notice,
10 which would trigger a rather long rulemaking process, years
11 long. It turned out not to be true, but if an ice condenser
12 plant happened to be in what we call a high population zone,
13 then it might have additional studies as to further design
14 features to reduce risk like I think Mr. Denton talked to
15 the subcommittee yesterday.

16 The emergency planning rulemaking -- and there is
17 another rulemaking being considered by uniform or minimum
18 engineered safety features standards. All could impact the
19 ice condenser likely with everything else. I think that is
20 pretty much the ongoing activities going beyond the design
21 basis.

22 MR. OKRENT: Let's see. Is there somewhere where
23 you think I could read why it is -- namely the logic -- why
24 it is that the staff is now recommending that all BWR's be
25 inerted, or I can read what they specifically think should

1 be done as far as study on ice condensers, and why the
2 things that they are not recommending now, they are not
3 recommending be studied or done?

4 MR. TEDESCO: We have talked about the proposed
5 interim amendments that relate to hydrogen control.

6 MR. OKRENT: Have they changed from those that you
7 had in previous documents on hydrogen control?

8 MR. ROSS: No, no, they are unchanged. There is a
9 SECY-80-107 series, and then the logic is the same. They
10 should be available to the committee, but if they are not, I
11 can see that they will be sent.

12 MR. OKRENT: I have seen the earlier ones.

13 MR. ROSS: There is no change.

14 MR. LAWROSKI: When you answered Mr. Bender's
15 question about the basis of your locations of the igniters,
16 what you said did not include what was referred to last
17 week. That is, you have some constraints on you in the
18 Sequoyah design as to where you can put the igniters that we
19 heard about. You did not say anything about that now.

20 MR. MYERS: I think what you were told in the
21 subcommittee meeting is that the igniters are located where
22 there used to be emergency lighting fixtures. That is true,
23 but we are not constrained to that. If we find the need to
24 have it somewhere else, then we will move it to that, but
25 basically the kind of coverage criteria our igniters needed

1 were roughly the same as those lights needed, and so they
2 came out very nicely in roughly the same kind of places,
3 considering our criteria is not such that we need an igniter
4 right here instead of six inches away.

5 We did not use all those lighting fixtures. We
6 only used part of them.

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. LAWROSKI: Unfortunately, what you just said --

2 MR. MYERS: We are not constrained.

3 MR. LAWROSKI: It is a concern.

4 MR. MYERS: We are willing to move it somewhere
5 else if we find a basis for that.

6 MR. MARK: Something Mr. Ross said. You use the
7 phrase "design basis" as if hydrogen control in TMI amounts
8 was sometime part of the design basis, is that correct?

9 MR. ROSS: No, I was using that design basis on
10 the terms of what is required by today's regulations.
11 Obviously, TMI-2 exceeded the design basis amount of
12 hydrogen. I don't know if it exceeded the core coolability
13 or not. I guess not by definition since it was cooled. It
14 is a toss-up.

15 MR. PLESSET: Paul, and then Jesse.

16 MR. SHEWMON: I am disoriented here. Was that an
17 introduction to what is coming, or is that the summary.

18 MR. PLESSET: They have more but they got
19 interrupted.

20 MR. SHEWMON: He got up and he went way, but I
21 find a bunch of handouts have come out of heaven onto my
22 desk.

23 MR. PLESSET: We will try to fix that, Paul.

24 MR. SHEWMON: Fine. What comes next?

25 MR. PLESSET: I think Jesse seems to be anxious to

1 ask a question.

2 MR. OKRENT: Could you tell me what the TVA
3 presentation is? Is that it? Are there five talks or what?

4 MR. PLESSET: They have more. Why don't you tell
5 us what we want to do?

6 MR. MILLS: Our next presentation will be from a
7 Westinghouse gentleman, Mr. Dave Gasser, who will talk about
8 the Fenwall test which we are undergoing at this time on the
9 igniters. After that we don't have anything else planned.
10 We will try to answer any questions that you might have.

11 MR. SHEWMON: I would like to see a copy of what
12 he handed out. My total recall failed me this afternoon.

13 MR. MILLS: I am sorry, sir.

14 MR. SHEWMON: I would like to see a copy of some
15 of the assertions he made, of which he had two pages, so I
16 might question him on some of them or decide if I want to.

17 MR. PLESSET: Do you have a copy?

18 MR. MILLS: Yes, sir. They should be there.

19 MR. SHEWMON: There is a bunch of figures that
20 talk about the tests that you conducted. Now, where do I
21 find it?

22 MR. LAU: Sir, the reason the presentation was so
23 short was we were given 20 minutes and that includes TVA's
24 presentation and Westinghouse's presentation. So I used a
25 very brief position statement and then used the handout to

1 support those statements.

2 MR. SHEWMON: Okay. If I wanted to find support
3 for your statements in the handout, where should I look?

4 MR. LAU: Sir, that depends on the subject that
5 you want to locate.

6 (Laughter.)

7 MR. SHEWMON: Let's talk about why you think your
8 containment would take 700 pounds of hydrogen without any
9 cooling at all.

10 MR. LAU: That is based on the adiabatic burn.
11 That particular statement, unfortunately, is not in the
12 handout at all.

13 MR. SHEWMON: You asserted also that things would
14 be even better in an ice condenser. Where is that supported?

15 MR. LAU: That is going to be presented by the
16 Westinghouse presentation next. Obviously --

17 MR. SHEWMON: There is a lot of information there
18 and it is not very useful or germane to what you said.
19 Okay, I will wait.

20 MR. PLESSET: Jesse.

21 MR. EBERSOLE: I just wanted to ask --

22 MR. BENDER: Can I just ask quickly. The summary
23 statement that you presented, Mr. Lau, have you got it so
24 that it can be reproduced? You were reading from it, weren't
25 you?

1 MR. LAU: Yes, sir.

2 MR. BENDER: Why don't you let one of our staff
3 reproduce the few pages and pass them out. It would probably
4 save a lot of time.

5 MR. LAU: I would be glad to.

6 MR. PLESSET: Jesse, you had a question.

7 MR. EBERSOLE: There is not any information
8 available now, I take it, concerning your understanding of
9 the functionability of this glow plug under various
10 environments. I am particularly thinking of a deluge which
11 would depress the temperature until you don't get any
12 temperature, and maybe accumulate -- probably evaporate
13 compounds on the surface.

14 It is a shielded plug, isn't it? The conductor is
15 under a cladding of some sort.

16 MR. MYERS: That is correct.

17 MR. EBERSOLE: It can take a lot of beatings.

18 MR. MYERS: We believe it can take a lot of
19 beating. That is the reason we selected it.

20 MR. EBERSOLE: Are you going to hit it with
21 intermittent sprays which will put it out and turn it on and
22 so forth?

23 MR. MYERS: The Fenwall test program has in it at
24 this point some humidity tests. We expect to try to run
25 some actual spray tests and some flow tests in the same

1 area, and that will be covered in the later presentation.

2 MR. EBERSOLE: Aren't you going to be dealing with
3 a tremendous variation in cooling on the surface?

4 MR. MYERS: Yes, and we are doing analytical
5 studies at this time to try to estimate that as a basis for
6 figuring out what kind of testing might be appropriate.
7 There is also the question, of course, of the different
8 environment that it will be in, the moisture fraction in the
9 air, and we are trying to test and understand that because
10 that is different than it was originally designed for.

11 MR. EBERSOLE: Thank you.

12 MR. PLESSET: Okay. Why don't you go ahead with
13 the next presentation?

14 MR. GASSER: Dave Gasser, Westinghouse.

15 As at the Subcommittee meeting, the set of
16 presentations, in order to minimize the total time taken,
17 there will be a run-through of the transient analyses that
18 support the statement that Wang Lau made earlier about
19 having more capability than what he presented using the
20 CLASIX code, and that is scheduled to be done by the NRC
21 staff subsequent to our presentations.

22 I would suggest that we defer it until then,
23 although if you would like, I also have some slides here
24 that I can present. I was thinking perhaps for the
25 Committee's time it would be better to just compress it, go

1 through the hydrogen test program and then follow the
2 presentation with the staff presentation in total.

3 As Wang mentioned, as a part of the total program
4 going on with respect to the hydrogen control, we are doing
5 testing work at Fenwall Labs in Ashland, Massachusetts. We
6 have started this test work. The TVA igniter grooming has
7 been started, and we have now run five tests within the
8 six-plus foot diameter vessel that they have up there, and
9 those tests have been run at 8, 9, two at 10 percent, and
10 one at 12 percent hydrogen concentrations in dry air at room
11 temperature.

12 We are scheduled right now to take delivery of the
13 heaters for this chamber at the end of this week. Following
14 the installation of the heaters, an initial grooming of the
15 facility with the heaters on, we would run through the
16 sequence of some 13 tests that had been defined -- and I
17 will discuss those in a little bit more detail in just a
18 minute -- and complete that effort in the first series of
19 tests by approximately the 1st of October, which relates to
20 a question earlier in terms of schedule.

21 What I have also shown on this Vu-graph, within
22 the facility grooming, the igniter, based on the results at
23 Singleton, heats to a full temperature in some 30 seconds.
24 In our tests we have seen ignition at 17, 16, 16 and 15, and
25 I cannot tell you what the fifth one is other than it is

1 between 15 and 17. We just ran that yesterday. I am saying
2 15 to 17 based on just having watched my watch as opposed to
3 having gone through the actual reduction of the data.

4 This shows the peak pressure that was reached
5 within the chamber for each of the burns that the igniter
6 started. Note with this ignition time we are seeing
7 ignition sooner than we thought.

8 MR. EBERSOLE: Don't your times just define the
9 heat at the dry igniter and had nothing to do with the
10 combustion rate?

11 MR. GASSER: I did not mean to give the impression
12 they had anything to do with combustion rate. This is when
13 ignition occurred. And it is the time --

14 MR. EBERSOLE: Was the igniter preheated?

15 MR. GASSER: The igniter was off. We filled the
16 vessel and then stirred the vessel, allowed it to sit and
17 become quiescent, and then turned on the igniter. The
18 igniter characteristic that has been measured at Singleton
19 shows that it goes from turn-on to the time it reaches its
20 maximum temperature in the range of 1700 degrees Fahrenheit
21 in approximately 30 seconds.

22 Now, we are seeing the ignition here in something
23 like 15 seconds, which means -- the meaning I take out of
24 that is we are getting ignition in the dry air at a
25 temperature less than the maximum of the igniter. The

1 actual burn, looking at the traces -- and the equipment up
2 there has the capability of running at 64 inches a second --
3 we see about one second or less to go from zero to
4 approximately 10 pounds in this 10 percent case, and you
5 have fully gone through the pressure transient to the peak
6 in less than 5 seconds.

7 MR. EBERSOLE: What is the time response of your
8 pressure measuring equipment?

9 MR. GASSER: The pressure recording equipment and
10 pressure sensing equipment that they have up there is
11 designed to be able to pick up detonation pressures. It is
12 extremely high frequency. The actual charts run out, and we
13 are running them on one of the slower speeds at 4 inches a
14 second. So we get 5 feet of paper before we even start
15 anything, and then have 100 millisecond tiny marks on it.

16 So we don't expect definition.

17 MR. EBERSOLE: What is the size of your vessel?

18 MR. GASSER: It is a six-foot diameter vessel, 130
19 some-odd cubic feet sphere.

20 MR. EBERSOLE: Is there variability on peak
21 pressures as a function of volume at your content of the
22 device due to self-compression?

23 MR. GASSER: There is some. In particular there is
24 a change in the velocity of burn that you get.

25 MR. EBERSOLE: What is that sort of function,

1 volume versus pressure peak?

2 MR. GASSER: I would have to go back and get David
3 to respond to that because I cannot give you a fair answer.
4 We have information on it.

5 MR. EBERSOLE: It is a needed piece of
6 information, isn't it?

7 MR. GASSER: For this type of burn, as long as you
8 are into a burn phenomenon, I don't think you will see a
9 variation in the peak pressure as against the volume. The
10 peak pressure now, you will see a change in the time you get
11 to that pressure, but I don't believe you will see a change
12 in the peak pressure until you move into things like very,
13 very turbulent deflagrations or detonations.

14 MR. SHEWMON: What is the temperature at which
15 you think ignition is occurring?

16 MR. GASSER: We have not checked back yet.

17 MR. RAY: How many igniters were there in this
18 vessel?

19 MR. GASSER: One.

20 MR. PLESSET: Go ahead.

21 MR. GASSER: The initial test --

22 MR. MOELLER: This is in air.

23 MR. GASSER: Yes. We don't have the heaters on
24 yet. The initial test with the heaters will be aimed at a
25 very rapid, establishing initially the igniter performance.

1 What we are looking to do here is pick up concentrations of
2 hydrogen at two sides, one of which we get a complete
3 conversion into pressure somewhere in the range of 10 to 12
4 percent based on the current data if you think of it in
5 terms of dry air.

6 The other one on the other side, consistent with
7 that 8 percent that we saw there, where you get a
8 considerable amount of burning but you never get up high in
9 pressure, and during the course of the actual tests we will
10 take samples, having charged the chamber. We will then take
11 a sample before and after ignition and go through a chemical
12 analysis of that to find out just what we did to get a burn
13 to correlate with the pressure conditions.

14 We will be looking at a sequence of tests that
15 have 100 percent humidity conditions. We have varying
16 pressures corresponding to, in a judgment sense, the kind of
17 pressures that we might be seeing to initiate burns based on
18 a preliminary analysis. We will be doing both static and
19 flowing gas streams past the igniter within the test at
20 pressures that are the same.

21 So we would have one ignition in a given set of
22 conditions with zero velocity. We will also then have the
23 capability with the fan to put approximately 5 and 10-foot
24 per second velocities past that igniter and the one you are
25 looking at back there, blowing that stream right past the

1 igniter and checking on any differences if they should show
2 up in the ignition characteristic.

3 MR. LAWROSKI: One hundred percent humidity?

4 MR. GASSER: Having set the pressure that we want
5 to run at, we have established an introduction of steam or
6 water such that we would be at effective 100 percent
7 humidity or saturation condition and then set the
8 temperature of the vessel. We will hold constant
9 temperature on these tests prior to starting.

10 MR. LAWROSKI: Relative humidity.

11 MR. GASSER: Yes.

12 MR. ETHERINGTON: Is the peak pressure reached a
13 little later than the ignition time?

14 MR. GASSER: Yes, for the 10 percent case. And
15 from zero to 10 pounds on that with 750 milliseconds. And
16 as I recall, and I will have to confirm this number, the 50
17 pounds was reached about 1.1 seconds.

18 MR. ETHERINGTON: About 1.1 after ignition.

19 MR. GASSER: After ignition. The later tests that
20 we have scheduled for the Fenwall facility on the TVA
21 igniter work are aimed at further performance confirmation.
22 What we want to do is take these initial results plus some
23 things that we are seeing from the analyses and further go
24 through characterization of performance of these devices in
25 the kinds of atmospheres that we may see.

1 We will do additional hydrogen concentration
2 tests. We have the capability within the facility to inject
3 steam and hydrogen in varying mixes, starting from any
4 condition that we chose, but at least theoretically starting
5 from a condition of air in the igniter, inject steam and
6 hydrogen and varying flow rates into the chamber with the
7 igniter turned on, and see if we get the kinds of repetitive
8 burns within that if the igniter is capable of doing that at
9 the concentrations we will see.

10 The final one that we are currently contemplating
11 if we can run the test is to look at the effects of sprays.
12 I might note that the igniter itself is designed with that
13 thing that comes out over the top, and it is a flash shield
14 to prevent direct spray impingement onto the igniter, the
15 heated element itself.

16 And finally -- and Don, you might bring that up --
17 the last of the Vu-graphs with respect to the testing at
18 Fenwall. We have run five burns. The igniter that we used
19 up there was not sealed, and it continues to perform, or at
20 least it did until I took it on an airplane last night, and
21 I am not sure what it would do right now.

22 There are no major signs of external damage.
23 There are some indications of minor penetration into the
24 inside without apparent performance degradation. This now
25 is the device that was put in. This one was not painted

1 orange and white. This was put in and run through those
2 five burns.

3 The inside, if you choose to look, with the
4 transformer is apparently in mint condition. Even the
5 outside other than some marks that have apparently, I think,
6 occurred in transit, has no apparent blackening or
7 degradation even though we measured using just taped on for
8 the grooming. You can see the place where the tape is and
9 some blackening at the tape.

10 We did measure temperatures in excess of 600
11 degrees in the gas stream that was coming through. We see
12 some evidence here of penetration apparently inward during
13 the course of the test, and we don't know whether it
14 happened in the first or the last test or anywhere in
15 between, but nothing showing up inside in terms of
16 degradation.

17 So initially, at least, the igniter is -- and this
18 is the actual igniter itself. We have taken it off the
19 front so people can look at it and potentially even compare
20 it back there. The igniter does seem to be capable of
21 functioning within the environment that would be created in
22 a hydrogen burn, a single burn.

23 Now, we remain to characterize whether it will
24 ignite in the kinds of conditions and temperatures and steam
25 and pressure that it would see.

1 MR. MOELLER: The igniter that was in this box was
2 actually the one that caused the hydrogen to burn. It was
3 not just placed there in another igniter.

4 MR. GASSER: The whole box you are looking at
5 right now was inside that six foot vessel for five burns.

6 MR. MOELLER: And the igniter inside -- there was
7 an igniter inside this box which did the ignition?

8 MR. GASSER: It is actually sticking outside, as
9 you can see back there, and this is the one that came off of
10 that.

11 MR. PLESSET: Let me ask you a question regarding
12 this. Are you going to try to get into the range of
13 detonation?

14 MR. GASSER: Initially, no.

15 MR. PLESSET: Will you try to do it eventually?

16 MR. GASSER: I think the only way that we would,
17 at least I would think right now, that we would move into
18 this is if we found in analyses that are currently
19 contemplated for looking at the distributional effects that
20 there was a potential for reaching that kind of condition.
21 Then we may well go into that in the test program.

22 But Jack Myers might like to add something to that.

23 MR. PLESSET: What is the vessel like?

24 MR. GASSER: Six foot diameter, 2-inch thick. It
25 is a coated vessel.

1 MR. PLESSET: Two-inch what?

2 MR. GASSER: Two-inch steel.

3 MR. PLESSET: Okay.

4 MR. GASSER: Two hundred or five hundred pounds.

5 I don't recall.

6 MR. PLESSET: Why don't you try to go into the
7 detonation range. That won't hurt that thing. You might get
8 some interesting results.

9 MR. MYERS: The first phase of the testing, as he
10 indicated, gets the baseline data to check with the data
11 that is in the literature and used as a basis to go to Phase
12 II where we are going to do more detailed studies. One of
13 the possibilities in that phase, if it appears it can be
14 safely done with the apparatus, is explore where the
15 detonation limits are with the kind of environmental
16 conditions such as water vapor that we are exploring for the
17 flammability limits.

18 MR. PLESSET: I am trying to urge the staff to ask
19 you to run the detonation range. Maybe they will.

20

21

22

23

24

25

1 1 MR. BENDER: What are your plans for the
2 testability of this thing?

3 MR. GASSER: I could not hear all the question.

4 MR. BENDER: What are your plans for determining
5 the testability of the igniter? Are you planning to install
6 in such a way that it can be turned on every day or every
7 few days to see whether it will heat up in its post heat-up?

8 MR. GASSER: I will defer that to TVA.

9 MR. MYERS: We proposed to the NRC a surveillance
10 program for those igniters. And the current plan is they
11 are on circuits and we are going to run basically a pre-op
12 test or a baseline test to see what the current trial of
13 those circuits is with the igniters working.

14 We will do some surface temperature checking at
15 that point, and then we can go back in surveillance tests,
16 turn them on and heat them up. And if there is a
17 significant change in the current characteristics, we can go
18 and check out why.

19 MR. BENDER: With regard to your test program, I
20 could envision a circumstance where the igniter that was
21 nearest to the high concentration of hydrogen was not the
22 one which ignited the hydrogen. It might ignite it at low
23 concentration and then propagate the deflagration or
24 whatever it is into a higher concentration area.

25 Does your test program allow for that kind of

1 circumstance?

2 MR. GASSER: In a single six-foot sphere, I do not
3 believe we can get two different, significantly different
4 initial distributions of hydrogen. As I mentioned, one of
5 the things that we are going to try to do is, within that
6 sphere, the igniter itself is located on a stand effectively
7 in the middle, here. One of the ports that allows for
8 filling is here, and angled up towards it.

9 We can run a test and come up with some reasonable
10 data -- we can put in steam and hydrogen mixtures from here
11 into potentially either an atmospheric no-hydrogen mix or
12 no-hydrogen concentration and get test results that I am not
13 sure that they do exactly what you want, but they begin to
14 move in that direction.

15 MR. BENDER: Okay. It is just a matter of -- it
16 is just being sure that we don't start the reaction in the
17 wrong place and then get the detonation that we really did
18 not want.

19 MR. MOELLER: How many different igniters did you
20 look at and how did you choose this one?

21 MR. GASSER: I defer to TVA in terms of the test
22 work on that.

23 MR. MYERS: We set out looking at a wide variety,
24 and let me go through the process and you will see why I
25 have some difficulties giving you an exact number. We knew

1 roughly that we needed something that would give us a
2 surface temperature in the range of 1500 degrees F. So we
3 went looking for devices that would do that, and we came up
4 with and actually got examples of a large number of devices
5 that were alleged to do that or specified to do that.

6 And they ranged from things that were a foot or
7 more long, with large coils, to a little bitty thing they
8 use in model airplanes, which is a very small resistance
9 fire that is open to the air.

10 And we looked at those, first of all, to see
11 whether they were specifying. We checked back on a limited
12 number of those that looked useful; I would say about six
13 that we dug into in some detail. And some of those were
14 supposedly going to do the job, but when we actually turned
15 them on they could not cut it. When we turned them on,
16 heated them up, they failed.

17 The diesel glow plugs, we have looked at the
18 7-G's, we have looked at another kind from General Motors.
19 We looked at about -- and I believe -- at those that appear
20 to function at the kind of temperatures that we are after.
21 And the Bosch and the 7-G plug have been run for some time.
22 So we have some confidence that it can maintain that
23 temperature.

24 And so we are doing now screening analyses, sample
25 analyses, to see what the relative reliability and ambient

1 conditions are. So we have looked at a large number and
2 slowly culled down until we get down to the 7-G plugs being
3 our primary. But we are looking at backups in case we find
4 some fault with the 7-Gs.

5 MR. MOELLER: What would the source of power be
6 for this in an emergency?

7 MR. MYERS: They are run off the diesel generators.

8 MR. EBERSOLE: They call this a distributed
9 ignition system, so it must be important to have
10 distribution of some sort. Is there any carefully worked
11 out plan about the degree of distribution?

12 MR. MYERS: Okay. The mechanism -- the interim
13 system, okay. What we have designed right now is to be used
14 on -- I would like to call bulk combustion. That is where
15 the flame propagation is, basically, in all directions. So
16 therefore, in a given volume, if the flame starts it will
17 progress unless it runs into a rarefied atmosphere or one
18 that is non-combustible.

19 That is the basis for the interim system.

20 MR. EBERSOLE: As it runs forward, it compresses
21 the unburned gases in front of it and is approached by
22 another wave, so that you do have autocatalytic compression.

23 MR. MYERS: At the velocities of wave front we are
24 talking about, there is nothing in the sense of a wave
25 front, if you will. The pressure is relatively uniform.

1 But there is a difference in the composition and there is
2 experimental data to show some difference in flame speeds.
3 And of course, there is the heating going on in that
4 compressed gas. There is some data to give us confidence in
5 what is going on there.

6 MR. EBERSOLE: I remember the delay tanks at the
7 Browns Ferry stack discharge, that we were forced to go to
8 900 psi piping because of potential detonation effects
9 there. There is a lot of data on hydrogen combustion.

10 MR. MYERS: Yes, sir. We are using that data. We
11 are very familiar with that.

12 MR. ETHERINGTON: Your first slide showed eight
13 percent hydrogen and pressure that looks like 3.2; is that
14 right?

15 MR. GASSER: That is correct, 3.2. Perhaps it is
16 worth putting this up, since it is available. I don't think
17 it is worth spending a whole lot of time on, since it is
18 only indicative of what we have. But what is shown here is
19 the data from 1971, 12-foot diameter sphere, room
20 temperature conditions, empirically testing what the
21 pressure rise, the delta p, was from atmospheric, given
22 varying concentrations of hydrogen.

23 You are looking at 4, 2, 12 percent. You see
24 there data down in the range of 4 to 8 percent; there was a
25 very low pressure rise. There was none in the area from 8

1 into the range of 12, where this data peaks up very steeply
2 to what is the calculated delta p on a pure theoretical
3 basis for that.

4 And the x's that are shown here just represent
5 where we have been now with those four grooming runs, and we
6 were not intending to reproduce this curve. That curve is
7 in the literature and well done. We were just using it as
8 an indication of how well our apparatus is in fact
9 performing.

10 From this data, one would expect that somewhere in
11 the range of 8 to 9 percent you are coming off of this curve
12 very steeply and down. In that 8 percent we are showing;
13 it. In fact, we are just right about there, with a couple
14 of psi rise.

15 MR. ETHERINGTON: With your igniter on, will that
16 hydrogen eventually burn?

17 MR. GASSER: We will find out how much burns
18 within the test program. We are planning to run, as I
19 mentioned, 8 percent tests, having taken a sample before and
20 a sample after the burn, and then doing measurements on that
21 and correlating against what we saw as pressure and finding
22 out whether or not all of it burns slowly and the effects of
23 the heat sink of just building up temperature in the vessel.

24 We are not planning to attempt to glean that data
25 from the test program, even in this initial phase.

1 MR. MARK: It is certainly believed and frequently
2 said that the bottom of that can burn a very small percent
3 of the hydrogen present.

4 MR. GASSER: That is right.

5 MR. OKRENT: I was wondering, can someone remind
6 me of the relationship between the numbers like 50 psi that
7 we saw at 10 percent hydrogen here and the 38 psi that we
8 heard the staff and Chet and others talking about before?

9 MR. GASSER: Perhaps the easiest thing that I
10 might do here, Dr. Okrent, is show -- and this is coming a
11 little bit ahead --

12 MR. OKRENT: If someone is going to do it, I will
13 wait.

14 MR. GASSER: To direct your attention to it, this
15 is the transient run made igniting a 10 volume percent any
16 time that it came, any time that we reached that
17 concentration, within the CLASIX code, and then burning all
18 the hydrogen that was available. And what is shown here is
19 you come up and you peak not quite at 27 psi, come back
20 down, back up, and there is a series of nine burns that take
21 place.

22 And basically what is happening is, you have the
23 hydrogen introduced, it burns, it exhausts through the ice
24 condenser, and there is more air coming back in from the air
25 return fans. And you also have the hydrogen coming back in

1 from the presumed introduction using the MARCH. It becomes
2 another burn, and you continue to do that.

3 And this happens also to be the basis, then, for
4 the statement that Dr. Lau made a little bit earlier, in
5 that this total transient includes the introduction of 70
6 percent of the core hydrogen potential, or some 1500 plus
7 pounds of hydrogen into the containment, and then tracks
8 that on through its burn. And in fact, you burn some 950
9 pounds, and there is some 600 left at the end.

10 That is going a little bit ahead into what Charlie
11 Tinkler will be presenting. That is, in effect, a direct
12 relationship in terms of what we calculate and then what we
13 are looking at in the test program in terms of trying to
14 determine the hydrogen at 10 percent is converted, and it
15 will be ignited in the kinds of conditions that we see.

16 MR. OKRENT: Let me see. Just to test what I am
17 hearing, if I reach, say, 10 percent in the upper
18 compartment and ignite it there, what pressure should I
19 expect, and is it okay?

20 MR. GASSER: If you reach 10 percent in the upper
21 compartment, I cannot give you a figure off the top of my
22 head for what 10 volume percent is in the upper
23 compartment. If I go back, we know that if you take the 700
24 pounds and burn it uniformly you get up to the 57.

25 But this now, as you move into this and the

1 calculations that are being done with plastics, you are
2 looking at a coupled transient situation, and I do not have
3 the number off the top of my head for what a 10 volume
4 percent burn in the upper compartment means.

5 MR. OKRENT: Let's see.

6 MR. GASSER: You cannot use that pressure as the
7 pressure that one would reach in that scenario that you are
8 postulating. Those peak pressures merely show what happens
9 within that chamber and the effects show completion of the
10 burn or noncompletion of the burn. But those cannot be
11 related to a situation within the containment.

12 MR. SHEWMON: The difference between what you do
13 in your chamber and the question that Okrent is asking is
14 that he -- you could relieve your pressure by expanding the
15 gas into parts of the vessel -- parts of the containment
16 which do not have hydrogen in them, just air.

17 MR. GASSER: Basically, you have a situation in
18 the containment in which you have the lower compartment, the
19 ice condenser, the upper compartment will get this -- this
20 is part of the code -- with these things connected directly,
21 in the sense of coming up this way; and also with the fan
22 return and other things.

23 Now, as you track the accident scenario, where is
24 the hydrogen introduced and how does it go, given the
25 assumptions of mixing within these.

1 MR. SHEWMON: I thin you can answer my question by
2 saying yes. But since you have not, let me ask it again.

3 The premise was that if the hydrogen is only in
4 the upper containment -- compartment -- that it is the 10
5 percent and it burns. If the pressure does not relieve
6 itself during the burn, you get 50 pounds. You assert you
7 do not get 50 pounds. So you must relieve it somehow.

8 MR. GASSER: You will not necessarily get 50
9 pounds. You will get a delta p above what the atmospheric
10 --

11 MR. SHEWMON: You get 50 pounds in your six-foot
12 containment?

13 MR. GASSER: Yes.

14 MR. SHEWMON: There is no way that that --

15 MR. GASSER: And the initial conditions are
16 standard. You get 50 pounds.

17 MR. SHEWMON: Let me ask again. Given 10 percent
18 in only the upper compartment and it flashes, the pressure
19 rise will be much less than 50 pounds, and the reason is
20 that there is intercommunication between those regions.

21 MR. GASSER: Go ahead, Chet.

22 MR. MYERS: That is correct. There is another
23 factor, though. First you have the communication through
24 the open spaces between -- that go through the deck, if you
25 will.

1 The second thing is, there is water spray in the
2 atmosphere of the -- in the atmosphere of the upper
3 containment. If the sprays are on -- and it looks like they
4 should be at this time -- and the heat of evaporation eats
5 up a lot of the pressure energy.

6 And the third thing is, if it is a reasonably slow
7 burn, as we would expect at these concentrations, there is
8 actually water put in during the burn process to make up a
9 little more heat.

10 MR. OKRENT: The last time we met I think there
11 was somebody from Westinghouse that indicated that there was
12 a difference between a burn in the lower part of the
13 containment and the upper part.

14 MR. GASSER: There is.

15 MR. OKRENT: And I guess first let me ask: How
16 much is the difference and what is it attributed to? In
17 other words, let me just for the moment postulate that we
18 burn only in the lower part, starting with 10 percent, or we
19 burn only in the upper part, starting with 10 percent. And
20 let's leave the core sprays out of this -- containment
21 sprays out of this, as if they were not on.

22 Is there a difference in expected pressure, in how
23 much, and what can it be attributed to?

24 MR. GASSER: Yes, there is a difference in
25 expected pressure. I cannot give you the answer because I

1 don't know the number for the top. One of the major
2 differences is you can relieve significantly through the
3 lower compartment into the ice, because that is the way the
4 flow is. From the upper side those doors will tend to
5 close, and you cannot have the same size relief path as you
6 do from the lower compartment.

7 MR. OKRENT: This is what I assumed. I just did
8 not know how big the effect is. What I want to know is, is
9 it urgent that you not ignite in the upper part?

10 MR. EBERSOLE: Are you thinking about collapsing
11 the intermediate --

12 MR. OKRENT: I am not thinking about anything
13 now. I am trying to understand whether they really cannot
14 afford to have it burn in the upper compartment. I would
15 like them to tell me yes or no.

16 MR. MYERS: We have a capability for much more
17 hydrogen burning in the lower compartment than the upper
18 compartment. So a burn in the upper compartment -- a lower
19 concentration of hydrogen will challenge the containment
20 first.

21 MR. OKRENT: Do you know what concentration?

22 MR. MYERS: We only know it is bigger than 10
23 percent.

24 MR. EBERSOLE: Is the weak point the upper?

25 MR. MYERS: We don't think so, no, sir.

1 MR. EBERSOLE: Do you know accurately the rate of
2 pressure rise?

3 MR. MYERS: We do not know that accurately,
4 because that depends on flame speed and the flame speed is
5 dependent on environmental conditions that we are trying to
6 test.

7 MR. EBERSOLE: That can become very critical.

8 MR. MYERS: Yes, sir.

9 MR. OKRENT: Again, I would like to know a little
10 bit more about the upper part. You said you know 10 percent
11 hydrogen is okay -- I think you said that a moment ago -- in
12 the upper part. That means you have done a calculation of
13 some kind assuming 10 percent burn in the hydrogen and the
14 ignition is taking place; is that correct?

15 MR. MYERS: Yes, sir. The very simple,
16 straightforward, adiabatic combustion problem.

17 MR. OKRENT: What humidity did you assume?

18 MR. MYERS: 75 percent humidity at 90 degrees
19 Fahrenheit.

20 MR. OKRENT: All right. And no water drops and so
21 forth?

22 MR. MYERS: That is right. I also checked it at a
23 slightly higher water load.

24 MR. OKRENT: What delta p did you get?

25 MR. MYERS: About 50 pounds, plus or minus a

1 pound. I don't remember.

2 MR. OKRENT: I don't know why that is okay,
3 because earlier I heard the staff say 38, if I understood
4 correctly.

5 MR. MYERS: You must remember, I heard that first
6 this afternoon and do not necessarily agree, you know, until
7 I look at the basis they gave.

8 MR. OKRENT: I don't think I heard -- I am not
9 sure what Dr. Siess was saying.

10 MR. PLESSET: The staff can tell you.

11 MR. OKRENT: It seems at the moment that we do not
12 quite know whether -- whether you would be willing to turn
13 those igniters on deliberately if you knew there was 10
14 percent in the upper part or you'd say, maybe I'd better
15 look and see if there is something else I can do, burn in
16 the bottom after I get it down.

17 Let me just assume a scenario. Hydrogen is
18 generated and it is lighter than air and it moves to the
19 upper part. Okay. In fact, there is some tendency
20 sometimes of that to be in the upper part of the building.
21 And you find it up there and you measure 10 percent up
22 there. And it is 4 percent in the lower part. Would you in
23 fact be willing to turn the igniters on, confident that your
24 containment can take it? That is the question I am asking.

25 MR. MYERS: By the time one reaches that, I really

1 do not know what kind of decisionmaking process I would go
2 through. I think I would have to turn them on earlier than
3 that, and I have not -- I have not gone through the
4 decisionmaking logic that says whether I turn those on or
5 not.

6 I would have reasonable confidence if it were
7 below 10, based on the analysis we have seen. I would be
8 very concerned if we were significantly above 10.

9 MR. OKRENT: It would be nice if it started
10 burning at 5.

11 MR. MYERS: Yes, sir. What we are hoping the test
12 data will show, because the literature shows that you get
13 some partial burns; so we will get some removal, if you
14 will, at lower concentrations as a benefit. But we are not
15 relying on it.

16 MR. OKRENT: If I understand what I remember, most
17 of your igniters are in the lower part.

18 MR. MYERS: Yes, sir.

19 MR. OKRENT: The place we want to be sure that we
20 get ignition below 10 percent is in the upper part. I sort
21 of have seen inverted logic in that.

22 MR. MYERS: The reason for the number is that
23 there are a lot more compartments on the lower level. That
24 is the reason.

25 MR. OKRENT: I understand. But you need a rather

1 high degree of confidence in that upper part that you^u ignite
2 before you get to --

3 MR. GASSER: One of the things to remember about
4 the location: there are a number that are coming directly
5 at the exit of the ice chest as it moves in. Those add to
6 the ones that are in the upper compartment itself.

7 MR. SHEWMON: I am afraid I heard more about the
8 strength of containments than I care to know, I thought.
9 But I read Dr. Lau's thing here and it says, our analysis
10 indicates that with a reasonable design limit of 57 psig for
11 the containment. As I understand it, the design limit was
12 12 or 13 psig. The yielding limit is somewhere between 38
13 and 50, depending on who you talk to.

14 So did I slip a gear someplace or what does that
15 statement -- whose reasonable design limit for the
16 containment is 57 psig?

17 MR. LAU: Perhaps I did not choose the right
18 word. But in this case what I meant is that the 57 is the
19 number that we have been talking about earlier this
20 afternoon. And the design is indicated with this particular
21 series of events.

22 MR. SHEWMON: It is your fond hope and maybe
23 professional belief that it would not rupture at 57 psi; is
24 that what you are saying?

25 MR. LAU: It is not mine; it is our structural

1 people's opinion.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. MILLS: There is one question. A gentleman at
2 Brookhaven raised a question about ignition temperatures
3 with regard to the foam insulation around our ice
4 condenser. We submitted a response to the staff today, NRC
5 staff, about six pages long. I would like to summarize that
6 in about two sentences, if we could.

7 I will ask Mr. Don Williams of engineering design
8 to address it.

9 MR. WILLIAMS: For the purposes of this meeting, I
10 am going to read from the letter of September 4 to Mr.
11 Tedesco of the NRC.

12 "The containment wall was insulated with a rigid
13 urethane foam which is poured in place behind the air
14 handling ducts. The ducts run the full circumference of the
15 height of the ice condenser containment wall interface, and
16 are steel panels which provide an effective thickness of at
17 least one-quarter of an inch of galvanized steel.

18 "The foam insulation after installation is sealed
19 at the top and the bottom to form an airtight compartment."

20 That is the end of the text in the letter.

21 Just in summary, Westinghouse has test data on the
22 foam insulation which shows that the foam encased -- when
23 the foam is encased, it is open at the top. It leaves a
24 readily available source of air to burn. The foam will not
25 burn by itself. It needs air, and our fire protection

1 engineers have also looked at the flammability of this foam,
2 and in summary we are convinced that the foam insulation in
3 the ice condenser walls is sufficiently sealed to preclude
4 any burning.

5 MR. PLESSET: Did you have any other comments you
6 wanted to make?

7 MR. MILLS: No, sir. I did want to say
8 particularly Dr. Lau rushed through his talk. We thought
9 maybe it would save some time, and I realize it was rather
10 skimpy in parts, and we would be willing to expand on any
11 portion that any member would be interested in, or to answer
12 any questions along those lines.

13 MR. PLESSET: Well --

14 MR. MILLS: Whatever your desire is, sir.

15 MR. PLESSET: Let me ask you another question
16 about the status of the review of the vent pipe repair.
17 Have you got a comment for us on that brief comment, or were
18 you prepared for that? Staff is going to tell us about that.

19 MR. STAHL: We are prepared to discuss the I&E
20 inquiry with respect to the repair. As far as repair of the
21 weld, we believe that is complete, and of course it is
22 discussed in our SER Supplement Number 2.

23 MR. PLESSET: Okay.

24 MR. STAHL: Would you like --

25 MR. OKRENT: That is the hydrogen issue?

1 MR. PLESSET: Do you want some more? Let him
2 finish this.

3 MR. OKRENT: I assumed we have not finished this.

4 MR. PLESSET: On hydrogen or on this?

5 MR. BENDER: Just a short question. It won't take
6 long. With regard to the elastic seals, are you planning to
7 do anything further about the elastic seals than you have
8 done?

9 MR. MYERS: At this time we have not chosen a
10 course of action, but I would say that that action would
11 lead one of two ways, one, either to be able to show by
12 analysis and available data that the seals would not suffer
13 the kind of deformation that would open them up when the
14 pressure was released, or to actually do some testing
15 ourselves under those pressures. That would be our intent.

16 MR. BENDER: That is a good answer. Thank you.

17 MR. PLESSET: Let me clarify one thing, Dave. You
18 were asking about these pressure limits, and Dr. Zudans says
19 he would feel comfortable with 50 psi, just to give you a
20 number to cherish and remember.

21 MR. SHEWMON: Fifty psi for what?

22 MR. PLESSET: For containment pressure to yielding.

23 MR. SHEWMON: How about between floors of the
24 containment?

25 MR. PLESSET: You did not go into that, right?

1 MR. ZUDANS: Right.

2 MR. PLESSET: He is not worried about that, I
3 gather.

4 MR. EBERSOLE: Mr. Chairman, are we going to talk
5 about survivability of apparatus inside, or is that a
6 separate business?

7 MR. SHEWMON: Telephones don't do very well.

8 MR. EBERSOLE: There are many things in there that
9 will give you trouble. I don't know if that was within the
10 scope.

11 MR. PLESSET: It was not originally planned, but
12 if you have a need --

13 MR. EBERSOLE: I can think of a good many needs,
14 like where we have imploding of apparatus not ready to
15 receive this rather high spike pressure, which may or may
16 not be fitting.

17 MR. PLESSET: That is a legitimate question.

18 MR. EBERSOLE: It is interesting to note that you
19 may have a gale through your air return fans, which will
20 either stall them or make generators out of them and make
21 them go ten times their normal capacity.

22 MR. MYERS: Let me tell the committee where we
23 stand on that issue. We have first of all gone through and
24 identified equipment which we have determined to be
25 critical. That is the kind of stuff that you either should

1 .ave, have to have, or would like to have post the kind of
2 events we are talking about. We are now in the process of
3 going through and finding out what our paper says about that
4 equipment.

5 Let me take pressure, for instance, static
6 pressure. We have been through the bulk of those
7 components, and most of the components in an ice condenser
8 are qualified for pressure, the same as a dry containment,
9 from 55 to 75 pounds, so the ice condenser has that margin
10 already built in.

11 There are a few components we found which were
12 qualified to about ten pounds, but each of those that I
13 looked at so far were things that we did not need, and if
14 they were to respond in a very bad manner because of the
15 high pressure, would not cause us any pain.

16 I think the committee is probably aware that we
17 some years ago took off the little push buttons on the wall
18 that you operate valves and motors with, and use
19 disconnects, which are supervised circuits in the control
20 room, so the pressure pulse could not push those buttons.
21 Pressure, we feel quite comfortable with at this time. We
22 may find a few instruments that we would like to have that
23 do not have the qualification, and those may need to be
24 changed out, but we have not found any yet.

25 As far as pressure pulse, the kind of flame rates

1 we are talking about so far they really aren't a problem
2 from a pressure pulse point of view, so until we get into
3 much faster burn times, that is sitting on the back burner,
4 if you will. The temperature question is one where our
5 codes are grossly conservative, in that they do not account
6 for heat sinks, and so at this point we do not have a real
7 firm handle. We have a very conservative handle, I guess,
8 on the temperature transient things we go through.

9 You have seen the igniter that has been throug
10 some of these transients, and we are going to in later tests
11 probably test some material to see what kind of -- what this
12 transient temperature does to them.

13 As far as the dynamic effects, such as flow
14 through the air return fans, the air return fans are one of
15 the critical components, and that is something we have to
16 look at both when it is assisting and when it is blowing
17 back against you.

18 MR. EBERSOLE: Yes.

19 MR. CKRENT: I have a question of the staff. In
20 their SER supplement, they mentioned that they have a report
21 from their consultant at Brookhaven National Laboratory.
22 They do not discuss it very much, unless I missed where it
23 is discussed, but I think it falls in the category of what
24 Paul Shewmon calls fast reading.

25 (General laughter.)

1 MR. OKRENT: But he did not complain about this
2 package. I do not know why. In any event --

3 MR. SHEWMON: Nobody promised me a quiz on that
4 tomorrow.

5 MR. OKRENT: I would like to ask the staff whether
6 in the letter of August 8, 1980, from Barry to Ross, there
7 are any reservations that have been raised there that stem
8 either -- either now look troublesome based on what they
9 know or they would consider potentially troublesome, you
10 know, or do they think these are likely all to wash out.

11 MR. KERR: Isn't a copy of that letter included
12 with one of the SECY papers? I have seen a copy. You
13 perhaps probably have one somewhere, Dave, if you knew where
14 to look.

15 MR. OKRENT: I have the letter from Barry to Ross.

16 MR. KERR: Okay, you have the letter.

17 MR. OKRENT: It is an appendix in Supplement
18 Number 2 to the SER.

19 MR. KERR: Okay, you have the letter. I am sorry.

20 MR. STAHLER: We do have a vu-graph on this matter,
21 if you would like to have the staff discuss it in a little
22 more detail. This may answer your question.

23 MR. OKRENT: It would be relevant, Mr. Chairman,
24 since we do have these questions posed. A couple of them
25 have been discussed already, but not all

1 MR. STAHL: I will have Mr. Tinkler go into this
2 subject.

3 MR. PLESSET: Harold, did you have a question?

4 MR. ETHERINGTON: Yes.

5 MR. PLESSET: We will come back to it, unless it
6 is on this.

7 MR. ETHERINGTON: There must be some concern
8 whether the 10 percent of water, steam, or whatever it is at
9 90 degrees plus the possibility of sprays is going to raise
10 that region of non-combustion from 8 percent into maybe the
11 10 or more percent. Then we have to be really concerned
12 about the containment capability. Are we going to have
13 answers to those questions before they desire to go to
14 power? Or do we have answers now on a theoretical basis?

15 MR. PLESSET: I don't think your question got
16 across quite. Could you repeat it?

17 MR. ETHERINGTON: We have a region of
18 non-combustion of hydrogen, around 8 percent dry air. In
19 the presence of steam and particularly sprays, that surely
20 is going to be higher. Is that correct? And that is
21 pushing us into a region where we have to worry about our
22 peak pressure in view of our containment limit being under
23 50 psi.

24 My question is, do you have any discussion of
25 that, or do you expect to have answers before you go to

1 power?

2 MR. PLESSET: That is a question they will have to
3 consider. Maybe we will come back to that, if you can hold
4 it for just a minute.

5 MR. ETHERINGTON: Yes, surely.

6 MR. PLESSET: All right, go ahead.

7 MR. TINKLER: Okay. Regarding the comments in the
8 report -- here is the Brookhaven letter, Possible Objections
9 to Igniters. One of the comments was, "Ignition may occur
10 when some regions are detonable."

11 Our general response to that is, one of the
12 functions of the igniters is to prevent large detonable
13 admixtures from accumulating. Igniters will be turned on
14 early, be effective as early as possible so we can burn the
15 smallest possible quantities of hydrogen at a time. The
16 fans do provide active mixing to promote small gradients
17 within the various regions of the containment, and it is
18 based on our preliminary information.

19 We believe that the containment shell and interior
20 walls could survive small local detonations. There remains
21 to be more work done on the last item, but that in essence
22 is our basis for believing that that is not a substantial
23 concern. Detonable regions may also occur if we do not have
24 distributed ignition systems. Random ignition could cause
25 local detonation, as well as an intentional ignition system.

1 MR. OKRENT: Those statements are true, except
2 presumably some people are thinking about alternatives to
3 ignition systems, and it is not ignition system or nothing.

4 MR. TINKLER: It would have to be a suppressant.

5 MR. OKRENT: All right. So, I am not sure you
6 have given all the alternatives that are potentially
7 possible in giving your arguments, and you might have --

8 MR. TINKLER: If you inerted the atmosphere, you
9 would prevent that sort of mixture. Okay? That is the only
10 other way I foresee that you would guarantee you would not
11 have detonable mixtures.

12 MR. OKRENT: I have seen other things that may or
13 may not do it also, but I just wanted to note that you have
14 a somewhat incomplete stage on which you are presenting your
15 players.

16 MR. TINKLER: Assuming we go with ignition
17 control, those would be our options.

18 MR. SHEWMON: So what if you get detonation? I
19 mean, ignition may occur in some regions that are
20 detonable. Why don't you just say, so what?

21 MR. TINKLER: Well, we cannot say so what right
22 now.

23 MR. SHEWMON: Why can't you?

24 MR. TINKLER: Because we have not demonstrated, at
25 least not to my knowledge, that the detonations will be --

1 that all the possible detonations will be sufficiently small
2 that you could never rule out the problem. You could never
3 rule out the concern for problems during detonations,
4 problems such as pressure loading, shock effects on
5 equipment.

6 We do feel --

7 MR. SHEWMON: Pressure loadings on what?

8 MR. TINKLER: On the shell. TVA has examined it
9 briefly by reference to other work that has been done in the
10 area, I believe, and has concluded that the effects of
11 detonation on the containment shell are minimal.

12 MR. SHEWMON: If you can find any references that
13 that is not true, we would very much appreciate seeing them.

14 MR. TINKLER: I do not know -- and I am not aware
15 of any references that say that is not true.

16 MR. SHEWMON: I will provide you one before you go
17 home.

18 MR. TINKLER: Okay. If we could guarantee that
19 detonation poses no threat to the containment shell, we
20 would be glad to state that as a reason for not being
21 concerned with it.

22 MR. PLESSET: I think Dr. Shewmon is aware of some
23 analysis that maybe you are not aware of for which he is
24 partly responsible.

25 MR. EBERSOLE: I get a little uneasy about people

1 not looking on the slab between the upper and lower
2 compartment that holds the air return fans and a lot of
3 other stuff as being a significant structural member, which,
4 if damaged or destroyed, may cascade into other equipment
5 failures, even though the shell is good.

6 So, the slab has some defined psi loading, and it
7 is rate sensitive, and if you get the detonation rates, I
8 wonder if it will relieve fast enough.

9 MR. TINKLER: Are you talking about the effects of
10 actual detonation loading or equilibrium pressure that would
11 result after detonation?

12 MR. EBERSOLE: Whatever the effect of shock load
13 on the slab is. I suspect it is critical upward as well as
14 downward. I am not sure. You don't know what the loadings
15 are, do you? It is a rate thing, because it has apertures
16 in it.

17 MR. TINKLER: There is some limit above which you
18 cannot tolerate deflagration of hydrogen in the upper
19 compartment, let alone detonation. I doubt very seriously
20 -- We would have a lot of problems if you had a deflagration
21 of 12 percent of the upper compartment, let alone a
22 detonation.

23 Another point of the Brookhaven memo was,
24 "Focusing effects can develop detonations." This is a valid
25 concern as far as we know. The problem should be addressed

1 with or without igniters, assuming you do not suppress the
2 burn in some other fashion. But again, in general, early
3 ignition we feel is favorable, burning the hydrogen at lower
4 concentrations or as low a concentration as possible.

5 One of the comments was regarding combustion.
6 "associated pressure and temperature histories unknown.
7 These have not been calculated." That is not true. It
8 should say, these have been calculated, and have been
9 presented before the subcommittee. These results are based
10 on the CLASIX code, the MARCH code, and various adiabatic
11 calculations.

12 The Brookhaven memo expressed concern over lower
13 compartment ignition that would propagate to the upper
14 compartment. We have done analysis where we propagated
15 burns to the upper compartment, and the results of those
16 analyses have demonstrated the pressures are below yield.

17 Again it is true that the flexibility is more
18 limited when you burn in the upper compartment, but to date,
19 based on the analyses that have been performed, we have seen
20 that given the distributions that are calculated in the
21 codes due to the mixing of the fans, that the concentrations
22 are such that even with burning in the upper compartment,
23 the pressures were tolerable.

24 MR. OKRENT: What enrichment do you think can be
25 burned in the upper compartment acceptably?

1 MR. TINKLER: If we judge it by 38 psig, I would
2 say that 10 percent is getting close to the limit, or maybe
3 at limit. It would be simple to do an adiabatic calculation
4 of 10 percent. If you want to ignore the sprays, which I do
5 not think is appropriate, but if you did ignore them, it
6 would be simple to do the hand calculation, but just as a
7 guess, I would have to say probably around 10 percent.

8 The question regarding insulation has been
9 addressed already, and there is a question regarding
10 reliance on the air return fan system. Unless the air
11 return fans are made inoperable by hydrogen burning, we see
12 no reason to assume all the air return fans are --

13 MR. OKRENT: That is just the question they
14 posed. Your answer that it is safety grade --

15 MR. TINKLER: The system is safety grade. That
16 just addresses the fact that other than the effects of
17 hydrogen burning, we see no reason to assume that fans are
18 not operating.

19 MR. OKRENT: Unless you do not have AC power,
20 which is a frequently touted cause of the original event.

21 MR. TINKLER: Yes, but I would point out that the
22 effects of hydrogen burning on the air return fan system is
23 an area that we intend to pursue. There is not much else we
24 can say about it right now.

25 MR. BENDER: The purpose of deciding whether and

1 when to turn on the igniters, how much sampling do you need
2 to have?

3 MR. TINKLER: Well, the TVA position right now is
4 that the sampling system that was originally designed for
5 the plant is adequate for interim operation. They have
6 indicated that they will continue to study the need for
7 upgrading sampling. We feel that may be prudent, that they
8 increase sampling so they know concentrations in local
9 regions or in subregions or some portions of the
10 containment. Right now, most of their sampling is based on
11 a sample of gas that is mixed before it goes to the analyzer.

12 MR. BENDER: I would think sampling ought to be on
13 that list, then, somewhere.

14 MR. TINKLER: Well, this is the Brookhaven list.
15 We have a list of topics for further review, and that is one
16 of them.

17 MR. OKRENT: Do you envisage that the igniters
18 would be turned on when you reach the right concentration,
19 or they would be left on early if you thought there was a
20 chance of building up hydrogen?

21 MR. TINKLER: Right now I believe the igniter
22 actuation is a step in the emergency procedures after which
23 certain other actions are taken. If we demonstrate that
24 igniters do not pose a threat, or do not result in a loss of
25 safety, it would presumably be beneficial to turn them on as

1 early as possible.

2 MR. OKRENT: Does TVA have a position on this? Do
3 they think they should not be turned on early for some
4 reason?

5 MR. MYERS: Let me give you just the picture
6 here. TVA committed in their nuclear program review to
7 study and backfit if possible. We decided this interim
8 system was feasible to do, and so the first thing we checked
9 was to see if we could find any safety drawbacks, assuming
10 no benefit, were there any safety drawbacks.

11 We did not find anything significant, and that was
12 largely due to the fact that we believed there was a large
13 number of ignition sources there already. They may not be
14 as reliable as ignition sources as we would like, so our
15 policy for the interim system is to turn them on as soon as
16 we know we have a LOCA at this point.

17 That is what the procedure is based upon, and the
18 rationale for that was that we -- one of the ways you can
19 get into degraded core conditions is the operator screws up
20 and does not make a decision at the right time, and to turn
21 on the igniters is just another decision. We don't have the
22 monitoring at this point to justify that.

23 TVA is committed to upgrading the monitoring
24 system, the hydrogen monitoring system at all our plants.
25 We are going to add additional monitors and additional

1 monitoring locations. We have already started on that.

2 MR. SHEWMON: Let me make a statement and then, I
3 guess, ask both of these people to reply. I have in front
4 of me a figure here. In my speed reading, I got halfway
5 through this. Anyway, it is a report diagram quoted in WASH
6 1400 on combustion and flammability of hydrogen-steam-air
7 mixtures. It shows the flammability limit being some place
8 at 5 percent and below, rather independent of the amount of
9 steam that surrounds it.

10 The question is, is there any reason that either
11 the staff or TVA has to believe that this is not applicable,
12 and thus the gas mixture would not start burning at 5
13 percent?

14 MR. TINKLER: Okay. As we reported in the
15 subcommittee meeting, we have obtained the assistance of
16 Lawrence Livermore in order to test the igniters, and they
17 will test the igniters in varying atmospheric conditions of
18 steam, air, and hydrogen, in order to expand that portion of
19 the curve so we have a better understanding of the effects
20 of steam at low hydrogen concentrations.

21 The slope is so steep there it is very difficult
22 to see the exact effect.

23 MR. SHEWMON: What slope?

24 MR. TINKLER: Of the curve there. The effects of
25 steam on a flammability limit. It appears to be very small.

1 MR. SHEWMON: There is virtually no effect of
2 steam up to about 40 percent.

3 MR. TINKLER: The Livermore test will be run with
4 steam concentrations all the way up to 70 percent. Okay?
5 So we should have an assessment of the effect of steam on
6 the flammability limits, and I believe that Fenwall test
7 programs will eventually include those effects, too.

8 What you saw were shakedown tests where they just
9 run it on dry air.

10 MR. OKRENT: I asked if you believe this curve.
11 You said yes, but you are getting it reconfirmed.

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. TINKLER: We want to learn more about it.

2 MR. MYERS: I am not an expert on hydrogen
3 combustion, but my people have been going through the
4 available literature and are working with a test program.
5 So what I have to say just basically reflects what we have
6 found to date in the literature. Ignoring the steam
7 component initially, about 4 percent you can ignite hydrogen
8 in a quiescent stream or it will burn upward basically.

9 Somewhere in the range, depending upon the source,
10 of 6 to 8 to 9, it starts moving sideways, and then it will
11 actually propagate in all directions. So in actual fact,
12 the physical arrangement of the ignition source, if you
13 will, to physically what is going on around it may change.
14 What you call your flammability limit, that is, hydrogen may
15 burn at 4 percent but it will not propagate in all
16 directions, so you may have to get higher than that to get
17 three dimensional propagation.

18 The literature does indicate that steam moves this
19 lower limit the equivalent of 4 percent. It does affect
20 that. At this point we don't have any data that indicates
21 to us how much it burns at that very steep slope on the
22 curve that was shown a while ago.

23 MR. SHEWMON: You were trying to convince us that
24 you had complete mixing in any part -- if you are in here
25 trying to show us you have complete mixing in any part of

1 that thing, we would hoot you out of the room.

2 MR. MYERS: We are quite sure we have
3 inhomogeneities between the different compartments already.
4 We know that.

5 MR. SHEWMON: That is a plus, because when one
6 starts to go, you have the rest of your system.

7 MR. MYERS: Yes, sir.

8 MR. SHEWMON: Okay.

9 MR. BENDER: I would not be all that
10 enthusiastic. I think the ignition might start in the wrong
11 place.

12 MR. SHEWMON: I don't understand what you are
13 talking about then or now. Can we do it over supper?

14 (Laughter.)

15 MR. EBERSOLE: Mr. Chairman. Chuck, in the
16 consideration of alternatives, the question has come up of
17 how many man hours do you spend in Sequoyah per year inside
18 the containment and what for, and ultimately with all this
19 array of junk inside the containment that you have to go in
20 and tend versus the Browns Ferry case where you don't have
21 any.

22 MR. MYERS: I cannot give you exact numbers, but
23 they are not a few percentage points difference between the
24 entry requirements at Browns Ferry with this inerted
25 containment, very small, and Sequoyah, which has a lot of

1 complex equipment.

2 We have gone through on the inerting question --
3 and I don't have those results with me today -- and looked
4 at our best estimate working with the operating people, what
5 equipment is in there and how frequently it actually
6 requires maintenance as opposed to a designer's idea of how
7 often it would be required, and then looked at moving those
8 things outside, if possible.

9 We were able to reduce significantly the entries,
10 which were several times a week at this point. We hope they
11 will get less than that.

12 MR. EBERSOLE: Would it be in hundreds of man
13 hours per year?

14 MR. MYERS: Yes, sir.

15 MR. EBERSOLE: How many hundreds?

16 MR. MYERS: I don't know. But when you go in for
17 planning purposes, two or three men more than once a week,
18 it will build up pretty fast.

19 MR. EBERSOLE: Thank you.

20 MR. OKRENT: We talked around Harold Etherington's
21 question, but I don't think we have heard TVA or the staff
22 directly address it.

23 MR. PLESSET: Would you repeat your question,
24 Harold, since we may have forgotten it?

25 MR. ETHERINGTON: The premise was that in the

1 presence of hydrogen or sprays, the composition of the
2 noncombustion was 8 percent in air, and it is likely to be
3 higher and push us up into the 10 or 11 percent, and then we
4 are beyond the peak pressure -- the pressure is beyond the
5 containment capability.

6 My question was whether we are going to have
7 answers to this question either on a theoretical or
8 experimental basis for the plant goes to power.

9 MR. MYERS: The question of when the plant goes to
10 power is outside of my area where I can do anything about
11 it. We are ready at this point and we do not expect to have
12 the kind of data you are talking about and the kind of data
13 you want before the next several months, two to three months.

14 MR. ETHERINGTON: You would like to go to power
15 without it.

16 MR. MYERS: Yes, sir. We do not know
17 theoretically how it would move, but there is good reason to
18 believe that it would go up. There is another effect that
19 cannot be forgotten. Ten percent hydrogen is not the same
20 no matter what kind of water content you have. As the vapor
21 fraction goes up, that has a beneficial effect on you -- not
22 real strong, but it is beneficial.

23 MR. OKRENT: One can think of a scenario possibly
24 where you have a lot of steam and that suppresses the
25 combustion. If you have a lot of spray, it is hard to see

1 how you could have too much steam. Let me for the moment
2 suggest you have hydrogen steam and you need those sprays
3 and so you turn it on. Because they have been on long
4 enough, you turn them off. And there you are.

5 MR. MYERS: One has a little difficulty, when one
6 assumes several hundred pounds of hydrogen and choosing its
7 location, ruining most containments, including the ice
8 condenser.

9 MR. OKRENT: This is not completely out of the
10 realm of situations that could occur.

11 MR. MARK: Could I mention, Harold, perhaps this
12 curve which has the fuzzy zone, as we produce frequently, is
13 not the only curve on flammability limits. There is a curve
14 at 300 degrees Fahrenheit with experimental points all the
15 way up to 50 percent steam for flammability limits. Those
16 numbers are known.

17 MR. OKRENT: I think what you are interested in
18 here is that ratio where it will burn horizontally and
19 downwards. You may not get enough combustion.

20 MR. MARK: If it is close to the flammability
21 limits, fine. If you run far beyond them, it is quite
22 different.

23 MR. OKRENT: Mr. Chairman.

24 MR. PLESSET: Yes.

25 MR. OKRENT: I would like to get back to the staff

1 a little bit.

2 MR. PLESSET: On what subject?

3 MR. OKRENT: Hydrogen.

4 MR. PLESSET: Okay.

5 MR. PLESSET: But in a broader context. In this
6 document entitled Hydrogen Control for Sequoyah, prepared by
7 the staff, they discuss, I guess, what their plan is with
8 regard to the interim rule, and what they say is that this
9 interim rule design analyses would be performed for all
10 other plants to evaluate measures that can be taken to
11 mitigate the consequences of large amounts of hydrogen
12 generated within eight hours after onset of an accident.

13 Design analyses would be filed six months after
14 the effective date of the rule, or by the date of filing of
15 the application for the operating license, whichever is
16 later. I assume that is similar to what they are proposing
17 or have just gotten approved.

18 MR. STAHL: That is correct.

19 MR. OKRENT: As I indicated earlier, in my own
20 mind the generation of large amounts of hydrogen is
21 sometimes associated with an event which stops, like TMI,
22 but perhaps with at least equal probability with an event
23 that goes further.

24 At the moment it is not clear to me by what
25 rationale the staff, for example, has decided that they

1 should ask for design analyses for measures that can be
2 taken to mitigate the consequences of large amounts of
3 hydrogen, but not ask for design analyses for other measures.

4 The ACRS has recommended once or twice -- I cannot
5 remember -- that the Commission ask for a more broad kind of
6 analysis. And since this is still low pressure containment
7 compared to most, although people have moved it up to 12-1/2
8 or some pressure like 38 or something where it might fail,
9 it is more subject to overpressurization in a range of
10 transients than the large dry containment.

11 I think at the moment I find it a little bit hard
12 to rationalize the staff position, and in a sense the
13 Sequoyah review is in the context of the staff's proposal
14 for what I guess they call an interim rule. So somehow it
15 seems to me in what we say to the Commission on this, either
16 we reiterate our previous recommendation and say don't do
17 just design studies on hydrogen control but do it in a
18 broader way -- and this is certainly applicable to Sequoyah
19 -- or we would be -- I don't know -- in some ill-defined
20 situation or position with regard to what the ACRS thinking
21 was.

22 I want to call that to your attention. We
23 discussed this obliquely at the last meeting. I think the
24 applicant says he was going to do some kind of study, not in
25 what we have seen here. But in any event, I have a problem

1 with the staff at the moment aside from the applicant
2 because I do not understand their logic.

3 Let me go one step further because I think it is
4 relevant. We were earlier talking about failure to scram
5 and what was the probability of a serious accident there.
6 I don't know what the real numbers are, but some of the
7 numbers we saw for BWRs possibly are significant when you
8 look at the probability per year.

9 There is a document that the staff has just made
10 available to us either last week or today -- I am not sure,
11 it may be both -- in which somebody has looked at auxiliary
12 feedwater systems that are nonseismically qualified, and
13 they arrived at the judgment that maybe this might lead to a
14 probability of 10⁻⁴ core melt, and they would look at
15 WASH-1400, and they say if we let this run three years while
16 we figure it out, this will only double the probability.

17 Now, I find that these are getting to be big
18 numbers. In fact, I am not saying that these numbers are
19 unrealistic. I think when you start looking at all the
20 avenues and all the experience that we have had, we had
21 better assume, at least for purposes of planning, that the
22 numbers might be pretty big.

23 In other words, I don't see any basis for being
24 very confident that they are small or even within the band
25 of WASH-1400. If, in fact, they are fairly large, I would

1 say that is all the more reason for the Commission not
2 dragging for several years through some kind of ill-defined
3 rulemaking on degraded cores and core melts before it does
4 something

5 MR. PLESSET: Well, I think that was a nice
6 summary.

7 MR. BUTLER: May I react, Mr. Chairman, with
8 respect to the first part of Dr. Okrent's question?

9 MR. PLESSET: I think that is fine, but I thought
10 you might want to think it over.

11 MR. BUTLER: If we have that opportunity, we will
12 read the transcripts and provide a response later.

13 MR. PLESSET: Which would you prefer, Dave?

14 MR. OKRENT: I would be interested in hearing any
15 comment they have now and later.

16 MR. PLESSET: Both. All right, go ahead.

17 (Laughter.)

18 MR. BENDER: Why don't we encourage them to think
19 it over some so we just get one answer.

20 MR. PLESSET: All right. Will you accept that?
21 You will not be unhappy with that. We will take one answer
22 later.

23 Any other questions on these items? I want to
24 give the NRC staff an opportunity to make a few comments,
25 and I think we are running a little behind schedule, not

1 surprisingly. So could we go to the staff?

2 MR. STAHL: Mr. Butler will make a few comments.

3 MR. BUTLER: I intend to rely on only the last
4 four or five sheets of that handout. This will be just a
5 very brief statement on how the staff would respond to
6 Commissioner Gilinsky's two questions. There is an extra
7 slide there, I think, that should not be in there, and it
8 will be clear shortly.

9 The first question: Does the staff believe
10 additional hydrogen control measures are necessary for ice
11 condenser containment? It is the staff's view, in response,
12 that hydrogen control measures beyond those prescribed in 10
13 CFR, Section 5044 are required for ice condenser plants but
14 that a reasonable period of time, that is, within a year,
15 may be allowed for implementation of these measures so that
16 appropriate studies and tests can be completed.

17 The staff's bases for this view are: one, TMI
18 Short-term Lessons Learned items have been implemented,
19 placing Sequoyah in the same risk space as Surry and Peach
20 Bottom; two, aggressive applicant and staff programs are in
21 place to improve the hydrogen management capability of
22 Sequoyah with a time frame of the next four months.

23 Preliminary work shows the interim distributed
24 ignition system to be a very promising approach. Four,
25 backup programs are in place should the IDIS prove

1 unacceptable. And finally, operations at full power do not
2 foreclose later adoption of alternative measures.

3 (Slide)

4 The next slide is a restatement of Commissioner
5 Gilinsky's question number 2, and I have just directed it to
6 the staff. Is the staff reasonably persuaded of the
7 effectiveness of distributed igniters in ice condenser
8 containments? It goes on. The response is the longer one,
9 A.2.

10 The staff's view is that the distributed igniter
11 system appears very promising as an additional hydrogen
12 control measure. Analyses with the CLASIX and MARCH codes
13 have shown the system can substantially improve capability
14 of an ice condenser containment to accommodate the hydrogen
15 releases from the degraded core accident.

16 However, further analyses and tests need to be
17 conducted to determine its range of efficacy and to assure
18 that overall safety is not degraded. The work is now under
19 way and should be completed by December 1980. Pending the
20 results of further work, the staff's view is that use of an
21 igniter system during accident sequences involving TMI-like
22 quantities of hydrogen would be the containment pressures
23 that exceed design pressures but that are less than
24 containment failure or yield pressures.

25 We find these features of the IDIS acceptable

1 pending the rulemaking proceeding on much the same bases
2 indicated in our response to the first question. Those are
3 the staff's views on how it would respond to the two
4 questions.

5 MR. PLESSET: Okay, thank you.

6 Any question?

7 MR. MOELLER: I guess I have a question. This
8 addresses Sequoyah. Where does D.C. Cook fall in all of
9 this? I mean I am not prolonging it, but here are measures,
10 and you are saying it is okay for Sequoyah to operate maybe
11 a year or four months or whatever. We have D.C. Cook in
12 operation and I wondered where it fits in.

13 MR. PLESSET: D.C. Cook 1 and 2.

14 MR. MOELLER: Yes. It is a two-unit station.

15 MR. BUTLER: The staff's view on that was
16 presented during the subcommittee meeting, and it goes as
17 follows. Once a mitigated device or system is found
18 suitable and acceptable for the Sequoyah station, the staff
19 will then make that kind of a system required for all ice
20 condenser plants.

21 MR. MOELLER: Thank you.

22 MR. PLESSET: Any other questions of either the
23 staff or TVA people?

24 If not, let me mention again an announcement that
25 I made this morning. The Committee is meeting with the

1 Commissioners tomorrow at 1:30 to discuss this item, the
2 Sequoyah license item. I believe it will be upstairs. So
3 that any of you who are interested might want to come at
4 that time. It will be an open meeting.

5 There will be part of it that precedes that
6 relating to quite different items that are closed, but after
7 the closed session we will go into open session on the
8 Sequoyah matter. So those of you who would like to
9 participate and listen should be aware of that.

10 MR. KERR: When you say those of you who would
11 like to participate, you are talking about members of the
12 Committee.

13 MR. PLESSET: Beg your pardon? Well, I will get
14 that later.

15 We will go into recess for ten minutes.

16 (Whereupon, at 6:45 p.m., the Committee recessed,
17 to reconvene in executive session.)

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS - 245th Meeting

Date of Proceeding: September 4, 1980

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

David S. Parker

Official Reporter (Typed)



(SIGNATURE OF REPORTER)

CURRENT ASSESSMENT
ROLE AND EFFECTIVENESS OF IGNITERS

- . IGNITERS ARE NEEDED TO ASSURE THAT CONTAINMENT PRESSURES DO NOT EXCEED FAILURE PRESSURES FOR A SUBSTANTIAL FRACTION OF DEGRADED CORE ACCIDENT SCENARIOS.

- . THE LIKELIHOOD THAT THE IGNITERS WILL BE CALLED INTO SERVICE HAS BEEN MADE VERY REMOTE BY IMPLEMENTATION OF STILL MEASURES, I.E., THE STILL ITEMS HAVE PLACED SEQUOYAH IN THE SAME RISK SPACE AS SURRY AND PEACH BOTTOM.

- . PRELIMINARY RESULTS FROM ANALYSES WITH THE CLASIX AND MARCH CODES SHOW THAT IGNITERS CAN KEEP HYDROGEN BURN PRESSURES BELOW ABOUT 26 PSIG FOR CASES INVOLVING SUBSTANTIAL AMOUNTS AND RATES OF HYDROGEN RELEASE.

EFFECTIVENESS OF IGNITERS

PRELIMINARY ANALYSES OF HYDROGEN BURNS DURING THE S₂D SEQUENCE -
WITH CLASIX/MARCH INDICATE THAT:

- . PEAK CONTAINMENT PRESSURE WILL BE ABOUT 26 PSIG IF ICE
DOES NOT EXIST DURING THE HYDROGEN BURNS

- . PEAK CONTAINMENT PRESSURE WILL BE ABOUT 13 PSIG IF ICE
EXISTS DURING THE HYDROGEN BURNS

ROLE OF IGNITERS

1. PERMITS THE CONTROLLED BURNING OF LEAN MIXTURES (8-12%).
2. ALLOWS ICE BEDS, SPRAYS, AND HEAT SINKS TO ABSORB THE BURN ENERGY.
3. PROMOTES BURNING IN LOWER COMPARTMENT.
4. PREVENTS DEVELOPMENT OF DETONABLE MIXTURES IN LARGE VOLUMES.

ASSESSMENT OF THE NEED FOR
ADDITIONAL HYDROGEN CONTROL MEASURES

THE STAFF'S VIEW IS THAT HYDROGEN CONTROL MEASURES BEYOND THOSE PRESCRIBED IN 10 CFR SECTION 50.44 ARE REQUIRED FOR ICE CONDENSER PLANTS, BUT THAT A REASONABLE PERIOD OF TIME, I.E., WITHIN A YEAR, MAY BE ALLOWED FOR IMPLEMENTATION OF THESE MEASURES SO THAT APPROPRIATE STUDIES AND TESTS CAN BE COMPLETED.

THE STAFF'S BASES FOR THIS VIEW ARE:

- . TMI STILL ITEMS HAVE ALREADY BEEN IMPLEMENTED PLACING SEQUOYAH IN THE SAME RISK SPACE AS SURRY AND PEACH BOTTOM.
- . AGGRESSIVE APPLICANT AND STAFF PROGRAMS ARE IN PLACE TO IMPROVE THE HYDROGEN MANAGEMENT CAPABILITY AT SEQUOYAH (TIME FRAME: 4 MONTHS)
- . PRELIMINARY WORK SHOWS THE IDIS TO BE A VERY PROMISING APPROACH.
- . BACKUP PROGRAMS ARE IN PLACE SHOULD THE IDIS PROVE UNACCEPTABLE.
- . OPERATIONS AT FULL POWER DO NOT FORECLOSE LATER ADOPTION OF ALTERNATIVE MEASURES.

Q - 1. DOES THE STAFF BELIEVE ADDITIONAL HYDROGEN CONTROL MEASURES ARE NECESSARY FOR ICE CONDENSER CONTAINMENTS?

A - 1. THE STAFF'S VIEW IS THAT HYDROGEN CONTROL MEASURES BEYOND THOSE PRESCRIBED IN 10 CFR SECTION 50.44 ARE REQUIRED FOR ICE CONDENSER PLANTS, BUT THAT A REASONABLE PERIOD OF TIME, I.E., WITHIN A YEAR, MAY BE ALLOWED FOR IMPLEMENTATION OF THESE MEASURES SO THAT THE APPROPRIATE STUDIES AND TESTS CAN BE COMPLETED.

THE STAFF'S BASES FOR THIS VIEW ARE:

- . TMI STILL ITEMS HAVE BEEN IMPLEMENTED PLACING SEQUOYAH IN SAME RISK SPACE AS SURRY AND PEACH BOTTOM.
- . AGGRESSIVE APPLICANT AND STAFF PROGRAMS ARE IN PLACE TO IMPROVE THE HYDROGEN MANAGEMENT CAPABILITY AT SEQUOYAH (TIME FRAME: 4 MONTHS),
- . PRELIMINARY WORK SHOWS THE IDIS TO BE A VERY PROMISING APPROACH,
- . BACKUP PROGRAMS ARE IN PLACE, SHOULD THE IDIS PROVE UNACCEPTABLE
- . OPERATIONS AT FULL POWER DO NOT FORECLOSE LATER ADOPTION OF ALTERNATIVE MEASURES

Q - 1. DOES THE STAFF BELIEVE ADDITIONAL HYDROGEN CONTROL MEASURES ARE NECESSARY FOR ICE CONDENSER CONTAINMENTS?

A - 1. THE STAFF'S VIEW IS THAT HYDROGEN CONTROL MEASURES BEYOND THOSE PRESCRIBED IN 10 CFR SECTION 50.44 ARE NOT REQUIRED IN THE NEAR TERM FOR FULL POWER OPERATIONS AT ICE CONDENSER PLANTS. BY NEAR TERM WE MEAN WITHIN THE NEXT YEAR.

Q - 2. IS THE STAFF REASONABLY PERSUADED OF THE EFFECTIVENESS OF DISTRIBUTED IGNITERS IN ICE CONDENSER CONTAINMENTS? CAN SUCH IGNITERS BE COUNTED ON TO KEEP PRESSURE INCREASES CAUSED BY HYDROGEN BURNS AT SUITABLY LOW VALUES -- WHICH I WOULD DEFINE AS DESIGN PRESSURES -- DURING ACCIDENT SEQUENCES INVOLVING TMI-LIKE QUANTITIES OF HYDROGEN?

A - 2. THE STAFF'S VIEW IS THAT THE DISTRIBUTED IGNITER SYSTEM APPEARS VERY PROMISING AS AN ADDITIONAL HYDROGEN CONTROL MEASURE. ANALYSES WITH THE CLASIX AND MARCH CODES HAVE SHOWN THAT THE SYSTEM CAN SUBSTANTIALLY IMPROVE THE CAPABILITY OF AN ICE CONDENSER CONTAINMENT TO ACCOMMODATE THE HYDROGEN RELEASES FROM A DEGRADED CORE ACCIDENT.

HOWEVER, FURTHER ANALYSES AND TESTS NEEDS TO BE CONDUCTED TO DETERMINE ITS RANGE OF EFFICACY AND TO ASSURE THAT OVERALL SAFETY IS NOT DEGRADED. THIS WORK IS NOW UNDERWAY AND SHOULD BE COMPLETED BY DECEMBER 1980.

PENDING THE RESULTS OF FURTHER WORK, THE STAFF'S VIEW IS THAT USE OF AN IGNITER SYSTEM DURING ACCIDENT SEQUENCES INVOLVING TMI-LIKE QUANTITIES OF HYDROGEN WOULD LEAD TO CONTAINMENT PRESSURES THAT EXCEED DESIGN PRESSURES BUT THAT ARE LESS THAN CONTAINMENT FAILURE OR YIELD PRESSURES.

WE FIND THESE FEATURES ACCEPTABLE PENDING THE RULEMAKING PROCEEDING ON MUCH THE SAME BASES INDICATED FOR THE FIRST QUESTION.

CONTROL ROD

G. J. King




FIGURE 2.2 BWR CONTROL ROD DRIVE MECHANISM (SIMPLIFIED SKETCH)




FIGURE 2.1 BWR SCRAM HYDRAULIC SYSTEM (NORMAL VALVE LINEUP, PRE-SCRAM)





FIGURE 2.3 BWR SCRAM HYDRAULIC SYSTEM (SCRAMMED VALVE LINEUP)





FIGURE 2.4 BROWNS FERRY SCRAM DISCHARGE INSTRUMENT VOLUME

(93) EAST

WEST (92)




Control Rod Scram Group Assignment

Figure 3.2 Control Rod Positions After Second Scram

(93) EAST

WEST (92)



Control Rod Scram Group Assignment

Figure 3.3 Control Rod Positions After Third Scram






FIGURE 2.3 BWR SCRAM HYDRAULIC SYSTEM (SCRAMMED VALVE LINEUP)



PERCH BOTTOM Reactor Protection System Trip Discharge Headers




FIGURE 3.4 BROWNS FERRY SDV EQUIPMENT LAYOUT (ISOMETRIC VIEW)




FIGURE 3.5 SKETCH OF BROMNS FERRY SDV EQUIPMENT LAYOUT (ELEVATION)




FIGURE 3.6 SIMULATED EAST SDV VENT LINE BLOCKAGE TEST

WEST SIDE

EAST SIDE





FIGURE 3.7 SIMULATED WEST SDV VENT LINE BLOCKAGE TEST




FIGURE 3.8 SIMULATED EAST AND WEST SDV VENT LINE BLOCKAGE TEST






FIGURE 3.9 NORMAL DRAIN TEST


SOUTH

NORTH



A damaged pipe supports







4

SOUTH

NORTH






A E O D FINDINGS

1. THE CAUSE OF THE PARTIAL SCRAM FAILURE WAS WATER ACCUMULATION IN THE EAST SDV.
2. THE SDIV "HIGH WATER LEVEL TRIP" DID NOT AND DOES NOT PROVIDE PROTECTION AGAINST FILLING THE EAST SDV EVEN FOR NORMAL VENTING AND DRAINING CONDITIONS.
3. A SINGLE FAILURE (E.G., WEST SIDE SDV VENT OR DRAIN LINE BLOCKAGE) CAN COMPLETELY DISABLE THE SDIV "HIGH WATER LEVEL TRIP" INSTALLED TO PROTECT AGAINST LOSS OF SCRAM CAPABILITY FOR THE CONTROL RODS.
4. WITH THE PRESENT SDV/SDIV LAYOUT, A SINGLE FAILURE (BLOCKAGE) OF AN SDV VENT OR DRAIN PATH CAN CAUSE A PARTIAL LOSS OF SCRAM CAPABILITY.
5. THERE ARE NUMEROUS ACTUAL AND POTENTIAL MECHANISMS FOR INTRODUCING AND ACCUMULATING WATER IN THE SDV'S WITH NO ACCUMULATION IN THE SDIV.
6. THE CURRENT SDV/SDIV LAYOUT RESULTS IN THE AUTOMATIC "HI WATER LEVEL TRIP" SAFETY FUNCTION BEING DIRECTLY DEPENDENT ON THE NON-SAFETY RELATED REACTOR BUILDING WASTE DRAIN SYSTEM.
7. THE FLOAT-TYPE WATER LEVEL MONITORING INSTRUMENTS ON THE SDIV HAVE A SIGNIFICANT DEGREE OF UNRELIABILITY.
8. THE CURRENT BWR RPS LOGIC DOES NOT ALLOW SCRAM RESET TO ATTEMPT A RE-SCRAM IF CERTAIN AUTOMATIC SCRAM SIGNALS ARE PRESENT.
9. FAILURE TO CLOSE OF A SINGLE SDV VENT OR DRAIN VALVE DURING A REACTOR SCRAM CAN RESULT IN A UNISOLATABLE RELEASE OF REACTOR COOLANT OUTSIDE THE PRIMARY CONTAINMENT INTO THE SECONDARY CONTAINMENT.
10. THE EMERGENCY OPERATING INSTRUCTIONS AT BROWNS FERRY DID NOT COVER A PARTIAL OR TOTAL SCRAM FAILURE EVENT.

AEOD RECOMMENDATIONS

1. THE OPERABILITY OF THE SDIV "HI WATER LEVEL TRIP" SHOULD BE INDEPENDENT OF THE VENTING AND DRAINING REQUIREMENTS.
2. SDIV INSTRUMENTS SHOULD BE BOTH REDUNDANT AND DIVERSE.
3. ALL VENT AND DRAIN PATHS FROM THE SDIV SHOULD HAVE REDUNDANT AUTOMATIC ISOLATION VALVES.
4. EMERGENCY OPERATING PROCEDURES AND OPERATOR TRAINING SHOULD BE PROVIDED FOR COMPLETE AND PARTIAL SCRAM FAILURE CONDITIONS.
5. CONSIDER MODIFYING THE SDIV VENT AND DRAIN ARRANGEMENT TO IMPROVE DRAIN RELIABILITY.

GE RECOMMENDED SDV CONFIGURATION






FIGURE II 6-16 Reactor Protection System Reduced Fault Tree






FIGURE II 6-16 Reactor Protection System Reduced Fault Tree

II-521

Adapted from Appendix II WASH-1406



Calculated Probability = 1×10^{-3}



3PPF002P
(3PPF001P)
 1.3×10^{-7}

Calculation: $(1 \times 10^{-3})(1 \times 10^{-3}) + [1 \times 10^{-3} + 1.3 \times 10^{-7}] + 1.3 \times 10^{-7} = 1 \times 10^{-3}$ Upper bound
 $(1 \times 10^{-4})(1 \times 10^{-4}) + [1 \times 10^{-4} + 1.3 \times 10^{-7}] + 1.3 \times 10^{-7} = 1 \times 10^{-4}$ Lower bound

BWR HYDRAULIC SCRAM SYSTEM

NRC STAFF REPORT

1. BROWNS FERRY EVENT AND ASSOCIATED EVENTS - W. MILLS.
2. NRC SHORT TERM RESPONSE - W. MILLS.
3. NRC REGIONAL MEETINGS - V. PANCIERA.
4. PLAN OF ACTION TO RESOLVE PROBLEM - V. PANCIERA.
5. RESULTS OF ACCIDENT ANALYSES - M. MENDONCA.
6. IMPLICATIONS FOR ATWS - A. THADANI

NRC REGIONAL MEETING

OBJECTIVE - IN-DEPTH UNDERSTANDING OF AS-BUILT CONDITIONS IN SDV INSTRUMENTED VOLUME, INTERCONNECTING PIPING AND VENT & DRAIN SYSTEMS

1. GENERAL AREAS COVERED

A. SYSTEM CONFIGURATIONS

- (A) GENERAL LAYOUT
- (B) SYSTEM DESIGN REQUIREMENT
- (C) SYSTEM INERTIES
- (D) NSSS - AE INTERFACE

B. RECENT TEST RESULTS

- (A) VALVE OPEN/CLOSE TESTS
- (B) DRAIN TESTS

C. EMERGENCY PROCEDURE VERIFICATION


SYSTEM CONFIGURATIONS


- I. SDV - IV HYDRAULIC COUPLING
 - A) TWO BASIC CONFIGURATIONS
 - 1. SINGLE IV
 - 2. IV OFF EACH SDV HEADER

- II. SDV VENT SYSTEM
 - A) LARGE VARIABILITY IN DESIGN
 - 1. DEDICATED VENT PIPING
 - 2. CROSS-TIE BETWEEN SDV HEADERS
 - 3. INTERTIES WITH OTHER SYSTEMS

- III. SDV DRAIN SYSTEMS
 - A. BASIC CONFIGURATIONS
 - B. INTERTIES WITH OTHER SYSTEMS

- IV. DESIGN REQUIREMENTS
 - A. SDV VOLUME REQUIREMENT
 - B. PIPING SLOPES
 - C. DYNAMIC LOADS
 - D. DESIGN INTERFACES





LONG TERM ACTIONS

1. COMPLETE REVIEW OF BULLETIN RESPONSES.
2. REVIEW OF AS-BUILT SYSTEM CONFIGURATIONS.
3. ENCOURAGE OWNERS GROUP PARTICIPATION
 - A. SUBGROUP TO DEVELOP DESIGN & PERFORMANCE CRITERIA FOR SDV.
4. APPROVE CRITERIA.
5. IMPLEMENT PLANT MODIFICATION IN CONFORMANCE WITH CRITERIA.
6. AUDIT PLANT MODIFICATIONS.




FIGURE 1

UPCOMING ACTIONS

1. MEETING OF OWNER'S SUBGROUP - SEPT. 3 & 4, 1980.
2. RESULTS OF SUBGROUP MEETING TO STAFF - SEPT. 8, 1980.
3. STAFF - SUBGROUP MEETING - WEEK OF SEPT. 15, 1980.
4. APPROVED DESIGN AND PERFORMANCE CRITERIA IN PLACE -
OCTOBER 17, 1980.
5. SCHEDULES FOR PLANT-SPECIFIC MODIFICATIONS - DECEMBER 15,
1980.

MSIV CLOSURE
PRESSURE VESSEL CRITERION*

•GENERIC BWR
NO RPT
EOC

$P_{MAX} = 1460$ PSIG

*PRESSURE VESSEL LEVEL C SERVICE LIMIT = 1500 PSIG

MSIV CLOSURE FROM 100% POWER
FOR PLANTS WITH RPT
SUPPRESSION POOL TEMPERATURE LIMIT*

BROWNS FERRY PLANT (PRELIMINARY FROM GE)

- BF3 TYPE SCRAM
1 RHR @ 30 MINUTES
1 SLCS @ 30 MINUTES
 $T_{MAX} = 190^{\circ}F$
- RODS ON ONE HALF OF CORE STAY OUT
2 RHR @ 30 MINUTES
1 SLCS @ ABOUT 8 MINUTES
 $T_{MAX} = 200^{\circ}F$

GENERIC BWR

- BF3 TYPE SCRAM
2 RHR @ 10 MINUTES
1 SLCS @ 10 MINUTES
 $T_{MAX} = 153^{\circ}F$
- WITH 1 SLCS @ 30 MINUTES
 $T_{MAX} = 186^{\circ}F$
- RODS ON ONE HALF CORE STAY OUT
2 RHR @ 10 MINUTES
1 SLCS @ A BIT GREATER THAN 5 MINUTES
 $T_{MAX} = \text{LESS THAN } 200^{\circ}F$

*SUPPRESSION POOL TEMPERATURE LIMIT = 160°F w/o QUENCHERS
AND 200°F w QUENCHERS

BF-3 EVENT IMPACT ON ATWS

BWR ESTIMATED ATWS FREQUENCY

	<u>CURRENT</u>	<u>ALT. 3A</u>	<u>ALT. 4A</u>
PRIOR TO BF-3	$\sim 2 \times 10^{-4}/\text{RY}$	$\sim 1 \times 10^{-5}/\text{FY}$	$\approx 1 \times 10^{-6}/\text{RY}$
BF-3 (BWR'S ONLY)	$\sim 1 \times 10^{-3}/\text{RY}$	$\sim 5 \times 10^{-5}/\text{RY}$	$\approx 5 \times 10^{-6}/\text{RY}$
LWR'S	$\sim 5 \times 10^{-4}/\text{RY}$	$\sim 2.5 \times 10^{-5}/\text{RY}$	$\approx 2.5 \times 10^{-6}/\text{RY}$

EFFECTS OF BF3 EVENT FROM 100% POWER


FROM RODS OUT, ROD MOVEMENT EQUAL TO BF3 EVENT AND RPT
POWER = 10%

HALF RODS IN OTHER HALF OUT WITH RPT
POWER = 20%

HALF RODS IN OTHER HALF OUT NO RPT
POWER = 40%

BROWNS FERRY 3 EVENT (PARTIAL SCRAM)

- I. CONCERNS RAISED
- II. SHORT-TERM ACTIONS TAKEN -
BULLETIN 80-17
80-17 REQUIREMENTS
80-17 FINDINGS
- III. SHORT-TERM ACTIONS ONGOING
- IV. CONCLUSIONS



BROWNS FERRY 3 EVENT

CONCERNS RAISED

- RELIABILITY OF SCRAM FUNCTION
- UNDERSTANDING OF THE AS-BUILT SDV CONFIGURATION
- SHORT-TERM ACTIONS NEEDED TO JUSTIFY CONTINUED OPERATION
- LONG-TERM ACTIONS NEEDED TO PROVIDE:

SDV DESIGN WITH IMPROVED
RELIABILITY

ATWS RELATED PROCEDURES
AND MODIFICATIONS

BROWNS FERRY 3 EVENT

1. WITHIN THREE DAYS VERIFY SDV EMPTY, VERIFY SDV OPERABLE
2. WITHIN 20 DAYS PERFORM ONE AUTOMATIC AND ONE MANUAL SCRAM TEST AT NORMAL OPERATING TEMPERATURE AND PRESSURE
3. AFTER SCRAM TESTS VERIFY SDV EMPTY AND OPERABLE
4. DEVELOP PROCEDURES TO MONITOR THE SDV DAILY FOR WATER ACCUMULATION
5. REVIEW EMERGENCY OPERATING PROCEDURES AND ENSURE THAT REQUIRED OPERATOR ACTIONS ARE ADEQUATE FOR BF-3 TYPE EVENT
6. TAKE ACTIONS SPECIFIED TO MITIGATE THE CONSEQUENCES OF AN ATWS EVENT
7. WITHIN FIVE DAYS OF PERFORMANCE OF EACH SCRAM TEST, SUBMIT RESULTS TO NRC
8. BWRs CURRENTLY SHUTDOWN, PERFORM THE SCRAM TESTS PRIOR TO POWER OPERATION

BULLETIN 80-17, SUPPLEMENT 1

REQUIRES:

- CONTINUOUS ALARM MONITORING
BY SEPTEMBER 1
- DESIGN REVIEW OF VENT SYSTEM
BY SEPTEMBER 1
- PROCEDURAL CONTROLS FOR
AVAILABILITY AND USE OF
STANDBY LIQUID CONTROL SYSTEM
- VERIFICATION OF AS-BUILT
DRAWINGS OF SDV AND DESCRIPTION
OF VENTS AND DRAIN

BULLETIN 80-17, SUPPLEMENT 2

REQUIRES:

EACH BWR WITH SDV VENT SYSTEM THAT DEPENDS ON ANY COMPONENT OTHER THAN THE VENT VALVE ALONE FOR PROPER VENTING MUST PROVIDE AN ALTERNATE VENT PATH CONTINUOUSLY OPEN TO BUILDING ATMOSPHERE WITHIN 48 HOURS OF NOTIFICATION TO CONTINUE OPERATION. IT MUST BE POSITIVE IN ITS FUNCTION AT ALL TIMES.

BULLETIN 80-17, SUPPLEMENT 3

REQUIRES:

- IMMEDIATE MANUAL SCRAM ON
LOW CRDS AIR PRESSURE

- IMMEDIATE MANUAL SCRAM ON
EITHER MULTIPLE ROD DRIFT
ALARMS OR MARKED INCREASE
IN CRD HIGH TEMPERATURE
ALARMS

- FUNCTIONAL TEST OF ALL SDIV
LEVEL SWITCHES FOLLOWING
EACH SCRAM, PRIOR TO REACTOR
STARTUP

80-17 STATUS AND FINDINGS

STATUS:

- ALL PLANTS HAVE RESPONDED TO 80-17, SUPPLEMENTS 1, 2
- SCRAM TESTS HAVE BEEN COMPLETED (EXCEPT BRUNSWICK 2, S/D)
- STAFF REVIEW OF RESPONSES IS ONGOING
- RESPONSES TO SUPPLEMENT 3 DUE SEPTEMBER 2, 1980

FINDINGS:

- SOME SCRAM SYSTEM DEFICIENCIES HAVE BEEN FOUND
- RESPONSES TO BULLETIN 80-17, SUPPLEMENTS 1, 2 HAVE BEEN SATISFACTORY FOR ALL PLANTS,
 - EMPTY AND OPERABLE SDV VERIFIED
 - DATA ON SDV DESIGN/OPERATION OBTAINED
 - DAILY MONITORING FOR WATER IN SDV ESTABLISHED
 - PROCEDURES FOR SBLC INITIATION PROVIDED
 - ATWS ANALYSES PROVIDED TO THE STAFF

EXCEPT,

- CONTINUOUS MONITORING FOR WATER IN THE SDV NOT INSTALLED FOR MOST PLANTS BY SEPTEMBER 1, 1980, AND INCREASED FREQUENCY OF DAILY SURVEILLANCE NOT PROPOSED IN THE INTERIM

SCRAM SYSTEM DEFICIENCIES

BRUNSWICK UNIT 1 - CRUSHED FLOATS
IN HIGH LEVEL ALARM AND ROD
BLOCK INSTRUMENTS. DRAIN PIPING
SUPPORTS DAMAGED.

HATCH UNIT 1 - TWO HIGH LEVEL SCRAM
INSTRUMENTS FOUND INOPERABLE DUE
TO BENT FLOAT STEMS

DRESDEN UNIT 3 - SDV HEADER DID NOT
DRAIN PROPERLY

BROWNS FERRY UNIT 1 - SDIV DID NOT
DRAIN PROPERLY

MILLSTONE UNIT 1 - 10-SECOND DELAY
RELAY WAS NOT CONNECTED ELECTRICALLY

DUANE ARNOLD - SDV DRAIN VALVE WAS
INSTALLED BACKWARDS

PEACH BOTTOM UNITS 2 & 3 - BACKUP
SCRAM VALVE SOLENOIDS CONNECTED
TO INCORRECT ELECTRICAL SOURCE

NINE MILE POINT UNIT 1 - ONE ROD FAILED
TO SCRAM DURING MANUAL SCRAM TEST -
SCRAM PILOT VALVE FAILURE

FITZPATRICK - LOOP SEAL FOUND IN
INSTALLED SDV DRAIN PIPING

HATCH 2 - TWO SDV HIGH LEVEL SCRAM
FLOATS FOUND CRUSHED

SHORT-TERM ACTIONS ONGOING

-
- ONGOING REVIEW OF 80-17
RESPONSES

 - ONGOING REVIEW TO IDENTIFY
NEED FOR IMPROVEMENT IN OTHER,
RELATED AREAS

 - CONSIDERING FURTHER STAFF ACTIONS
TO REQUIRE INSTALLATION OF
CONTINUOUS SDV MONITORING BY
DECEMBER 1980, WITH MONITORING
ONCE PER SHIFT IN THE INTERIM

CONCLUSIONS

- CORRECTIVE ACTIONS BEING TAKEN ENSURE THAT THE SDV IS EMPTY DURING POWER OPERATION

- THESE CORRECTIVE ACTIONS ARE NECESSARY AND SUFFICIENT TO JUSTIFY CONTINUED OPERATION

- LONG-TERM ACTION IS NECESSARY AND IS UNDERWAY
 - NRR TASK FORCE




FIGURE 2.2 BWR CONTROL ROD DRIVE MECHANISM (SIMPLIFIED SKETCH)




FIGURE 2.1 BWR SCRAM HYDRAULIC SYSTEM (NORMAL VALVE LINEUP, PRE-SCRAM)





FIGURE 2.3 BWR SCRAM HYDRAULIC SYSTEM (SCRAMMED VALVE LINEUP)





FIGURE 2.4 BROWNS FERRY SCRAM DISCHARGE INSTRUMENT VOLUME

(93 RODS) EAST

WEST (92 RODS)




Control Rod Scram Group Assignment

Figure 3.1 Control Rod Positions After First Scram

(93) EAST

WEST (92)



Control Rod Scram Group Assignment


Figure 3.2 Control Rod Positions After Second Scram

(93) EAST

WEST (92)

0°

180°



46/93

0/92

Control Rod Scram Group Assignment

Figure 3.3 Control Rod Positions After Third Scram






FIGURE 2.3 BWR SCRAM HYDRAULIC SYSTEM (SCRAMMED VALVE LINEUP)



PERCH Bottom Reactor Protection System Trip Discharge Headers





FIGURE 3.4 BROWNS FERRY SDV EQUIPMENT LAYOUT (ISOMETRIC VIEW)

WEST SIDE



EAST SIDE




FIGURE 3.5 SKETCH OF BROWNS FERRY SDV EQUIPMENT LAYOUT (ELEVATION)




FIGURE 3.6 SIMULATED EAST SDV VENT LINE BLOCKAGE TEST




FIGURE 3.7 SIMULATED WEST SDV VENT LINE BLOCKAGE TEST




FIGURE 3.8 SIMULATED EAST AND WEST SDV VENT LINE BLOCKAGE TEST







FIGURE 3.9 NORMAL DRAIN TEST

SOUTH

NORTH










SOUTH

NORTH








A E O D F I N D I N G S

1. THE CAUSE OF THE PARTIAL SCRAM FAILURE WAS WATER ACCUMULATION IN THE EAST SDV.
2. THE SDIV "HIGH WATER LEVEL TRIP" DID NOT AND DOES NOT PROVIDE PROTECTION AGAINST FILLING THE EAST SDV EVEN FOR NORMAL VENTING AND DRAINING CONDITIONS.
3. A SINGLE FAILURE (E.G., WEST SIDE SDV VENT OR DRAIN LINE BLOCKAGE) CAN COMPLETELY DISABLE THE SDIV "HIGH WATER LEVEL TRIP" INSTALLED TO PROTECT AGAINST LOSS OF SCRAM CAPABILITY FOR THE CONTROL RODS.
4. WITH THE PRESENT SDV/SDIV LAYOUT, A SINGLE FAILURE (BLOCKAGE) OF AN SDV VENT OR DRAIN PATH CAN CAUSE A PARTIAL LOSS OF SCRAM CAPABILITY.
5. THERE ARE NUMEROUS ACTUAL AND POTENTIAL MECHANISMS FOR INTRODUCING AND ACCUMULATING WATER IN THE SDV'S WITH NO ACCUMULATION IN THE SDIV.
6. THE CURRENT SDV/SDIV LAYOUT RESULTS IN THE AUTOMATIC "HI WATER LEVEL TRIP" SAFETY FUNCTION BEING DIRECTLY DEPENDENT ON THE NON-SAFETY RELATED REACTOR BUILDING WASTE DRAIN SYSTEM.
7. THE FLOAT-TYPE WATER LEVEL MONITORING INSTRUMENTS ON THE SDIV HAVE A SIGNIFICANT DEGREE OF UNRELIABILITY.
8. THE CURRENT BWR RPS LOGIC DOES NOT ALLOW SCRAM RESET TO ATTEMPT A RE-SCRAM IF CERTAIN AUTOMATIC SCRAM SIGNALS ARE PRESENT.
9. FAILURE TO CLOSE OF A SINGLE SDV VENT OR DRAIN VALVE DURING A REACTOR SCRAM CAN RESULT IN A UNISOLATABLE RELEASE OF REACTOR COOLANT OUTSIDE THE PRIMARY CONTAINMENT INTO THE SECONDARY CONTAINMENT.
10. THE EMERGENCY OPERATING INSTRUCTIONS AT BROWNS FERRY DID NOT COVER A PARTIAL OR TOTAL SCRAM FAILURE EVENT.

A E O D . R E C O M M E N D A T I O N S

1. THE OPERABILITY OF THE SDIV "HI WATER LEVEL TRIP" SHOULD BE INDEPENDENT OF THE VENTING AND DRAINING REQUIREMENTS.
2. SDIV INSTRUMENTS SHOULD BE BOTH REDUNDANT AND DIVERSE.
3. ALL VENT AND DRAIN PATHS FROM THE SDIV SHOULD HAVE REDUNDANT AUTOMATIC ISOLATION VALVES.
4. EMERGENCY OPERATING PROCEDURES AND OPERATOR TRAINING SHOULD BE PROVIDED FOR COMPLETE AND PARTIAL SCRAM FAILURE CONDITIONS.
5. CONSIDER MODIFYING THE SDIV VENT AND DRAIN ARRANGEMENT TO IMPROVE DRAIN RELIABILITY.

GE RECOMMENDED SDV CONFIGURATION






FIGURE II 6-16 Reactor Protection System Reduced Fault Tree




FIGURE II 6-16 Reactor Protection System Reduced Fault Tree


II-521

Adapted from Appendix II WASH-1400

1

Calculated Probability = 1×10^{-3}

TRIP HEADER "A"(C)
FAILS TO DRAIN



Calculation: $(1 \times 10^{-3})(1 \times 10^{-3}) + [1 \times 10^{-3} + 1.3 \times 10^{-7}] + 1.3 \times 10^{-7} = 1 \times 10^{-3}$ Upper bound

$(1 \times 10^{-4})(1 \times 10^{-4}) + [1 \times 10^{-4} + 1.3 \times 10^{-7}] + 1.3 \times 10^{-7} = 1 \times 10^{-4}$ Lower Bound

SHORT TERM REVIEW PROGRAM

OBJECTIVES

- . EVALUATE FUNCTIONABILITY AND DURABILITY OF THE GLOW PLUG IGNITER

- . EVALUATE EFFICACY OF THE PROPOSED IDIS IN IMPROVING HYDROGEN CONTROL CAPABILITY

- . ASSURE NO SIGNIFICANT LOSS IN SAFETY BY USE OF THE PROPOSED IDIS

- . INVESTIGATE H₂ CONTROL FEATURES ALTERNATIVE TO IDIS

APPROACH TO ESTABLISH
FUNCTIONABILITY/DURABILITY OF IGNITERS

NRC

- . TESTING OF THE GLOW PLUG AT LIVERMORE LABORATORY ADDRESSING OPERABILITY IN VARIOUS ENVIRONMENTS
- . COMPLETED OCTOBER 31

TVA

- . DURABILITY TESTING AT TVA SINGLETON LABORATORY
 - 148 HR CONTINUOUS TEST HAS BEEN SUCCESSFULLY COMPLETED
 - OPERABILITY ESTABLISHED WITH 1720°F AT 14V
- . FUNCTIONABILITY TESTING AT SINGLETON LABORATORY
 - SERIES OF TESTS DEMONSTRATED COMPLETE COMBUSTION OF H₂ IN 12-14% MIXTURES
- . TESTING OF THE IGNITER UNIT AT FENWALL LABORATORY
 - TEST MATRIX OF VARYING ATMOSPHERE COMPOSITIONS AND TURBULENCE
 - COMPLETED OCTOBER 1
 - FURTHER TESTING WILL CONTINUE INCLUDING EFFECTS OF SPRAYS

RESULT: NRC WILL EVALUATE IGNITER PERFORMANCE BY REVIEW OF INDIVIDUAL TEST DATA AND COLLECTIVE ASSESSMENT OF RESULTS.

APPROACH TO EVALUATE EFFICACY
OF IDIS IN IMPROVING H₂ CONTROL CAPABILITY

- . GENERAL APPROACH IS FOUNDED ON EVALUATION OF CONTAINMENT TRANSIENT ANALYSIS FOR DEGRADED CORE ACCIDENTS. -

- . RANGE OF DEGRADED CORE ACCIDENTS TO CONSIDER WILL BE SELECTED BY TVA AND REVIEWED FOR ACCEPTABILITY BY THE STAFF.

- . TVA WILL PERFORM ANALYSIS (USING CLASIX) FOR THESE ACCIDENTS DEMONSTRATING THAT CONTAINMENT PRESSURE IS LESS THAN A PRESELECTED VALUE.
 - . YIELD STRENGTH/ULTIMATE STRENGTH
 - . INPUT TO THE CALCULATION WILL BE IGNITER PERFORMANCE PARAMETERS VERIFIED BY TESTING

- . TVA WILL COMPLETE INITIAL VERIFICATION OF CLASIX CODE AND REPORT RESULTS.

- . NRC WILL PERFORM CONFIRMATORY ANALYSES THROUGH BCL USING MARCH.

RESULT: NRC WILL EVALUATE CLASIX CODE AND THE ANALYSIS RESULTS.

APPROACH TO ASSURE NO SIGNIFICANT
LOSS IN SAFETY BY USE OF THE IDIS

I/A

- . TVA WILL EVALUATE RANDOM IGNITION SOURCES FOR COMPARISON TO IDIS.

- . LOCATION OF IGNITERS WILL BE EVALUATED TO SEE THAT BURNING IN IMMEDIATE AREA WILL NOT IMPAIR ESSENTIAL EQUIPMENT.

- . POTENTIAL FOR AND CONSEQUENCES OF LOCAL DETONATIONS WILL BE ASSESSED.

STAFF WILL REVIEW TVA SUBMITTALS AND WILL INDEPENDENTLY ASSESS EFFECTS OF LOCAL DETONATIONS.

H₂ RELATED ACTIVITIES

1. TECHNICAL ASSISTANCE CONTRACT A0249
2. TECHNICAL ASSISTANCE CONTRACT
3. TECHNICAL ASSISTANCE CONTRACT
4. SHORT TERM RESEARCH ON H₂ CONTROL
5. RESEARCH ON DEGRADED MELTED CORE ACCIDENTS
6. ZION/INDIAN POINT STUDIES (I)
7. ZION/INDIAN POINT STUDIES (II)
8. ZION/INDIAN POINT STUDIES (III) TECHNICAL ASSISTANCE
9. IGNITER TESTING
10. H₂ CONTROL
11. H₂ GENERATION AND CONTROL

TABLE 1. PRELIMINARY CONTAINMENT ANALYSIS SENSITIVITY STUDIES

	TOTAL H ₂ BURNED (LB)	PEAK TEMP. (°F)			PEAK PRESS (PSIA)	
		LOWER COMPARTMENT	ICE BED	UPPER COMP.	LOWER COMP.	UPPER COMP.
1. BASE CASE	900	2200	1200	150	26.5	28.5
2. H ₂ IGNITION AND PROPAGA- TION @ 8%	1050	1200	700	260	28.5	30.5
3. 1 AIR FAN	900	2200	1350	160	26.5	29.5
4. NO ICE*	850	2400	2000	270	41	41
5. NO AIR FANS	1200	2370	2580	1090	46.4	92.4

* ICE EXISTS ONLY FOR THE FIRST TWO OF 7 BURNING CYCLES.

SUMMARY OF RESULTS

Case	Ignition Point v/o H ₂	Burn Limit v/o H ₂	Burn Time, sec	Flame Propagation 1 ↓ 2	PT psia ⁽¹⁾	PNEW psia ⁽²⁾	PMAX psia ⁽³⁾
1	10	0	1	no	23	58	141
2	10	0	5	no	23	58	136
3	10	0	25	no	22	58	131
1X	10	0	1	yes	44	58	126
1X ⁽⁵⁾	10	0	1	yes	53	66	150
4	10	4	1	no	22	44	122
5	10	4	25	no	22	44	114
6	12	0	1	no	24	64	141
7	12	0	25	no	23	64	137
6X ⁽⁵⁾	12	0	1	yes	60	71	181
8	8	0	1	no	22	51	132
9	8	0	25	no	22	51	127
10	8	4	1	no	22	36	120
11	8	4	25	no	21	36	110
10X	8	4	1	yes	27	36	112
18	4	0	1	yes	24	41	111
17 ⁽⁴⁾	10	0	1	no	31	79	146
18 ^(4,5)	10	0	1	no	35	68	223
19 ^(4,5)	10	0	1	yes	50	66	149

- (1) Peak pressure prior to core slump
 (2) Peak adiabatic H₂ burn pressure prior to core slump
 (3) Peak containment pressure after head failure
 (4) Ice melt complete at 21 minutes
 (5) Modified treatment of suspended water droplets

VERIFICATION OF CLASIX


- . INITIAL ASSESSMENT COMPLETED.
- . BASED ON COMPARISON OF RESULTS WITH DESIGN CODES
 - . COCO (COCOCLASS 9) - DRY CONTAINMENT CODE USED TO MODEL H₂ BURNING IN ZION/INDIAN POINT STUDY
 - . TMD - SHORT TERM TRANSIENT ICE CONDENSER CODE
- . CLOSE AGREEMENT OF CLASIX VS TMD RESULTS AND CLASIX VS COCOCLASS 9 RESULTS
- . CLASIX RESULTS ARE REASONABLE/CONSERVATIVE.
- . FUTURE WORK
 - . COMPARISON OF RESULTS WITH LOTIC CODE (LONG TERM TRANSIENT ICE CONDENSER CODE)
 - . COMPARISON WITH TEST DATA (FENWALL)

SHUTDOWN TESTING OF FENVAL LABORATORY TEST FACILITY
WITH SEQUOYAH INTERIM DISTRIBUTED IGNITION SYSTEM IGNITER UNIT

TEST NO. ⁽¹⁾	HYDROGEN CONCENTRATION (V/O)	IGNITION TIME ⁽²⁾ (SEC)	PEAK PRESSURE (PSIG)	TIME TO PEAK PRESSURE (SEC)	PEAK TEMPERATURE OF VESSEL ⁽³⁾	PEAK TEMPERATURE OF IGNITER UNIT OUTER SURFACES ⁽³⁾
1	8	17	3.2	33	NO MEASURABLE INCREASE	310
2	9	16	41	3.1	425	600+ ⁽⁴⁾
3	10	16	50 ⁽⁵⁾	1.075	620	930
4 ⁽⁶⁾	10	16	48	1.05	630	850
5	12	15	67	0.5		


NOTE: POST-BURN ANALYSIS OF VESSEL ATMOSPHERE NOT DONE FOR TEST FACILITY SHUTDOWN TESTING, TO DETERMINE CONSTITUENT CONCENTRATIONS.

- (1) HYDROGEN/AIR MIXTURES AT AMBIENT PRESSURE AND TEMPERATURE.
- (2) ELAPSED TIME FROM ENERGIZING GLOW PLUG TO FIRST INDICATION OF PRESSURE RISE.
- (3) IGNITER AND VESSEL SURFACE TEMPERATURES MAY NOT BE TOO MEANINGFUL SINCE THERMOCOUPLES ARE PRESENTLY TAPED TO SURFACES.
- (4) SPECULATED THAT THERMOCOUPLE LIFTED FROM SURFACE SLIGHTLY AND MEASURED VESSEL ATMOSPHERE TEMPERATURE SINCE THE TEMPERATURE READING JUMPED TO 1260°F.
- (5) PRESSURE DECAYED TO 25 PSIG IN 3.2 SEC; EQUILIBRIUM PRESSURE WAS 10 PSIG.
- (6) RESULTS WERE ESSENTIALLY IDENTICAL TO TEST NO. 3.



SEQUOYAH NUCLEAR PLANT
FINAL SAFETY
ANALYSIS REPORT

PRELIMINARY PHASE I
MOUNTING DETAIL
FIGURE 6.2-147



TYPICAL OF ONE CIRCUIT

(NUMBER OF GLOW PLUGS PER CIRCUIT VARIES FROM ONE TO EIGHT)


ELECTRICAL SCHEMATIC
FIGURE 15

TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

SUBMITTED	RECOMMENDED	APPROVED
-----------	-------------	----------


REV	NO.	DATE	BY	CHKD	APPV	ENGR	INSP	SUB	RECH	APPV
DES										
CHKD										
APPV										


P3311




SEQUOYAH NUCLEAR PLANT
 FINAL SAFETY
 ANALYSIS REPORT

CONTAINMENT LIGHTING
 FIXTURE ELEVATION
 FIGURE 6.2-141






- A= ACCUMULATOR
- C= COOLING AIR UNIT
- P= REACTOR COOLANT PUMP
- SG= STEAM GENERATOR
- ⊠ = HATCH OPENINGS
- ⊙ = IGNITER LOCATIONS




SEQUOYAH NUCLEAR PLANT
 FINAL SAFETY
 ANALYSIS REPORT

CONTAINMENT LIGHTING FIXTURES
 EL. 689.0'
 FIGURE 6.2-142




SEQUOYAH NUCLEAR PLANT
 FINAL SAFETY
 ANALYSIS REPORT

CONTAINMENT LIGHTING FIXTURES
 EL. 700.3
 FIGURE 6.2-143




SEQUOYAH NUCLEAR PLANT
 FINAL SAFETY
 ANALYSIS REPORT

CONTAINMENT LIGHTING FIXTURES
 EL 731.0'
 FIGURE 6.2-144



SEQUOYAH NUCLEAR PLANT
 FINAL SAFETY
 ANALYSIS REPORT

CONTAINMENT LIGHTING FIXTURES
 EL 792.0'
 FIGURE 6.2-145



SEQUOYAH NUCLEAR PLANT
FINAL SAFETY
ANALYSIS REPORT

CONTAINMENT LIGHTING FIXTURES
EL 818.0'
FIGURE 6.2-146

CONTAINMENT VESSEL

UPPER CONTAINMENT

1000 CFM

1000 CFM

CONTAINMENT DOME
HYDROGEN COLLECTORS

FROM UPPER CONT.
40,045

FROM UPPER CONT.
40,045

9,800 FT³
STEAM GEN CAVITY
375 CFM

9,800 FT³
STEAM GEN CAVITY
375 CFM

3,350 FT³
PRESSURIZER
CAVITY
375 CFM

9,800 FT³
STEAM GEN CAVITY
375 CFM

9,800 FT³
STEAM GEN CAVITY
375 CFM

LOWER CONTAINMENT

REACTOR WELL
300 CFM

REACTOR WELL
300 CFM

16,800 FT³

AIR RETURN
FAN
42,395

AIR RETURN
FAN
43,375 CFM

40 CFM
ACCUMULATOR
RM
10,200 FT³

25 CFM
ACCUMULATOR
RM
5,380 FT³

75 CFM
INCORE
INSTRUMENT
19,815 FT³

25 CFM
ACCUMULATOR
RM
5,380 FT³

55 CFM
ACCUMULATOR
RM
13,780 FT³

PRELIMINARY TESTING TO IDENTIFY

COMMERCIALY AVAILAABLE IGNITERS

TESTING CONDUCTED AT TVA'S

SINGLETON LABORATORIES

1.0 Introduction

TVA has a testing program which is being conducted at TVA's Singleton Laboratory to obtain preliminary information about the performance of commercially available igniters. The purpose of these tests was to screen alternative igniters and to gain a degree of confidence that the igniters could ignite hydrogen. The tests were not run under normal laboratory test conditions since the objective was to identify which igniters, if any, were most promising as subjects for more detailed testing and evaluation. Nonetheless, TVA gained considerable information and assurance that commercially available igniters could ignite hydrogen.

2.0 Preliminary Screening

A number of igniter types were evaluated, ranging from high energy spark igniters to large diameter (1-1/2" I.D.) heater coils. Although the spark plug type igniter was considered an excellent candidate for this application, it was rejected prior to preliminary testing due to potential problems with electromagnetic interference (EMI) with critical instrumentation. TVA's Electrical Engineering Branch is researching the problems associated with EMI generators, and spark type igniters may be considered at a later date for use in Sequoyah unit 2 or Watts Bar.

Two other potential candidates, both coil heaters, were rejected

after the first one, a large diameter (1-1/2" I.D.) coil, could not reach sufficient surface temperature, and the second one failed at the connector in less than five minutes. Therefore, testing was restricted to diesel engine glow plugs, since they were known to be capable of achieving the 1500^oF minimum surface temperature desired by TVA and because of their rugged design.

TVA determined that at 12 volts ac, acceptable surface temperatures could be achieved but that considering line losses, variances in system voltages, possible plug cooling due to high humidity, and other effects, TVA would need to operate the plugs at 13 volts ac \pm 1 volt.

Since the possibility existed that TVA could overstress the plugs by overvoltage, TVA consulted glow plug manufacturers and identified two types of failure modes which could be expected. The first type of failure caused by overstressing would be the failure of the heater wire within the glow plug sheath. This type of failure due to the breaking of the circuit would outwardly cause the plug to discontinue glowing. The second type of failure caused by overstressing would involve offgassing of the glow plug tip. Unlike the first type of failure after offgassing, the glow plug may continue to glow; however, the surface temperature would drop significantly.

3.0 Description of Glow Plugs

Glow plugs manufactured by three different companies have been

levels both on the primary and secondary side and at the plug were measured by a digital voltmeter (Fluke model number 8024A), and the current levels were measured by an amp meter (Triplett model number 10 type 2). The surface temperature of each of the glow plugs was measured by either a thermocouple (type S) connected to a potentiometer (Leeds and Northrop model number 8690-2) in contact with the surface of the plug or by an optical pyrometer (Pyro model number 85). A total of 12 plugs have been tested to date.

4.2 Surface Temperature

A GMAC model 7G plug was operated at 12, 14, and 16 volts ac. Surface temperatures as measured by the thermocouple were 1480, 1550, and 1650^oF, respectively. Since the thermocouple would be expected to increase local heat loss and hence reduce the measured local surface temperature of the thin-walled plug sheath, these values were probably somewhat lower than actual surface temperatures. This conclusion was supported by later readings with the pyrometer while testing another GMAC model 7G at 14 volts ac and getting 1720 \pm 15^oF.

A Bosch plug has been tested at 13 volts ac. It produced a surface temperature of 1700^oF as measured by an optical pyrometer. Based on these results, TVA concluded that the diesel glow plugs could produce the desired surface temperatures.

4.3 Voltage Tests

Voltage tests have been completed on only the GMAC model 7G plugs. Based on tests on 5 GMAC 7G plugs, reliable operation at 14 volts was confirmed by two other 7G plugs failed at 16 volts ac after a few minutes.

Inconclusive testing on 2 Bosch plugs resulted in failure when operated at 14 volts ac; however, one Bosch plug operated satisfactorily at 13 volts ac. One Isusi plug was tested at 14 volts ac but lasted for only 30 minutes.

4.4 Extended Operation

Endurance tests have been performed on only two plugs for extended periods of time. A GMAC model 7G plug was operated continuously for 148 hours without failure and was later used in the hydrogen burning tests. A Bosch 10.5 volt plug was operated at 13 volts for 90 hours, then cooled down for two hours and turned back on. It has been running continuously after being reenergized since August 20, 1980, at 10 a.m.

5.0 Hydrogen Testing

One igniter (AC 7G) was installed in a "PARR" (229HC6-T316-031579-

5142) pressure vessel in order to determine feasibility of igniting hydrogen in a sealed container. The vessel lid has a silicone rubber sealed gas injection sampling port. Hydrogen concentrations in the vapor phase were determined before and after ignition intervals. An ignition interval is the time current flows through the igniter circuit. The hydrogen was measured by a Perkin-Elmer gas chromatograph equipped with 3920 thermal conductivity detector and an M-2 integrator. The chromatograph was standardized with hydrogen and air mixtures prepared from research grade hydrogen and laboratory air.

Temperature measurements were made with a mercury and glass (484635, ASTM 9C) thermometer. Temperatures reported are ambient for tests 1 through 3. Prior to tests 4-10, 100 grams of water was added to the vessel. The vessel was heated by a temperature adjustable hot plate to saturation temperature of the water and maintained throughout the test. The reported temperature is the water temperature after completion of the test. Results of the 10 ignition tests are given in table 1.

6.0 Future Tests at Fenwall Laboratories

TVA and Westinghouse have contracted with Fenwall Laboratories to perform hydrogen burn testing on the AC igniter and its mounting enclosure in an enclosed vessel. Attachment 1 is the proposed Test Plan for the testing. The final test plan is being prepared by Fenwall and should be available in the near future. These tests are designed to prove the effectiveness of this

igniter assembly to burn a volumetric quantity of hydrogen in environmental conditions which approximate postulated accident conditions inside containment.

7.0 Conclusions and Summary

The purpose of these tests at Singleton was to select a commercially available igniter that was capable of igniting hydrogen. From the results obtained, the GMAC model 7G glow plug produces more than adequate temperatures at a range of voltages that can be provided inside the Sequoyah containment.

In addition, the plug seems capable of extended operation at high temperatures and has been shown in small tests to be able to ignite 12 percent and lower volumetric quantities of hydrogen. Although it has not been tested as thoroughly, the Bosch plug appears like it may also be an optional igniter.

TABLE 1
HYROGEN IGNITION TESTS

<u>Test No.</u>	<u>Vessel Contents</u>	<u>Temp. (°F)</u>	<u>Initial Hyd. Conc. (% Hyd.)</u>	<u>Final Hyd. Conc. (% Hyd.)</u>	<u>Ignition Intervals (Min.)</u>
1	Hyd., Air	90	12.5	0.1	5
2		80	7	0.1	5
3		80	3.5	0.1	5
4	Hyd. Air, Water	120	12	0.1	3
5		180	14	0.5	3
6		180	4	2.5	1
7		180	2.5	1.5	1
8		180	1.5	1.3	1
9		180	11	5	1
10		180	5	2	1.3

Vessel Volume 1.1 dm³ (0.039 ft³)

Operating Voltage 12V dc

E50239.07

ATTACHMENT 1

SUMMARY

SEQUOYAH PLANT

HYDROGEN IGNITER TEST PLAN

1. Introduction

The following describes tests to be conducted on a type of hydrogen igniter to be installed in the Sequoyah Nuclear Plant. The igniter consists of a "glow plug" as used in diesel engines, the surface of which exceeds 1500° F and serves as a hot surface to initiate hydrogen burning, and a power transformer and an enclosure for the unit. The function of the igniters in the nuclear power plant containment is to burn hydrogen, in accidents where it could be released, when it reaches a burnable concentration thereby precluding its buildup to high concentration levels. The tests will be conducted by Fenwall, Incorporated, at their facilities in Ashland, Massachusetts. The unit, consisting of glow plug and enclosed transformer, will be placed in a test vessel and subjected to a range of environmental conditions (including hydrogen concentration, temperature, pressure, and steam), and its hydrogen ignition performance monitored.

1.1 Purpose of Tests

The primary purpose of the tests is to demonstrate that the igniter will initiate a volumetric burn of the hydrogen for the specified environmental conditions (pressure, temperature, water vapor). A secondary objective of the tests is to narrow down the hydrogen concentration range for which a volumetric burn of hydrogen will be initiated.

1.2 Acceptance Criteria

For the initial set of tests, the following acceptance criteria will be used:

1. Data generated are internally consistent (i.e., ignition at 8% consistently produces low pressure rise).
2. Data gathered confirm theoretical predictions.
3. Igniters reliably ignite mixtures at high (12%) concentration and provide relatively complete combustion.

2. Description of Igniter

The igniter is a General Motors Ac Division Model 7G glow plug

(thermal resistive heating element) requiring 14V ac supply at a maximum of 8-1/2 amps. The surface temperature of the plug as measured by an optical pyrometer should be a minimum of 1500° F. TVA has measured 1720° F surface temperature on one of the glow plugs at their facilities. The igniter is powered by 120V ac stepped down to 14V ac. The power transformer is a Dongan Electric, Incorporated, Model 52-20-187 specially wound transformer having the following characteristics:

120V	RMS	AC	on primary side
14V	RMS	AC	on secondary side
200V	A	Min.	

Class H (High temperature insulation)

Open style with 18" flexible leads

Certified capability that transformer will operate at 220° C.

The igniter and transformer are mounted as a unit as shown in Figure 1 with the glow plug extending from the side. The unit is encased in a 1/8-inch steel plate box type casing and sealed with a rubber seal for water tightness.

3. Description of Test Facility

The tests will be conducted by Fenwall, Incorporated, at their facilities in Ashland, Massachusetts.

3.1 Test Vessel

The igniter unit will be tested in a spherical vessel in excess of six feet in diameter. The internal volume of the test vessel is 1000 gallons (134 ft³). The vessel is constructed of carbon steel (exterior) and is lined with stainless steel. The vessel is designed for a working pressure of 500 lb/ft². The vessel is equipped with five diameter access ports (four on circumference, 90° apart,

and fifth at the top), one of which is drilled to attach to a manifold with valves and connecting lines to air, steam, and hydrogen makeup sources.

The vessel is heated externally via electrical heaters. The vessel will be equipped internally with a fan to promote mixing and also to create a draft at the igniter heating surface during testing when desired.

3.2 Instrumentation and Measurements

The vessel is instrumented with two pressure transducers to monitor the pressure including the pressure transient during the hydrogen burn. The output is carrier amplified and feeds to an oscillograph device. Thermocouples are provided which will monitor vessel atmosphere temperature prior to and after a burn. In addition, a thermocouple will be used to measure the temperature of its heated

surface. Gas mixtures will be formed using pressure instrumentation and a partial pressure method in which a given gas is added until the appropriate partial pressure is indicated. Sampling capability exists via a 1-inch by 1-foot lecture bottle. Hydrogen and oxygen analyzers will be provided to measure pre- and post-burn concentrations of these gases:

	<u>O₂ Analyzer</u>	<u>H₂ Analyzer</u>
Manufacturer	Hays Republic	Hays Republic
Model	A 00632	SH-A-00643D
Range	0-5%/0-20%	0-5%/0-20%
Accuracy	± 1% F.S.	± 2% F.S.

4. Test Plan

4.1 Identification of Tests

The unit consisting of the glow plug and encased transformer will be positioned in the test vessel (via 18-inch port) with the glow plug heating surface located near the center of the test vessel. Various mixtures of H₂, steam, and air will be adjusted with pressure and temperature as specified and then the igniter turned on. The pressure transient will be recorded and the mixture analyzed for H₂ and O₂ content prior to and after the burn. The test matrix for the first series of 12 tests is shown in Table 1. Initial total pressures of 15, 21, and 27 lb/ft² will be covered at hydrogen concentrations of 8 and 12-volume percent. Initial temperature will vary from 180° F (dry case) to 350° F (superheated steam) with most of the tests being conducted at saturation temperature corresponding to the pressure to be tested. In addition, a fan will be located in the test vessel to provide drafts of 5 and 10 FPS in the vicinity of the glow plug to simulate turbulence which may be developed in the vicinity of the igniters.

Further testing will be developed based on the outcome of test series #1, and may include addition of an instrumented transmitter and steel or concrete surfaces with thermocouples attached to measure temperature response on hydrogen burn. In addition, means to simulate spray droplet entrainment in the atmosphere are under investigation.

4.2 Test Procedure

The basic procedure is to adjust mixture concentration temperature and pressure, then energize glow plug and record the pressure and temperature transient. Hydrogen concentration after the burn will be measured to assess completeness of burn. The steps for the different tests are as indicated in Table 2. In one of the tests with a steam environment, the glow plug will be energized after the steam, pressure, and temperature environment conditions

are reached, but before hydrogen is added, and allowed to stand for two hours. Then the glow plug will be deenergized, hydrogen adjusted, and then the glow plug energized. The purpose of this is to allow for preburn exposure to the environment.

4.3 Test Schedule

The test schedule is tentatively planned as follows:

Facility Preparation	8/18 through 8/29
Test Series No. 1	9/1 through 9/5
Subsequent Tests	9/8 through 9/12
Test Evaluation	9/15 through 9/19

DE01;SQNHVD.AA

TABLE 1

TEST SERIES NO. 1

<u>Test</u>	<u>Temp (°F)</u>	<u>Total Pressure* (Gauge)</u>	<u>Hydrogen Concentration (Volume Percentage)</u>	<u>Fan Induced Flow Speed (fps)</u>
1	180	0	12	0
2	180	0	8	0
3	Sat temp	6	12	0
4	Sat temp	6	8	0
5	Sat temp	12	12	0
6	Sat temp	12	8	0
7	Sat temp	6	12	5
8	Sat temp	6	8	5
9	Sat temp	6	8	10
10	Sat temp	6	12	10
11	350	12	12	0
12	350	12	12	10

*This is the total pressure due to air, hydrogen, and steam. For tests 1 and 2, the pressure will be higher than 0 due to the added hydrogen partial pressure and the evaluated temperature.

PROPERTIES OF HALON 1301

- o LOW BOILING POINT (-72°F)
- o LOW TOXICITY (UL GROUP 6)
- o INSOLUBLE IN WATER (0.0095 W/O)
- o INERT
- o LOW RADIOLYTIC DECOMPOSITION
(0.00023 g/d/R/h)
- o NO LONG TERM ACTIVE MIXING REQUIRED
AFTER INJECTION

SUITABILITY OF HALON 1301

- o PREVENTS HYDROGEN IGNITION AT SUFFICIENT CONCENTRATIONS.

- o ATLANTIC RESEARCH CORPORATION REPORT SHOWED HALON 1301 SUITABLE FOR USE IN A MARITIME REACTOR CONTAINMENT.

- o INITIAL STUDY BY ARC FOR AEP/DUKE/TVA INDICATES HALON 1301 SUITABLE FOR USE IN ICE CONDENSER CONTAINMENT.

AREAS OF FURTHER STUDY BY ARC FOR AEP/DUKE/TVA
ON HALON 1301

- o EFFECT OF HALON 1301 AND ITS DECOMPOSITION PRODUCTS ON CONTAINMENT MATERIALS
- o TEMPERATURE AND PRESSURE EFFECTS ON CONTAINMENT DUE TO INADVERTENT ACTUATION
- o POTENTIAL PROBLEMS ON LONG TERM ACCIDENT RECOVERY
- o EFFECT OF HIGH CORE TEMPERATURES ON HALON 1301 DECOMPOSITION
- o POTENTIAL FOR NON-INERTED HYDROGEN POCKET DETONATION TO INITIATE COMBUSTION IN INERTED MIXTURES
- o PERSONNEL HAZARD DUE TO INADVERTENT OPERATION
- o SYSTEM DESIGN AND INCORPORATION

Degraded Core

- o TVA is following the state-of-the-art developments at national laboratories (Battelle, Columbus, Brookhaven, Oak Ridge), AIF, EPRI, etc.
- o TVA is building the capability to use MARCH as a starting point.
- o MARCH is not intended for design.
- o TVA has set a goal to obtain a hydrogen generation rate curve (into the containment) for a fair range of core damage accidents.

STATEMENT IN RESPONSE TO QUESTION -

DO ICE CONDENSERS NEED ADDITIONAL HYDROGEN MITIGATION SYSTEMS?

The nuclear power industry and NRC have identified many lessons in the TMI-2 event. As a result of studies by the staff, the Kemeny Commission, consultants, ACRS, and others, including TVA's own Nuclear Program Review, a large number of changes have been identified. Some were implemented almost immediately, some are in various stages of implementation, and others are the subject of intensive study or planned rulemaking. The issue of the effects of hydrogen generation from degraded cores was considered by many, including TVA, as one of the more important raised.

We are addressing all of our containment designs; while the lower design pressure is a disadvantage for this issue, the ice condenser containment also has definite advantages, including a large, passive heat removal capability.

As a result of its Nuclear Program Review, TVA committed to:

Study ways to contain larger amounts of hydrogen and to backfit feasible features into the Sequoyah design. (TVA Nuclear Program

Review: Sequoyah Nuclear Plant and the report of the President's Commission on the accident at Three Mile Island, November 1979.)

TVA moved immediately to fulfill that commitment by committing significant resources to the issue. That effort continues and at this point has resulted in a significant study of degraded core accidents and their mitigation, in a long range plan to further study and act on the recommendations of that study, and in installation of an interim distributed ignition system. We feel that the steps taken and planned to reduce the likelihood and minimize the extent of core damage events, when coupled with the plants' inherent capability to withstand substantial core damage (about 25% metal-water reaction), would provide a sufficient degree of safety for the short term until TVA's and others' studies could be completed. However, since TVA is committed to make feasible improvements in the safety of our plants, we proceeded to install the interim distributed ignition system once we were convinced that it would not reduce plant safety and had the promise of increasing the amount of metal-water reduction that the plant could withstand. Our efforts are being placed on determining how much increase in capability the interim system affords and on our long term program which addresses other alternative measures in addition to controlled ignition.

TVA believes: that Sequoyah can be safely operated at least in the short term until our studies can be completed; that the plant already has significant capabilities to withstand a range of core damage

events; and that the interim distributed ignition system increases this range of capability. We are firmly committed by policy, by staff opinion, and by actual work to take the lead on this safety issue.

E50238.02

TVA IGNITOR TEST FACILITY GROOMING STARTED

H ₂ %	IGNITION (SEC)	PEAK PRESSURE PSIG
8	17	3.2
9	16	4.1
10*	16	5.0
12	15	6.7

*2 TESTS

INITIAL TESTS AIMED AT ESTABLISHING IGNITOR PERFORMANCE

CONCENTRATIONS FOR COMPLETE AND LOW PRESSURE CONVERSIONS

100% HUMIDITY CONDITIONS

STATIC AND FLOWING GAS STREAMS

VARYING PRESSURES

LATER TESTS SCHEDULED FOR FURTHER PERFORMANCE CONFIRMATION

ADDITIONAL H_2 CONCENTRATIONS

MULTIPLE BURN IN TRANSIENT CONCENTRATIONS

SPRAY EFFECTS

AFTER FIVE BURNS, UNSEALED IGNITOR CONTINUES TO PERFORM

NO MAJOR EXTERNAL DAMAGE SIGNS

INDICATIONS OF MINOR PENETRATION WITHOUT
APPARENT PERFORMANCE EFFECT