Telephone 617 366-9011

TWX 710-390-0739

YANKEE ATOMIC ELECTRIC COMPANY

B.4.1.1 WYR 80-91



20 Turnpike Road Westborough, Massachusetts 01581

July 29, 1980

United States Nuclear Regulatory Commission Office of Inspection and Enforcement Region I 631 Park Avenue King of Prussia, Pennsylvania 19406

Attention:

Mr. Boyce H. Grier, Director

Office of Inspection and Enforcement

References:

(a) License No. DPR-3 (Docket No. 50-29)

(b) USNRC Letter to YAEC dated June 27, 1980

Dear Sir:

Subject:

Response to IE Bulletin 80-16 - Rosemount Model 1151 and 1152

Pressure Transmitters

We have determined that the subject pressure transmitters with output codes "A" or "D" are installed in safety related applications at Yankee Rowe. However, we have also determined that these transmitters, or those that are planned for installation, would not be exposed to input pressures that could result in anomalous signals during normal operation, anticipated transients, or design accidents; therefore, no further action is necessary.

The following information is submitted in response to your request for estimates of manpower expended in the research and subsequent performance of actions associated with this letter/bulletin/document:

Manpower Requirements	Hours
Bulletin Response	80
Corrective Actions	None required

It should be clearly understood that this information is not adequate to enable a value/impact assessment. The cost of equipment, the cost of additional resources to perform additional work, and cost of installation are also necessary. In addition, an adequate determination of the safety improvement as a result of this document needs to be included.

Mr. Boyce H. Grier, Director Office of Inspection and Enforcement July 29, 1980 Page 2

If you have any questions or desire additional information, please contact us.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY

D. E. Moody

Manager of Operations

JAK/dis