



*ms*  
Jersey Central Power & Light Company  
Madison Avenue at Punch Bowl Road  
Morristown, New Jersey 07960  
(201) 455-8200

August 13, 1980


Mr. Boyce H. Grier, Director  
Office of Inspection and Enforcement  
Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

Subject: Oyster Creek Nuclear Generating Station  
Docket No. 50-219  
I E Bulletin No. 80-19

I E Bulletin 80-19 pertains to the use of "Mercury Wetted Matrix Relays in Reactor Protection Systems" at operating nuclear plants. The Oyster Creek Nuclear Station does not utilize mercury wetted relays either in the reactor protection or any safety related equipment. Therefore, the referenced bulletin does not apply to Oyster Creek.

A total of 12 man-hours were expended to review plant systems and prepare this response. Since no corrective action is required there will be no additional time expended.

  
Ivan R. Finfrock, Jr.  
Vice President Generation

IRF:WB:dh  
cc: NRC Office of Inspection & Enforcement  
Division of Reactor Operations Inspection  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8049090031