U. S. NUCLEAR REGULATORY COMMISSION NRC FORM 366 (7-77) LICENSEE EVENT REPORT (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) CONTROL BLOCK: 10 3 4 1 1 1 1 1 1 36 LICENSE TYPE JO 120000000000000 0 F F C S 1 LICENSE NUMBER CONT 10 10 10 12 18 15 0 10 18 10 14 18 10 18 10 18 12 5 18 10 9 REPORT 6 0 5 IL 0 1 SOURCE EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10 During normal power operation, it was discovered by Operations personnel that the 0 2 setpoint selector switches for RMO-61, stack particulate radiation monitor, were 0 3 set in the higher of the two setpoint positions. This position is normally used 0 4 when temperature inversions exist. At the time of finding the switches in the 0 5 wrong position, an inversion did not exist. Tech. Spec. 5.9.2(3) applies. 0 6 0 7 COMP SYSTEM CAUSE VALVE CAUSE SUBCODE CODE ZI Z D 7 (16 0 9 REVISION OCCURRENCE SEQUENTIAL REPOR CODE NO. REPORT NO LER RO REPORT 0 13 0 7 11 0 0 NUMBER 32 COMPONENT SUPPLIER NPRO-4 SUBMITTED SHUTDOW (22 HOURS FORMSUB ON PLANT 19 19 19 N 24 Y 23 0 Z 26 010101 Z 1(2 (25 Z (19) Z (20) G (18) CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The setpoint selector switches were immediately set to the proper position and the 0 recorder chart was read to insure Technical Specification limits had not been exceeded. The switches were left in the wrong position as a result of performing a routine surveillance test on the radiation monitors. 2 1 4 80 METHOD OF FACILITY (30) DISCOVERY DESCRIPTION (32 OTHER STATUS % POWER Operator Observation A (31 NA 1101 0 29 (28 80 LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY (35 EASED NA NA (33) (34) 6 80 PERSONNEL EXPOSURES DESCRIPTION (39 TYPE UMBER NA 0 0 0 38 80 PERSONNEL INJURIES DESCRIPTION (41 MBER NA 010 (40) 80 OSS OF OR DAMAGE TO FACILITY (43) DESCRIPTION 120 NA (42) 80 PUBLICITY NAC USE ONLY DESCRIPTION 45 1(44 NA N NOT 58 69 30 402-426-401 M. R. Core PHONE NAME OF PREPARER. 8009090 536

LER No. 80-017 Omaha Public Power District Fort Calhoun Station Unit No. 1 Docket No. 05000285

#### ATTACHMENT NO. 1

### Safety Analysis

RMO-61, stack particulate radiation monitor, has dual setpoints for both alert and alarm. The higher set of setpoints is used when a temperature inversion exists to account for increased background radiation due to increased radon activity. Radon is naturally occurring radiation, emitted from the earth's surface. When a temperature inversion exists radon, normally released by the earth to the upper atmosphere, is trapped near the earth's surface. Due to the trapping action of the inversion, background activity can go as high as 2020 CPM, (rather than the normal 60 CPM) thus causing the need for higher setpoints than those used in a non-temperature inversion climate. With the selector switches set in the high setpoint position, Technical Specifications limits could have been violated if the conditions were normal background and normal line up of the ventilation system. However, a review of the recorder chart for the time the switches were inadvertantly left in the high position revealed that the release rate did not exceed the rate allowed by the lower settings. Additionally, Technical Specification limits are significantly lower than the limit imposed by 10CFR20. The limits of 10CFR 20 could not have been violated in either switch position.

NOT

LER No. 80-017 Omaha Public Power District Fort Calhoun Station Unit No. 1 Docket No. 05000285

ATTACHMENT NO. 2

#### Corrective Action

 $\mathbb{C}$ 

4 \* \* \* \*

. \*

180 x 200

The setpoint selector switches were inadvertantly left in the incorrect position after the performance of ST-RM-2, F.2, Process Monitor Checks surveillance test. The test has been revised with a sign-off to indicate that the switches have been returned to the proper position in accordance with the presence of a temperature inversion. No further corrective action is anticipated.

int

LER No. 80-017 Omaha Public Power District Fort Calhoun Station Unit No. 1 Docket No. 05000285

## ATTACHMENT NO. 3

# Failure Data

 $\mathbf{C}$ 

2

. . .

18.00 \*

18 B

3

This is the first reportable occurance of its kind at Fort Calhoun Station.

wyz

0

. .