

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A | R | A | N | O | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 | REPORT SOURCE | L | 0 | 1 | 5 | 0 | 1 | 0 | 0 | 3 | 1 | 1 | 3 | 7 | 0 | 1 | 4 | 1 | 0 | 1 | 1 | 8 | 1 | 0 | 8 | 1 | 0 | 1 | 3 | 1 | 8 | 1 | 0 | 9
7 8 60 61 66 68 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 Based on piping system as-built configuration review as required by
03 I.E. Bulletin 79-14, the attached list of 21 hangers were declared
04 inoperable. System redundancy was maintained in every case.. A
05 hanger design change was immediately prepared to upgrade the affected
06 hanger to meet design requirements. LER's 50-313/79-010 & 80-10
07 were similar occurrences. Reportable per T.S 6.12.3.2(b).
08

09 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. NUMBER | VALVE SURCODE
L | X | X | B | A | S | U | I | P | O | R | I | T | X | Z
9 10 11 12 13 14 15 16 17 18 19 20
17 | LER/NO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
18 | 18 | 80 | 0111 | 013 | | 5
21 22 23 24 25 26 27 28 29 30 31 32
18 | X | Z | Z | 0 | 0 | 0 | 0 | Y | Y | A | B | I | 1 | 3 | 0 | 26
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 The affected hangers were repaired or modified within the time frame
11 allowed by Tech. Spec. All design changes were governed by DCP 80-1007
12 and its amendments. The affected systems were Service Water (WA),
13 Main Steam (cc), Decay Heat (CF), Makeup (PC), Emergency Feed Water (WB)
14 & Rx. Bldg. Spray (SB). This review is continuing.

15 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
E | 100 | NA | D | Notification from A/E
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
16 | ACTIVITY CONTENT RELEASED OF RELEASE | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
Z | Z | NA | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
17 | PERSONNEL EXPOSURES NUMBER | TYPE | DESCRIPTION
0 | 0 | 0 | Z | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
18 | PERSONNEL INJURIES NUMBER | DESCRIPTION
0 | 0 | 0 | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
19 | LOSS OF OR DAMAGE TO FACILITY TYPE | DESCRIPTION
Z | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
20 | PUBLICITY ISSUED | DESCRIPTION
N | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER: L. S. Bramlett
PHONE: 501/968-2519
5009080 568

Hanger Number

System

HBD-14-H35	Service Water
HBD-14-SW20	Service Water
MS-175	Main Steam
HBD-20-H15	Service Water
HBD-14-H2	Service Water
MS-156	Main Steam
GCB-1-141	Decay Heat
DH-100	Decay Heat
DH-95B	Decay Heat
DH-148	Decay Heat
DH-146	Decay Heat
DH-F-1	Decay Heat
DH-F-8	Decay Heat
MU-219	Makeup
HBD-2-H2	Service Water
HBD-4-H17	Emergency FW
EFW-53	Emergency FW
HBD-20-H47	Service Water
SW-4	Service Water
HBD-20-H57	Service Water
HCB-6-SK-A	R. B. Spray

