


VIRGINIA ELECTRIC AND POWER COMPANY

NORTH ANNA POWER STATION

MONTHLY OPERATING REPORT

MONTH August YEAR 1980

APPROVED:



STATION MANAGER

8009290 321

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-338

UNIT NA 1

DATE 9-9-80

COMPLETED BY W. A. Woodsmall, III

TELEPHONE (703) 894-5151

MONTH August

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>809</u>
2	<u>810</u>
3	<u>808</u>
4	<u>808</u>
5	<u>808</u>
6	<u>807</u>
7	<u>807</u>
8	<u>807</u>
9	<u>809</u>
10	<u>744</u>
11	<u>832</u>
12	<u>831</u>
13	<u>830</u>
14	<u>809</u>
15	<u>834</u>
16	<u>830</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>631</u>
18	<u>833</u>
19	<u>838</u>
20	<u>838</u>
21	<u>838</u>
22	<u>838</u>
23	<u>836</u>
24	<u>828</u>
25	<u>820</u>
26	<u>810</u>
27	<u>835</u>
28	<u>841</u>
29	<u>835</u>
30	<u>829</u>
31	<u>837</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

OPERATING DATA REPORT

DOCKET NO. 50-338
 DATE 09-09-80
 COMPLETED BY W.A.Woodsmall, III
 TELEPHONE 703/894-5151

OPERATING STATUS

1. Unit Name: North Anna 1
2. Reporting Period: August 1980
3. Licensed Thermal Power (MWt): 2775
4. Nameplate Rating (Gross MWe): 947
5. Design Electrical Rating (Net MWe): 907
6. Maximum Dependable Capacity (Gross MWe): 880
7. Maximum Dependable Capacity (Net MWe): 850
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
N/A

Notes

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>5,855</u>	<u>19,632</u>
12. Number Of Hours Reactor Was Critical	<u>744</u>	<u>4,979.8</u>	<u>15,145.0</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>55.6</u>	<u>203.9</u>
14. Hours Generator On-Line	<u>744</u>	<u>4,780.7</u>	<u>14,833.9</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2,037,456</u>	<u>12,158,081</u>	<u>38,437,994</u>
17. Gross Electrical Energy Generated (MWH)	<u>648,429</u>	<u>3,806,398</u>	<u>12,152,747</u>
18. Net Electrical Energy Generated (MWH)	<u>611,343</u>	<u>3,577,404</u>	<u>11,430,850</u>
19. Unit Service Factor	<u>100</u>	<u>81.6</u>	<u>75.5</u>
20. Unit Availability Factor	<u>100</u>	<u>81.6</u>	<u>75.5</u>
21. Unit Capacity Factor (Using MDC Net)	<u>96.7</u>	<u>71.9</u>	<u>68.5</u>
22. Unit Capacity Factor (Using DER Net)	<u>90.6</u>	<u>67.4</u>	<u>64.2</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>11.3</u>	<u>6.8</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Refueling-six weeks: December 1980 and January 1981

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A

26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

Forecast	Achieved
_____	_____
_____	_____
_____	_____

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH August 1980

DOCKET NO. 80-338
 UNIT NAME North Anna 1
 DATE 9-9-80
 COMPLETED BY Neufer
 TELEPHONE (703) 894-5151 ext. 22

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
No significant power reductions or plant shutdown's.									

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A Equipment Failure (Explain)
 B Maintenance or Test
 C Refueling
 D Regulatory Restriction
 E Operator Training & License Examination
 F Administrative
 G Operational Error (Explain)
 H Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

⁵
 Exhibit I - Same Source

OPERATING DATA REPORT

DOCKET NO. 50-339
 DATE 9-9-80
 COMPLETED BY W. A. Woodsmall, III
 TELEPHONE (703) 894-5151

OPERATING STATUS

1. Unit Name: North Anna 2
2. Reporting Period: August 1980
3. Licensed Thermal Power (MWt): 2775
4. Nameplate Rating (Gross MWe): 947
5. Design Electrical Rating (Net MWe): 907
6. Maximum Dependable Capacity (Gross MWe): 928
7. Maximum Dependable Capacity (Net MWe): 898
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
Item 3 changed from 139 to 2775 by Full Power License dated 8-21-80.
9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

Notes

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>1,208</u>	<u>1,208</u>
12. Number Of Hours Reactor Was Critical	<u>225.8</u>	<u>736.4</u>	<u>736.4</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>55</u>	<u>55</u>	<u>55</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>39,455</u>	<u>43,817</u>	<u>43,817</u>
17. Gross Electrical Energy Generated (MWH)	<u>8,174</u>	<u>8,174</u>	<u>8,174</u>
18. Net Electrical Energy Generated (MWH)	<u>6,562</u>	<u>6,562</u>	<u>6,562</u>
19. Unit Service Factor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
20. Unit Availability Factor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
21. Unit Capacity Factor (Using MDC Net)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
22. Unit Capacity Factor (Using DER Net)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
23. Unit Forced Outage Rate	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>TMI Modifications: November 1, 1980: 11 days</u> <u>Maintenance: April 1, 1981: 11 days</u>			
25. If Shut Down At End Of Report Period, Estimated Date of Startup:	<u>09-4-80</u>		
26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved	

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

6/12/80
8/25/80
11/15/80

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-339

UNIT NA 2

DATE 9-9-80

COMPLETED BY W. A. Woodsmall, III

TELEPHONE (703) 894-5151

MONTH August

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>28</u>
26	<u>14</u>
27	<u>102</u>
28	<u>128</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH August

DOCKET NO. 50-339
 UNIT NAME North Anna 2
 DATE 09-09-80
 COMPLETED BY A.G. Neufer
 TELEPHONE 703/894-5151

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
Initial Power Generation begins 08-25-80 at 0547. (Not commercial)									
80-01	80-08-26	F	18.1	H*	3				Turbine trip/ Reactor trip when generator breaker was opened. Placed recorders on Reactor Protection Circuits to trace cause.
80-02	80-08-27	F	2.4	H*	3				Turbine Trip/Reactor Trip when Overspeed Protection Controller was activated during test.
80-03	80-08-28	F	2.0	A*	3				Steam Generator Lo Level Reactor Trip caused by loss of Feedwater Flow when Condensate Pump Suction Strainers were clogged up. Cleaned strainers.
80-04	80-08-23	F	79.5	D	1	80-051/03L-0	HH	VALVEX	Unit Shutdown to comply with Technical Specifications TS. 3.6.3.1 Feedwater/Containment Penetration Isolation.

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

5
 Exhibit I - Same Source

(9/77)

-See Attached Sheet

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH August

DOCKET NO. 50-339
 UNIT NAME North Anna 2
 DATE 09-09-80
 COMPLETED BY A.G. Neuffer
 TELEPHONE 703/894-5151

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
80-04 Shut Down		F		Continues through	end of month.				

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

⁵
 Exhibit I - Same Source

UNIT SHUTDOWN AND POWER REDUCTIONS

EXPLANATION SHEET

DOCKET NO. 50-339REPORT MONTH AugustUNIT NAME North Anna 2YEAR 1980DATE 09-09-80COMPLETED BY A. G. Neufer

- 80-01 Unit was being removed from service for a scheduled turbine overspeed test. When the last generator output breaker was opened, the turbine and reactor tripped. An improperly set transmitter PT-MS-232 caused turbine valves to pulse open raising the 1st stage press to greater than 10% (turbine power greater than 10% with generator output breakers open causes a turbine trip) resulting in a turbine trip and reactor trip.
- 80-02 When the Overspeed Protection Controller pulsed during the planned overspeed test it caused First Stage Impulse Pressure to go greater than 10% inducing a signal to reinstate the at-power trips.
- 80-03 Condensate Pump Suction Strainers clogged up causing a loss of Feedwater Flow.