

ATTACHMENT 3

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2
PROPOSED REVISIONS TO TECHNICAL SPECIFICATIONS
TMI-RELATED REQUIREMENTS

SEPTEMBER, 1980

1009290372

INDEXLIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.2 POWER DISTRIBUTION LIMITS</u>	
3/4.2.1 LINEAR HEAT RATE.....	3/4 2-1
3/4.2.2 TOTAL PLANAR RADIAL PEAKING FACTOR - F_{xy}^T	3/4 2-6
3/4.2.3 TOTAL INTEGRATED RADIAL PEAKING FACTOR - F_r^T	3/4 2-9
3/4.2.4 AZIMUTHAL POWER TILT.....	3/4 2-10
3/4.2.5 FUEL RESIDENCE TIME.....	3/4 2-12
3/4.2.6 DNB MARGIN.....	3/4 2-13
<u>3/4.3 INSTRUMENTATION</u>	
3/4.3.1 REACTOR PROTECTIVE INSTRUMENTATION.....	3/4 3-1
3/4.3.2 ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION.....	3/4 3-10
3/4.3.3 MONITORING INSTRUMENTATION.....	3/4 3-26
Radiation Monitoring.....	3/4 3-26
Incore Detectors.....	3/4 3-30
Seismic Instrumentation.....	3/4 3-32
Meteorological Instrumentation.....	3/4 3-36
Remote Shutdown Instrumentation.....	3/4 3-39
Chlorine Detection Systems.....	3/4 3-42
Fire Detection Instrumentation.....	3/4 3-43
<u>3/4.4 REACTOR COOLANT SYSTEM</u>	
3/4.4.1 REACTOR COOLANT LOOPS.....	3/4 4-1
3/4.4.2 SAFETY VALVES - SHUTDOWN.....	3/4 4-2
3/4.4.3 RELIEF SYSTEM - OPERATING.....	3/4 4-3
3/4.4.3 SAFETY VALVES - OPERATING.....	3/4 4-3
3/4.4.3 RELIEF VALVES - OPERATING.....	3/4 4-3a

REACTOR COOLANT SYSTEM

3/4.4.3 RELIEF SYSTEM

SAFETY VALVES - OPERATING

LIMITING CONDITION FOR OPERATION

3.4.3.1 All pressurizer code safety valves shall be OPERABLE with a lift setting of 2500 PSIA \pm 1%.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

With one pressurizer code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 15 minutes or be in HOT SHUTDOWN within 12 hours.

ch. 3

SURVEILLANCE REQUIREMENTS

4.4.3.1 Each pressurizer code safety valve shall be demonstrated OPERABLE with a lift setting of 2500 PSIA \pm 1%, in accordance with Subsection IWV-3510 of Section XI of the ASME Boiler and Pressure Vessel Code, dated July 1, 1974.

POOR ORIGINAL