

REACTOR COOLANT SYSTEM

RELIEF VALVES - OPERATING

LIMITING CONDITION FOR OPERATION

3.4.3.2 Two power operated relief valves (PORVs) and their associated block valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With one or more PORV(s) inoperable, within 8 hours either restore the PORV(s) to OPERABLE status or close the associated block valve(s) and remove power from the block valve(s); otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 72 hours.
- b. With one or more block valve(s) inoperable, within 8 hours, either restore the block valve(s) to OPERABLE status or close the block valve(s) and remove power from the block valve(s); otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 72 hours.

SURVEILLANCE REQUIREMENTS

4.4.3.2.1 Each PORV shall be demonstrated OPERABLE:

- a. Once per 31 days by performance of a CHANNEL FUNCTIONAL TEST, excluding valve operation, and
- b. Once per 18 months by performance of a CHANNEL CALIBRATION.

4.4.3.2.2 Each block valve shall be demonstrated OPERABLE once per 92 days by operating the valve through one complete cycle of full travel.