

Y1003J01A09

June 1980

SUPPLEMENTAL RELOAD LICENSING SUBMITTAL  
FOR  
MILLSTONE UNIT 1  
RELOAD 7

---

NUCLEAR POWER SYSTEMS DIVISION • GENERAL ELECTRIC COMPANY  
SAN JOSE, CALIFORNIA 95125

GENERAL  ELECTRIC

8009300302

IMPORTANT NOTICE REGARDING  
CONTENTS OF THIS REPORT  
PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Northeast Utilities Service Company (NUSCo) for NUSCo's use with the U.S. Nuclear Regulatory Commission (USNRC) for amending NUSCo's operating license of the Millstone Nuclear Power Station. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained or provided to General Electric at the time this report was prepared.

The only undertakings of the General Electric Company respecting information in this document are contained in the contract between Northeast Utilities Service Company and General Electric Company for nuclear fuel and related services for the nuclear system for Millstone Nuclear Power Station, dated April 14, 1967, and nothing contained in this document shall be construed as changing said contract. The use of this information except as defined by said contract, or for any purpose other than that for which it is intended, is not authorized; and with respect to any such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy or usefulness of the information contained in this document or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.

## 1. PLANT-UNIQUE ITEMS (1.0)\*

## Appendix A: New Bundle Loading Error Event Analysis Procedures

## 2. RELOAD FUEL BUNDLES (1.0, 3.3.1 and 4.0)

<u>Fuel Type</u>	<u>Number</u>	<u>Number Drilled</u>
Irradiated 8DB262	20	0
Irradiated 8DB274L	120	0
Irradiated 8DB274H	124	0
Irradiated 8DRB265H	48	48
Irradiated 8DRB265L	100	100
New P8DRB265H	40	40
New P8DRB282	128	128
Total	580	316

## 3. REFERENCE CORE LOADING PATTERN (3.3.1)

Nominal previous cycle exposure: 17,131 MWd/t. Assumed reload cycle exposure: 17,889 MWd/t. Core loading pattern: Figure 1.

## 4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM WORTH - NO VOIDS, 20°C (3.3.2.1.1 and 3.3.2.1.2)

BOC $k_{eff}$	
Uncontrolled	1.120
Fully Controlled	0.960
Strongest Control Rod Out	0.989
R, Maximum Increase in Cold Core Reactivity with Exposure Into Cycle, $\Delta k$	0.0

\* ( ) refers to areas of discussion in General Electric Boiling Water Generic Reload Fuel Application", NEDE-24011-P-A-1, July 1979.

## 5. STANDBY LIQUID CONTROL SYSTEM SHUTDOWN CAPABILITY (3.3.2.1.3)

<u>ppm</u>	<u>Shutdown Margin (<math>\Delta k</math>) (20°C, Xenon Free)</u>
600	0.029

## 6. RELOAD-UNIQUE TRANSIENT ANALYSIS INPUTS (3.3.2.1.5 &amp; 5.2)

	<u>EOC8</u>	<u>EOC8-1800 MWd/t</u>
Void Coefficient N/A,* (c/% Rg)	-6.18/-7.72	-7.25/-9.07
Void Fraction (%)	36.85	36.85
Doppler Coefficient N/A (c/%°F)	-0.217/-0.206	-0.210/-0.199
Average Fuel Temperature (°F)	1217	1217
Scram Worth N/A (\$)	-37.79/-30.22	-35.72/-28.58
Scram Reactivity	Figure 2a	Figure 2b

## 7. RELOAD-UNIQUE GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS (5.2)

	<u>8x8/8x8R/P8x8R</u>	<u>8x8/8x8R/P8x8R</u>
	<u>EOC8</u>	<u>EOC8-1800 MWd/t</u>
Peaking factors (local, radial and axial)	1.22/1.20/1.20 1.56/1.68/1.66 1.40/1.40/1.40	1.22/1.20/1.20 1.65/1.77/1.75 1.40/1.40/1.40
R-Factor	1.094/1.051/1.051	1.094/1.051/1.051
Bundle Power (MWt)	5.304/5.674/5.606	5.582/6.004/5.930
Bundle Flow (10 <sup>3</sup> lb/hr)	101.8/99.9/100.2	100.0/97.8/98.2
Initial MCPR	1.37/1.37/1.39	1.29/1.29/1.31

## 8. SELECTED MARGIN IMPROVEMENT OPTIONS (5.2.2)

Exposure-dependent limits: 8OC8 to EOC8-1800 MWd/t  
EOC8-1800 MWd/t to EOC8

\*N = Nuclear Input Data  
A = Used in Transient Analysis

9. CORE-WIDE TRANSIENT ANALYSIS RESULTS (5.2.1)

Transient	Exposure	Power	Core Flow	$\hat{\phi}$	Q/A	$P_{SL}$	$P_v$	$\Delta CPR$			Plant Response
		(%)	(%)	(% NBR)	(% NBR)	(psig)	(psig)	8x8	8x8R	P8x8R	
Load Rejection w/o Bypass	EOC8	100	100	305	116	1193	1226	0.30	0.30	0.32	Figure 3a
	EOC8- 1800 MWd/t	100	100	252	111	1183	1217	0.22	0.22	0.24	Figure 3b
Loss of 100°F Heater Feedwater	--	100	100	116	117	1033	1072	0.15	0.15	0.15	Figure 4
Feedwater Controller Failure	--	100	100	111	106	1033	1072	0.06	0.07	0.07	Figure 5

10. LOCAL ROD WITHDRAWAL ERROR (WITH LIMITING INSTRUMENT FAILURE) TRANSIENT SUMMARY (5.2.1)

Rod Block Reading	Rod Position (Feet Withdrawn)	$\Delta CPR$			LHGR		Limiting Rod Pattern
		8x8/8x8R/P8x8R	8x8/8x8R and P8x8R	8x8/8x8R and P8x8R	8x8/8x8R and P8x8R		
104	3.5	0.19/0.11/0.11	10.6/13.4	10.6/13.4	↓ Figure 6		
105	3.5	0.19/0.11/0.11	10.6/13.4	10.6/13.4			
106	4.0	0.22/0.12/0.12	10.9/13.6	10.9/13.6			
107*	4.5	0.24/0.14/0.14	11.0/13.7	11.0/13.7			
108	5.0	0.27/0.15/0.15	11.0/13.7	11.0/13.7			
109	5.0	0.27/0.15/0.15	11.0/13.7	11.0/13.7			
110	6.5	0.32/0.18/0.18	11.0/13.8	11.0/13.8			

\*RBM Setpoint

11. OPERATING MCPR LIMIT (5.2)

EOC8-1800 MWd/t to EOC8	BOC8 to EOC8-1800 MWd/t
1.37 (8x8 fuel)	1.31 (8x8 fuel)
1.37 (8x8R)	1.29 (8x8R)
1.39 (P8x8R)	1.31 (P8x8R)

## 12. OVERPRESSURIZATION ANALYSIS SUMMARY (5.3)

<u>Transient</u>	<u>Power (%)</u>	<u>Core Flow (%)</u>	<u>P<sub>sl</sub> (psig)</u>	<u>P<sub>v</sub> (psig)</u>	<u>Plant Response</u>
MSIV Closure (Flux Scan)	100	100	1244	1276	Figure 7

## 13. STABILITY ANALYSIS RESULTS (5.4)

Decay Ratio: Figure 8

Reactor Core Stability:

Decay Ratio,  $x_2/x_0$                       0.61  
(Natural Circulation-Rod  
Block Power)

Channel Hydrodynamic Performance

	Decay Ratio (Natural Circulation - Rod Block Power)
P8x8R channel	0.20
8x8 channel	0.26

## 14. LOSS-OF-COOLANT ACCIDENT RESULTS (5.5.2)

See NEDO-24085-1.

## 15. LOADING ERROR RESULTS (5.5.4)

See Appendix A.

## 16. CONTROL ROD DROP ANALYSIS RESULTS (5.5.1)

Maximum incremental control rod worth: 0.89%  $\Delta k$






Figure 2a. Scram Reactivity and CRD Specifications, EOC8






Figure 2b. Scram Reactivity and CRD Specifications, EOC8-1800 MWd/t







Figure 3a. Generator Load Rejection, Without Bypass, EOC8







Figure 3b. Generator Load Rejection, Without Bypass, EOC8-1800 MWD/t







Figure 4. Loss of 100°F Feedwater Heating







Figure 5. Feedwater Controller Failure

	01	03	05	07	09	11	13
01				06		06	
03			36		38		38
05		06		06		08	
07	36		38		38		38
09		06		08		10	
11	38		38		40		40
13		08		10		00	

- NOTES: 1. Rod pattern is 1/4 core mirror symmetric.  
 2. Number indicates number of notches withdrawn out of 48.  
 Blank is a withdrawn rod.  
 3. Error rod is (11,13).

Figure 6. Limiting Rod Pattern







Figure 7. MSIV Closure, Flux Scram




Figure 8. Reactor Core Decay Ratio vs Power



## APPENDIX

NEW BUNDLE LOADING ERROR EVENT ANALYSES PROCEDURES

The bundle loading error analyses results are based on new analyses procedures for both the rotated bundle and the mislocated bundle loading error events. The use of these new analyses procedures is discussed below.

## A.1 NEW ANALYSIS PROCEDURE FOR THE ROTATED BUNDLE LOADING ERROR EVENT

The rotated bundle loading error event analysis results presented in this supplement are based on the new analysis procedure described and approved in Reference A-1. This new method of performing the analysis is based on a more accurate detailed analytical model.

The principle difference between the previous analysis procedure and the new analysis procedure is the modeling of the water gap along the axial length of the bundle. The previous analysis used a uniform water gap, whereas the new analysis utilizes a variable water gap which is more representative of the actual condition, since the interfacing between the top guide and the fuel spacer buttons, caused by misorientation, causes the bundle to lean. The effect of the variable water gap is to reduce the power peaking and the R-factor in the upper regions of the limiting fuel rod. This results in the calculation of a reduced CPR for the rotated bundle. The calculation was performed using the same analytical models as were previously used. The only change is in the simulation of the water gap, which more accurately represents the actual geometry.

The results of the analysis indicate for the P8x8R bundle a 17.3 kW/ft LHGR and 0.19  $\Delta$ CPR (includes a 0.02 penalty due to variable water gap R-factor uncertainty) with a minimum CPR of 1.07.

## A.2 NEW ANALYSIS PROCEDURE FOR THE MISLOCATED BUNDLE LOADING ERROR EVENT

The mislocated bundle loading error event analyses results presented in this supplement are based on the new analysis procedure described in Reference A-1.

This new method of performing the analysis employs a statistically corrected Haling procedure and analyzes every bundle in the core.

The use of the statistically corrected Haling analyses procedure indicates that the LHGR is 17.2 kW/ft and that the minimum CPR for mislocated bundles is greater than the safety limit (1.07) for all exposures throughout Cycle 5.

### A.3 REFERENCES

- A-1 Safety Evaluation Report (letter), D. G. Eisenhut (NRC) to R. E. Engel (GE), MFN-200-78, dated May 8, 1978.

ATTACHMENT 2

"LOSS-OF-COOLANT ACCIDENT ANALYSIS REPORT  
FOR MILLSTONE UNIT 1 NUCLEAR POWER STATION",  
NEDO-24085-1, JULY, 1980