



Portland General Electric Company
Trojan Nuclear Plant
P.O. Box 439
Rainier, Oregon 97048
(503) 556-3713

September 25, 1980
CPY-936-80

Mr. R. H. Engelken, Director
Nuclear Regulatory Commission
1990 North California Blvd.
Walnut Creek, California 94596


Dear Sir:

Subject: Immediate Report of Reportable Occurrence

This letter is a followup to a report made by C. P. Yundt, General Manager to Mike Malmros, USNRC Resident Inspector at 3:30 p.m., on Wednesday, September 24, 1980, and by R. P. Barkhurst to the NRC Operations Center, via the automatic ringdown NRC notification circuit (red phone) concerning a situation where the high steam flow bistable trip setpoints were set incorrectly, but were within the limits allowed by the Technical Specifications.

This occurrence will be reported to the Nuclear Regulatory Commission as a Licensee Event Report in accordance with our established Technical Specifications.

Sincerely,


C. P. Yundt
General Manager

CPY/JCP:na

c: LER Distribution

Moo7
5/10

8009300471

S