

House of Representatives

Report of Proceedings

MAY 11 1979

Hearing held before

COMMITTEE ON INTERIOR AND INSULAR AFFAIRS

TASK FORCE ON

THREE MILE ISLAND ACCIDENT

Washington, D. C.

FRIDAY, MAY 11, 1979

AM

ACE - FEDERAL REPORTERS, INC.

Official Reporters

444 North Capitol Street
Washington, D. C. 20001

NATIONWIDE COVERAGE - DAILY

800 1200 078

Telephone:
(202) 347-3700

CP 1758

1 TASK FORCE ON
2 THREE MILE ISLAND ACCIDENT

3 FRIDAY, MAY 11, 1979

4
5 U. S. House of Representatives,
6 Committee on Interior and Insular Affairs,
7 Washington, D. C.

8
9 The committee met at 10:10 a.m. in room 1324, Longworth
10 House Office Building, the Honorable James Weaver presiding.

11 Present: Representatives Weaver, Carr, Markey, Vento, and
12 Cheney.

13 Staff present: Messrs. Reis, Meyers, Scoville, Thurber,
14 Burnham, and Terrell.

15 Also present: Edward Frederick, Craig Faust, William Zewe,
16 Gary Miller, and Frederick Scheimann.

17

18

19

20

21

22

23

24

25

1 Representative Weaver. The Task Force will come to order,
2 and we continue our inquiry into the facts as to what happened
3 at Three Mile Island beginning on March 28th, 1979. And we
4 are very pleased to have two very fine people with us today.
5 And would you please identify yourselves. And you've got a
6 recorder here. We will take it down. Don't let that worry
7 you. But we want some record of the questions and answers.

8 So if you would, just identify yourselves, who you are,
9 where you work, and what you were doing on -- as I say, it
10 sounds like Perry Mason -- what were you doing on the night of
11 March 28th?

12 Would you please start?

13 Mr. Frederick. My name is Ed Frederick. I am a control
14 room operator for Metropolitan Edison Company at Three Mile
15 Island Unit 2. I was the control room operator on duty when
16 the accident occurred.

17 Representative Weaver. What is a control room operator?

18 Mr. Frederick. A control room operator is a licensed
19 person, licensed by the NRC, who is designated to operate the
20 controls of a nuclear power plant, for which he is qualified,
21 and no one else is allowed to touch the controls unless he is
22 licensed.

23 Representative Weaver. Turn those knobs?

24 Mr. Frederick. Touch the switches or in any way manipu-
25 late the controls that could in some way affect the state of

1 the reactor.

2 Representative Weaver. On one shift how many control room
3 operators are there?

4 Mr. Frederick. On our shift there are two control room
5 operators licensed with reactor operator licenses. There is
6 a foreman and a supervisor, each with senior reactor operator
7 licenses. So four licenses total, plus seven operators that
8 are not licensed, that operate the auxiliary equipment in the
9 other buildings.

10 Representative Weaver. I see.

11 Would you identify yourself, sir?

12 Mr. Faust. My name is Craig Faust. I too work for
13 Metropolitan Edison Company. I am licensed on Unit 2. I am
14 also a control room operator.

15 Representative Weaver. Would you begin by just simply
16 telling us what happened. I mean, you were standing around
17 having a cup of coffee or watching the gauges. What was the
18 first thing that happened?

19 By the way, how many times have you been interviewed now
20 so far on this?

21 Mr. Frederick. Several: The NRC, the General Public
22 Utility, Metropolitan Edison.

23 Mr. Faust. Just people we know.

24 Mr. Frederick. The President's Commission yesterday.
25 Mostly with the NRC. I think we have had several individual

1 interviews with them.

2 Representative Weaver. How long did the interview with
3 the NRC take?

4 Mr. Frederick. They last anywhere between one and three
5 hours.

6 Representative Weaver. Now, would you mind just starting
7 out. Just tell us, if you can remember, what you were doing.

8 Mr. Faust. Well, first of all, we just have to set up
9 that we were just doing routine things at that time as far as
10 operation of the plant goes. I myself am known as the switching
11 and tagging CRO that night. What it amounts to is I take the
12 readings that are involved throughout the shift during the
13 night, and also perform any surveillance, surveillances that
14 are needed to be done on the plant, as well as, if there is
15 tagging orders that are to be written up by people needing to
16 work on pieces of equipment that are taken out of service, in
17 other words, tagged out by isolating components and hanging
18 tags, depending upon the nature of what they're doing, to
19 perform the job and protect them from having any damage to
20 equipment or themselves by inadvertently operating the equip-
21 ment.

22 I was at that time, just a little bit before 4:00, I was
23 finishing up on readings on our main turbine generator and
24 returning to the desk that I normally operate from in this
25 capacity.

1 Representative Weaver. This desk is right in the control
 2 room?

3 Mr. Faust. It is right in the control room. My desk
 4 faces -- I should say, the desk faces the control panel. And
 5 I was just turning, I was saying something to Ed. I can't
 6 remember what it was. But as I was turning around, I caught
 7 a set of lights coming on on the ICS panel. These are alarm
 8 lights that are above.

9 If you are picturing the control room like you could
 10 picture the desk you're sitting at right here, the lights
 11 would be up in the upper right-hand corner. At the same time,
 12 I pointed to Ed and said something like, something is wrong
 13 in the plant, or something's going wrong, or we have troubles.
 14 I can't even remember exactly what I said there to him.

15 At the same time, I caught other alarm lights coming on
 16 on our electrical board, which things that were flashing. In
 17 my mind, I just drew the position of the alarms that were
 18 coming in. I could not read them from that distance, but
 19 where they are located is significant to me. It was that we
 20 were into a runback on the reactor, and that the turbine
 21 generator had tripped due to the generator breakers being
 22 open and the position of these lights on the panel.

23 I proceeded to go around the desk, and I was getting
 24 ready to take initial actions on our EPs, emergency procedures,
 25 which designate verification of a lot of things coming up, as

1 well as some manual manipulations of the switches up there on
2 the panels. As I was coming around the desk and heading over,
3 my course changed a little bit, because I noticed rod bottom
4 lights coming on in the reactor, which told me further that we
5 had a reactor trip trip.

6 Representative Weaver. The scram?

7 Mr. Faust. The scram.

8 My course of action then changed in my mind from what I
9 was going to do initially, which took me to what is known as
10 our makeup system, which would be the letdown, where I shut a
11 valve first which is known as NEV-376.

12 Representative Weaver. You were going to, after you saw
13 the scram, you were going to shut this valve?

14 Mr. Faust. I did shut this valve. That is what I'm
15 trying to say, I changed. In our EPs, the direction of the
16 course I was going to take involved doing this.

17 The next thing I did was try to get another makeup pump
18 on, which I didn't succeed in doing. I tried two times. The
19 first time I did not hold. We have what is known as an inter-
20 lock or a time delay on the switch that allows a lube oil pump
21 to come on first to pre-lube the pump. I let go of that switch
22 too soon. It was like a second time delay, and it was a matter
23 of turning on the switch and let it go. And I went immediately
24 back on the switch and held it over longer.

25 I got a run indication on the pump as far as light. When

1 I left off on the switch again, the pump tripped off for some
2 reason. I don't know yet.

3 Ed at that time was moving across the panel -- turning,
4 I should say, across the panel or moving across. And he saw
5 the pump was still off, and reached down and grabbed a hold of
6 the switch. And I left at that time. I was heading to another
7 station.

8 Representative Weaver. What was this valve you were
9 going to open?

10 Mr. Faust. It is the NEV-376, and the idea behind this
11 is to limit the amount of water coming out of the reactor, the
12 primary system, because what you want to do is keep your water
13 inventory in there.

14 Right now, what normally happens is you go into a cooldown
15 plant. Your water is going to contract on you. So you want
16 to minimize the amount of water you're letting down. The system
17 is normally on the purification system, so you shut it off.
18 That is one of the first courses you do.

19 The next thing is, if you need it, you want another pump
20 on, so that you can provide more water, if you need it, into
21 the reactor.

22 Representative Weaver. And that pump is what?

23 Mr. Faust. That is the makeup pump. It is one of three
24 we had at the time, one running, which is NUP-1B, which is
25 normally running.

1 Representative Weaver. We've heard of the high-pressure --
2 Mr. Faust. These are high-pressure injection pumps.
3 When we're talking about these pumps, these are, all three
4 pumps are high-pressure injection pumps.

5 Representative Weaver. A, B, and C, and you've got B
6 running?

7 Mr. Faust. Right.

8 Representative Weaver. It was running to adjust pressure
9 on a normal basis and you were going to put on A, then, is
10 that right?

11 Mr. Faust. Right.

12 These pumps are part of a volume control system, and also
13 supplying water to our motor cooling pumps for sealing the
14 shafts. So that is why B would normally be running on our
15 pump. The other two are backups for ES actuation and they were
16 in that capacity at that time.

17 We have a capacity, of course, to be able to start them
18 whenever we want to, and that is part of our procedure, put
19 another one on. The A is normally picked because it is lined
20 up to our makeup tank. This gives it an immediate source of
21 water right off that we can put it on and we don't have to
22 draw from any other tank at that moment.

23 So that was my initial action. As I said, after Ed
24 started the pump, I was moving across the panel to what is
25 known as our feed station.

1 Representative Weaver. We are 13 seconds in now.

2 Mr. Frederick. Are we pretty clear on the sequence he
3 just gave you as to what he did?

4 Representative Weaver. Yes, I think I've got it.

5 Mr. Frederick. There is an awful lot that happened in
6 the first seven or eight seconds.

7 Representative Weaver. You're talking about in the plant
8 itself?

9 Mr. Frederick. Yes.

10 Representative Weaver. Yes, we've been going over that
11 for a number of days.

12 Representative Cheney. Had you ever been through this
13 thing before?

14 Mr. Faust. Yes, a reactor trip and turbine trip, we have.

15 Mr. Frederick. Up to this point it is fairly routine.

16 Representative Cheney. It happens what, once a month or
17 once a year?

18 Mr. Frederick. It happened several times on our shift
19 in the past year, maybe two times.

20 Representative Weaver. Which plant, because obviously
21 not Unit 2?

22 Mr. Frederick. Yes, Unit 2. Unit 2 had been in operation
23 for a year.

24 Representative Weaver. I see. You hadn't been actually
25 licensed to operate it, but you had been testing it for a year?

1 Mr. Frederick. We were licensed, we were testing, and
2 we were generating power for seven or eight months. However,
3 we were not receiving a commercial rate. The accounting thing
4 had changed on December 30th. In other words, they declared
5 themselves a commercial plant, reliable for providing so many
6 megawatts of electricity every day. It was just a declaration
7 of, from now on we will give you so much power.

8 Representative Weaver. So you fellows had been operating.
9 this Unit 2 for almost a year?

10 Mr. Frederick. Yes.

11 Representative Weaver. And how many times had we
12 actually experienced a transient in Unit 2 up to this point?

13 Mr. Faust. A transient?

14 Mr. Frederick. During the testing procedure, we initiate
15 these transients intentionally.

16 Representative Weaver. Intentionally?

17 Mr. Frederick. Yes, to verify that the proper response
18 is taking place. In other words, the safety systems have to
19 be tested under actual operating conditions before the plant
20 can be licensed to progress through the power escalation
21 from zero percent to 100 percent.

22 Representative Weaver. Had you initiated a transient
23 comparable to the one that started off at this Three Mile
24 Island accident?

25 Mr. Frederick. We had not simulated this transient with

1 the emergency feed isolated and a leaky relief valve.

2 Representative Weaver. I see.

3 Mr. Frederick. During the testing procedure you test
4 things as they are designed to respond. You don't intentionally
5 try to make it break and go into what we had. That is not the
6 general idea.

7 Representative Weaver. How many unintentional -- I don't
8 know the difference between a transient and an incident and an
9 accident.

10 Mr. Frederick. We may have pointed that out, because
11 there's a difference between a runback and a trip and a power
12 reduction. These are different. There are all kinds of dif-
13 ferent terms that come in.

14 A reactor trip is initiated whenever a reactor protection
15 system, which is an automatic system which monitors parameters
16 in the reactor coolant system, decides we are approaching an
17 unstable condition, as undesirable. As an automatic trip, that
18 will be initiated, and that has happened, I would have to guess,
19 maybe five times in the last year.

20 Representative Weaver. We've been calling it a scram,
21 a scram, meaning a reactor trip.

22 Mr. Frederick. An unplanned reactor trip. I would anti-
23 cipate maybe five times. You could get that off the record.
24 There is an accounting and a report given to the NRC each time
25 that happens.

1 Representative Weaver. So you had five scrams in Unit 2's
2 lifetime up to this point?

3 Mr. Faust. I was just going to say, he's trying to
4 indicate that you can get the actual number.

5 Mr. Frederick. From the NRC. They have that.

6 Like I say, we went through many of these trips and these
7 transients intentionally. And it would be hard right now to
8 figure out which ones were intentional and which ones were not.
9 You could count them on your fingers and say there were five.

10 Representative Weaver. Five unintentional?

11 Mr. Frederick. Yes, there were probably five, about.

12 Representative Weaver. And nothing untoward happened in
13 those?

14 Mr. Frederick. Well, each time that it was unintentional,
15 of course, an investigation starts to find out what initiated
16 it and what can be done to prevent it. And each time it was
17 either a string of events started, like we did have some trips
18 from the pumps before. I believe there were two of them, but
19 not from the same reason. It was loss of suction pressure
20 or something like that.

21 And we had an emergency safeguards actuation in which
22 this relief valve stuck open once before. And all this stuff
23 is on record somewhere, I'm sure. I know it is in my log.

24 Representative Cheney. When the valve stuck open once
25 before, was that planned or accidental?

1 Mr. Frederick. That was unplanned. It was not because
2 of the trip, but it was one of the things that happened during
3 the transient.

4 Representative Weaver. But did you know it stuck open
5 that time?

6 Mr. Frederick. No, we had the same problem with valve
7 indication, that there was nowhere on the panel that indicates
8 that the valve was open. We still don't have that. They made
9 an attempt at providing valve indication for it by monitoring
10 the initiation signal that goes to the valve and give a red
11 light on the panel whenever there's a signal calling for that
12 valve to be open.

13 However, once that signal to open the valve goes away the
14 light goes out, and it does not indicate the actual position
15 of the valve. In other words, it says it is supposed to be
16 open. There is no way of verifying whether it is or is not.

17 Representative Cheney. And when the valve stuck open
18 once before, was there then some kind of inspection to find out
19 why it stuck open?

20 Mr. Frederick. Yes, it was worked on and repaired, and
21 the indication that we have now was installed in order to
22 preclude this from happening again.

23 Representative Cheney. I'm sorry, I did not catch that.

24 Mr. Frederick. I say, they repaired the valve and then
25 they installed this new indication, this new valve indication,

1 hoping that in the future, if it was stuck open, we would be
2 able to tell.

3 Representative Cheney. Do you recall why it was that it
4 stuck open that time?

5 Mr. Frederick. No.

6 Representative Cheney. We had testimony previously
7 involving another valve in a different reactor, where it stuck
8 open at one point and they found out that there was a missing
9 light of some kind.

10 Representative Weaver. Why don't you just go on and tell
11 us what you did then, what happened?

12 Mr. Frederick. I will just give you up to where Craig is
13 right now, I will tell you what I was doing in the meantime.
14 When Craig pointed at the panel, I was facing away from the
15 alarms that were coming in. I had turned to see what was
16 going on, and I read a few of the alarms as I was turning.

17 The first ones I read were condensate pump trip and
18 turbine trip. Now, that in my mind initiates the emergency
19 procedure for turbine trip, which calls for verifying that the
20 runback, reactor runback has taken place.

21 I monitored the ICS system, the integrated control system,
22 for a runback. You have to study the gauges to see if they
23 are moving from 100 percent down to 15 percent for demand
24 sequence. As I started to do that, Bill Zewe came out of his
25 office and came up on my left, and he was also scanning the

1 panel, and he said: You just lost the reactor. In other
2 words, he was indicating that we had a reactor trip while I
3 was looking down at the panel.

4 So that initiated a different emergency procedure. We
5 moved from turbine trip to reactor trip. And the verifications
6 there are different. So I verified that all of the rods had
7 been dropped into the core. The individual rod positions are
8 straight ahead on the panel, and so I verified that and the
9 neutron power indication coming down.

10 And my first manual action other than verification of all
11 this going on was to place the pressurizer, the pressure
12 control systems, in automatic, which had previously been in
13 manual.

14 We were doing some water inventory control several weeks
15 before this and it was necessary to have the pressurizer
16 instruments in manual. But it is undesirable to have them in
17 manual during the transient, so I threw them in automatic
18 almost immediately.

19 And, as Craig said, I moved to the left. He was already
20 at the makeup system. I saw he was having trouble with the
21 pump. I started it and he left.

22 At this point, the way we run the drill on a simulator
23 and at the plant, one of us should take charge of the reactor
24 cooling system and one take charge of the secondary plant, and
25 try and communicate with each other on what is happening. So

1 I took the primary and he took the secondary. It was my job
2 to maintain the water inventory in the reactor cooling system
3 by adding water through the makeup system and monitor the
4 pressure, the pressurizer level and the system temperature,
5 to assure that a normal cooldown was going to take place. That
6 is what I was doing when he went to the emergency feed station.

7 Representative Cheney. How far along are we now at this
8 point?

9 Mr. Frederick. We're still within the first minute or
10 minute and a half.

11 Mr. Faust. Then I picked up and ran behind or moved
12 across behind Ed. I came in across. The first place I wanted
13 to look at was the steam generator levels. The first thing I
14 saw was that the operating range had several indicators up
15 there of steam generator level. The operating range was off
16 on the bottom.

17 The next area I looked at was our startup range of
18 indication, which was approximately midway. It was coming down
19 on scale.

20 The next thing I did was I looked over at the main feed
21 pumps. Both had been tripped off. So I verified that our
22 emergency feed pumps were on. There were three of them. They
23 were all indicating operation at that time.

24 Another thing I looked for was the EFE-11A and B valves,
25 which are automatic emergency feed valves that throttle to

1 control level in the generators if you lose normal feed. The
2 signals should have been generated at this time to go on what
3 is known as low-level limits. It was 30 inches, approximately,
4 in the steam generators.

5 Representative Cheney. I just wonder on this -- we're
6 all novices in technology. We've got a chart. It wouldn't be
7 possible for you to just show us the pieces of equipment in
8 the plant?

9 Mr. Frederick. On these pictures, you mean?

10 This is the area of the plant that we were in. Looking
11 at the level for the steam generator, which was right here.
12 The emergency feed valves we were trying to operate are these
13 black boxes right here.

14 Mr. Faust. The emergency feed valves I'm trying to
15 operate at this time are up here, these two boxes here. I
16 was monitoring them, just looking at them. The light indica-
17 tion I was looking at were the traveler valves set up here.

18 Mr. Reis. Could we just arrange this so the members
19 could get seated and see what's going on here?

20 Mr. Frederick. We're told that by the time the reactor
21 tripped we had only been in emergency three seconds.

22 Representative Weaver. Three seconds when the scram
23 occurred?

24 Mr. Frederick. From the time the condensate pump tripped
25 to the reactor trip, the total time was seven seconds. So

1 all this that we talked about so far happened in seven seconds.

2 Mr. Reis. Although we're sitting across the table, this
3 may has got to hear. So speak up a little.

4 Representative Carr. And before you get into the
5 details, setting the stage, when did you come on duty?

6 Mr. Frederick. We'd been there about four hours out of
7 an eight-hour shift. We'd been there about half the time.
8 Actually, it was five hours.

9 Representative Carr. Okay, go ahead.

10 This is Mr. Faust and Mr. Frederick.

11 Mr. Faust. The place I was looking at, like I said,
12 when I was monitoring the steam generator level in the startup
13 range, which would be these two indicators here. The first
14 ones I looked at were operating range, and they were on the
15 bottom, indicating that -- in other words, you have to picture
16 where these operating ranges were monitoring on the steam
17 generator.

18 The operating range covers a level something like 96 to
19 300.

20 Representative Weaver. What is that?

21 Mr. Faust. Inches of water in the steam generator. The
22 startup range goes from zero to 250 inches. So I was already
23 down in the midrange and on the startup range. As far as I
24 could see at that time, the operating range had bottomed out.
25 Levels were coming down, which I expected them to do. I was

1 looking for that.

2 I look at EFV-11 valve here, which indicated -- the first
3 thing I looked at were these controllers here, which were
4 indicating a demand signal calling for the valves to open.
5 The other thing I noticed were these lights up here were red
6 and green. In other words, that was indicating that the
7 valves were traveling from what I supposed to be a closed to
8 open position or in between there.

9 Representative Cheney. Which valves were these?

10 Mr. Faust. These are the emergency feed valves.

11 Representative Cheney. On the secondary system?

12 Mr. Faust. Right.

13 Mr. Frederick. There is an automatic valve in there.

14 Mr. Faust. The next thing I did was I looked over -- at
15 this time I wasn't aware of actually the status on the
16 secondary plant as far as our feed goes. I looked over and I
17 caught -- if I can show you the lights, it is up in this
18 corner here. You see these two top switches here. There are
19 lights, indications up there that are indicating to me that
20 both our feed pumps had tripped, the normal feed pumps.

21 Okay. The next thing I did was immediately -- I guess
22 you should realize the position of me against the panel right
23 now. I'm up against the panel, right in this corner right
24 here. So that I looked down under me and over to the side,
25 which would be over in here, starting over in here, to verify

1 that our steam-driven and electric-driven steam pumps had
2 picked up, which they had. I had a discharge pressure indica-
3 tion on the gauges above, which are essentially these three
4 gauges. If you just want a location on the panel, they are
5 right across the top.

6 So I felt we were going down to low-level limits. I was
7 going to leave that station and go further over on the panel,
8 over to our turbine generator and also to monitor the output
9 breakers on the generator itself. These are parts of our
10 EP that we follow up on.

11 Representative Carr. "EP" meaning?

12 Mr. Faust. Emergency procedures.

13 So the first thing I came across was I saw one valve,
14 the throttle valve -- I can't identify now which one it is.
15 I would be guessing to say. The indicator on one throttle
16 valve was hanging up. All the governor valves were shut. In
17 others, there are four valves, eight valves we're talking
18 about here.

19 Mr. Frederick. The valves he's talking about are the
20 steam valves that make the turbine turn. At this time they
21 should all be shut and he noticed that one was open.

22 Mr. Faust. The indication was that it was hanging up.
23 I pushed the trip button on the turbine at that time just to
24 ensure that the trip signal was indeed into everything. It
25 drops out the hydraulics on it, too.

1 So I didn't pay much more attention to that at that time,
2 except to note in my mind for later reference. I had four
3 other valves fully shut to isolate steam to the turbine. The
4 idea here is you don't want to drag steam off, too much steam
5 off the turbine generator, the reactor right now or the steam
6 generators, because you will subcool yourself and you will
7 shrink out of the pressurizer. In other words, you will lose
8 your level.

9 So the idea is you want to stabilize the plant out right
10 now and hold pressure and temperature at about 547. That's an
11 average temperature across the timer. And also, 2155, which
12 is the normal pressure that we operate at, you want to hold
13 there and cool from there, just to remove decay heat, at this
14 time.

15 So I hit the turbine button, the turbine trip button.
16 The indication was that it still had hung up, but I had indi-
17 cation that the others were down.

18 Part of our verification is to ensure that the extraction
19 steam valves going to our feedwater heaters are shut or go
20 shut. I verified movement on them going from -- there was
21 dual indication at the time that they were going shut.

22 Another thing I did was I took the turbine generator
23 breakers and the field breakers for the generator and put them
24 in a polar lock to ensure that they were open. All the indi-
25 cations at this time were normal that they were open, except

1 for the one indication on the throttle valve hanging up on the
2 turbine. We found out later that was just the valve shut so
3 fast that it ripped an indicating arm off. The valve was
4 actually shut.

5 I came back across the secondary panel. I made a decision
6 during that time that I had time to ignore part of our EP until
7 a later date. In other words, this involves just putting
8 turning gears, switches for turning gears in automatic, so
9 that when the turbines coast down they don't come to a dead
10 stop with a large hot rotor there. That could cause distortion
11 of the rotor. These things spin for a while, so I had time to
12 leave that go for this point.

13 I came back over to the emergency feed station. The
14 first thing, again, that I looked at was the startup level.
15 They were indicating 10 inches on the startup range. It was
16 at that time that I announced that the generators are dry.

17 I started looking. I took control of EFV-11A and B, these
18 Bailey stations, right here. I took them into manual and went
19 to full open on the demands, and it indicated once again that
20 the valves were traveling from shut to open. At this time
21 they should have been open. Something was abnormal. I had to
22 wait.

23 It turns out that time is the big thing here in the way
24 we're thinking. I actually ended up waiting, apparently,
25 overall 8 minutes before I actually got the feed reestablished

1 to the generator. But during that time --

2 Representative Weaver. And is this this valve you're
3 talking about?

4 Mr. Faust. No, it's EFV-11.

5 Representative Vento. The indicator valves that you saw
6 were open and closed? Where are the valves in the system?

7 Mr. Frederick. It's the one I drew, just there. That is
8 an automatic valve that should be full open at this time.

9 Representative Vento. And it's indicating it's still
10 moving?

11 Mr. Frederick. Yes, it's indicating it's still moving.

12 Representative Vento. And these were the generators, and
13 you took control. When you took manual control, they indicated
14 that they were dry.

15 Mr. Faust. Yes.

16 Representative Vento. Both?

17 Mr. Faust. You're talking about the steam generators?
18 Yes, on the secondary side.

19 Mr. Frederick. It's undesirable not to have water in
20 the steam generator.

21 Representative Vento. Oh, yes.

22 Mr. Frederick. The steam level showed just at the bottom
23 of the generator. He said he had 10 inches of water.

24 Mr. Faust. The indicators did not move any lower or any
25 higher at the time. In other words, they stayed at 10 inches.

1 From past experience, we come up with that whenever, I
2 believe, we set 10 inches to consider whether it is or it is
3 not that the generators are dry and to treat it as such. In
4 other words, we start looking for trouble and correct it.

5 So my first actions were to, like I said, take manual
6 control and go to full demand on them, raising the full
7 demand.

8 Representative Carr. P these, again, go to these valves
9 here?

10 Mr. Faust. Right, the controls for those valves.

11 Once again, I had to wait.

12 One other thing that I looked at was T-Ave at this time.
13 T-Ave was up from 570 degrees. It should have been lower. At
14 this point in the game, I should have been down around 4 or
15 547.

16 Representative Carr. Where do you find that?

17 Mr. Faust. It's right here, a digital display. It was
18 575 and it should have been 547.

19 Representative Vento. Now where do they go to? Is that
20 within the system?

21 Mr. Faust. These temperature indicators are indicating
22 at loop temperatures. In other words --

23 Representative Vento. They are not directly on the
24 reactor, not the reactor core?

25 Mr. Faust. It would be a temperature indicator off here,

1 this point in the primary loop, and also coming out of the
2 bottom of the steam generators. It would be TC and TH. The
3 average of those is what I'm looking at at this time.

4 Representative Vento. So one or more may be hotter or
5 colder at this point, you don't know? Or are they about the
6 same?

7 Mr. Faust. I'm looking at one indication right now.
8 These are all averaged together in one.

9 Representative Vento. And there are how many points on
10 there that test for that in this type of generator, do you
11 know?

12 Mr. Faust. We've got two in each loop as far as TH that
13 are going to this purpose right now, and we have two legs
14 coming out of each generator that go to the pumps. So that
15 makes four TC indicators or sensing points for the purpose of
16 displaying T-Ave, of which we select -- these are averaged, so
17 we will select averages of these TCs and feed them together
18 for loop T-Ave.

19 And we feed also from both loops, then, and get an
20 average T-Ave of the core or the overall system. What we're
21 looking at is an average temperature, or I'm looking at at
22 this point is an average temperature of both loops in the
23 primary system. And as I said, it should not have been as
24 high as it was. It was there due to the loss of feed, and
25 that was my job, to try to establish feed at that point, which

1 is what I was trying to do.

2 The indications I need to do that are an increase in
3 steam generator level. Steam generator level is on the bottom,
4 so I have to wait.

5 The first thing I knew at that point was that I took an
6 action, it was on those valves, and I had to wait for an
7 indication.

8 Another thing I was looking at was steam generator pres-
9 sure. I expected to see it down at that point, but once again,
10 it wasn't doing what it was supposed to do. In other words,
11 our turbine bypass valves which pull steam off the steam
12 generator in a situation like this and control for a 1010
13 signal sent in to them to maintain pressure in the steam
14 generator at 1010, that was a little lower than 1010. I can't
15 give you an exact number on that. I was looking. It was right
16 around 1,000 pounds.

17 So I looked over to see if the turbine bypass valves were
18 open and they weren't, which is the way it should have responded,
19 really, for what the pressure it was seeing in the generator.
20 The thing that I was seeing was that I wanted T-Ave to start
21 dropping. I wanted to cool down.

22 So I took the turbine bypass valves at that point into
23 manual. And the control for these are sitting up here, where
24 I'm monitoring over here. I took those to manual and I just
25 cracked them. And the way I got that indication was that we

1 have lights on those valves. So I gave them just enough demand
2 signal that as soon as I got the red light indication on it,
3 it told me that. I just cracked the valve open and I just
4 cracked them open to promote some kind of cooling out of the
5 steam generators.

6 What I received was a decrease in pressure on the steam
7 generators, which was indicating to me that I wasn't getting
8 feed also at that point, because it was just bleeding off, a
9 generator sitting there dry. It bottled itself up.

10 You are supposed to try to maintain 1010 in it. So I
11 started looking further. That is when I scanned the panel
12 further.

13 My first indication was, when I looked down I looked to
14 see and make sure, I looked at the pumps again and I came back
15 across, and the tag that you may be hearing about that was over
16 an indicator would be over this. It was a yellow caution tag,
17 and it's on FWV-17B, which is a recyc valve for the feed pump,
18 the B feed pump. We had problems with it.

19 That caution tag was just to indicate and tell the operator
20 of the problem. And if the pump tripped, we wanted to give
21 the pump recirc flow path to protect it.

22 At that time, that tag was hanging down where it was
23 covering the upper indicating lights on the EFV-12B.

24 Mr. Frederick. It's doing it right now, as a matter of
25 fact.

1 Mr. Faust. No, it was flipped to the side. This tag
2 was hanging straight down.

3 Representative Weaver. Who put that tag on there? Not
4 the person, but is that an NRC tag?

5 Mr. Faust. No, that is part of our --

6 Mr. Frederick. That's been on there for about a week
7 before that. I think I put it on.

8 Mr. Faust. It is not uncommon for tags like that. In
9 fact, you can see there are tags all over the place.

10 Representative Weaver. Does the NRC put any of these
11 tags on?

12 Mr. Frederick. No.

13 Representative Weaver. These are all done by utility
14 personnel?

15 Mr. Faust. Yes.

16 Representative Carr. But this is a standard thing
17 throughout utility companies?

18 Mr. Faust. Yes, they have some sort of switching and
19 tagging at all utilities.

20 Representative Vento. You noticed, though, in looking
21 at that at this point that you weren't getting feedwater. In
22 other words, the feedwater indicator or light here, is that
23 right?

24 Mr. Faust. No. All that is is a valve. It is a valve
25 in the feedwater train.

1 Representative Vento. And it was closed and that light
2 was on?

3 Mr. Faust. Like I said, I made a first scan at it. That
4 tag that was covering it -- I was actually sort of leaning over
5 the panel. I don't know how to say it. I was just standing
6 over it like this, because I was trying to see an indication
7 over here on the panel.

8 Representative Vento. This is the valve right here that
9 we're talking about in this diagram?

10 Mr. Faust. The upstream isolation.

11 Representative Vento. That's the valve right here?

12 Mr. Faust. Yes.

13 Representative Vento. And this one you were reading
14 showed that it was going from open to closed or closed to
15 open?

16 Mr. Faust. At this time it was closed. Once again, at
17 this time it was going again from closed to open, as far as I
18 could determine.

19 Representative Vento. Is that a normal procedure when
20 you have had this valve -- this now has been, I don't know how
21 many minutes you had said, eight minutes --

22 Mr. Faust. Well, the eight minutes I'm talking about is
23 from the point from graphs that we have, that we can determine
24 once we started feeding.

25 Representative Vento. I guess my question is, does it

1 normally take that time for a valve to go from closed to open
2 in this situation?

3 Mr. Faust. No.

4 Mr. Frederick. Some time confusion is in here. He may
5 have noticed that. When he looked at that valve, it may have
6 been only several seconds into the accident, and he was just
7 impatient for it to open and that stuck in his mind. We have
8 an indication that this thing is operating now.

9 Representative Vento. We have time limitations, so we're
10 going to have to press on. Why don't you proceed?

11 Mr. Faust. I made a scan of it, found those two valves
12 shut. The first one I saw was the bottom one, which would be
13 down here, those indicating lights there. I announced it at
14 the same time I was reaching for the control switch on that
15 one and flipped the tag off the upper one. And the 12s were
16 shut. That is what I called out, I believe.

17 Anybody who was concerned at that time knew what I was
18 talking about as far as relationships to those valves. It was
19 at that time that we heard from our loose parts monitor. There
20 was very cold water going into a hot pipe. We knew we were
21 feeding at that point.

22 I started regaining pressure in the steam generator also.
23 I continued to feed. I watched T-Ave dropping. It was coming
24 down as I started feeding the generators up. As soon as I got
25 a level indication that I could tell -- as soon as I got level

1 indication, then I started backing off on the feed rate going
2 into the generators.

3 I established 30 inches in the generator for low-level
4 limits and went back to a more normal situation for the
5 generators at this point and just promoted cooling. I came
6 down -- I can remember three temperatures mainly that I saw at
7 that time. One was, as I said, 570. The next one I remember
8 was 550. And then I ended up around 547, and I think 540 was
9 the lowest I remember seeing it go. And then we seemed to hold
10 there.

11 Mr. Frederick. His job now is maintaining the steam
12 generator level and establish a controllable cooldown rate.
13 He's taking manual action to make up for what the automatic
14 system did not do. And once he gets it going in the right
15 direction, he can just monitor it, and that is what he is
16 doing.

17 Representative Weaver. What time was it now?

18 Mr. Faust. I guess it was eight or nine minutes.

19 Mr. Frederick. During the time that he was having the
20 problem with the steam generators, I was having a problem with
21 the pressurizer level. During the initial transient, the
22 reactor trip, we expected the pressurizer level to drop
23 rapidly as the system cooled off. You should see a tremendous
24 shrinkage.

25 My job is to start another pump, the high-pressure

1 injection system, and try to get ahead of the shrinkage, so
2 that we can recover pressurizer level back up to around 200
3 inches, maintaining a minimum of 100 inches. That is what I
4 was doing. I was starting an extra pump, and I did gain control
5 over the pressurizer level during the transient and begin to
6 turn it back up prior to the system low pressure signal that
7 initiated the emergency safeguard system.

8 Now, the pump, the high-pressure injection pump that I
9 was controlling and the valves received emergency safeguard
10 signals. And when the plant reached 1600 pounds in pressure,
11 that automatic signal took control of the pumping valves away
12 from it. In other words, I had no control over them as long
13 as the automatic signal was overriding me.

14 So after I saw the initial turn in the level starting to
15 go back up, then the safeguard system continued to inject more
16 water to raise the level more rapidly. Over the next few
17 minutes, it seemed to me that the pressurizer level was rising
18 too rapidly. It was faster than I had seen it go before. So
19 I just continued to monitor it, hoping that it would taper off
20 as the pressure was regained in the system and begin to auto-
21 matically control itself.

22 However, it reached about 385 inches, 400 being the upper
23 limit, and the rate was still constant. Okay, it was my
24 concern not to let the pressurizer fill solid with water,
25 because a solid water system is difficult to control and we

1 had never done it before. So I was very concerned about
2 preventing the pressurizer from filling.

3 At this point, after having verified that the emergency
4 safeguard signal had in fact initiated all the safeguards
5 equipment and that it was now going to be a problem and that
6 I was going ahead on full automatic and going to cause another
7 problem, I bypassed the emergency safeguard system. In order
8 to that -- it is right next to the makeup system -- I just
9 stepped to the left and pushed six bypass buttons, which gave
10 me control over the system. It didn't change anything except
11 to give me back manual control.

12 What it did was cut off one high-pressure injection pump
13 and shut two of the four injection valves. In other words,
14 I cut the injection flow rate in half, looking for a drastic
15 change in the pressurizer level rate of increase. I saw a
16 slight tapering, and then it went right back on the same rate.
17 And so, what I had done was not stop the increase in the level.
18 Within a few seconds, it seemed to me, it went off the scale.

19 I had already remarked about this to the supervisor and
20 said, we're about to go solid, which is undesirable.

21 Representative Cheney. At this point, can you quickly
22 explain why you think the pressurizer level went up and did
23 not perform as you thought it would perform?

24 Mr. Frederick. What I think now or then?

25 Representative Cheney. Now.

1 Mr. Frederick. Now, because of the loss of the heat
2 removal from the steam generators, the hot leg in the primary
3 system, with the water coming out of the reactor coming to the
4 steam generators, the increase in temperature was sufficient
5 to begin to generate steam in the pipes, in the high point of
6 the pipe as the water got hot enough to start boiling, and it
7 caused the steam generation at the highest point. So what
8 had happened, we formed more steam in the system other than
9 the one I was monitoring.

10 What had happened was that high pressure point had pushed
11 the water from the rest of the system into the bubble.

12 Representative Weaver. What did you think was happening
13 at the time?

14 Mr. Frederick. What I thought was happening was that
15 the high-pressure injection rate was too high and that we did
16 not have a leak in the system, so all we were doing was
17 increasing our inventory. So I was reacting or putting too
18 much water into the system, and so I cut back the fill rate
19 and increased the drain rate to the purification system, because
20 now I could control the valve that we originally shut to take
21 water out of the system, trying to drain some of the water out.

22 Representative Weaver. Which valve are you talking about?

23 Mr. Faust. That is 376.

24 Representative Weaver. Go ahead.

25 Mr. Frederick. The valve designation is NUV-376.

1 After several minutes of trying to get the pressurizer
2 level back, I thought I had control over it because I could
3 see the pin occasionally dip down on the scale and go back up.
4 So I thought I was very close to controlling it. But actually,
5 it was just the instrument response to the abnormally high
6 level. It was just bouncing. I did not know that at the time.

7 So after he gained control of the steam generators, we
8 still had this problem with the full pressurizer level. We
9 had conflicting instruments. We had a full pressurizer, which
10 meant the system should be solid. We had a decrease in the
11 temperature and a decrease in the pressure system.

12 Now, what we should have seen was a definite rise in
13 pressure through the injection of the water. You should see
14 a rapid pressure increase.

15 The temperature was high. That was what was causing the
16 steam generation. So we had high temperature and low pressure,
17 and we had a full pressurizer. So the pressure was going up.
18 So these things were conflicting. And we were talking about
19 it, trying to figure out what was wrong.

20 We began to distrust the pressurizer level instrument,
21 and we later verified that it was working properly.

22 Mr. Meyers. When did you verify that it was working
23 properly?

24 Mr. Frederick. The instrument technician --

25 Mr. Meyers. This is right around that time, as opposed

1 to the next day?

2 Mr. Frederick. No, it was the same morning. We had an
3 instrument man verify that the signals going to the indicator
4 were correct. We just checked it from points on the computer
5 and he gave a quick verification. It is unlikely all three
6 pressurizer instruments would have failed at the same time in
7 the same direction. So we assumed it was working.

8 So for the next hour or so, we continued to operate with
9 full pressure, system pressure about 1200 pounds or so, and
10 temperature relatively hot. But we attributed the low pressure
11 to the problems he was having with the steam generator. In
12 other words, the excessively fast feed rate he had would have
13 caused excessive cooling in the RCS, which could have contri-
14 buted -- could have caused the low pressure.

15 So when we got the steam generator stabilized as far as
16 level and feed rate, the steam generator seemed to be masking
17 what was going on in the pressure cooling system. So for the
18 next hour or so we worked on trying to stabilize the steam
19 generators, which we finally did about 50 minutes in or so.
20 We eliminated the steam generators as being the cause of our
21 problem.

22 And it was about an hour into it that we started having
23 a problem with the reactor cooling pumps that led to us turning
24 them off and losing the flow in the system.

25 Representative Cheney. At what point in this period were

1 you aware when the relief valve dropped in the pressurizer?

2 Mr. Frederick. The relief valve opened in the first few
3 seconds of the transient. During the reactor trip, the reactor
4 opened. The reactor tripped on high pressure, because the
5 turbine tripped. When the turbine tripped, the RCS begins to
6 heat up, the pressure goes way up and causes an automatic
7 trip. That is the way it's supposed to work. That's what
8 caused the reactor trip.

9 As the pressure went up, that relief valve would have
10 opened. It is a motor-driven valve. It would have opened to
11 relieve the high pressure and bring it back down to the normal
12 pressure.

13 Representative Weaver. Which? You're now talking about
14 the relief valve up here?

15 Mr. Frederick. Yes. That's the one that we believe
16 stuck open. That is when it opened and we had indications
17 that it opened.

18 Representative Carr. Where is that indicator on these
19 pictures?

20 Mr. Frederick. It's over in this corner of the panel.
21 So when the light went out, that means that it went shut.

22 Representative Cheney. This is all automatic? You didn't
23 have to do that?

24 Mr. Frederick. We did not have to do that at all. So,
25 believing that we were stable for some time, we just continued

1 to try and wrap up the plant and establish a cooldown rate.

2 The next problem is the reactor coolant pump vibration.

3 Do you want to go into that?

4 Representative Cheney. Yes.

5 Mr. Faust. Do you want me to bring you up to date over
6 on the secondary? I don't know where they want to head on
7 that, because I had problems on the secondary that I was working
8 on, in addition to this.

9 Representative Weaver. The problems you would have had
10 would have been the same as in a coal or oil plant, would they
11 not?

12 Mr. Faust. Yes.

13 Representative Weaver. Albeit they obviously are more
14 dangerous.

15 Mr. Faust. What I had over there, if you want to just
16 ignore that part of it, I had reestablished feed, emergency
17 feed, and I was doing other things to try to get back onto the
18 normal situation over there. But we were removing heat. So
19 maybe that is as far as you want to go on it.

20 Representative Weaver. I have another question. When
21 you found out in the midst of all this that this valve right
22 here had to be closed, what was your reaction?

23 Mr. Frederick. He shouted it out.

24 Representative Weaver. He said "The 12s are closed," was
25 that it?

1 Mr. Faust. Yes, I shouted out. I'm pretty sure I was
2 pretty boisterous about it. It is not something I wanted to
3 find or I expected to see.

4 Mr. Frederick. He shouted it out loud, and that is such
5 an unusual thing that it took all of our attention away from
6 what we were doing. We had to go see what caused that and to
7 make sure that he was in fact opening them.

8 He nearly ripped them out of the panel.

9 Representative Carr. You opened them, now?

10 Mr. Faust. Yes.

11 Representative Vento. They were manually closed to begin
12 with, then, or what? I mean manually, when I say dropped the
13 panel --

14 Mr. Faust. Well, we can't tell that. In other words,
15 these valves could have been operated locally, if that's what
16 you mean.

17 Representative Vento. You don't know how they got to be
18 closed? No one knows? You didn't do it?

19 Mr. Frederick. They can be operated from another building.

20 Representative Carr. And if they are operated from
21 another site, the indication would be --

22 Mr. Faust. It would be changed.

23 Mr. Frederick. It would not be something you would
24 notice unless you were looking at it.

25 Representative Carr. What I'm getting at is, the light

1 responds to the valve. It doesn't respond to your switch
2 indication.

3 Mr. Frederick. That's right.

4 Representative Vento. One other thing before we go on
5 to the other problem in the secondary system, what you did
6 next. This relief valve, of course, is a key part of this,
7 apparently. But there was some tail pipe temperature and
8 some other indicators there that were also available.

9 Who was responsible for watching those at this particular
10 point? The tail pipe temperature?

11 Mr. Frederick. What you're talking about is the outlet
12 temperature of the relief valve.

13 Representative Vento. And there's also a tank that this
14 goes to that is not shown on here, and that has an indicator
15 on it and a temperature and so forth. There is a thermocouple
16 on here, and who was responsible for watching those in this
17 particular process? It was just a generally shared thing?

18 Mr. Frederick. The points that you're talking about are
19 not displayed. They are not on the console. They are in the
20 computer. You have to manually call them up.

21 Representative Vento. You have to call those things up.
22 But weren't they called up during this procedure at all?

23 Mr. Frederick. No.

24 Representative Weaver. How many minutes are in we in now?
25 Where are we?

1 Mr. Faust. It is not a normal thing.

2 Mr. Frederick. About an hour.

3 Mr. Faust. We did not know a problem like that existed
4 at the time.

5 Mr. Frederick. If the valve indicated shut, there's no
6 reason to look at the downstream temperature.

7 Representative Vento. The relief valve indicated it had
8 closed?

9 Mr. Frederick. It indicated not open. The red light
10 comes on if it's open and the red light goes off if it is not
11 open.

12 Representative Vento. The impulse to the valve was
13 opening, but not the valve itself?

14 Mr. Frederick. It's not a valve indicator. It is the
15 control signal, on-off switch.

16 Representative Vento. But there is nothing else in the
17 display panel that tells you what the thermocouple reading is,
18 what the tank pressure is, what the temperature in that is?

19 Mr. Frederick. The drain tank, what you're talking about,
20 the quench tank, indications for that are on the reverse side
21 of the panel. In other words, the consoles that are upright,
22 you would have to go around to the back of the panel.

23 Representative Vento. So the only way you could get that
24 is really calling it up from the computer?

25 Mr. Frederick. I did eventually go around there to look

1 and verified that the tank was receiving water. All I could
2 see was that it was heated up and under pressure, which I
3 would have expected after the relief valves had exhausted.

4 Mr. Ries. How many people -- you said this was through
5 the first hour you did not check this, did not call up the
6 temperatures?

7 Mr. Frederick. That's right.

8 Mr. Ries. Who else was in the control room at this point,
9 say through the first hour?

10 Mr. Frederick. Mr. Sheinman the foreman, the Unit 1
11 supervisor was there, and us.

12 Mr. Faust. What he was doing was he got procedures out
13 so we could pick up, when we got the time, to look at the
14 procedures to make sure we carried out actions that were needed
15 and to make sure we carried them all out.

16 Mr. Frederick. So we're operating this on memory now.

17 Mr. Reis. What about alarms on the drain tank?

18 Mr. Frederick. The alarms -- this is a big problem.
19 There is only one audible alarm in the control room for the
20 1600 alarm windows that we have, in other words, the ones that
21 are displayed on the front of the console along with the ones
22 on the reverse panel. So that during the emergency, I made a
23 point of announcing that I didn't want anybody to acknowledge
24 the alarm, that is, push the acknowledgment to silence the
25 alarm, because that would make all the windows stop flashing,

1 and I wanted to read them all to see what was happening. As
2 we began to run out of ideas, I wanted to review all of the
3 alarms that we received to see if anything was happening that
4 we couldn't see.

5 So the alarms that came in on the drain tank were not
6 displayed as being different from any other alarms.

7 Mr. Meyers. So if you had turned off the audible alarm,
8 that meant that would have turned off all of the flashing?

9 Mr. Faust. They would be in and you would not be able
10 to determine which ones were there first and which ones were
11 normally in.

12 Mr. Meyers. Okay.

13 Mr. Frederick. There are several steps in the alarm
14 process. As the alarm comes in, it sounds an alarm and a
15 flashing light. And as long as the alarm stays in -- and you
16 push the button, and the light will go solid. If in the
17 meantime the alarming condition clears itself or goes away
18 and you push the button, the light will go out and you won't
19 be able to tell that it ever came in.

20 If you have three or four alarms at the same time, only
21 one may stay lit out of the three or four. We had probably
22 100 or 200 alarms flashing within the first few minutes.

23 Representative Cheney. But only one audible?

24 Mr. Frederick. Yes.

25 Representative Vento. If they correct themselves, the

1 alarm turns off and the light quits flashing?

2 Mr. Frederick. Yes.

3 Representative Vento. Well, if you weren't pushing the
4 buttons and you just told us you wanted to have a full history
5 of this before you -- if you don't push the button and the
6 problem clears --

7 Mr. Frederick. Then there's a difference in the way it
8 flashes. It would flash brightly if they are coming in, and
9 they would flash somewhat dimmer.

10 Representative Vento. But you wanted a chronology of
11 that?

12 Mr. Frederick. I wouldn't be able to establish the
13 chronology. I just wanted to see what systems were affected
14 by the transient and if we could see something. There are
15 some alarms you expect to get. If you read over them, you
16 just discount them as being normal.

17 But there may be a few that come in that you hadn't
18 e. ced, and those are the ones I was looking for.

19 Representative Carr. Is there any way to isolate the
20 individual alarm? In other words, to shut off the horn and
21 the bell so you can think a little bit and get the lights to
22 flash?

23 Mr. Frederick. No.

24 Mr. Meyers. Were you aware during this time that the
25 reactor had a built-in sump pump that turned on, and what was

1 the significance of that?

2 Mr. Frederick. The operator told me that the pumps were
3 running. I had no indication of that in the control room.

4 Mr. Reis. Any indication what time?

5 Mr. Frederick. Approximately an hour.

6 Mr. Meyers. And that was water that had come out of the
7 reactor cooling drain tank?

8 Mr. Frederick. Yes.

9 Mr. Meyers. So at 10 minutes that drain tank had
10 overflowed? Since the knowledge of the 1019, the sump pump
11 came out?

12 Mr. Frederick. Yes.

13 Mr. Meyers. So that means that the drain tank had sort
14 of overflowed at that point?

15 Mr. Frederick. Yes.

16 Representative Cheney. But you would not have had any
17 indication in the control room that the sump pump was running?

18 Mr. Frederick. No. The sequence of alarms that comes
19 out of the computer that they were able to read later on was
20 backlogged. The alarms came in 100 at a time. The computer,
21 the IBM typewriter just types them out one at a time. So as
22 they were coming in rapidly, probably 10 or 15 per second,
23 it just couldn't keep up. So there was a backlog of maybe
24 two or three hours.

25 Mr. Faust. I don't know what time this fits into, but

1 we had problems with the alarm typewriter, too, at this time.
2 And I don't know what it was, but the easiest way for me to
3 say it is, it sort of started eating the paper. In other words,
4 it got off the track.

5 Representative Carr. Yes, we've all seen that in our
6 offices.

7 Representative Vento. I was going to say, someone called
8 about the sump pump and let you know that it was going. Does
9 that go on frequently?

10 Mr. Frederick. The pump does cycle once or twice per
11 shift on a normal basis. What it is doing then is removing
12 the humidity. It is just about raining in that building.
13 That's normal. The temperature is 100 degrees and the humidity
14 is probably 60 or 70 percent, and it's just always sweating.
15 And that water drips down on this basis and it pumps out on
16 a regular basis.

17 Now, when he called and told me the pump was running, he
18 also told me that the sump level was off scale high. That is
19 when he called me. It wasn't unusual for the pump to be
20 running; it was unusual for the level to be high and the pump
21 still running.

22 So I called up the sump level on the computer through a
23 manual operation and verified that mine was also reading off
24 scale high, and told him to secure the pumps, turn them off,
25 which he did.

1 Representative Cheney. Was that the last time the pumps
2 operated?

3 Mr. Frederick. That is the last time they operated. As
4 far as I know, they stayed off for the rest of the time,
5 because soon after that we went to the auxiliary building and
6 no one could operate them.

7 Representative Vento. But you told them to turn them
8 off. Why?

9 Mr. Frederick. I told them to turn them off because the
10 source of the water now was obviously not sweat on the walls.
11 We were getting water out of the drain tank. So rather than
12 transfer that water out of the building, I told him to stop
13 it.

14 Representative Vento. How much was it at about that time?

15 Mr. Frederick. If the pumps had been running for 19
16 minutes until I told him to turn them off -- someone else
17 would have to compute that. It is probably several thousand
18 gallons that were transferred. They pump normally in a few
19 minutes, like one or two minutes you can pump 200 to 300 gallons
20 out of the building. So probably 50 or 70 gpm pumps each.

21 Representative Vento. Did this prompt any special action
22 on your part when you realized there was some source of water
23 coming from, obviously, not from the condensation but from
24 other sources? What action did you take at that time?

25 Obviously you've got a lot of things that were before you that

1 were going on.

2 Mr. Frederick. I checked the radiation levels and they
3 were not in a line state. And I figured that the volume of
4 water in the building was either not highly contaminated or
5 that it was -- it may have been highly contaminated in a
6 small volume, but it was not enough to set off the alarm.
7 Either way, it did not present a radiological problem at that
8 time, so isolating the pumps, to me, would eliminate the
9 problem, would take care of the problem.

10 Mr. Reis. You said earlier that an outlet temperature
11 was not requested. In the utility's chronology they provided,
12 it was requested at 25 minutes and again at 80 minutes, and it
13 showed that at 25 minutes 285 degrees as the outlet temperature.

14 Mr. Frederick. That would not be abnormal. The tempera-
15 ture of the system being nearly 600 degrees, the outlet
16 temperature of the valve, if it were open, should be 600
17 degrees.

18 Mr. Reis. Right. But wouldn't that indicate that it
19 had stayed open rather than closed?

20 Mr. Frederick. No. You expect the pipe during the
21 discharge to rapidly increase to 600 degrees, and it may take
22 hours for it to cool off.

23 Representative Weaver. I want to impose a generality
24 here to try to help me feel my way. It strikes me, from the
25 answer you just gave now and the other things, that your

1 gauges and other measuring devices were not telling you what
2 was going on in this plant. That is what I am led to surmise.

3 Mr. Frederick. Let me make a statement about the indica-
4 tions. All you can say about them is that they are designed
5 to provide indications for whatever anticipated casualties
6 you might have. If you go out of the bounds of an anticipated
7 casualty, if you go beyond what the designers think might
8 happen, then the indications are insufficient and they may lead
9 you to make wrong inferences.

10 In other words, what you're seeing on the gauge, like
11 what I saw on the high pressurizer level, I thought it was
12 due to excess inventory. In other words, I was interpreting
13 the gauge based on the emergency procedure, where the emer-
14 gency procedure is based on the design casualties. So the
15 indications then are based upon my interpretation.

16 Hardly any of the measurements that we have are direct
17 indications of what is going on in the system. They're all
18 implied measurements.

19 Representative Weaver. But I'm not absolutely clear of
20 the conclusion of design there, because you've got a gauge,
21 you say, on the sump pump that, because of sweating, you expect
22 some operation.

23 Mr. Frederick. I would not expect six feet of water.
24 The level indicator tops out at six feet. The sump is six
25 feet deep.

1 Representative Weaver. Well, when you heard it at six
2 feet, what did you do?

3 Mr. Frederick. That's when I isolated the pump.

4 Representative Weaver. With the relief valve that is
5 open at this point -- were you in the operating room when that
6 relief valve opened?

7 Mr. Frederick. No, that's a different shift. The only
8 way they found out it was open was to go around to the reverse
9 panel.

10 Representative Vento. On a different shift they found
11 that. But you weren't aware it was stuck. You've already
12 said that.

13 But that's not the point I'm getting at, what I'm getting
14 at, since you weren't there. But in other words, this tail
15 pipe temperature apparently remained high for some time after
16 that. You claimed it had been 574 in the system, and finding
17 out that it was 230 an hour later didn't particularly seem
18 unusual to you.

19 Representative Vento. But I'm wondering --

20 Mr. Faust. That's an average temperature. It actually
21 should have been up around 600 degrees.

22 Representative Vento. If it had been -- in other words,
23 what you're saying, if it had been 600, that would have indi-
24 cated to you the temperature inside the system was the same
25 as that tail pipe, and obviously the only way that could happen

1 is if you've got the steam passing through there directly and
2 it is still open. And you were reading at 300. But the
3 thermal qualities, I guess in retrospect, are somewhat dif-
4 ferent.

5 Doesn't your procedure that you follow indicate what the
6 temperature range would be for that or could be for that at
7 all, do you recall?

8 Mr. Faust. We have a procedure that covers a leaking
9 relief valve, if we suspect it. At that point we did not
10 suspect it.

11 Representative Vento. So your parameters you were looking
12 at were not necessarily based on procedure.

13 Mr. Faust. What maybe you should try to understand here
14 is that we are trying to gain the proper procedure to go at
15 it. We were into possibilities of several procedures, not just
16 one, to cover what was happening. It hasn't been written, in
17 fact. So we were still trying to determine which procedure
18 to go by.

19 Representative Vento. Well, obviously the proper procedure
20 here would have said that 300 degrees or 280 degrees in the
21 tail pipe should have been an indication.

22 Mr. Frederick. That's the point he's talking about. In
23 other words, what came out of the computer on the typewriter
24 was an alarm that said: Temperature hot. But we could not
25 see that, because the alarm typewriter was backlogged several

1 hours.

2 Representative Weaver. Mr. Frederick, back to the sump
3 pump. Where did you think this water was coming from?

4 Mr. Frederick. The drain tank, the reactor cooling
5 drain tank.

6 Representative Weaver. What would that signify?

7 Mr. Frederick. That would signify that we had opened
8 the relief or blown the rupture disk on the reactor cooling
9 tank due to the exhaust of the relief valve.

10 Mr. Ries. When did you start to assume that that was
11 not closed? When you were getting all that water continuing
12 to come out?

13 Mr. Frederick. I did not assume that it was continuing
14 to come out. I just presumed that it came out and it was
15 lying there, and this was the first time I saw it.

16 Representative Weaver. Enough came out to rupture the
17 disk, is that what you're saying?

18 Mr. Frederick.. Yes.

19 Representative Weaver. And so the valves closed again,
20 but the water was up sufficient already.

21 Mr. Frederick. That is the way I was reading it.

22 Representative Weaver. On Wednesday you guys went off,
23 what, at 5:00?

24 Mr. Faust. 3:30 in the afternoon.

25 Representative Weaver. When you caucused, did you have

1 any feeling that there might be damage to the reactor?

2 Mr. Frederick. Yes. During the day we found out.

3 Representative Weaver. Significant damage?

4 Mr. Frederick. The possibility existed that there was.
5 What everybody calls significant and what I call significant
6 are different. During the time that the reactor cooling
7 pumps were secured and the reactor cooling system temperature
8 was recorded high, we felt that we were developing a problem
9 in the core as far as excessive temperature. Now there was
10 no way to tell what the core temperature was. I was just
11 assuming it was very hot. It had to be at least 620 degrees.
12 So, being without cooling water flow and without having
13 circulation, that was the time when I was feeling that we
14 were damaging the core.

15 Representative Cheney. Can we talk for a minute, Jim,
16 about that?

17 Representative Weaver. Sure.

18 Mr. Frederick. We turned them off because of excessive
19 operation and because the minimum temperature for operating
20 those pumps had already been exceeded, the minimum tempera-
21 tures. We were seeing degradation of flow, moving from
22 100 percent down to 60, 40. They were beginning not to pump
23 any more water. They were securing themselves. Eventually
24 they would have been spinning steam and not doing anything,
25 the problem there being that we could have damaged the reactor

1 cooling pump seals and developed a leak where the steam would
2 come out through the pumps.

3 So, since the flow was degrading and we had the potential
4 for damaging the seals, we decided then to secure the pumps,
5 first to see if we could survive on just two pumps. And then
6 we could not keep the other ones on either.

7 Representative Vento. And then you went completely on
8 convection cooling?

9 Mr. Frederick. That was the idea. Once we secured the
10 pumps, we were already in the process of raising the steam
11 generator level and we established natural circulation.

12 Representative Weaver. What events ther -- the problem
13 is still this relief valve, right? What events finally brought
14 about that -- brought that about?

15 Mr. Frederick. That decision was, I'm pretty sure, two
16 and a half hours into the accident. Once we had established
17 an equilibrium in the steam generators and we were on natural
18 circulation, no one could comprehend why we couldn't raise
19 pressure in the system.

20 Representative Weaver. Were you talking a lot about
21 this?

22 Mr. Frederick. Yes. We were trying to decide what it
23 was that was holding the pressure down. We had no indication
24 of a leak in the primary system. A leak in the primary system
25 should give you a radiation alarm. All we had was a high

1 building pressure, which we thought was caused by a steam leak
2 on the secondary side.

3 Once we bottled up the steam generator and isolated it --
4 one time we isolated it. The pressure came down. That con-
5 vinced us it was steam. So the primary relief valve was not
6 entering into the picture as a source of pressure building up.

7 But when we finally isolated the generators and eliminated
8 them as a source of steam, then it occurred to us that some
9 other source of water was going into the building, even though
10 it was not radioactive. Someone suggested, isolate the auto-
11 matic relief valve; it may be leaking. It was not thought
12 that that was going to solve all our problems because that
13 did not appear to be the problem, even then. But when we shut
14 it building pressure dropped rapidly, and that allowed us to
15 increase pressure in the system.

16 We could press up to about 2,000 pounds.

17 Representative Vento. During this period after, you
18 didn't give us an average temperature. What was happening to
19 your temperature? In other words, you said it started to drop
20 in your initial sequence. It started to drop?

21 Mr. Faust. Yes.

22 Representative Vento. It was starting to drop. Did it
23 start rising again?

24 Mr. Faust. Well, what came about was, when we shut the
25 pumps off we had TH payout on our indicators.

1 Representative Vento. What does that mean?

2 Mr. Faust. In other words, they went high. They went off
3 the high scale. They couldn't go any further.

4 Representative Vento. And during this time the pressurizer
5 indicators were all right? These were indicating that they
6 didn't -- at one point you said they were way down. But they
7 were now indicating --

8 Mr. Faust. 50 percent was what I was shooting at. I was
9 having a problem with the B generator in that this was just
10 indicating to us possibilities of a primary-secondary leak,
11 which led us to bottle up the B generator.

12 Mr. Frederick. The problem with the system temperature
13 was that he was looking at an average temperature. The two
14 parameters that you average together, he was able to lower the
15 cold temperature, but the high temperature was pegged out. So
16 that as it averaged, that value wouldn't change any more even
17 if the system temperature went way above that. That temperature
18 wouldn't go any higher.

19 So the average, with this cold temperature going down,
20 it appeared that the temperature, the average temperature was
21 going down, because the average would get lower, where in fact
22 the system temperature was going up, because we just could not
23 read it any higher.

24 Representative Vento. But it had initially started to
25 drop. You suggested it went from 570.

1 Mr. Faust. Maybe we should reemphasize that TH coming
2 out of the top of the core, in other words, was going up as
3 far as we could tell. We had an indicator over on a panel
4 that sits over to the left that is back behind that one man
5 was monitoring, and he was indicating, I believe, that he could
6 just see an indication of TH up around 800, which is as high
7 as that went. And he said it looked like it was just bordering
8 that.

9 But that was some input, too. And the TC was being
10 cooled off by me feeding the generators.

11 Representative Vento. So in other words, what you're
12 saying is the instrumentation was not adequate to give you --
13 to know the parameters of what was happening?

14 Mr. Faust. This board you see right now, if that had
15 been up and had been in our display up in front, it would
16 have told us a lot. That would have read up into the four-digit
17 place. That would have told us what the core temperature was.

18 Representative Vento. Was that something that was just
19 put in for this experience?

20 Mr. Frederick. Yes.

21 Representative Weaver. This was after the accident.

22 Representative Vento. But are they normally in reactors?

23 Representative Weaver. The thermocouples themselves are
24 very seldom there. This is just an experiment.

25 Representative Vento. I see. In other words, they didn't

1 know what the parameters were because it was off the top of
2 the peg.

3 Representative Weaver. That's right.

4 Representative Vento. In other words, they didn't know
5 what the temperature at the high range was. You had no way
6 of knowing.

7 Mr. Faust. Not at that point.

8 Representative Weaver. Before the accident, did anyone
9 ever question the idea that the levels of the pressurizer
10 could possibly be different than the levels in the reactor
11 vessel? Or just did you absolutely assume that that was the
12 way it was?

13 Do you follow me?

14 Mr. Frederick. What everybody punches into you on an
15 emergency procedure that involves a cooldown was, don't let
16 the level go out of the pressure vessel.

17 Representative Weaver. Right now you read the level of
18 the reactor vessel from the level in the pressurizer.

19 Mr. Frederick. That's right.

20 Representative Weaver. Did anybody ever say, hey, I
21 wonder if that actually was right, or that was just gospel?

22 Mr. Frederick. None of the transients that we had
23 examined either on the simulator or through the emergency
24 procedures supposes that you would develop a steam bubble in
25 the plant in the tubes, somewhere other than the pressurizer.

1 Representative Weaver. So nobody ever questioned that?

2 Mr. Faust. Well, as far as we know, we don't know that.

3 Representative Weaver. But what I'm talking about is
4 you personally. You never heard anybody question this?

5 Mr. Frederick. We always talk about emergency procedures
6 and stuff. But if the level had went on in the pressurizer,
7 we could not predict what would happen. We didn't have any
8 emergency procedures or safety reports that told us what we
9 could expect or any indications that would tell us actually
10 what happened.

11 Mr. Faust. That is the level going out of the pressurizer.
12 We didn't face that. We were faced with the full pressure.

13 Representative Vento. If this had happened somewhere
14 else, you could have read it up here without any trouble? You
15 would have read it if indeed the source of the loss of pressure
16 was located anyplace else in the system? You would not have
17 had the same type of problem?

18 Mr. Frederick. No, not really.

19 Representative Vento. Because it would have been demon-
20 strated in the system. It would have been demonstrated by
21 reading it off of the gauge. But insofar as you read it off
22 of this at this source --

23 Mr. Frederick. If the leak had been somewhere else in
24 the system, then that low pressure point would have caused the
25 pressure to go down.

1 Representative Vento. Unless the reactor heat as such --
2 I suppose that you could still get a bubble, but you would have
3 been able to isolate it.

4 Mr. Faust. I see what you're getting at. I don't think
5 that's necessarily true. We are dealing with a very hot system
6 that still might have forced the pressurizer level up with a
7 leak elsewhere. But later on it might have gone down.

8 Representative Vento. That is another possibility. But
9 I guess your procedures take that into consideration. Because
10 of the tremendous heat here, this could have forced all of
11 this up here, so you would have water up here, but the pressure
12 down here, created by the intense heat, could have offset
13 your gauges again.

14 Representative Weaver. No, the alarms -- you say how
15 many audio alarms were going off right at first?

16 Mr. Frederick. There is only one audio signal in the
17 room.

18 Representative Weaver. There is only one?

19 Mr. Frederick. Off the annunciators on the panel, there
20 is only one.

21 Representative Weaver. The distinct differences -- there
22 are not seven different bells going off?

23 Mr. Frederick. No.

24 Representative Weaver. There is just one.

25 Mr. Frederick. Right. If you get a panel alarm, you

1 get a beeper. Then when the alarm comes in on the computer,
2 you get a different beeper.

3 Representative Weaver. Those are only two different
4 sounds, is that correct?

5 Mr. Frederick. Yes. The radiation monitors are a differ-
6 ent sound, but we didn't have those.

7 Representative Weaver. Let's get to the spike. Who had
8 the responsibility? What person had the responsibility for
9 reading the strip chart?

10 Mr. Frederick. I was on it when it happened. Are you
11 talking about the reactor building a pressure spike?

12 Representative Weaver. Yes.

13 Mr. Faust. And he pointed it out to me.

14 Representative Weaver. And then what happened?

15 Mr. Frederick. It initiated the reactor building spray.
16 Before the reactor building spray even fully initiated, the
17 spike was gone. In other words, the transient was only
18 seconds. So the need to continue the reactor building spray
19 was gone already.

20 Now, the reactor building spray, there are chemicals in
21 there. There is acid and caustic, designed to remove iodine
22 and to maintain the Ph. Okay, it is undesirable to spray that
23 stuff all over the equipment. That is why I stopped the spray
24 signal.

25 Representative Weaver. But what did the spike mean to

1 you? What caused it? What caused that spike, that buildup
2 of pressure?

3 Mr. Frederick. I had no idea at the time?

4 Representative Vento. Did you hear any noise at that
5 time?

6 Mr. Frederick. No.

7 Representative Markey. Had the sprinkler system ever
8 gone off before?

9 Mr. Frederick. No, never.

10 Representative Markey. What were you told if the
11 sprinkler system did go off that it indicated? What would
12 have been your visceral reaction? What did it mean to you?

13 Mr. Frederick. It shouldn't go off unless there is a
14 buildup of the pressure. We see graphs that project a buildup
15 of the pressure. It should round out the graph and bring it
16 back down to normal.

17 Representative Weaver. Did you say hey?

18 Mr. Frederick. Yes.

19 Representative Markey. To who?

20 Mr. Frederick. The people standing around were engineers.

21 Mr. Reis. How many people were in the room at the time?

22 Mr. Faust. That's a hard question to ask us. We weren't
23 taking count of the people in the building. We were watching
24 the system.

25 Representative Markey. So you were the first one to

1 notice it.

2 Mr. Faust. No, Ed was over at that point on the panel.

3 Mr. Frederick. I told Mr. Marshall, Mr. Logan.

4 Mr. Reis. Who are they?

5 Mr. Frederick. Superintendents, supervisors.

6 Representative Weaver. Was there any NRC persons there?

7 Mr. Faust. I don't know.

8 Representative Weaver. Did you have respirators on at
9 that time?

10 Mr. Faust. I don't think so.

11 Mr. Frederick. I don't remember.

12 Mr. Faust. Because of conditions in the control room,
13 there wasn't a necessity to have the respirators on full-time
14 at that time, depending upon what the health physics people
15 were relaying to us for the conditions in the control room.

16 Mr. Frederick. Several times we had communications
17 problems because of the respirators. So we would just pull
18 them off and say what we had to say, and then put them back
19 on. I know several times when I wanted to talk to the super-
20 intendent or to the supervisor in charge I did have to take
21 off the mask. I don't know if this was at that time.

22 Representative Weaver. Then after the spike occurred,
23 you told the other people?

24 Mr. Frederick. I assured the spray and was assured that
25 the building pressure on both channels was indicating back

1 down to where it was. I discounted that as not being signi-
2 ficant enough to stop what I was doing and let the makeup
3 system take care of it. The building pressure was back to
4 normal. It could have been an instrument malfunction that
5 caused that. It was such a rapid spike that it did not imme-
6 diately tell me that there was an explosion in the building.

7 Representative Markey. What about the sprinkler system
8 being triggered, though? Your instinct must have told you
9 there was something unusual going on.

10 Mr. Frederick. Certainly. But it could have been an
11 instr-ment panel malfunction.

12 Representative Markey. Was there anyone else in the room
13 at the time that occurred who would have had superior knowledge
14 to what you would as far as what was going on? Anybody from
15 NRC or Babcock & Wilcox?

16 Mr. Frederick. It wasn't until a day and a half or two
17 days later that I was told that there could possibly have been
18 a hydrogen explosion. No one brought that up at the time.

19 Mr. Reis. When you announced it or said, oh, we've got
20 a spike, or whatever you said, was there a reaction from other
21 people in the room? Did anybody else, when you walked back
22 over to start fiddling with your other instruments, your
23 makeup instruments, did anyone go over to try and analyze
24 that? Or did it just get lost in the air?

25 Mr. Frederick. I think Mr. Marshall tried to figure it

1 out, and Gary Miller was particularly interested in it.

2 Mr. Reis. You said it could have been an instrument
3 malfunction. We all know that now, that it could have been.
4 But at that time, did that occur to you or did anyone else say
5 that immediately?

6 Mr. Frederick. Yes.

7 Mr. Faust. We both said it.

8 Representative Vento. Have you seen those type of
9 instrument malfunctions before?

10 Mr. Frederick. On a graph.

11 Representative Vento. Have you seen them at this plant?

12 Mr. Frederick. Yes.

13 Representative Vento. In other words, you have had those
14 type of instrument malfunctions before?

15 Mr. Frederick. Yes. Any kind of graph recorder, which
16 is what it is, a little pen recorder like that is sensitive
17 to all kinds of things, a bump on the arm or whatever.

18 Mr. Meyers. But this meant that the actual something --
19 what was it, reading pressure actually went to 28 psi. So
20 there had to be something real. Whatever instrument was
21 sensing pressure did sense a high pressure.

22 Mr. Frederick. That's true. The trace on the graph would
23 to me, which it did, indicate that it was not a pressure
24 transient in the building due to steam release or the reactor
25 cooling drain tank release or anything like that. It was

1 sufficiently abnormal to be just completely out of my realm of
2 experience.

3 Representative Markey. Could you show us what you saw
4 there?

5 Mr. Frederick. This graph, both of them, in fact -- we
6 saw it on one, the pen moved up to 30 pounds and then straight
7 down.

8 Representative Weaver. That's red, isn't it?

9 Mr. Frederick. It's green. There's a red one and a green
10 one. The green is low range. The red is wide range.

11 Representative Weaver. Now we know why there were two
12 singers.

13 Mr. Frederick. This is a picture of the graph. This is
14 the line that it was tracing. It went straight up and right
15 back down again.

16 Representative Weaver. This is up, isn't it?

17 Mr. Frederick. This is up. This is high pressure.

18 Now, if I was going to see a pressure transient in the
19 building due to steam, it would look like this, and when I
20 turned on the spray it would look like that. And this time
21 here could be several minutes. We're talking 15 or 20 minutes.
22 A spike like this is absolutely meaningless to me. Now I know
23 what it means.

24 Representative Markey. How long, to the best of your
25 knowledge, was that visible?

1 Mr. Frederick. That's less than a second.

2 Representative Weaver. No. On the chart.

3 Mr. Frederick. It would be there for 20 minutes to a
4 half an hour before it went around the corner on the chart.
5 Usually on a chart like that one hour's worth of information
6 is displayed directly in the center of the chart, and it just
7 moves on around the side.

8 Representative Markey. So it would be in the center for
9 about a half an hour. So it might be on the chart for about
10 an hour.

11 Representative Weaver. We've been told it was up for
12 two hours where it was still exposed.

13 Mr. Frederick. Probably seven or eight hours until it
14 went all the way around and it went up in the spool. But you
15 don't see that. All you see is the front of the graph like
16 this. And what I'm saying is that this display here was
17 probably an hour alone before it goes around the corner and
18 you can't see it any more.

19 Representative Vento. Is this the single-pressure one
20 or is there more than one here?

21 Mr. Frederick. These two are both reactor building
22 pressure reporters.

23 Mr. Faust. There's actually four indicators right there,
24 two low range and two high range.

25 Representative Vento. But the point is that they both

1 recorded the same thing?

2 Mr. Frederick. I don't know that for sure.

3 Mr. Faust. They are recording -- one is more sensitive.
4 In other words, in the low range --

5 Representative Vento. So when an instrument malfunction
6 would occur on one, you would not expect it to occur on both,
7 would you?

8 Mr. Frederick. The conclusion I made that it was an
9 instrument malfunction was incorrect.

10 Representative Vento. Well, I don't know if it is or
11 not. I don't know, maybe it was right. But I'm just saying
12 it did occur on both of them simultaneously, at the same time.

13 Mr. Frederick. All I'm saying now is that what I saw on
14 the graph did not relate to any of the procedures or any of
15 the transients that I had analyzed previously. So that when
16 I saw that spike and it went away and we were back to normal
17 and I was able to secure the spray, I had to discount it as
18 being something that happened that had very little effect.

19 Representative Carr. The spray sensors are different
20 from the instrument sensors, right? Or does the spray communi-
21 cate with this?

22 Mr. Frederick. The only way that you can tell that you're
23 spraying the building -- another direct indication is the pump
24 is running and the outlet valve is open and you have pressure
25 on the pump.

1 Representative Carr. I'm interested in the spray sensor.
2 The spray senses an increase in pressure independently from
3 that?

4 Mr. Frederick. No. This is the instrument that activates
5 the spray system.

6 Representative Carr. So if the instrument malfunctions,
7 the spray will go off.

8 Mr. Frederick. You would have to have three instrument
9 malfunctions.

10 Mr. Meyers. There are three pressure sensors. So
11 actually, each of those has to independently --

12 Representative Carr. So there is a voting procedure.

13 Mr. Meyers. Do all three have to indicate high pressure
14 or two out of three?

15 Mr. Frederick. Two out of three.

16 Mr. Vento. In the other instrument malfunctions, have
17 you ever had these sprays go off before?

18 Mr. Frederick. No. When we tested this system, we did
19 it with air to see if the nozzles would pass. You don't want
20 to spray this. There are electrical wires and everything.

21 Mr. Meyers. What could have had two of those three
22 sensing devices sense high pressure and lead them to think the
23 pressure was high, other than high pressure, real high pressure,
24 actual high pressure? Is there anything that decides the
25 pressure is going up that could have led those sensors to

1 think the pressure was high?

2 Mr. Frederick. A test signal.

3 Mr. Meyers. Would a test signal go to two of them at the
4 same time?

5 Mr. Faust. No. In fact, you would have to hook it up.

6 Mr. Frederick. It would have to be a lengthy manual
7 action to get it to do it, other than actual building pressure.

8 Mr. Meyers. Is there anything that you can think of other
9 than excess building pressure that could have simultaneously
10 led the meter to read 28 psi and to turn on the spray tanks
11 or turn on the containment spray?

12 Mr. Frederick. No, it had to be high-level pressure.

13 Mr. Faust. There had to be a pressure surge in the
14 building for it to happen.

15 Representative Markey. How long was the sprinkler system
16 on?

17 Mr. Frederick. A few minutes.

18 Representative Markey. And did you turn it off?

19 Mr. Frederick. I turned it off. You have to do it
20 manually.

21 Representative Markey. And what was your basis for
22 turning it off?

23 Mr. Frederick. One, that the building pressure had
24 returned to its original value. The spray system is designed
25 to return the building back. And two, the danger of spraying

1 the caustic and acid on the operating equipment in the building
2 could cause more problems. And I told the supervisor I was
3 going to secure it, and I turned it off, and he agreed with
4 me that it was all right to do, because the building pressure
5 on all four channels indicated low.

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 Mr. Markey. Did the supervisor agree with you at that
2 point, that it was an aberration?

3 Mr. Frederick. Because of the spike, we didn't understand
4 it at the time, but we went on with the emergency procedures.

5 Mr. Markey. And because of the confusion, did you not
6 have time to go back?

7 Mr. Frederick. Right.

8 Mr. Cheney. During this period of time -- between when
9 you cooled off the reactor coolant pumps and discovered that
10 the relief valve was stuck open and got it closed, what was
11 that an hour?

12 Mr. Frederick. You want to know how much time between
13 when we turned off the pumps and when we shut the reactor
14 coolant pump?

15 Mr. Cheney. Yes. Wasn't that the key time in terms of
16 damage to the core?

17 Mr. Frederick. I believe it was probably about an hour --
18 the recorded time that I've seen was we turned up the pumps at
19 70 minutes, shut the valve at 2.3 hours.

20 Mr. Faust. These pumps went off at different times now.

21 Mr. Cheney. What did you think was the status of things?
22 Was was going on in the control room?

23 Mr. Frederick. We were trying to establish natural circu-
24 lation. We were looking for decrease in temperature to indic-
25 cate that natural circulation was taking place.

j1 2

1 As time went on, and that indication did not come about,
2 we became increasingly anxious to do something. Eventually
3 we restarted the pumps in spite of the damage that may have
4 occurred to the pumps. We had to restart them, because natural
5 circulation never did occur.

6 Mr. Cheney. And this is the same time when you're trying
7 to figure out where the leak is in the system?

8 Mr. Frederick. Yes, where the low pressure is coming from.

9 Mr. Faust. I should say that I find it hard to say that
10 natural circulation didn't occur -- myself, I feel we had some
11 sort of cooling going on there -- to me, and if you look at it.
12 Now, we had to have some sort of cooling going on. Temperatures
13 were high, but from what you're hearing in reports, we did not
14 get any melt -- that is, from samples that were pulled out of
15 there, so it's telling me we were removing heat, which wasn't
16 a desirable way to do it, but it was -- I guess you could say
17 it was what we had at the time.

18 Mr. Frederick. Craig and I have speculated that the only
19 cooling we had was from the B-loop, high-pressure injection
20 that was going in the B loop. It had to move across the core,
21 and then out the pressurizer through the relief valve. That
22 was the only cooling water path -- flow path that we think we
23 had.

24 Mr. Carr. What would be the source of the pressure spike
25 say if you had a hydrogen explosion in the reactor?

1 Mr. Frederick. In the building, not in the reactor.

2 MR. Faust. It might have been down where the gases would
3 have possibly, if you want to look at it that way -- this is
4 if you want to try to look at that way, would have been down
5 where the RC drain tank is, because that is inside a little
6 containment building itself down there.

7 And that is where your gases would have been building up
8 possibly. And if that is where it would have occurred, that
9 is where I would have said it might have happened. And it
10 looked more like it would have a burn.

11 Mr. Meyers. Why did you say it looked more like it was a
12 burn?

13 Mr. Faust. Well, apparently we didn't lose anything if
14 that spike occurred. What we were looking at, also, we were
15 still monitoring the system pressure and nothing changed.
16 That spike occurred; nothing changed in the system.

17 Mr. Meyers. You mean if it had been an explosion, you
18 would have expected the equipment to be damaged?

19 Mr. Faust. Yes.

20 Mr. Weaver. Let me ask this question, then you can go
21 on.

22 My question is -- well, Bob's question is -- your background
23 and training, let's ask that first.

24 Go ahead, Bob, if you want to put it differently.

25 Mr. Carr. Well, what was your professional track which

j1 4

1 took you to that room that day? I don't want high school or
2 anything like that, but were you in the Naval Reactor Program
3 or what?

4 Mr. Frederick. All my training came through the Naval
5 Reactor Training Program, six months at Bainbridge, Maryland;
6 six months at a Westinghouse simulator prototype in Connecticut;
7 and then the remainder of my six years in the Navy was on a
8 submarine, operating an S3G core.

9 Mr. Carr. What is that?

10 Mr. Frederick. It's a General Electric steam plant for a
11 submarine, the same type of pressurized water reactor, just on
12 a small scale.

13 Mr. Faust. And it is also the difference in controlling
14 features here, because they do controlling off rods due to
15 highly enriched uranium fuel, where we do it on a boron control,
16 a lot of it. There is a little shift in it.

17 Mr. Carr. But you are familiar with the reactors pumps --
18 house all this?

19 Mr. Frederick. Yes.

20 Metropolitan Edison has a training program, too.

21 Mr. Weaver. How do you compare the two programs,
22 Metropolitan Edison and the Navy?

23 Mr. Frederick. Almost identical.

24 Mr. Carr. So you were at Met Ed and they have a training
25 program, and did you operate any of there other reactors

1 before you went to this one?

2 Mr. Frederick. Unit 1. We weren't licensed on it, but
3 we operators-in-training.

4 Mr. Carr. Now, B&W also has a simulator, and did you go
5 and do work there as well?

6 Mr. Frederick. Probably a total of 10 or 12 weeks on the
7 simulator altogether. It is a computer; that's all.

8 Mr. Carr. In terms of your experience, had you at other
9 times gone through the experience of going through emergency
10 procedures, or was this the first emergency?

11 Mr. Frederick. No, we had had several. We had a safeguards
12 evacuation.

13 Mr. Faust. You're talking about in the Navy now, too. And
14 it is not new, going through transients in plants, for us.

15 Mr. Frederick. In Unit 2 we had several.

16 Mr. Carr. And of course there was your entire thing at the
17 B&W simulator emergency procedures over and over again.

18 Mr. Frederick. Along with start-ups.

19 Mr. Carr. And is your background the same?

20 Mr. Faust. Almost the same. You could say it's almost
21 identical, the same as far as schooling goes, right up until
22 licensing at Three Mile Island.

23 Mr. Weaver. Did you have a six-year hitch?

24 Mr. Faust. Seven years.

25 Mr. Carr. When were you licensed?

1 Mr. Faust. The 30th of October, '77.

2 Mr. Reis. You were in the same class or something?

3 Mr. Faust. Yes.

4 Mr. Cheney. Are you licensed for a specific reactor?

5 Mr. Frederick. Only Three Mile Island, Unit 2.

6 Mr. Cheney. Then it's not good at another reactor?

7 Mr. Frederick. That's right.

8 Mr. Carr. One other thing in terms of the background of
9 this whole event, is a lot of these events happened within the
10 first 12 or 15 minutes, and things were very hectic. As part
11 of your training, were you trained in remembering things --
12 I mean, I can't remember what my secretary told me this
13 morning. I'm kind of interested -- your brains were slammed
14 rough a hectic event, and ever since that event, up to this
15 day, and probably for several years or after, you're going to
16 be asked to reconstruct what happened.

17 And my own experience in interrogating witnesses -- it
18 isn't a question of lying; it's a question of memory cells
19 trying to make order out of what was probably a pretty chaotic
20 system, and it goes to really how confident are you?

21 I know that you're confident, because you wouldn't tell
22 all this. But in the deep recess of your mind, is there
23 something that you have omitted or something that you have put
24 in the wrong sequence. I mean, you did five steps.

25 Mr. Faust. We're still doing that.

1 Mr. Frederick. In the course of an emergency like that,
2 you may take 50 or 75 actions in a very short time, some of
3 them being automatic, or things that you have drilled enough
4 to know what to do; and in the course of trying to recover or
5 doing something abnormal, you may attempt three or four avenues
6 to try to get something to work, and the only one you remember
7 is the one that worked.

8 That is what I'm finding now. All the things that I tried
9 in the make-up system to reestablish the pressurizer level I
10 don't remember valves I hit, which flows I tried to adjust.
11 The only sequence of events that I can remember is the stuff
12 that worked.

13 Mr. Carr. Have you gone out to the BSW simulator to try
14 and perhaps -- try to go through this thing in your mind?

15 Mr. Frederick. I'm dying to go.

16 From what I understand, they have been able to reconstruct
17 the accident on a simulator, but I would pay first class to
18 get there and see it.

19 Mr. Carr. Do you think it would help your recollection?

20 Mr. Frederick. Sure.

21 Mr. Carr. That it might bring some things to life. I'm
22 sure your stories aren't going to change radically, but would
23 it refine your recollection to go out there?

24 Mr. Frederick. It would probably bring back a few things.
25 I'm not saying going down there would -- I would all of a

1 sudden remember what happened.

2 But it is more curiosity than anything else.

3 Mr. Weaver. Do you think you were prepared enough; is
4 that one of your motivations to go down there, that after this
5 accident -- that you weren't prepared enough, they didn't give
6 you enough training?

7 Mr. Frederick. I think that the training philosophy was
8 inadequate. In other words, the basic assumption is that the
9 design encompasses enough emergencies and anticipated casualties
10 that what happened there probably couldn't happen.

11 So every time we approach this type of accident, the outcome
12 was assumed. In other words, the safety systems all activated,
13 the emergency feed system worked, and the transient was
14 monitored down to a shutdown condition.

15 And although they would throw in a few instrument errors
16 every once in awhile, the basic philosophy was everything is
17 going to work, and it will be okay.

18 We never failed two or three safety systems on the simulator.
19 As a matter of fact, the simulator is not capable of reproduc-
20 ing a solid pressure. The program breaks down and it doesn't
21 work.

22 Mr. Cheney. Do you mean the simulator that B&W has?

23 Mr. Frederick. One of the drills you go through is manually
24 controlling the plant -- in other words, no automatic system;
25 put two guys on the pile and try to do a start-up and a

1 shutdown manually, controlling every knob, and sometimes you
2 make mistakes -- overfeed, underfeed, whatever, and the
3 pressurizer goes solid -- well, that is when you reinitiate,
4 because the computer can't understand that. The computer
5 can only do what you tell it to do, and they have not programmed
6 it for that.

7 Mr. Cheney. So you have never previously gone solid and
8 been able to manage it.

9 Mr. Frederick. Been able to see what happens.

10 If they had a program to show you how a solid -- we have
11 seen it in the Navy.

12 Mr. Faust. We are also taking things out -- like you said,
13 we are taking things that normally, under conditions at plants,
14 aren't set up for that. I mean, we were not setting it up to
15 go manually in power or down. We expect certain automatic
16 things to happen; the system should be lined up.

17 Mr. Frederick. A failure of the emergency feedwater system
18 is always assumed to be the pumps didn't start or the automatic
19 valves jammed shut, but only one train.

20 We have two emergency feedwater systems. In this case
21 both of them failed simultaneously. That assumption is against
22 the rules.

23 Mr. Vento. But they failed because of the pressure, didn't
24 they?

25 Mr. Frederick. They failed because of the blocked valves.

j1 10

1 Mr. Faust. The blocked valves were shut. They shouldn't
2 have been shut.

3 Mr. Weaver. We had somebody yesterday tell us -- an
4 expert on this kind of thing tell us that it was a minor thing,
5 and there is no real problem.

6 Mr. Frederick. That transient we could have survived.

7 Mr. Faust. Even we feel that way. What happened though
8 was that covered up a problem, another problem that developed
9 in the plant.

10 Mr. Vento. But you opened those up. You opened those up,
11 didn't you?

12 Mr. Faust. About eight minutes into it.

13 Mr. Vento. That was at eight minutes, but then you came
14 back and closed those down because you were worried about going
15 to a solid system?

16 Mr. Faust. No; that is feed. That was establishing the
17 level in generator.

18 Mr. Vento. I want to ask you a question: Does the simu-
19 lator that you have go through a scenario where you damage
20 those feed pumps?

21 Mr. Faust. No, it doesn't.

22 Mr. Vento. It does not go through that type of scenario?

23 Mr. Frederick. It will go through a scenario, where out
24 of the two emergency feed systems, one might be disabled --
25 one entire train, you can assume.

1 Mr. Vento. So they always leave you with this train that
2 is operable?

3 Mr. Frederick. Sure.

4 Mr. Faust. In other words, you are saying we could possibly
5 lose something here, but you would not lose them both.

6 Mr. Vento. I had another question, but it does not deal
7 with the training program.

8 Mr. Weaver. Let me just make a comment here, because I
9 think one of the central questions that each of us are going
10 to have to ask ourselves that is relevant here, is that you
11 can go on and get more training and put a solid pressurizer
12 into the computer and train for that.

13 Really, the question we're going to have to ask ourselves
14 is is that it, a few more things like this, in training people
15 to handle them. Or are there an infinite number of potentials?

16 You know, there are 2 billion possible moves in the first
17 four moves of chess -- 2 billion. In other words, there are
18 an infinite number of moves.

19 Is this what we are dealing with here -- an infinite number
20 of things that could go wrong -- or not? Or are they finite
21 and rather simple, and we solve this problem, and we're all
22 right?

23 I'm not asking you this question. It just occurred to me
24 that that is really a central question that we're going to
25 have to determine after we determine the facts. Then we're

j1 12

1 going to have to think about that conceptually.

2 Well, Bruce, go ahead.

3 Mr. Vento. Well, I don't want to if you have questions on
4 training. I think you should proceed with that.

5 Mr. Frederick. The training -- by the way, I want to say
6 this, the training that we get is in response to the examina-
7 tion procedures that the NRC uses. In other words, they know
8 the type of questions the NRC is going ask, the type of response
9 that they want to emergency procedure questions.

10 Invariably the NRC will say, "What are your immediate
11 actions on this emergency," and you are supposed to memorize
12 them and reproduce them word for word on a piece of paper.

13 That type of examination procedure I think is detrimental
14 to expanding your training, in other words.

15 Mr. Carr. You train to pass a test, rather than operate a
16 plant?

17 Mr. Frederick. Right. We should be probing deeper into
18 how these keep changing.

19 Mr. Carr. I was going to ask about the licensing process.
20 Is the licensing process merely a written examination?

21 Mr. Frederick. No, it is an eight-hour written and
22 eight-hour oral.

23 Mr. Carr. Eight-hour oral -- do they ever -- do you go to
24 the simulator and use the simulator as part of the testing
25 procedure, in other words, they set up?

ce-Federal Reporters, Inc.

1 Mr. Frederick. Routinely, in the annual requalification,
2 we do go down for training, but it is not supervised by the NRC.
3 We run ourselves through a few drills and refresh our memories
4 in the initial start-up qualifications that we go through.

5 The NRC did look over our shoulder while we were doing it,
6 and the simulator was used in fundamental emergency procedures
7 to show how we performed. But the NRC does enforce the
8 training on a cold-licensing -- a person who has never operated
9 that plant.

10 You will qualify for start-up on the simulator and on a
11 similar plant; and then on your own plant, the initial start-up
12 is done under supervision of the NRC.

13 Mr. Carr. Now, your license expires after one year unless
14 requalified?

15 Mr. Frederick. Two years. Our licenses expire this
16 October.

17 Mr. Carr. And you, to requalify, have to have what kind of
18 an examination?

19 Mr. Frederick. The same exam, different questions.

20 Mr. Carr. Now, in terms of the questions, does the NRC
21 make these questions available -- not that they give you the
22 test, or make the examination public, but is there a published
23 test guide, say, for studying for the examination?

24 Mr. Frederick. No.

25 Where we get most of our information for the test is from

1 other people who've taken the test before. They say, "Well,
2 they asked us these questions," and you can reconstruct.

3 At the Training Department at Metropolitan Edison --
4 writes a test that is very similar in format to the NRC exam,
5 the same type of questions and the same groupings: emergency
6 procedures, operating procedures, plant response, insurance,
7 and controls. They are divided into groups.

8 Mr. Carr. Does Metropolitan Edison have a training program
9 above and beyond the NRC?

10 In other words, the NRC qualifications say every two years
11 you have to go through this, but does Met Ed have a different
12 --

13 Mr. Frederick. We have it every year, and the Training
14 Department is probably larger than any other training department
15 in the country.

16 Mr. Reis. Is the test -- the NRC test, is it hard -- I
17 mean, subjectively, obviously -- but we've taken tests through
18 school, all of us, and some are harder than others; is it a
19 particularly hard test to take?

20 Mr. Frederick. It is grueling.

21 Mr. Reis. It has got to be tiring if it's eight hours, but
22 is there a big failure rate? Is it something that's really
23 hard to take? Is it rough?

24 Mr. Frederick. I think it's particularly rough. In other
25 words, you have a potential of some 5- or 7000 questions they

1 can ask you, and over such a diversity of information, that
2 it is difficult to prepare for.

3 Mr. Weaver. What is the failure rate?

4 Mr. Frederick. I don't know. No one in our group has
5 ever failed.

6 Mr. Carr. One thing that strikes me from what you've
7 said is that the two of you were at console, and you had a
8 supervisor back in a box, behind that console -- well, there
9 were three of you in the control room.

10 Mr. Frederick. Yes.

11 Mr. Carr. The two of you were from the same class and
12 roughly out of identical experiences; how about the supervisor?

13 Mr. Frederick: He has been at it a few years longer, but
14 basically, I think he'll tell you that his experience is
15 similar to ours.

16 Mr. Carr. And so, essentially, --

17 Mr. Frederick. He is also licensed on Unit 1.

18 Mr. Faust. He is a Senior Operator.

19 Mr. Carr. But in other words, you have people of the
20 exact, almost the exact experience level?

21 Mr. Frederick. Experience levels are probably different,
22 but training is probably very similar.

23 Mr. Weaver. Excuse me, Bob.

24 I'm going to call the Task Force back at 1:00 to meet with
25 the supervisors. I'm going to leave now, but you can stay.

1 Mr. Vento. I had one question.

2 Mr. Weaver. Thank you very much.

3 Mr. Vento. Do you want to continue?

4 I have one question.

5 Mr. Carr. I have a couple of questions I would like to
6 ask off the record, because I don't they have anything to do
7 with the charge of the committee to come up with facts.

8 Mr. Vento. Fine.

9 I just wanted to ask a question: On the boron level in
10 the water, what type of information are you getting back during
11 this experience concerning that, and whose responsibility is
12 it to monitor that?

13 Mr. Frederick. The Chemistry Department.

14 Mr. Vento. And what type of information were they getting
15 back, or were you getting from them?

16 In other words, did you ever ask for a readout or any
17 information on this?

18 Mr. Frederick. Yes, twice.

19 Mr. Vento. What did it tell you?

20 Mr. Frederick. It told us the boron concentration was
21 extremely low. The first report we had was 400 parts per
22 million. The second report, about an half an hour later, was
23 700.

24 Mr. Vento. What time did you call for that?

25 Mr. Frederick. I don't know.

1 Mr. Vento. But it was early?

2 Mr. Frederick. In the first two hours.

3 Mr. Cheney. And what does that mean when you say it was
4 extremely low?

5 Mr. Frederick. Boron concentration should be in the
6 neighborhood at this time in the nature of 1000 or 2000 parts
7 per million.

8 Mr. Vento. That means it's being lost or absorbed.

9 Mr. Frederick. What it meant to us was it was probably a
10 sample inaccuracy due to the other chemicals that we been
11 introducing. That is what we assumed.

12 Mr. Faust. We were experiencing problems with our letdown,
13 so it could have just been misrepresented, because we did not
14 have a good letdown flow at that time. We were experiencing
15 oscillation.

16 Mr. Frederick. Boron concentration is difficult to begin
17 with.

18 Mr. Vento. Would it common to find it that low? Would it
19 occur at 400 parts?

20 Mr. Frederick. No. But the fact that we were injecting
21 sodium hydroxide would have made it difficult to make a boron
22 determination because of the caustic present in the chemical
23 solution. It would have thrown off the analysis.

24 Mr. Vento. Well, the sodium would have absorbed some of
25 it maybe.

1 Mr. Frederick. The pH would have been masked by the caustic
2 and it would have thrown off the results.

3 The Chemical Department can probably explain that better.

4 Mr. Carr. What was the first time you interviewed -- you
5 were interviewed for a reconstruction?

6 Mr. Faust. The second night.

7 Mr. Frederick. The engineer on the site tried to get us
8 the same day, but we were too busy. We answered a few questions
9 but we really didn't have time. His name is Marshall. He's
10 an operations engineer.

11 The next day was when we were interviewed the first time.
12 That was by Met Ed again.

13 Mr. Carr. I think we will be off the record right now.

14 (Discussion off the record.)

15 Mr. Cheney. Let's go back on the record now.

16 In connection with NRC's presence on the site, were they
17 a significant presence in the room?

18 Mr. Frederick. They were not present initially.

19 Mr. Cheney. But I think you told us they arrived about
20 10:00 o'clock.

21 Mr. Frederick. That's right.

22 Mr. Cheney. Were you aware of their presence in the
23 control room?

24 Mr. Frederick. No.

25 Mr. Cheney. They didn't deal directly with you?

j1 19

1 Mr. Frederick. No. We made a point of keeping everyone
2 away from the panel, because we were busy.

3 Mr. Cheney. Did you have any problem with the number of
4 people in the room.

5 Mr. Frederick. Yes.

6 Mr. Faust. In the near future, that was one of the things
7 that was one thing -- voice level had to be kept down, and
8 people had to be kept out of the area that we were operating in.

9 Mr. Cheney. So that made it difficult, in other words,
10 because of the people that showed up?

11 Mr. Frederick. Yes.

12 Mr. Cheney. Who were these people, most of them connected
13 with Met Ed?

14 Mr. Frederick. Yes, most of them -- radiological monitoring
15 teams. More operators came in at 7:00 o'clock, their normal
16 shift.

17 Mr. Carr. I noticed that, in this diagram here, these are
18 all radiation monitors, right?

19 Mr. Frederick. Yes.

20 Mr. Carr. So radiation personnel presumably would come in
21 and come back here, right?

22 Mr. Frederick. No. We assigned an operations format to
23 constantly monitor them and inform the Health Physics Department
24 of any changes, and that was his sole job. So that kept people
25 away from the panel. He related information to people who

1 needed it.

2 Mr. Reis. There seems to be two major areas where you can
3 get information.

4 After the first 10 minutes, when you caught your breath --
5 a little bit, anyway -- one, of course, or even during those
6 first few minutes, for the first area of information -- one,
7 of course, is the control room panel, what is going on, and
8 the instruments, et cetera; and the strip charts, et cetera.

9 The other would be, say, an engineer who responded and came
10 in, et cetera.

11 It is a broad question, but as well as you can answer it,
12 do you think that not the design of the plant, in terms of
13 giving you spurious signals, but in terms of the design of the
14 control room, did the control room provide you, in a timely
15 fashion, in an easy-to-read fashion, the information you
16 wanted and needed? And alternatively, during the accident,
17 that would be a general question given to hindsight, in the
18 course of the accident, would the communications in the control
19 room -- were they such so that when your supervisor, whoever
20 was at the panel and needed information -- conceptual informa-
21 tion -- in other words, this instrument, that instrument, and
22 this gauge are reading things that don't jibe together -- what
23 could that mean in terms of one engineer? Did you have that
24 sort access, immediately, to an engineer, and when did you get
25 it? Did it work well, so that you were able to conceptually

1 figure out what was going on in addition to what the gauge
2 actually read?

3 Mr. Frederick. The answer to the first question, the
4 instruments, in my opinion, were not adequate. I can come up
5 with a million questions on how to change them and the avail-
6 ability of additional input from the engineering staff.

7 It was not available to me, because I did not seek it out.
8 I would give whatever questions I had to the supervisor, and
9 he would refer them to whoever he could as far as more
10 operators, more engineers, to get more information. And he
11 would bring back whatever suggestions there were if there were
12 any.

13 And if things were that confusing, that I had to turn and
14 ask somebody a question, I would wait for their response and
15 their instructions on what to do next and then take the
16 prescribed action according to what they suggested rather than
17 what was on the panel.

18 Mr. Faust. I would say -- well, I can't change it much
19 from what he said -- we would continue to feed changes that
20 we were seeing, seeing in the plant, to the supervisor; as
21 well as if we thought we knew something that should be done,
22 we would be saying that, too.

23 Mr. Reis. In terms of the layout of the plant, in general,
24 do you think there could be some significant changes that
25 would make your job a lot easier?

1 Mr. Frederick. Yes.

2 Mr. Faust. Definitely.

3 Mr. Cheney. Do feel at this point, after having been
4 through the exercise now, and thought a lot about it, that
5 you've got a pretty good understanding for what exactly
6 happened inside the containment vessel?

7 Mr. Frederick. Yes.

8 The results of what happened are not clear; but as far as
9 the progression, yes.

10 Mr. Cheney. In other words, now, with the benefit of
11 hindsight, we're able to look back on the event, all of us,
12 and say, "This was the sequence of events that led ultimately
13 to having the core uncovered for a period. There are no
14 major holes or gaps"?

15 Mr. Faust. Something that we haven't seen, and maybe Ed
16 has, but we haven't sat down with all of the graphs and the
17 information in front of us and, as a group, looked at it and
18 tried to talk it out in that sense, whatever information was
19 there. And I don't know where it's at right now. I assume
20 the NRC has it.

21 Mr. Frederick. That is one thing that hasn't been done.
22 They haven't given us the opportunity, as a group, to evaluate
23 the information that they have accumulated and put additional
24 input into what we were doing at the time, as a group.

25 Individually, it is hard to remember when you bumped into the

1 guy next to you and stuff like that. But as a group, I'm sure
2 we could -- well, maybe not anymore, it's been almost two
3 months. But we could have remember more.

4 Mr. Cheney. You could have had sort of a better debrief-
5 ing?

6 Mr. Frederick. We did get together on our own a couple
7 of days afterward and put together our thoughts, but as far
8 as having the information from the computers and the graphs,
9 as they had mainly gone out, we did not have that.

10 Mr. Cheney. Is there anyone in terms of helping us with
11 our inquiry, recognizing that what we're about is trying to
12 establish basically what happens so we can better understand
13 the events at Three Mile Island, is there any area of inquiry
14 that you think we ought to especially follow up on that we
15 have not gotten into today?

16 Mr. Frederick. You're going to have to hit the general
17 emergency, the radiological releases. The people that are here
18 today, except for Gary Miller, they aren't the people to talk
19 to. The general emergency was handled by the Health Physics
20 Department and the unit superintendent, or the station super-
21 intendent.

22 During a general emergency, our job is to control the plant.
23 They were in back of us doing the other stuff.

24 Mr. Cheney. They're worried about the releases off-site
25 and so on.

1 Mr. Frederick. Right.

2 Mr. Cheney. Well, I would like to thank you all very much.

3 Mr. Meyers. I have one more.

4 You did have a feeling during the day, by the time you
5 left, that there had been significant core damage?

6 Mr. Faust. We definitely felt like we had core damage.

7 Mr. Meyers. But did you think that the core had been
8 uncovered?

9 Mr. Frederick. Yes.

10 Mr. Meyers. And that there had been metal, a metal-water
11 reaction, or the hydrogen had been generated in the core?

12 Mr. Frederick. I hadn't concluded that; no.

13 Mr. Faust. It's hard not to think along those lines.

14 Mr. Meyers. But you did think the core had been uncovered
15 for some time?

16 Mr. Frederick. Yes.

17 Mr. Faust. Well, there's a question about how long, or
18 how much of the core. I couldn't say.

19 Mr. Meyers. But long enough for there to have been some
20 oxidation of the fuel rods?

21 Mr. Frederick. At the time I was optimistically thinking
22 we had a steam bubble in the top of the core, at the top of
23 the vessel, not at the core.

24 Mr. Scoville. Were you discussing this with yourselves
25 and others in the room?

1 Mr. Frederick. During the emergency, were we discussing
2 core damage? Yes.

3 Mr. Meyers. Did anybody discuss whether it was possible
4 that the steam bubble had gone below the fuel, the level of
5 the fuel rods, and that there had been oxidation?

6 Mr. Frederick. I believe the engineers were working on
7 trying to figure out whether or not it had.

8 Mr. Meyers. But they were thinking of that, of the
9 possibility?

10 Mr. Frederick. I think so.

11 Mr. Faust. I imagine they would have been.

12 (Whereupon, at 12:25 p.m., the hearing was recessed, to
13 reconvene at 1:20 p.m., this same day.)

14

15

16

17

18

19

20

21

22

23

24

25

AFTERNOON SESSION

(1:20 p.m.)

1. Mr. Weaver. The Task Force will come to session.

2 We are just informally carrying on conversations here.
3 What we're trying to do is understand the facts.

4 Later on the Interior Committee, in drafting policy
5 decisions, the Chairman of the Interior Committee, Congressman
6 Udall, wants some members of the committee to have an idea of
7 what happened at Three Mile Island. And Mr. Cheney and I, and
8 others, are doing our best, not being scientists or engineers,
9 to understand.

10 And so what we would like you to do is to identify your-
11 selves for the gentlemen in back of us, and then to proceed to
12 tell us what happened, as you saw it.

13 Why don't you start, Mr. Zewe.

14 Mr. Zewe. I'm Bill Zewe.

15 Mr. Weaver. Say who you work for and what your background
16 is.

17 Mr. Zewe. I'm Bill Zewe. I work for Metropolitan Edison
18 Company. I'm a Station Shift Supervisor.

19 Mr. Weaver. Okay, Mr. Miller.

20 Mr. Miller. I'm Gary Miller. I work for Metropolitan
21 Edison Company as a Station Manager. He is Station Shift
22 Supervisor, and I am Station Manager for Three Mile Island.

23 Mr. Weaver. You look over the whole thing, Unit 2?
24
25

1 Mr. Miller. Both units.

2 Mr. Scheimann. My name is Frederick Scheimann. I work
3 for Metropolitan Edison in the capacity of Unit 2 Shift Foreman.

4 Mr. Weaver. Now, you are in charge of operations?

5 Mr. Millers. Operations and maintenance.

6 Mr. Weaver. For both units?

7 Mr. Miller. Yes.

8 Mr. Weaver. You are in charge of --

9 Mr. Zewe. Operation of both units on a shift basis.

10 Mr. Weaver. You report to Mr. Miller.

11 Mr. Zewe. No. There is a Supervisor of Operations for
12 Unit 1 and also for Unit 2. And I report directly to them, or
13 to Gary.

14 Mr. Weaver. And then you --

15 Mr. Scheimann. Shift Foreman, would be in charge of running
16 the people and operating the plant. I report to Mr. Zewe.

17 Mr. Weaver. So we interviewed two fine young people this
18 morning, Mr. Frederick and Mr. Faust; and they said there are
19 three in the control room.

20 And you would be the third one?

21 Mr. Scheimann. I would be the third one.

22 Mr. Weaver. And you would be where, in the control room,
23 too?

24 Mr. Zewe. In the control room in either unit. Normally,
25 when I'm there on shift, I have responsibility for each unit.

j1 28

1 You see, we have one Shift Supervisor, one Station Shift
2 Supervisor, that has overall -- for both plants. And then
3 there is one Shift Foreman in either plant. And then the
4 Control Room Operators, under each of the Shift Foreman; and
5 the Auxiliary Operator is under the Control Room Operators.

6 Mr. Weaver. Mr. Scheimann reports directly to you?

7 Mr. Zewe. Yes.

8 Mr. Weaver. Now, I've got the chain of command.

9 Mr. Cheney. Could we just have quickly a paragraph on
10 each of their backgrounds.

11 Mr. Weaver. Please.

12 Mr. Cheney. Your educational experience, et cetera.

13 Mr. Zewe. High school graduate. I was in the United
14 States Navy for a period of six years as a reactor operator
15 and a electronics technician.

16 Mr. Weaver. You mean a reactor operator, on a shift?

17 Mr. Zewe. Yes, I was.

18 Then I came to Three Mile Island in 1972 and was an
19 Auxiliary Operator for about 18 months, and then a Shift
20 Foreman for a couple of years, and then a Shift Supervisor for
21 the last three years.

22 Mr. Weaver. So your training is in the Navy, your
23 original training?

24 Mr. Zewe. Yes, it was.

25 Mr. Weaver. Mr. Scheimann.

1 Mr. Scheimann. I started off with eight years in the Navy.
2 I was electrical operator on three nuclear submarines, and then
3 I came to Metropolitan Edison. I was an Auxiliary Operator
4 for approximately 18 or 20 months. Then I was a Unit 2 Control
5 Room Operator for about two years. And then I began as a Unit 2
6 Shift Foreman.

7 Mr. Weaver. Mr. Miller.

8 Mr. Miller. I got out of the United States Merchant Marine
9 Academy in 1963. When you come out of there, you have a
10 commission, a license in the Merchant Marine as an engineer.

11 I went to work for the government initially, for a short
12 period. Following that, in about 1965, I went to work for
13 Newport News Shipbuilding and Drydock Company. I worked there
14 approximately eight years.

15 Mr. Weaver. Building nuclear plants in ships?

16 Mr. Miller. Yes, I originally was a test engineer on
17 submarines. Then I was the Chief Test Engineer on submarines,
18 somewhere between 10 and 13 test programs initially, test
19 programs on carriers and a cruiser.

20 My last job in Newport News was Manager of Construction
21 for the Nimitz and the Eisenhower. I came to Metropolitan
22 Edison in 1973 as the Test Superintendent. I was in charge
23 of Acceptance Test Program for the TMI Unit 1.

24 Following that, from 1974, I was appointed to Unit 2
25 Superintendent. In 1977, I was a Station Superintendent. At

1 the beginning of this year, I became Station Manager.

2 Mr. Weaver. Very good.

3 I would just like to ask the two young men who were here
4 earlier and ourselves -- you are all Navy people. Is this
5 typically -- of the nuclear utility industry, or is this just
6 Three Mile Island and Metropolitan Edison; do you have any
7 idea?

8 Mr. Zewe. I feel it is pretty typical.

9 Mr. Weaver. If you go to Chicago and have a nuclear plant
10 in Chicago, would you find that?

11 Mr. Scheimann. You would probably find quite a few Navy-
12 trained operators.

13 Mr. Weaver. Have you any order that you would like to go
14 in?

15 Who was there?

16 Mr. Reis. Mr. Scheimann was in the office behind --

17 Mr. Scheimann. I was down in the Turbine Building basement
18 at the time.

19 Mr. Zewe. I was there. I was in the rear of the control
20 room, in my office. There is a little office space in the
21 rear of the control room, and I was in there.

22 Mr. Weaver. At 4:00 o'clock a.m.?

23 Mr. Zewe. Yes, at 4:00 o'clock.

24 Mr. Weaver. Why don't you then proceed and tell how things
25 happened?

1 Mr. Zewe. The first thing that I noticed and heard was the
2 alarms in the control room. And then I looked out through the
3 glass windows of my office and I noticed that most of the
4 alarms on panel 15, which monitors the ICS alarms, were in
5 alarm at the time. Those are the ones right above here, that
6 I can see directly from my office.

7 So I jumped up out of my chair there and started out in the
8 control room area, and I looked and I saw that we had a turbine
9 trip. And so I called out that we had a turbine trip, that
10 the operators, Craig and Ed, were already up at the panels
11 following the emergency procedures for the turbine tripping.

12 And I took a couple of more steps and heard reactor trip.
13 I yelled out, "We just had a reactor trip, too." So I went over
14 to the page system to announce to the plant that we did have a
15 reactor trip and a turbine trip, which I did.

16 Then from there, I proceeded over to assist the operators
17 in handling the emergency procedures for the reactor trip and
18 the turbine trip.

19 Mr. Weaver. How many personnel are in -- at Unit 2, in
20 the entire plant, at such a time?

21 Mr. Zewe. Well, there was myself, the Shift Foreman, the
22 two Control Room Operators, and about seven other auxiliary
23 operators in the A classification, and B and C classification.

24 Mr. Weaver. So 10 people in that plant?

25 Mr. Zewe. Between 10 and 12 people, yes.

1 Mr. Weaver. You said "alarms," by the way.

2 Mr. Zewe. Yes.

3 Mr. Weaver. I was just told there was one.

4 Mr. Zewe. There is just one alarm that sounds for all of
5 the various alarms that we have, but individual alarm flashes
6 -- a light. But there is only one audible alarm.

7 Any of the flashing alarms will trigger the one audible
8 alarm; and then you hear the audible, and then you look up and
9 see what alarm is in alarm, and it should be flashing.

10 Mr. Weaver. But there is only one noise?

11 Mr. Zewe. That's correct.

12 Well, let me just clarify that. There is one overall
13 alarm, but we do have a separate alarm on the computer which
14 sounds a little bit differently. And there is an alarm for
15 the radiation monitoring system, which has its own alarm.

16 Mr. Weaver. Would you proceed?

17 What happened?

18 Mr. Zewe. I was over with the operator, who was at first
19 Craig and Ed, over by the makeup system, to start a high
20 pressure injection makeup, open up a high pressure injection
21 valve to anticipate the shrink in the reactor coolant system.
22 once you have the trip, which is normal.

23 So I was over there for the first part it. And then, after
24 that then, I went over to where the feedwater system is, to
25 where Craig was at that time, because this was a couple of

1 minutes into it, that my Shift Foreman came up to the control
2 room, and it was about three minutes after the trip that he
3 was up in the control room, so he was over by the primary
4 plant for pressurize level, and I assigned him and the one
5 Control Room Operator to monitor the pressure and the level,
6 and to take action.

7 And then I went over to look over the secondary side of
8 the plant, in the feedwater system, and assist the operator
9 there, who was Craig Faust.

10 Mr. Weaver. At this point, you didn't really know what
11 had happened?

12 Mr. Zewe. I did not know what had caused the turbine
13 trip or the reactor trip. We were only reacting to the indica-
14 tions we had at that point.

15 The operators, at this point, knew that we had had the
16 turbine trip, because of loss of feed problem. But at this
17 time I hadn't realized yet that what had participated it was
18 a loss of feed, and the reactor tripped because of that, too.

19 Mr. Weaver. Now, you say the shrink is a natural thing.
20 Doesn't the plant automatically take care of the shrink, or do
21 you have to do that?

22 Mr. Zewe. Per our emergency procedures, we try to maintain
23 pressure -- a pressurizer level above the heater cutoff point.
24 The pressurizer -- if the pressurizer gets too low, it
25 automatically deenergizes our heaters, so that the elements

1 are uncovered, and so they don't burn out.

2 Mr. Weaver. You're talking about the reactor core?

3 Mr. Zewe. No, the pressurizer.

4 Mr. Weaver. What did you mean by "heater"?

5 Mr. Zewe. There are electric heaters that are underneath
6 the water in the pressurizer.

7 Mr. Reis. Why don't you explain their function.

8 Mr. Zewe. The pressurizer actually has a steam water inter-
9 face that maintains the overall pressure in the system so that
10 the rest of the system, which is at about 582 degrees, average
11 temperature, is kept at in a water state by having a greater
12 pressure than the saturation temperature.

13 And the pressurizer actually acts as a surge chamber, if
14 you will, for the system, to provide the pressure and also to
15 surge water back into the system or bring the water out of the
16 system to maintain the primary system full of water.

17 Mr. Weaver. So you actually have a heater on the pressur-
18 izer?

19 Mr. Zewe. Exactly. The heaters come on automatically on
20 low pressure to maintain the steam bubble in the pressurizer
21 itself.

22 Mr. Weaver. What did you have to do though that wasn't
23 automatic in these first few seconds? What I'm trying to
24 establish is what is automatic, and what you had to do if you
25 didn't do something that would go wrong?

1 Mr. Zewe. When the primary system trips, the primary
2 system trips, the primary system cools off and the water
3 contracts. This water goes from the pressurizer into the
4 coolant system to make up for this.

5 So then we monitor the pressurizer level to make sure that
6 it does not get down to the heater cutoff point.

7 Mr. Weaver. There's no automatic thing?

8 Mr. Zewe. Well, we have an automatic valve which looks
9 at pressurizer level, which automatically opens to up to feed
10 more water from our makeup and purification system right into
11 the RCS, which effectively keeps up the water level in the
12 pressurizer. That is the Bravo pump that was running, like
13 it is normally.

14 And this valve would ordinarily makeup to the system. But
15 we find that the pressurizer level actually comes down fairly
16 close to where the heater cutoff point is if we do not start
17 high pressure injection pump and open up another flow path of
18 water into the system.

19 Mr. Weaver. That's all I wanted to know.

20 Why don't you proceed?

21 Mr. Zewe. Sort of on track here -- where do you want me
22 to go from here?

23 Mr. Weaver. Well, let's go to Mr. Scheimann.

24 Mr. Scheimann. Initially, I was down in the basement of
25 the Turbine Room, and I heard some pipes rumbling, and I heard

1 the word "reactor trip" -- "turbine trip" and then "reactor
2 trip."

3 Mr. Weaver. Over the loudspeaker?

4 Mr. Scheimann. Yes, over the loudspeaker, whereupon I
5 proceeded upstairs to the control room. When I got into the
6 control room, I pulled out copies of the Emergency Procedures
7 for Turbine Trip/Reactor Trip, and then I proceeded over to
8 the pressure control station. What I was trying to do there
9 was to monitor primary system pressure, as well as pressurized
10 level.

11 At the time I proceeded up there, a minute or so later we
12 had an automatic emergency safeguard initiation signal go in,
13 whereupon all the equipment started up as was required, and the
14 pressurizer level started to come back up to its normal level.

15 About this time, the pressurizer level continued to go up,
16 and we had high pressure injection on both systems for a total
17 of greater than 300 pounds per minute, whereupon we took in
18 manually, bypassed the ES signal, such as to be able to gain
19 manual control of the components.

20 Mr. Cheney. Why did you do that?

21 Mr. Scheimann. We did that in order to gain control, so
22 that we could throttle on the high pressure injection flow to
23 get it to where it would be in its normal -- what its required
24 flow -- gallons --

25 Mr. Cheney. Because you were worried about going solid?

jl 37

1 Mr. Scheimann. We were having too much flow going in there.
2 It is what it amounted to, and we wanted to keep it from going
3 solid -- yes.

4 Once we got the emergency safeguard system bypassed, we
5 traveled back on all four of the high pressure injection valves
6 until we got to 250 gallon per minute, per leg, which is the
7 required amount; and pressurizer level was still coming up, so
8 we started cutting back on one side.

9 Mr. Cheney. Who was reading the pressurizer level?

10 Mr. Scheimann. I was observing the pressurizer level
11 myself.

12 We got up to approximately 380 inches, and we tool off on
13 one string of the high pressure injection, which still left us
14 two strings of 250 gallons a piece per minute.

15 At about this time the pressurizer level went up, and our
16 indication was it was solid. And from that point we reopened
17 the letdown valve, isolation valve, and attempted to let down
18 at such a rate that we could take and try to bring the
19 pressurizer level back into the indicator range.

20 Mr. Cheney. There are a couple of things here. One is
21 at some point you had a relief valve on the pressurizer.

22 Mr. Scheimann. Before the reactor tripped.

23 Mr. Cheney. And at this point you had reason to believe
24 that the valve on the pressurizer was still open?

25 Mr. Scheimann. I had reason to believe, by my indication

1 on the panel that the valve had probably -- had lost its open
2 signal and was closed.

3 Mr. Cheney. Even before you went solid?

4 Mr. Scheimann. I had no indication that the valve was open
5 at that time.

6 Mr. Cheney. Would going solid ordinarily lead the valve
7 to open?

8 Mr. Scheimann. It would depend upon what your pressure is.
9 You would have to have sufficient pressure to lift that relief
10 valve. And at that time we did not have sufficient pressure to
11 lift the valve.

12 Mr. Cheney. And when you talk about drawdown or trying to
13 drop the level, what precisely are we talking about there?

14 Mr. Scheimann. What it would amount to under a primary
15 plan system. You have what is called the letdown line, which
16 is rated for approximately 140 gallon-minute maximum flow --
17 I don't see it on this schematic.

18 Mr. Reis. Could you point out where it was.

19 Mr. Zewe. When the letdown comes down off of the 1-A
20 reactor coolant pump, off that line from the pump, and it comes
21 down through some cores into the makeup and purification system,
22 which is always in service to purify the water and back in
23 through the high pressure injection pumps; it puts it back into
24 the cooling system.

25 What we were doing was just increasing our letdown flow.

1 Normally, our letdown flow is in the neighborhood of 45 to 50
2 gallons a minute. We could increase this up to 140 gallons a
3 minute to draw more water from the reactor coolant system and
4 put it into our holdup tank, which in this case is the makeup,
5 tank.

6 Mr. Cheney. You've still got some high pressure injection
7 going in.

8 Mr. Scheimann. We still had two full strengths going in --

9 Mr. Cheney. It was just not enough.

10 Mr. Scheimann. That's correct.

11 -- so that we could get our balance back in to the observ-
12 able degree.

13 Mr. Weaver. Is this something you've gone through before?

14 Mr. Scheimann. I've been on the pressure control station a
15 couple of times during the course of a reactor trip, so I had
16 seen the resultant increase in pressurizer level.

17 Mr. Cheney. Had you ever seen one go solid?

18 Mr. Scheimann. No, I've not seen one go solid.

19 Mr. Cheney. Have any of you ever experienced that?

20 Mr. Zewe. I've gone solid before, on purpose, in the Navy.
21 We have to do some primary plant instrument testing. I have
22 gone solid approximately three different times for special
23 testing to align our primary instrumentation, but we haven't
24 actually gone solid in the plant here, in this condition; no.

25 Mr. Cheney. Have you ever seen in under similar conditions

1 in commercial, as opposed to a Navy facility?

2 Mr. Zewe. Not under these conditions, no; not solid like
3 this, no.

4 Mr. Scheimann. I was mostly, from this point on, trying
5 to maintain pressurizer level control for just about the rest
6 of the time period we were in there.

7 Mr. Cheney. Were you watching light going and giving
8 instructions?

9 Mr. Scheimann. I was calling out where my level was and
10 trying to keep everybody posted as to what the conditions in
11 the primary were at the time.

12 Mr. Cheney. Was somebody else making decisions as to
13 what to do?

14 Mr. Zewe. Once Mr. Scheimann came up into the control room,
15 I assigned him the primary pressure and pressurizer level
16 responsibility, so he was on that. And I was trying to handle
17 other problems in the plant.

18 Mr. Cheney. Would be ordinary then for him, based upon
19 what you are reading, to give instructions as to what changes
20 might be made?

21 Mr. Scheimann. That's correct. In fact, I had mentioned
22 that we had cut back the one stream of high pressure injection.

23 Mr. Cheney. These would be your decisions then, the
24 operators would carry them out?

25 Mr. Scheimann. Yes.

1 Mr. Weaver. And what were you doing?

2 Mr. Miller. I was supposed to go to Oyster Creek that day
3 for the refueling meeting. I had gotten up at 4:00 in the
4 morning. Bill had the Unit Foreman, I think at Unit 1, call
5 me somewhere in that first couple of minutes to tell me we had
6 tripped.

7 Mr. Weaver. You get called in the first couple of minutes?

8 Mr. Miller. Yes, I was called very early.

9 So I knew that Unit 2 had tripped, and I knew Unit 1 was
10 in a hot shutdown condition for refueling. So I just, in that
11 first period of time, waited at home and did some paperwork,
12 and then I called back again somewhere around 5:00 o'clock to
13 see what was going on. And that is where I kind of got into
14 this, but I never interfaced with Bill, because I would not
15 have taken his time; I talked to another man in the control
16 room, so I wouldn't have to pull him away.

17 So I knew Unit 2 had had a turbine trip. I knew we had
18 had a reactor trip. And I knew we were in the recovery.

19 Mr. Weaver. How many of these had you gone through before?

20 Mr. Miller. A lot -- in Unit 1 and Unit 2; enough so that
21 it didn't concern me -- or from an overly concerned standpoint.
22 I was more concerned when I called back in at 5:00, before I
23 left for New Jersey, that I understood the recovery was under
24 way.

25 And also, the way the two units are arranged at Three Mile

1 42
1 Island, the steam facility -- it is hard to support both units,
2 and to shut down hot conditions, so my concerns were priority
3 kind of concerns at that time.

4 Mr. Weaver. What do you mean, "hard to support"?

5 Mr. Miller. We support steam; you need steam from a boiler
6 that's fired by oil. You need that steam to maintain the
7 equipment in its proper condition.

8 Pumps have seals on them that are maintained; feedwater is
9 heated up with steam. And now I have no steam; both reactors
10 are shut down. That kind of concern was what I was into at
11 that time.

12 I called back in at 5:00 o'clock to understand specifically
13 what they were doing, to understand the recovery, and also to
14 give instructions -- to determine the cause of the trip, which
15 would have been my concern, before we started back up.

16 Mr. Weaver. And then what did you do? Did you go to
17 New Jersey?

18 Mr. Miller. When I called back in, I talked to another
19 individual in the control room, and he described some of these
20 parameters to me. I guess I felt uneasy about some of them,
21 and I had a conference call set up, which occurred probably
22 around 6:00 o'clock in the morning. And I, at that time,
23 talked to a B&W representative, my boss, Jack Herbine, myself,
24 and George Cutter, who is a Technical Assistant in Unit 2,
25 more or less just to try and understand what was going on.

jl 43
1 Mr. Cheney. What was it? What parameters was it that led
2 you to think that this was a fairly unique situation?

3 Mr. Miller. Well, I wasn't talking to Bill, so I wouldn't
4 have gotten a tremendous display of information -- I guess the
5 pressurizer being solid, the pressurizer level

6 Mr. Weaver. The 380 inches?

7 Mr. Miller. Yes.

8 To me, it was solid, and I was concerned about that being
9 solid and the pressure being low.

10 Mr. Cheney. And you learned that at 5:00 o'clock.

11 Mr. Miller. I learned that at about 5:00.

12 Mr. Weaver. And then did you go to the plant?

13 Mr. Miller. No. I, in my mind, was still going to
14 New Jersey. I set up a conference call, and I included the
15 B&W representative and my boss, plus a plant guide, to be sure
16 I understood what we were doing on recovery and to talk about
17 it.

18 Mr. Cheney. Where was your boss?

19 Mr. Miller. He was in Philadelphia, as I remember.

20 Mr. Cheney. Is that where he is normally.

21 Mr. Miller. This is going on my best recall, but I believe
22 he was tied up with his Navy duties that week. But I can
23 always reach him, the same as Bill could always reach me; so
24 I called him down in Philadelphia at the Navy facility.

25 And more than anything else, I wanted to ask some more

1 technical questions of the people at the plant to understand
2 what they were doing.

3 Mr. Cheney. And why did you contact B&W?

4 Mr. Miller. Because the Technical Representative is a
5 guy I trust; and also, since it was the pressurizer was solid,
6 my concern was there.

7 Mr. Cheney. Aren't they on-site?

8 Mr. Miller. He was in the area. We have a guy on-site.

9 Mr. Weaver. There is a permanent B&W man there?

10 Mr. Miller. There has been at Three Mile Island since
11 1973, and not just one. They have a couple of individuals.

12 At this particular point, Unit 1 was finishing refueling,
13 and Unit 2 was operating normally.

14 We had had more than one of them there for the refueling
15 support.

16 Mr. Cheney. And how much -- what information did you have
17 at that time? Did you feel you had all the information you
18 needed?

19 Mr. Miller. As a result of the 6:00 o'clock phone call,
20 Jack directed me to go into the plant. There were a lot of
21 phone calls occurring then. I had to call four or five people
22 to turn off the trip to New Jersey, and things like this. Time
23 goes pretty quick when you're on the phone; so when I got on
24 the phone with Jack and Lee Rogers and George Kunter, following
25 that call, we could not get enough information. And Jack said,

1 "Go into the plant and call me."

2 So I had gotten up at 4:00, and I had never gotten to first
3 base as far as physically getting ready. I spent the whole
4 time on the phone.

5 So I started to get ready to go. About 20 of 7:00, I got
6 a call from Dan Shevlin, who's the Maintenance Superintendent;
7 and before this time, I had called Dan Shevlin and Jim Sieman,
8 who's the Unit 1 Superintendent, and told them to go in, more
9 from a support standpoint, because now both units are in -- are
10 down, and that is bad.

11 Mr. Cheney. That's not a good way to start the day.

12 Mr. Miller. No. I mean, you have a lot of priorities
13 there.

14 So Dan called me -- Dan's the Maintenance Superintendent;
15 he's not an operator, or trainer, or License guy -- Dan is
16 simply a radiation man.

17 He said, "We've got a reading in the hot machine shop," and
18 at that time then I just got in the car and started driving to
19 the site.

20 Mr. Cheney. This is about two hours and 40 minutes in?

21 Mr. Miller. This is about quarter to 7:00.

22 Mr. Cheney. In the meantime, what is going on inside the
23 plant? When did you discover that the emergency fuel water
24 valves were closed?

25 Mr. Zewe. Craig Faust was over trying to clarify that the

j1 46

1 turbine tripped, and all the procedures that he goes through
2 to verify risk; and he went over to verify that we had an
3 emergency feed flow, so he was observing the steam generator
4 levels coming down, which they normally would be coming down
5 to about a 30-inch range, where they should be maintained for
6 this tripped conditions. And he was watching them come down,
7 and observing.

8 He verified that the emergency feed pumps had, in fact,
9 started, and that the valves were trying to open up to try to
10 regulate the steam generator water level.

11 He looked at it, and the levels continued to come down
12 under the 30-inch point. So he looked at the indication on
13 control valves that should be controlling the water level at
14 30 inches, and he took these into hand and opened them up
15 manually, thinking that the valves just weren't responding
16 properly.

17 So he tried that, and he still did not have any indication
18 of the flow or a raise in water level. So he looked over his
19 panel pretty quickly, and he said that the 12s were shut; and
20 I heard this, and I was somewhat off to his left, over where
21 Fred and Ed were at this point in time, and said, "The 12s
22 are shutting."

23 And I said, "What? Why?"

24 And he said, "I don't know." So he started to open them
25 up, and I went over there to try to open them, too, to establish

47

1 them -- feeds to the steam generator. So we were there for a
2 short while trying to feed the steam generators, using emergency
3 feed and bringing them up to a normal 30-inch water level.

4 And Fred and Ed were still continuing to try to reduce the
5 pressurizer water level, and try to determine why the pressure
6 was low.

7 And I looked over on the turbine panel to look at other
8 problems, or alarms, at this point. And I went over and looked
9 and saw that the hot level was going off the scale -- high,
10 and we didn't have any feed pumps running, the condensate
11 booster pumps running, or any condensate pumps running, so I
12 attempted to try to start the condensate pumps so we could have
13 some flow and try to reject some of the water from the hot wall
14 back to the storage tanks. And we were finally successful in
15 starting the condensate pump.

16 And we didn't have any suction pressure to the condensate
17 booster pumps, and the only thing between the condensate pump
18 and the booster pump were the condensate polishers. So I went
19 back to try to open up a valve to bypass the condensate
20 polishers, and the valve would not open from the control room.

21 Just then an operator in the plant called and said that
22 we had a leak by the one condensate booster pump and he needed
23 some help to isolate it. So I went back and Fred and Ed were
24 still trying to maintain the pressurizer level and the reactor
25 coolant system pressure, and Fred had the feedwater stations

1 on emergency feed and seemed to be doing pretty well at this
2 point.

3 He had some problems trying to get the level, but he was
4 working on it pretty well. We were joined just before we
5 found that the emergency feed valves were isolated. We had
6 been joined by another shift supervisor who had been in Unit 1
7 at the time, so he was over there within about six minutes
8 after the trip, and his name was Ken Bryon. And Ken was also
9 helping out, trying to determine what we had to make sure that
10 we weren't missing anything and so forth.

11 All of us at this point were all talking together, trying
12 to give ideas to each other as a possible solution to what we
13 had seen.

14 Mr. Cheney. At this point, are you now into a set of
15 circumstances you had never seen before?

16 Mr. Zewe. Yes. Everything looked like it was fairly
17 stable, but we had the high level and the low pressure. And
18 we had some inclination that maybe the pressurizer level
19 instruments weren't reading correctly, because if, in fact, we
20 were solid, we should have seen the pressure increase, because
21 we were still feeding in water at this point and still trying
22 to let down. So we should have had a higher pressure than the
23 12- or 1300 pounds that we had at that point.

24 Mr. Weaver. And the reason of this anomaly and difference
25 is that the pressure relief valve on the pressurizer was opened.

1 Mr. Zewe. Yes, but we didn't determine that.

2 Mr. Weaver. I have another question, and that is the 12s,
3 the valve that was closed --

4 Mr. Zewe. There were two different valves that were
5 closed, but they both served the same function.

6 Mr. Weaver. They were closed. What if they had been
7 opened? Would we still have had the same eventual situation
8 at Three Mile Island, everything else happening exactly the
9 way it did?

10 Or was there a possibility that something would have
11 happened later on, or not happened if the valve had been
12 opened?

13 Mr. Zewe. The only thing that not having those valves
14 opened did is that they did allow the steam generators to go
15 dry and resulted in the primary system losing its heat sink
16 faster.

17 Mr. Weaver. S-i-n-k?

18 Mr. Zewe. Yes. Eye of heat being produced in the primary
19 system.

20 And now I lost my water in the steam generator, so I'm
21 now transferring the heat over to the steam generator, which
22 results in the primary heating up, so the primary would not
23 have heated up so far, initially; and it was also a rather
24 large shock to the steam generators to have them dry, and then
25 to refill them.

1 But the real problem was that the electromagnetic valve was
2 stuck open, and it was depressurizing the primary plant.

3 Mr. Weaver. So the valve being closed played, a matter of
4 degree -- it wouldn't have been quite so bad had the valve
5 been opened, as I understand it.

6 Mr. Zewe. Exactly. It aggravated it, but it would not
7 have put us in the ultimate condition that we were in. It did
8 add to the confusion factor, and it was another area to where
9 we devoted part of our time to. So in net effect, yes, it
10 did contribute.

11 Mr. Weaver. I see that.

12 Mr. Meyers. Are you sure that the secondary did go dry,
13 or it went below the level that you could read it?

14 Mr. Zewe. Our indication, when I looked at it, and I looked
15 at it fairly hard, was that we never got down less than 10
16 inches in the steam generator, either one. And it got down
17 to about 5 percent on the operating range, which is just
18 another range of our indication.

19 So that shouldn't have been dry. But looking back now, if
20 we didn't have feed for an 8-minute period of time, the steam
21 generators would have boiled dry; in about 90 seconds to 100
22 seconds, they would have been dry. So I'm sure, at this point,
23 they were dry. At the time, I didn't know that.

24 Mr. Meyers. Based on your calculations, you think they
25 were dry?

j1 51

1 Mr. Zewe. They definitely were dry; right.

2 By observation, it didn't look like it, but looking back
3 at it, with retrospect, knowing what we know know, they had to
4 have been dry.

5 Mr. Meyers. But this is a property of B&W steam generators.
6 That would not necessarily happen in Westinghouse; is that
7 right?

8 Mr. Miller. Any plant has to turn feed on at some time.
9 They might have had more time, based on their pipe configura-
10 tion and the volume in the steam generator at the time of the
11 trip. In other words, if your generator is a little bigger
12 than B&W's and you've got a little more time, but the
13 consequence of not feeding it is that goes dry. "Dry" is no
14 water.

15 Mr. Zewe. We consider anything less than 8 inches dry
16 from an operating standpoint, but in this case, in the 8-minute
17 period, it was probably completely dry.

18 Mr. Chaney. So now you've got problems with your generator
19 basically. And then at some point an hour or so later, however
20 later it is, where you discover that the emergency pressurizer
21 valve, the valve on the pressurizer is open, and you get it
22 closed --

23 Mr. Zewe. The only way that we finally determined that
24 that valve was partially opened was that we shut the blocked
25 valve -- or the downstream valve, if you will -- from the valve

1 that was open. Once we shut that, then we had indication that
2 that valve had been open previously.

3 Mr. Cheney. And how long was that?

4 Mr. Zewe. That was approximately 6:20 or so.

5 Mr. Cheney. That was before you arrived at the plant?

6 Mr. Miller. Yes, at the 6:00 o'clock phone call, one of
7 the questions we had asked is whether that valve was closed.
8 On the panel, the valve had a command signal that said, "Go
9 closed."

10 Mr. Cheney. So you asked, and checked it then?

11 Mr. Miller. I think they checked it many times before
12 that.

13 Mr. Scheimann. I checked it many times, and there was no
14 open indication for it.

15 Mr. Zewe. For that particular light, there is a very
16 bright red light for that valve; and it is really probably the
17 brightest light on our entire console.

18 Mr. Weaver. What are we talking about, the pressure
19 valve?

20 Mr. Miller. Yes.

21 Mr. Weaver. Why wouldn't you just -- you want it closed,
22 why didn't you just press is?

23 Mr. Miller. Well, the operator on the panel is thinking
24 in his mind that the red light is telling it to go closed. It
25 tells him it is closed.

1 Mr. Weaver. Well, can tell you, when I go vote, we use
2 this card here. We have little boxes in the house, you know,
3 when you put this card in the little slot and it says "Yes/No"
4 -- and voting is very important to me -- that's it for us, and
5 I always punch that "Yes" and the light lights up. Sometimes
6 it doesn't light up. Then you've got to go to another slot
7 and put it in, because it's not working. But I will punch it
8 "Yes," and then I will put the card in again, because I want
9 to be damned sure that my vote is registered.

10 And so then I punch it again even though the light is
11 lit up.

12 Now, what I'm asking you is why wouldn't you --

13 Mr. Miller. When you punch that light, do you go look at
14 the computer to see if it's punched in? That is where you're
15 at.

16 Mr. Weaver. We have a score card on the wall, but my
17 point is, but my point is would it ever occur to you that
18 because of the importance of this pressure relief valve and
19 the funny things going on, to just go punch that in? It
20 wouldn't hurt anything, would it?

21 Mr. Zewe. Not at this point, no, but we did check other
22 indications. We have thermocouples on the downstream side of
23 the relief valve which are monitored on plant computer, and
24 we did check down several times to see what the discharge
25 temperature was. And shortly after we tripped, I would say

j1 54

1 within about 10 minutes or so -- after we had tripped it, we
2 checked this temperature, and the temperature was not abnormal-
3 ly high. We knew that it had left it, and it should be a little
4 higher than normal.

5 Normally, it does read around 175 or 180 degrees, and it
6 was reading 220 degrees, which is not abnormally high for just
7 having lifted. So we checked that at least three different
8 times.

9 Mr. Cheney. Why did you check that.

10 Mr. Zewe. With the normal alarm status review, we had
11 checked that, and whenever the Shift Supervisor came over -- I
12 had asked him to look through there, and to see what the
13 discharge was.

14 Mr. Cheney. So was that an automatic readout on the
15 computer?

16 Mr. Zewe. It alarms the computer and prints out so you
17 can monitor it there, and also request that that particular
18 number -- and they will print you up the current value.

19 Mr. Cheney. If the valve was open, why was the reading
20 so low?

21 Mr. Zewe. That I don't know.

22 Mr. Miller. Somebody is looking into that, because I
23 remember it is thermocouple that is strapped to the pipe. It
24 is not a temperature weld in the pipe. The pressurizer might
25 be over 600 degrees; that is why it reads in the range he's

1 talking about. It reads the outside of the pipe. There --
2 I believe Bill was checking it to tell him to confirm the
3 light as he was discussing -- I don't think we know the answer.
4 I think somebody is looking at the indication and the parameter
5 and whether there was sub-cooling going on or expansion going
6 on, or something that would have caused that reading.

7 Mr. Cheney. In other words, you feel like even though
8 there was, first, the indicator light that indicated the order
9 had been given to close the relief valve, which showed that
10 you were closed; secondly, there was the tailpipe temperature
11 reading, but it, too, was showing a relatively low level,
12 lower than it would have been, given normal experience, if the
13 relief valve had been open. Is that an accurate statement?

14 Mr. Zewe. Correct.

15 Mr. Cheney. Were there any other indicators available
16 that might have given you a readout in the control room?

17 Mr. Zewe. Well, the tank that the valve discharges to,
18 that -- we did check it, and it was at a higher temperature,
19 and a low level, a low pressure, indicating that either its
20 relief valve was open or the ruptured disk had ruptured in
21 the tank. And I thought that that was true, because -- well,
22 it shouldn't have happened; but after we tripped, the relief
23 blows and it puts too much energy into the tank. It could
24 cause that condition in the tank. At this point, the tank was
25 at zero pressure, at a high temperature, with no indicated

1 water level.

2 So if the valve had just been opened somewhat, the pressure
3 in the tank should be elevated to a higher temperature. But
4 when it said no water level and zero pressure, that just
5 indicated there was some leakage path from that tank into the
6 reactor building itself.

7 So at this point it would be very hard to determine that
8 that valve was still discharging into that tank.

9 Mr. Weaver. Now, in 1977, a similar relief valve opened
10 or solenoid, and a similar signal was sent, and yet it remained
11 open for 20 minutes. Have you ever heard of that?

12 Mr. Zewe. I don't recall that at all.

13 Mr. Weaver. Have you ever heard of that, Mr. Miller.

14 Mr. Miller. I don't recall it. There may have been a
15 bulletin that passed my desk, but I don't recall one.

16 Mr. Weaver. Mr. Scheimann.

17 Mr. Scheimann. No.

18 Mr. Weaver. Have you heard about it before? I just
19 mentioned it to you today. You've never heard of that?

20 Mr. Scheimann. No.

21 Mr. Miller. I never heard of the part about the valves
22 sticking open.

23 Mr. Weaver. This is the first you've heard about it, my
24 telling you?

25 Mr. Miller. No.

1 Mr. Weaver. You've heard of it?

2 Mr. Miller. I heard about it the night of the incident;
3 somebody in the control room, in from the NRC, described it --
4 that at some date that Davis-Besse had occurred.

5 Mr. Weaver. On Wednesday night?

6 Mr. Miller. Yes.

7 Mr. Weaver. On Wednesday night, somebody told you that
8 they had seen this Davis-Besse?

9 Mr. Miller. I might say this, in 1978, this valve, at
10 this plant, had stuck open, but due to a different reason. The
11 valve had stuck open due to a power failure, and that had been
12 corrected. The valve had stuck open the day after the plant
13 went critical, on March 29th; but the valve had stuck open
14 that day, but it stuck open because of a power failure to
15 the valve.

16 Mr. Weaver. I would like to repeat that right now.

17 As of right now you've never heard of the Davis-Besse
18 situation?

19 Mr. Zewe. I have not.

20 Mr. Scheimann. I have not either.

21 Mr. Cheney. And I understood you to say that you hadn't
22 heard of the Davis-Besse situation until in the control room?

23 Mr. Miller. That's the first that I had heard of it.

24 Mr. Weaver. With the exception of possibly a memo?

25 Mr. Miller. There is possibly -- I don't remember if there

1 was. I'm saying that it was possible he could find a piece of
2 paper that was sent to the Station Superintendent with that
3 on there. I don't remember that piece of paper.

4 Mr. Chaney. On their prior closings, did you have any
5 -- I recognize, of course, that the relief valve is inside
6 the containment, and nobody is going to know it until they
7 take a look at it -- do you have any feel for why it failed
8 at this time?

9 Is there any indication that would point in the
10 direction of explaining what happened here? At Davis-Besse,
11 as I recall, it was a relay that wasn't pressed?

12 Mr. Weaver. It was same thing. The solenoid did exactly
13 the same thing; the valve did not close, but the solenoid
14 sent the signal, where the energizing of the solenoid was no
15 longer there.

16 Mr. Miller. The valve could have stuck open, in my mind,
17 and there are other people looking at this for one of two
18 reasons: One, the electrical setup that told the solenoid
19 to do something was improper; secondly, if the valve could have
20 maybe stuck up on a differential mechanical thing, like a
21 difference in pressure.

22 I don't think we know today -- I don't know today why this
23 valve stuck open on March 28th. With that drain tank being
24 full of water, and the water path, the valve could have hung
25 up, a difference in pressure. I don't know that, but that is

1 the other possibility; and people are looking into it. I don't
2 think any of us know.

3 Mr. Cheney. And when it did fail previously on Unit 2 --

4 Mr. Miller. When it failed here, it failed due to a
5 power loss. We lost power to the valve, and it failed to open.

6 Mr. Cheney. It failed to open.

7 Mr. Miller. It failed in the open position.

8 We fixed that problem by putting redundant power supply to
9 the valve.

10 Mr. Burnham. When it failed previously at Three Mile Island
11 twice -- one in 1978, and one on March 29th; is that right?

12 Mr. Miller. In 1977, it was not Three Mile Island.

13 Mr. Burnham. I thought there had been two previous
14 incidents at Three Mile Island.

15 Mr. Miller. I don't know of two, but I'm not trying to
16 quote that for the record.

17 I know on March 29th it failed, because it was a pretty
18 big transient.

19 Mr. Burnham. What did the indicator light say? Did you
20 have the same problem with the indicator light giving you a
21 misreading?

22 Mr. Scheimann. On March 29th, I don't believe that light
23 was in there.

24 Mr. Weaver. Why don't we say 1978, say we installed this
25 red indicator light that comes right off of the signal that

1 goes to the solenoid -- valve, as a result of that problem?

2 Mr. Miller. At that time, we did not have that light
3 before.

4 Mr. Cheney. And when that valve held previously, in 1978,
5 what was different about it that led to circumstances where
6 obviously you did not have the kind of problem that occurred
7 this year?

8 Mr. Miller. At that point, they recognized that problem
9 because they had had a failure of a vital power supply, so
10 they had -- that led right to that valve.

11 Mr. Zewe. They knew what precipitated it?

12 Mr. Miller. It was a lot simpler problem in my mind.

13 Mr. Chaney. Was there a point in the morning there where
14 all of a sudden lights went on, and you think, aha, maybe the
15 valve stuck open?

16 Mr. Zewe. It was about quarter after 6:00 that we
17 rechecked the discharge temperatures once more, and they were
18 still reading about 220. And we said, "That's hanging up there
19 too long, so let's go ahead and isolate the valve."

20 As soon as we isolated it, we saw the reactor building
21 pressure, which had been 2.2 pounds or so, take a marked
22 reduction; and that is when we realized, for sure, that the
23 valve was at least partially open and blowing to the drain tank,
24 and the drain tank was open directly to the building.

25 Mr. Cheney. Do you realize anything about -- remember

1 anything about the sump pump that morning?

2 Mr. Zewe. Yes, I do; somewhere around a half hour after
3 we had tripped and we had determined from the computer alarms
4 and also from an Auxiliary Operator -- had called saying that
5 his indication on the panel for the reactor building sump was
6 that it was full, and he has a scale -- it's like a zero to
7 six feet is the range of the sump -- and that the sump pumps
8 were running.

9 So the Control Room Operator, Ed Frederick, told me about
10 that and he suggested, "Bill, should we turn them off?"

11 And I said, "Yes. Tell the operator to go ahead and to
12 secure the sump pumps."

13 Mr. Cheney. Why would you secure them?

14 Mr. Zewe. Because we knew that we had a problem with the
15 RC drain tank, and it's water had got into the reactor building
16 sump. And I did not want that water to be transferred over
17 to the auxiliary building, because I didn't know how much
18 water we actually had and I knew that we didn't have very
19 much room for excess water in the auxiliary building.

20 Mr. Cheney. Were you concerned about radioactivity at
21 that point?

22 Mr. Zewe. No, I was not. I was just worried about the
23 volume of water and transferring water, not knowing the full
24 story.

25 I had told Ed to tell the operator to do that, and Ed told

1 me back that the operator, indeed, did turn off the two
 2 reactor building sump pumps. And I acknowledged that, and then
 3 we went on with the rest of the operation.

4 Mr. Weaver. I would like Henry to ask one question
 5 relative to this.

6 Mr. Meyers. That was a transient at Rancho Seco on
 7 March 20, '78, and they had had their relief valve blocked out
 8 because there had been leaks. Were you aware of that?

9 Did you get a copy of a similar letter? They sent a
 10 letter to Davie-Besse -- Babcock & Wilcox sent a letter to
 11 Davis-Besse on August 9, which discussed that Rancho Seco
 12 transient. Did you get that?

13 Mr. Zewe. August 9th of what year?

14 Mr. Meyers. '78.

15 Mr. Miller. In all fairness, I don't know how much mail
 16 you get, but mine gets trucked in and I look at almost every
 17 piece of it. If something had come that normally comes to
 18 my engineering people, who would get it and also would trans-
 19 late it into procedural change -- now, I don't remember seeing
 20 either of these, but you could find the letter maybe addressed
 21 to me. I would think I would remember it, but I don't
 22 remember it.

23 Mr. Weaver. Mr. Miller, I want to ask you --

24 Excuse me, Mr. Zewe.

25 Mr. Zewe. I believe this is the one where they had been

1 changing light bulbs, and they had a short in their instruments.
2 We had discussed this in our training review, and I remember
3 a comment from my one Control Room Operator in Unit 1 at that
4 point, saying "He isn't going to change any more light bulbs."

5 Mr. Meyers. Because this letter also suggests something
6 that might be an unambiguous instruction, where it says "the
7 pressurized level in reactor coolant system pressure share of
8 the reactor coolant system is filled."

9 That is saying that the pressurizer water level isn't full.

10 Mr. Zewe. That is true. Our key parameters are that as
11 long as we have water pressure in the pressurizer, that our
12 main cooling system is full, and the water level in the steam
13 generator is our main way of indicating removal.

14 Mr. Meyers. But that is as long as the temperature in the
15 rest of the system is less.

16 Mr. Zewe. Right. At the highest temperature the
17 saturation conditions occur in the pressurizer, that is true.

18 Mr. Meyers. Then you are aware that that temperature
19 condition was necessary in order for the pressurizer water
20 level to indicate a full pressure vessel. Were you aware
21 that the temperature in the rest of system had to less than
22 the saturation temperature?

23 Mr. Zewe. Yes, I realized this; yes.

24 But at the time, I felt that we still had the higher
25 temperature system in the pressurizer and not in the coolant

1 system itself.

2 Mr. Weaver. Mr. Miller, how many comparable messages do
3 you get about transients in different plants or problems in
4 other plants, or anything like this that cross your desk? Is
5 this an unusual thing, or do you just get all kinds of them?

6 Mr. Miller. I get a good many of these; an awful lot of
7 them come from the NRC themselves. They put out at least
8 three categories of bulletins, plus B&W puts out things
9 periodically. And those are handled by going into our
10 structure, attempting to determine whether you need a plant
11 change or a training change; and that is how he would have --
12 got that training memo.

13 Mr. Weaver. I have a couple of extraneous questions right
14 now.

15 One, isn't the computer printing out dollar signs at this
16 time? That's what we've been told.

17 Mr. Miller. I don't know whether Bill had the -- you know,
18 there are temperature indicators on some instruments inside
19 the reactor. When I arrived at the plant, somewhere around
20 7:00 to 8:00, I had an electrical engineer give me the N Core
21 readings. He said the computer had question marks, which
22 meant to me that it was not in the program.

23 At that time, we sent the instrument guide to take the
24 base signal reading and convert it.

25 I don't know, Bill, whether you had any other readings

65
1 that were like that before I got there.

2 Mr. Weaver. Let me first tell you how it was described to
3 me, and I think it was the press, so there's nothing sacred
4 about this information. And that is that for the first -- I
5 don't know -- hour or two hours, or whatever, the computer
6 was just reading out at first, we were told, question marks
7 and then dollar signs, meaning that it couldn't answer.

8 Now, this may have been later on. Maybe this was 7:00
9 o'clock, when the reactor vessel started going really bad,
10 and therefore all your temperature readings were way above the
11 612, or whatever the limits were.

12 Mr. Zewe. Normally -- all right, if the computer -- it
13 has a certain range to it, a certain range for the parameters
14 -- if you are outside that range, or it doesn't know if it's
15 valid or not, it will print up question marks, saying that
16 for the input it has it really can't get a very good reading,
17 so that is where a question mark would be.

18 At this point though, we were still using the console
19 indication, our normal TC, TH, and so on, from the console, not
20 from the computer. We were checking through the computer for
21 alarms and indications. There is a physical limitation to
22 the computer. Things were happening so quickly, and we had
23 so many alarms and so many things happened at the computer
24 monitors that it really could not keep up with the alarm
25 response time -- like 20 or 30 items may happen in fractions

1 of a second, but it takes a finite time for each of them to
2 print out on line, and it begins to get backlogged.

3 Mr. Miller. It types out. It's a line-type thing, so
4 there are physical limitations in the typing time. If it
5 gets 100 things happening in five minutes, it starts to pile
6 them up and then prints them out later.

7 He would be using the direct indications.

8 Mr. Weaver. Do you mean calling up the computer?

9 Mr. Miller. Looking at the console.

10 Mr. Weaver. Now I'm troubled by the newspaper reports.
11 One report, early on, had it that there was just page after
12 page of computer printout of question marks.

13 Mr. Miller. Looking back -- and we can come back to you
14 with further information, but there was a period of time in
15 the first two to three hours where the computer failed, I
16 believe.

17 Mr. Zewe. Yes, for over an hour period, it didn't give
18 us any information.

19 Mr. Cheney. Did you -- you mean you would query it and
20 nothing would happen?

21 Mr. Zewe. No. The question mark periods, and so forth,
22 the computer had hung up, where it really didn't scan the
23 parameters and print on in a fashion where we could interpret
24 it.

25 Mr. Cheney. It was unusable.

1 Mr. Miller. I think Bill would back this up. He was not
2 using that totally. He was using his console to operate the
3 plant, so when that went out, he just had to go away from it.

4 Mr. Weaver. What caused this? What was going on? What
5 happened?

6 We have it here in the chronology that 1 hour 13 to 2:37 --
7 in other words --

8 Mr. Miller. I think, in fairness, the machine has got a
9 tape, disk, and that sort of thing. It has experienced
10 problems. It is not a vital piece of equipment to Bill's use
11 of the emergency procedures or operations of the plant, so I
12 would guess Bill would just simply have told an electrical
13 engineer to call someone in and go on with the console.

14 Mr. Weaver. You haven't to have it in any way?

15 Mr. Zewe. No; it is just an operator's tool, but it isn't
16 anything that's really that critical to the operation.

17 Mr. Miller. It certainly hampered us in the detailed
18 analysis -- that is, your memory -- and that hurts.

19 Mr. Weaver. And there are sheets of printouts with
20 questions marks on them?

21 Mr. Miller. I haven't personally seen any of those sheets.

22 Mr. Weaver. There are printout sheets though?

23 Mr. Miller. I'm sure there are.

24 Mr. Zewe. I'm sure the printout sheets are all available,
25 but how long of an area we had that just prints out question

1 marks -- I assume that that time there is accurate, but I did
2 not go through it and say, "Well, it was out for this period
3 of time."

4 Mr. Miller. That would not have affected any decision
5 thought we would have made or Bill would have made at that
6 time.

7 Mr. Weaver. And we don't know what caused the computer
8 to go out?

9 Mr. Miller. I think we could probably come back to you.
10 There was an electrical engineer who got it moving again, so
11 he could probably be able to tell you that a component was
12 replaced or something, I would guess.

13 Mr. Weaver. And it prints out question marks and not
14 dollar signs, because the newspaper said dollar signs.

15 Mr. Zewe. That's right; it prints out question marks.

16 Mr. Cheney. Can we talk a little bit about the period
17 when the reactor pumps were turned off and how that process
18 happened, how you got to the point where you decided you had
19 to turn off the reactor coolant pumps?

20 Mr. Zewe. We were at the point where we began to
21 experience some flow oscillations, and we could determine on
22 our panel board flow indication, and we started to have some
23 flow isolations.

24 And George Kunter, the Superintendent of Technical Support,
25 and myself, and Fred, and Ken Bryon, and the Control Room

1 Operators were all looking at it, and we had our operating
2 curves. And we were right at the edge of our net positive
3 suction limit for running through a reactor cooler pump, so
4 we decided then to secure the two pumps to see if we could
5 correct that flow, that oscillation problem. So we did this;
6 we secured two pumps, and then later on, approximately half
7 an hour later or so, then the flow oscillations were coming
8 back.

9 They did subside for a short period, where we turned two
10 pumps down. And then that, we decided to secure the
11 remaining two pumps and to try to go on that full circulation
12 flow.

13 Mr. Cheney. So you would have expected -- obviously, you
14 did not want to turn off the pumps, but really you had to.

15 Mr. Zewe. We felt we were going to lose the pumps anyway,
16 so to help protect them, we decided to secure the pumps.

17 Mr. Cheney. But when you secured the pumps, you did it
18 with the expectation that you would be able to continue cooling
19 the reactor?

20 Mr. Zewe. Yes, using that full circulation flow.

21 Mr. Miller. If the last two pumps were turned off 100
22 minutes into -- it would be 5:40.

23 Mr. Cheney. So what happened, once you get the pumps
24 turned off?

25 Mr. Zewe. Then we monitored and we began right then to

1 raise our steam generator water level up to a natural
2 circulation condition, which is about 50 percent on the
3 operating range and 21 feet, to enhance the natural circulation
4 flow.

5 Mr. Miller. The plant is designed to use all those pumps
6 to do this, so that is the context I think Bill would be doing
7 it in.

8 Mr. Cheney. Is that the point at which the reactor may
9 have been uncovered?

10 Mr. Zewe. After then -- it is sometime after that is when
11 we feel now that the reactor did become uncovered; yes.

12 Mr. Cheney. And how did it come uncovered?

13 Mr. Miller. It was still relieving water through the
14 valve.

15

16

17

18

19

20

21

22

23

24

25

1 Mr. Zewe. Now you have the system where you have the
2 steam bubble in the cooling system.

3 Mr. Miller. You may have voids earlier for a short period,
4 but now you begin to form a bigger void.

5 Mr. Cheney. Do you know that at the time?

6 Mr. Zewe. I did not know that at the time.

7 Mr. Cheney. What did you think was going on?

8 Mr. Zewe. Well, the first time that we realized that
9 we had a problem as far as the actual core goes, is we started
10 to see a change in our intermediate range indication, our
11 source range indication, which took us by total surprise.

12 This measures the reaction rate inside the reactor. It
13 monitors the neutron flux for the core, and our source range is
14 just our first range of nuclear instrumentation. The
15 intermediate range is the next range above that, and then we
16 a third range which is the power range.

17 So both our source range and intermediate range were in
18 their right respective places, until after we had shut off the
19 pumps sometime like -- sometime after that, and I'm not sure
20 of the time frame there, but we noticed that our charts that
21 record the source range and intermediate range showed that our
22 count rate in the reactor was increasing; and I didn't know why
23 it was totally foreign to why the count rate in the reactor was
24 starting to come up, because we had done a shutdown margin
25 calculation, after we had tripped. And we were 6 percent

bw2

1 shut down. And we are required.

2 Mr. Cheney. 6 percent shut down?

3 Mr. Zewe. That just explains a condition of the reactor.

4 Mr. Cheney. You've got 6 percent to go?

5 Mr. Miller. As far as from a distance from being critical
6 where you have a chain reaction, it is a good distance away
7 from that. That's what that tells you. It is still making
8 decay heat, but the reactor is positively shut down as a result
9 of the introduction of negative activity through the boron.
10 That is what that would tell, that he was that percent away.

11 Mr. Zewe. I didn't know why the count rate could be
12 coming up, if we were that far shut down. That is a considerable
13 amount of shutdown margin.

14 Mr. Cheney. But ordinarily the count rate would go up,
15 as you pulled the rods and started to activate the reactor?

16 Mr. Zewe. Exactly.

17 Mr. Miller. The count rate would do that.

18 Mr. Meyers. Why is the count rate higher?

19 Mr. Zewe. At that point we didn't know why the count
20 rate was starting to increase. So we began to emergency
21 boring and put borated water into the reactor coolant system
22 to add to the negative reactivity to the core.

23 Mr. Cheney. Through your high-pressure system?

24 Mr. Zewe. That's right. And prior to this we had been
25 putting water into the reactor coolant system from our borated

1 water storage tank, which itself had a lot of borated water in
2 it, so that should have further increased our shutdown margin:

3 So we didn't understand why we had that indication of the
4 increase in count rate.

5 Mr. Miller. He's got a separate tank with very high
6 concentrations of boron in it. The borated water storage tank
7 is a big 500,000 gallon tank that as the shutdown, norma'
8 shutdown amount separate to that, he's got a very concentrated
9 amount, and he started to put some of that into that same --

10 Mr. Cheney. And that is designed exactly for this kind
11 system?

12 Mr. Zewe. Exactly. So it was just about this time after
13 we had initiated the boron injection again, that we got the
14 boron analysis from the reactor coolant system, and the first
15 boron analysis that we got was 700 ppm boron, which was far
16 less than it should have been.

17 Mr. Cheney. It would be less because there is some more
18 activity in the reactor?

19 Mr. Zewe. No. It was just that we started out at around
20 1000 parts per million boron concentration.

21 Mr. Cheney. That would be normal under normal operating
22 circumstances?

23 Mr. Zewe. Yes. That is where we were at 97 percent,
24 and we had expected that the boron sample would come back at
25 a much higher value because we have added boric acid from these

bw4

1 other sources.

2 Mr. Cheney. So instead of being 1000, it ought to be
3 1500 or 2000 or moving in that direction?

4 Mr. Zewe. Probably 1100 to 1125 or so.

5 Mr. Miller. But the water had been added from that
6 borated surge tank was 2200, so we would not have expected it
7 to go below 1000 in any case.

8 Mr. Zewe. That also the reduced boron concentration
9 plus the change in the count rate, we really didn't understand
10 why the count rate would be going up and why the boron
11 concentration was low. That was very confusing at this point.

12 Mr. Cheney. Now how far along are you? You are at 100
13 minutes when you close off the second set of reactor coolant
14 pumps?

15 Mr. Zewe. I would say it is around 6:30 maybe.

16 Mr. Cheney. So about 2-1/2 hours into the incident?

17 Mr. Zewe. Yes.

18 Mr. Miller. When he had the incident.

19 Mr. Cheney. And this is about the time you begin to get
20 radioactivity measured?

21 Mr. Miller. A little after that.

22 Mr. Zewe. Radioactivity began to come up about
23 quarter to 7:00 or about 10 to 7:00 or so.

24 Mr. Cheney. After you noticed the boron problem and the
25 count problem?

bw5

1 Mr. Zewe. Yes. That was after that. We had attempted
2 to start the reactor coolant pumps after we had seen this count
3 rate change and the boron load numbers we had selected to try
4 to start the reactor coolant pump to try to get some flow
5 through the coolant system. So we were successful in finally
6 starting the one Bravo loop coolant pump, but it did not
7 indicate to us normal indication that it was running.

8 The breaker closed on the pump, but it did not give
9 normal indications that we did see an effect on the count
10 rate from the source range, and the intermediate range showed
11 us that they came back down to a lower count rate value,
12 showing that we probably were putting some flow through the
13 core, even though the pump didn't give us normal communication.

14 Mr. Meyers. What physically was it that made the count
15 rate go up?

16 Mr. Miller. I think physically looking at it afterwards
17 we might have taken some water off the vessel. The device he's
18 talking about, nuclear instruments outside the reactor vessel.
19 vessel. By reducing the water level somewhat, there may have
20 been more leakage of neutrons because there was not as much
21 moderation. That is what I would guess.

22 Mr. Meyers. But there were neutrons, or just that there
23 was less water to absorb them, whatever radiation was being
24 produced?

25 Mr. Zewe. It was just physically more neutron leakage

bw6

1 from the core at that point.

2 Mr. Miller. If you'd take some of the water away, more
3 of those would have escaped.

4 Mr. Meyers. So the higher count rate was an indication
5 of voids?

6 Mr. Miller. Looking back, that is what we're saying.

7 Mr. Zewe. That is true.

8 Mr. Cheney. What did you find then when you arrived
9 at the scene just about this time?

10 Mr. Miller. Well, as I say, I got a call right around
11 this same time. You see the samples that were taken to
12 give Bill's backup chemistry boron, those sample lines run
13 from Unit 2 over into Unit 1, because that is where what we
14 call the "hot lab" is -- that is where you take the primary
15 samples from both units -- those lines physically are hundreds of feet
16 long. It probably takes 20 to 40 minutes to get a
17 representative sample. So when when they pulled the sample
18 of the reactor coolant system out around 20 to 7:00, that
19 sample showed radiation indications, and the technicians who
20 were down there would have noted that right away, and they
21 did.

22 Mr. Cheney. This is water out of the primary coolant?

23 Mr. Miller. Right. This comes off the left-hand line,
24 I believe. It comes off that big pipe that the water showed
25 radiation indications and significant radiation indications.

b7
1 The lines themselves showed significant, and that is when I
2 first got the call and started into the plant. When I arrived
3 in the control room, they had already passed through the
4 criteria and Bill had declared a site emergency, which is
5 declared based on radiation indication.

6 So between the time of 6:30 and 20 to 7:00 until 10 to
7 7:00, we already were into the intermediate, and there was
8 three levels of emergencies, local, site and general. He
9 was already into the site emergency by 10 till 7:00.

10 Mr. Cheney. And you got there based on the boron samples
11 or somewhere else?

12 Mr. Miller. He got there based on the radiation in the
13 boron samples. Just our -- a side issue, taking that sample
14 there showed us radiation in another area, prior to seeing it
15 on the monitor, I believe.

16 Mr. Cheney. But you were picking it up in air samples?

17 Mr. Miller. This was a liquid sample taken for a chemistry
18 reason, but it was out of the coolant system, so it would have
19 fission products it. It showed the technician that he had
20 radiation far above what he would normally get.

21 Mr. Cheney. Now are you talking about the boron?

22 Mr. Miller. The sample was taken for boron, but the
23 water itself had fission products.

24 Mr. Weaver. Wouldn't at 5:40, when you had to stop the
25 reactor coolant pumps, that is a major step, puts you in an

bw8

1 extremely precarious situation, does it not?

2 Mr. Zewe. Yes.

3 Mr. Weaver. Why didn't you declare it then?

4 Mr. Miller. Because the plant itself is designed to have
5 a loss of all reactor coolant pumps and cool down on natural
6 circulation, so it would not have been any concern, where you
7 got into the emergency point or into a radiation indication.
8 Without radiation indicated, it would not put you into that
9 type procedure alone. It is a serious thing, but it is not
10 a radiation concern at that time.

11 Bill and the operators felt they were cooling the core using
12 natural circulation, which is designed in the plant. The
13 plant is designed to sit at 100 percent power and lose all
14 power.

15 Mr. Weaver. Meanwhile the pressure is going out of the
16 relief valve and so you're still losing water?

17 Mr. Miller. He's still putting water in.

18 Mr. Weaver. You turned off the reactor coolant pump?

19 Mr. Scheimann. We're still in high-pressure injection
20 at this point.

21 Mr. Miller. He's still pumping water from the outside in.

22 Mr. Scheimann. Which is considerably cooler than the
23 water inside is.

24 Mr. Miller. They just circulate the water around in
25 his mind.

1 Mr. Weaver. Where's that little sketch?

2 Mr. Miller. In the operator's mind. Say we hear the
3 pumps here. All that they do is take the water and put it into
4 the reactor and it comes out and goes through the steam generator
5 and goes back to the pump. It is a closed cycle system.

6 Mr. Weaver. Now the high-pressure pumps?

7 Mr. Miller: They sit outside and they inject water.

8 Mr. Weaver. They are not on here, are they?

9 Mr. Miller. No, but they inject water into the leg.

10 Mr. Weaver. And that's A, B, and C?

11 Mr. Miller. There are four places, they're four cold
12 legs. They're four points of injection.

13 Mr. Weaver. What are the A, B, and C pumps.

14 Mr. Zewe. They're the makeup pumps. They're three
15 high-pressure injection makeup pumps. The pump you're referring
16 to here, they're four reactor coolant pumps.

17 Mr. Miller. So at that time when he turned the reactor
18 coolant pumps off, he was still putting water into the
19 system through these high-pressure injection pumps, plus he
20 is still steaming from this steam generator taking some
21 steam out.

22 Mr. Weaver. So the high pressure is still pumping water
23 in.

24 Mr. Miller. And the steam generators are still
25 steaming, so he still thinks he has cooling.

bw10

1 Mr. Weaver. And he wasn't getting cooling because?

2 Mr. Miller. He was getting some, but --

3 Mr. Weaver. Why wasn't it working?

4 Mr. Zewe. Because due to the voids that we had in the
5 reactor cooling system, we did not have flow from the hot
6 point, which was the reactor, from there to the steam generator.

7 We weren't transferring heat from the reactor to the
8 steam generator, so that we could remove the heat by the
9 secondary side from the steam generator, but we weren't getting
10 it to the steam generator.

11 You see, you come out of the reactor and into the steam
12 generator.

13 Mr. Weaver. And this actually goes over there; right?

14 Mr. Miller. Yes.

15 Mr. Zewe. And then the water passes through tubes that
16 are inside the steam generator, and then if you don't transfer
17 the heat from the core to the steam generator, you cannot use
18 the secondary system to draw the heat out of the steam
19 generator. So we had these voids which prohibited flow from
20 circulating through the steam generator, so we weren't removing
21 the heat from the core itself.

22 Mr. Cheney. Had you ever been through in any of your
23 drills or your tests either TMI or the simulator, or in your
24 Naval training the kind of situation where you got these kind
25 of voids, steam voids in the reactor?

bwl1

1 Mr. Zewe. No, I hadn't.

2 Mr. Miller. No, I have never personally seen a plant
3 with pressurizer solid this long in this condition.

4 Mr. Cheney. But it's not part of your training in terms
5 of -- we're talking about loss-of-coolant accidents and so
6 forth. This isn't something people are trained to deal with?

7 Mr. Miller. We all ought to answer that question
8 separately.

9 In my mind, you would normally think of a loss-of-coolant
10 accident as being a break in the system. You are pumping water
11 on top of the core, and it is not analogous to this. Here you
12 had a full system drawing voids which you would train for.
13 It would be awful hard to train for, because you could not
14 demonstrate it too well.

15 Demonstrating it might do damage, is what I'm trying to
16 say.

17 Mr. Cheney. Even a simulated?

18 Mr. Miller. I think you could simulate it.

19 Mr. Cheney. Do you know if anybody has ever simulated it?
20 You mentioned going through simulations of going solid, in the
21 Navy.

22 Mr. Zewe. No, actually, in the Navy we have gone solid.

23 Mr. Miller. In this plant there has been solid in a test
24 program. That is not the normal thing, you go solid when you
25 do a pressure test. But, to my knowledge, the training program

bw12

1 does not include the simulations of voids in the system.

2 Mr. Cheney. Do you think that is an oversight to the
3 training program now, with the benefit of hindsight?

4 Mr. Zewe. At this point, I would say yes. Most definitely.

5 Mr. Weaver. Take me back just briefly on where we got
6 these voids.

7 Mr. Miller. You are draining water. We are all looking
8 back, but you're draining water off the system from here.
9 You're pumping some water in, but you must have been draining
10 some water off. This is hot. The water is just going to
11 drain. It's all going to drain out here, so the voids are
12 going to start to occur.

13 So the voids are going to start to occur, plus the core
14 is hot, and it's forming voids, steam voids, that are coming
15 up.

16 Mr. Weaver. What is causing that drainage?

17 Mr. Miller. Heat production and drainage.

18 Mr. Zewe. You're just flashing the hot water you have.

19 Mr. Weaver. We got down to saturation. I understand
20 that. So therefore when the pressure went down, that water
21 flashed to steam and you got the void. And then you could
22 not get the void out.

23 Mr. Miller. Well, you were draining the system, and
24 the core would have been fairly hot, as we all know now, very
25 hot, and, therefore, getting it solid again was hard.

bw13

1 Mr. Weaver. I was going to ask you why you didn't call
2 the NRC earlier, but now I'm beginning to see that you didn't
3 really didn't know the voids were there, and that was the
4 real bad situation.

5 Mr. Miller. Right. If you look from 7:00 o'clock on,
6 you will find that from that time on, they were involved
7 pretty intimately with us, at least at the technical level.

8 Mr. Weaver. What was the first time you just kind of had an
9 uneasy feeling that there was core damage. I mean just maybe.

10 MR. ZEWE: When the source range and the intermediate
11 range began to show the count rate increase.

12 Mr. Weaver. That was actual measuring of radiation.

13 Mr. Zewe. The monitors measured the activity in the core,
14 and I know that something was really wrong at that point,
15 but I didn't know for sure.

16 Mr. Miller. They don't measure radioactivity. They are
17 used as an indicator of the amount of power which is
18 proportional to the number of neutrons in here. From my
19 standpoint when I got there at 7:00 in the morning, and the
20 radiation indicators, the monitors were reading and going
21 up, then I knew we had some damage, because that is where
22 it comes from. It comes from the core, and so I knew we had
23 some damage.

24 When the sample showed me radiation.

25 Mr. Reis. You mentioned when the source range measured,

1 but what time was that?

2 Mr. Cheney. It was around 6:30, wasn't it?

3 Mr. Zewe. Yes.

4 Mr. Weaver. So then you called the NRC at that time?

5 Mr. Miller. From the time I got there, the calls that
6 would have started at 10 till 7:00 would have included the NRC.
7 When I got to the plant about 5 after 7:00, and then I took
8 charge of the situation, and by 20 after 7:00 the radiation
9 readings were high enough that we were in a general emergency,
10 which is our highest category. And then we initiated the calls,
11 and my guess is, is that there is a chronology, but before
12 8 in the morning, the NRC and everybody were on the phones,
13 on hot lines with us.

14 Mr. Cheney. Now with a site emergency, it's automatic
15 that certain things happen?

16 Mr. Miller. Yes.

17 Mr. Cheney. And that's the point at which the NRC gets
18 notified?

19 Mr. Miller. They are one of the parties, along with about
20 seven others.

21 Mr. Cheney. This is just a set of procedures?

22 Mr. Miller. It is an emergency plan.

23 Mr. Zewe. I really didn't think that we had core damage
24 at this point up until quite some time after this. I felt
25 the results were very large crud burst from the system, that we

1 had a very severe transient.

2 Mr. Cheney. What's that?

3 Mr. Zewe. It's just that when you operate for a period
4 of time, you do have fission products, and it's like if you
5 have rust in the system, if you will, once you have a shock to
6 the system, this breaks loose and comes into your system. We
7 felt that we still had maybe a large crud burst, and the
8 activity that we saw on the monitors was just from the water
9 that was from the reactor building somehow getting over to the
10 auxiliary building.

11 Mr. Cheney. Some way other than the sump pump route?

12 Mr. Zewe. Yes, some way other than the sump pump route.
13 So we really didn't know that we had severe core damage or
14 moderate core damage, or if it was somewhere between some
15 core damage and a severe crud burst. We really did not know
16 at this point.

17 At least, as I recall, I didn't.

18 Mr. Cheney. What triggers the decision that there is a
19 site emergency? Is that also automatic?

20 Mr. Zewe. Yes. There are criteria for it.

21 Mr. Cheney. And what criteria were satisfied that
22 morning?

23 Mr. Zewe. The radiation levels that were in the
24 auxiliary building. Right here, if you look here, this whole
25 panel here on 12. These are all our radiation monitors. They

1 have an alert and an alarm function. Amber light and a red
2 light. Just about 10 to 7:00, all of these alarms started to
3 come in hot, just about the same time they were just going
4 amber-red, amber-red, on all the indicators, and I knew that
5 we had a tremendous problem at that point.

6 So that is when I made the announcement and sounded the
7 alarm that a site emergency had been declared in Unit 2.

8 Mr. Cheney. And then things started happening?

9 Mr. Miller. Then from then on, when I got in we had by that
10 time assembled some senior people in the control room and by
11 20 after 7:00 --

12 Mr. Cheney. Who else, in addition to yourself?

13 Mr. Miller. It was myself, Mr. Ross, who's the operations
14 supervisor, had come over from Unit 1.

15 Mr. Cheney. These people work for you?

16 Mr. Miller. Yes. They are senior people.

17 Mr. Zewe. They had been there already. Almost everyone
18 that we needed for the site emergency team were already there,
19 before Gary arrived. They had been called in to help support
20 us prior to the site emergency. The unit superintendent was
21 there. The unit superintendent, technical support. The health
22 physics supervisor was there. Various engineers in support
23 capacities. Other shift foremen and other shift supervisors
24 had been there anywhere from an hour and a half to a half
25 hour up to this point. And once we declared the site

1 emergency, I would say nine-tenths of everyone that we needed
2 was already right there.

3 Mr. Cheney. Then at this point are you beginning to get
4 concerned about radiation off-site?

5 Mr. Miller. Yes. At that point you are into the
6 emergency plan which puts the organization into another
7 status, essentially. When I came in and took the control
8 room, then I put senior people in charge of various areas.

9 Mr. Cheney. So when you arrived, you took control?

10 Mr. Miller. That's right.

11 Mr. Cheney. And were you in control up to that point?

12 Mr. Zewe. Yes.

13 Mr. Weaver. Were you worried about so many people being
14 in the control room?

15 Mr. Miller. The ones I didn't want, I threw out. We
16 run emergency drills every year, and I run those drills. When
17 I got to the control room, it was 7:15 in the morning, the
18 radiation indicators were escalating -- that's the best way
19 to put, and they were on everywhere.

20 I just took -- and I took one guy at a time, and I said,
21 "You're in charge of that," and I put Mike Ross in charge of
22 this. I took one other guy and I put him in charge of reading
23 the emergency plan. I took one other guy and put him in
24 charge of making all the calls. Another guy in charge of the
25 technical support. And I had a B&W representative there, and

bw18

1 once that got going, we started making the calls.

2 The only concern I had was to get all the calls started,
3 things like accountability, getting all the people on-site from
4 various places and getting their name and number, make sure you've
5 got all of them.

6 Getting all the off-site agencies on the phone. Getting the
7 NRC on the phone.

8 The biggest thing is getting teams out there with
9 radiation monitors. The whole emphasis shifts to founding
10 out what you are releasing.

11 Mr. Cheney. This then becomes very automatic, in the
12 sense that you have a very detailed plan all laid out?

13 Mr. Miller. It is very automatic.

14 Mr. Cheney. There's a small amount of judgment?

15 Mr. Miller. That's right. In other words, once you start
16 making calculations, you know the wind speed, you know the
17 source. You start getting people out to take radiation
18 readings. You start talking to the health physics people
19 who work for the state and they're EPA guidelines and action
20 levels and a plan that define what you do.

21 Mr. Weaver. The next day, Thursday, we had a hearing
22 where the NRC Commissioners appeared, and they mentioned
23 that there was some release of radioactive materials that
24 surprised them. They said these surprises occurred; they
25 weren't informed of them. Can you elaborate on that?
What is this building outside?

bw19

1 MR. MILLER: The auxiliary building.

2 MR. WEAVER: That sort of thing. What releases did you have to make
3 and why did you make them?

4 Mr. Miller. I have had a chance to look at some of those
5 words too. I don't know that the word "surprise" is a proper
6 one. We had the reactor building dome monitor which is a
7 radiation indicator inside that dome, went to very high readings.

8 Mr. Weaver. What did you think of that? The high reading
9 on that dome monitor?

10 Mr. Miller. I just didn't think about it in terms of
11 fuel damage. I knew that it meant there was a potential
12 to release things off-site. My only concern was to get
13 readings.

14 Mr. Cheney. Did you have any question about the values of
15 those readings?

16 Mr. Miller. I thought it was too high, but I didn't
17 need to be convinced that it was high enough to be concerned.
18 It was reading 40- or 50,000. I mean that was beyond what I
19 had ever envisioned ever seeing on the dome monitor, so you
20 can discuss whether there was shielding and moisture and
21 whether it was beta radiation, and all that sort of thing.

22 But I did not need to be convinced. What I really wanted
23 was somebody out there with a meter and an iodine kit sampling,
24 and the wind direction. That is real numbers. That is really
25 what someone is going to get out there. So that was our

1 concern.

2 From 7:30 on, quite frankly, we had a hot line to the
3 Region 1 office of the NRC. From 10:00 o'clock on, I had
4 five of them on-site, three in each control room. And I was
5 willing to take advice and consent from anybody. There were
6 no surprises, but the situation was a very serious one.

7 We didn't at that time have the thing terminated, we still
8 were pumping HP water in and pumping it onto the floor of the
9 reactor building. Still did not have the reactor coolant
10 pump running.

11 Mr. Cheney. You're saying the pressurized valve was still
12 open?

13 Mr. Miller. No, it shut, but now I have a void in the
14 system in the hot legs, and I have no way to go, other than
15 just keep pumping HP injection and try and cool the steam
16 generator.

17 Mr. Cheney. So how is the water then getting out of
18 the reactor vessel?

19 Mr. Miller. We were letting some of it out at that
20 point.

21 Mr. Cheney. Trying to get of the void?

22 Mr. Miller. No, just trying to pump it across the core
23 to make sure we have the coolant covered. That was the goal.

24 The same thing we haven't mentioned. The Bravo steam
25 generator had been isolated by the operators because of that

bw21

1 cold water injection, we suspected a leak in that generator had
2 occurred, so we only had one steam generator, the alpha
3 generator, and so we were steaming from that generator, pumping
4 high-pressure injection water out of a 500,000 gallon tank into
5 the reactor itself out onto the floor.

6 Looking back, we had a superheated condition in here and
7 we had to have 4000 pounds to go solid. We could not get to
8 that point, so our goal was just to keep cooling and pumping,
9 and we tried various methods from there until eight at night,
10 to collapse the voids.

11 Mr. Cheney. But you knew then that you had voids?

12 Mr. Miller. I know I had hot bubbles in hot legs at
13 10 after 7:00.

14 Mr. Weaver. Were you telling this to the NRC? Was
15 somebody telling this to the NRC?

16 Mr. Miller. Yes, sir.

17 Mr. Weaver. What you've described to me sounds like,
18 my God, this is on Wednesday really bad, and you knew it?

19 Mr. Miller. Yes, I knew it. I was talking to the NRC
20 and to B&W, and I formed a senior think tank of my best people.
21 That's why I did that, and every half hour I walked into a
22 room that he talked about, and we sat down and said, "Where
23 are we going next? Is the core covered? What is the readings
24 off-site?" We were talking to the health physics people in
25 the state from two phones, giving them readings.

1 By noon, I had not had any readings. I had nothing even
2 near an EPA guideline. My interest on, from 8:30 on, once the
3 emergency plan was fully implemented, and I've done it four
4 times, was to somehow get the stability to an operator, is
5 a reactor coolant pump running, because you can permanently
6 cool the core. That is where we were.

7 Mr. Cheney. But you say at 7:10 in the morning you knew you
8 had voids?

9 Mr. Miller. At 7:10 in the morning, I knew I had bubbles
10 in the hot legs, these two legs above the pressurizer, because
11 the first thing we did was try to start the reactor coolant
12 pumps again. The pump would energize, the current value would
13 be one-sixth of normal, which meant it was pumping steam.

14 Mr. Zewe. But we did not know how large we were, or that
15 the core was partially uncovered.

16 Mr. Miller. There's no indicator. I also had -- time is
17 a hard thing, but somewhere early in this frame, I had an
18 instrument engineer read. There are temperature indicators
19 there inside the vessel, and we could not read them on the
20 computer. We read the base voltage single down at the panel,
21 and they indicated numbers like nothing, 200 degrees, 2400
22 degrees, which meant the core was very hot. If you believed
23 them. I had no consistency, but I believed we were hot. I
24 believed the core was covered at that time. And we had hoped
25 just to pump water in, until we could get down to where we could

bw23

1 a system like decay heat. So we, between the hours of 7:00
2 and 9:00 on two separate occasions tried to start reactor
3 coolant pumps. We did not get any flow indicators, which meant
4 there was no water in the pump.

5 Mr. Weaver. How did you finally get the water in there?

6 Mr. Miller. We just kept pumping water in all day and
7 around the middle of the afternoon, well, we discussed this,
8 the five senior people or four that I was using, so that I
9 did not hamper the operators, we sat in a room and took all
10 the suggestions, including anybody else that was there.

11 The NRC was on the phone. We weren't in a procedure that
12 we'd never been in; we weren't scared. I didn't think we should
13 evacuate the whole county, but I had 500,000 pounds of water,
14 I knew I could pump all day.

15 I just wasn't at a stability point.

16 Around midday we came down in pressure, because you have
17 a set of so-called "core fed" tanks that come in through two
18 separate nozzles on top of the reactor vessel, and some of the
19 operators had discussed it, and we decided to come down. In
20 our mind, we thought if we got down, we could, number one, have
21 some level indicator on the coverage, which would tell us
22 that we were sure it was covered.

23 You can see we don't know how much heat we were going to
24 get, but we were going to try. There is no level indicator
25 on the legs, so you're going on pressures and temperatures, and

1 you're trying to be sure your cold temperature is pegged low,
2 your hot temperature is pegged high.

3 The amount of indication you had made it so you couldn't
4 totally convince yourself the core was covered, and that was
5 our concern, knowing that the emergency plan was working.

6 There was a lot of other dialogue going on with respect
7 to the emergency plan and decisions about moving people, and
8 my own people, when do I send them home, where do I send them
9 going around the site making sure nobody was there, because
10 the wind was blowing very slow, so the highest radiation was
11 on the site, so I was trying to make sure nobody was on the
12 site.

13 At the same time I had off-site teams on, and, for
14 instance, when I got there at 7:30 in the morning, the wind
15 was blowing towards Goldsboro, which is across the river.
16 It is a long drive at 7:30 in the morning. In Harrisburg,
17 I got a State Police helicopter to come in and take those
18 people over there.

19 At the same time coming back to the plant, trying to just
20 keep the core covered was our goal.

21 Later on in the day when we got rid of it, we pumped
22 enough water in and got enough coolant to where the alpha
23 loop, the A loop, should us that it was beginning to collapse.

24 Mr. Weaver. The steam bubble?

25 Mr. Miller. Yes, and we could see that with the

bw25

1 temperature indications.

2 Now at the time in the middle of the afternoon, as I remember,
3 we had problems with some pumps, oil pumps, to the reactor
4 coolant pumps. We had no oil pumps, so then we couldn't --
5 you know, you take a chance on wiping out the pump, if you
6 start it without an oil pump.

7 So we were working on that to somewhere that evening,
8 early in the evening we did get an oil pump back. We did
9 start a reactor pump up.

10 Mr. Weaver. You say the oil pumps failed?

11 Mr. Miller. There was a power problem. The supply to
12 them was tripped, the breaker was tripped.

13 Mr. Weaver. They are not on diesel?

14 Mr. Miller. No. Everything was hybrid. In this auxiliary
15 building things were hot, and I had to be careful. We had been
16 very careful who we sent where, and plus you had to put all
17 the gear on and serve into the area, try to make sure we didn't
18 overexpose anybody to a degree for something you didn't have
19 to do. That kind of thing, which eats up time and eats up
20 decisionmaking.

21 But finally that night around 6:00, or I guess 8:00
22 o'clock, we got a pump started, a reactor coolant pump
23 started.

24 Mr. Weaver. And that is because you just kept putting
25 water in then until you got it primed?

bw26

1 Mr. Miller. That's right.

2 Mr. Cheney. Then, so you got back to a much more stable
3 situation?

4 Mr. Miller. You're back to a condition, you recognize the
5 pumps are running. You know it's got a flow. You are
6 in a condition where you can begin to go to the next safe
7 level.

8 Mr. Cheney. But you've still got a bubble in the reactor.

9 Mr. Miller. By that time at night, we probably had
10 collapsed most of the voids. We probably had seltzer water,
11 a lot of air in the water, a lot of steam in the water, that
12 type of thing.

13 Mr. Weaver. The hydrogen bubble comes later.

14 Mr. Miller. We probably had it then, but we didn't know
15 it.

16 Mr. Zewe. We weren't making any more at this point in
17 time, though.

18 Mr. Weaver. There was an indication or implication that
19 you purposely released some radioactivity, because of the
20 problems you had here.

21 Could you clear that up for us?

22 Mr. Miller. No. You've got to remember that during the
23 day when we were supporting this primary system, we also had
24 some water going in and out. In other words, you had some
25 water you're trying to put in, you're bringing some out.

bw27

1 Mr. Cheney, But it's all inside the containment vessel?

2 Mr. Miller, But some of the water comes to a tank that's
3 outside, and that is probably releasing some fission product
4 gases that go into the ventilation system through charcoal
5 filters,

6 Mr. Cheney, But is that water in the auxiliary building?
7 Was there any transfer there after the sump pumps were shut
8 off?

9 Mr. Miller, No, except that you have -- the reactor
10 coolant pumps have seal injection, for instance. That is
11 a water seal on the pump that returns to the auxiliary building.

12 You also have letdown that returns to the auxiliary building.

13 They would have probably been bringing some fission
14 product out, which would have been offcast and gone out through --
15 It is designed to go out through the ventilation system through
16 charcoal filters, So not purposely but by design, some of that
17 would have gotten out, And you have to remember we had we
18 had radiation areas all over the auxiliary building. I mean
19 you would open a door, it would be 300-R; you open another
20 door, it would be 25-R.

21 We were running around that day, knowing we were releasing.
22 We running around putting polythene down on the floors, trying
23 to minimize overexposure. Now you've got a lot of exposure
24 in guys to put a suit on, put a respirator on. It is a pretty
25 detailed and hard thing to do.

1 We were trying to place piping diagrams to figure if there
2 was anyplace we were releasing that we didn't know about.

3 The plant is designed with charcoal filters, so the
4 part that's going to the ventilation system is not our major
5 concern, our concern would have been, "Are we leaking anywhere
6 else?" We made a survey of that building with an operator
7 and a shift supervisor. That type of -- and it's going on at
8 a fairly high frequency, and a lot of activity.

9 Mr. Weaver. Now the leak is coming from the auxiliary
10 building. No place else. Is that correct? The stuff that
11 did get out?

12 Mr. Miller. There's nothing out of the reactor building
13 that I know of. The reactor building was isolated.

14 Mr. Cheney. Except for the water.

15 Mr. Miller. Except for the water supporting the system.
16 We did not want to lose the seals to this reactor coolant
17 pumps, because that was one of our ways out of this. So we
18 did support the seals which would then bring some water back.
19 We were also probably letting down some water.

20 Mr. Weaver. But that's going to the auxiliary building?

21 Mr. Miller. That would go into a tank in the auxiliary
22 building which vents to a pipe that gets exhausted through
23 the charcoal filters.

24 Now we could not go everywhere in the auxiliary building.
25 We could have had leaks.

bw29

1 We were taking action to stop the release. The kind of
2 action putting poly on top of the water, because we thought
3 some of that water might have some fission products, since
4 we thought by putting poly over the top of it, we could minimize
5 the operation.

6 That is the kind of stuff we were trying to do in the,
7 but there was an awful lot going on between the emergency plan,
8 between that, and that is kind of where we were going through
9 that day.

10 Mr. Weaver. And the NRC's being apprised of all of this?

11 Mr. Miller. We were on the phone, to my knowledge, from
12 7:30 or 8:00 in the morning, we had a hot line to Region 1,
13 which is in King of Prussia.

14 By 10:00 we had five of them. We probably had 10 or 15 of
15 them there by evening. And, in fact, I know most of them,
16 and were asking their advice internally and technically. But
17 it was clear that it was my decision. It was clear to them
18 and clear to me.

19 Mr. Cheney. How does that set of relationships work?

20 Mr. Miller. Very directly, I gave them my radiation
21 data, my off-site data, I told them the status of the
22 plant, asked them for advice, and we very clearly knew that I
23 had to make the decisions. But it wasn't a conflict-type
24 relationship, it was a direct type of relationship.

25 Mr. Weaver. Help me to understand this. Listening to you

1 for the last half hour, there is an enormous divergence, at
2 least from what I have heard, between high-level NRC people
3 and their view of what was going on at Three-Mile Island, and
4 what you've described.

5 And so I'm wondering, is this a communications gap?
6 I mean, they just didn't see the urgency, apparently, that
7 you describe.

8 Mr. Miller. The people at my level. The technical people,
9 the principal inspector for the plant, the people that came
10 into the plant. I know most of them, because I've been around
11 in this business awhile. We know we had a serious situation.
12 We knew we were releasing, but we also had data from everywhere
13 on the site. Data from all the places the wind had blown.
14 We didn't have an incident, in our minds, that required like
15 evacuation or closing the area. We did not have that. At this
16 time that we had a serious problem, and we weren't out of it
17 yet.

18 I don't know the communications within the state of the
19 NRC. I talked directly to the health physics officer in the
20 state through two hot lines. I talked to the Region 1 inspector.
21 At no time was I told there was disagreement.

22 In a recommendation for action, at no time was I told to
23 do something technically that I did not evaluate. There were
24 no disagreements.

25 Now there is a gap that I don't understand. At the same time

1 I was talking to my own manager, and they knew what I was
2 doing.

3 Mr. Cheney. There is a sense from the NRC, in looking
4 at the transcripts of those days, that they were at a loss
5 to know what was going on and what was happening.

6 Mr. Miller. If I went on to say anything else, I would
7 be giving you my opinion. I will give you that, but I don't
8 think that's what you want.

9 Mr. Weaver. Why don't you, if you don't mind?

10 Mr. Cheney. What we're curious about, I think, primarily,
11 is how, once the crisis has occurred -- the accident has
12 occurred -- how we go about managing the current event.

13 Are we talking about a problem here that arose because
14 you didn't have any information or accurate information about
15 what was going on inside the reactor and, therefore, they
16 were puzzled, or because there was some kind of communications
17 problem -- gap from what you had and what they had?

18 Mr. Miller. I knew exactly what was going on. I didn't
19 know how to get out of it, but I had not been in this situation,
20 and did not ever imagine that I would be, but I had no panic.
21 There was no panic in the control room. We all knew what we
22 were doing, and I stayed out of his hair.

23 The direction was coming from me. I knew all the
24 radiation readings. I knew I had a hell of a problem. I
25 was talking directly. I had an emergency plan. That emergency

bw32

1 plan I practiced one a year. I talked to Jurusky and Maggie
2 Valli. Those are the health physics people for the state.

3 So I was communicating with people I knew about things
4 they knew about. I don't believe that communication had
5 ever been attempted to the senior levels.

6 You see the president of my company probably had the same
7 problem, but he knew that I was trying to do this, so he
8 didn't ask me what the hell I was doing.

9 Other people -- I was sitting in the control room, and
10 I heard the NRC people trying to explain to their home office
11 what was going on.

12 People at my level, they just could not understand.

13 Mr. Cheney. You dealt with the NRC people on your
14 level?

15 Mr. Miller. And there was a hot line to the Region 1
16 office.

17 Mr. Cheney. Did you ever talk to Bethesda Headquarters
18 of NRC?

19 Mr. Miller. Not that day. I did it through anybody I
20 could, because the number of questions I was answering and
21 the number of decisions I was trying to make were, you know,
22 the frequency and the magnitude of this thing went by like,
23 it was kind of stressed. It was very complicated. I don't
24 know how to describe it. It was just 10 hours of hell, as
25 far as keeping your focus, and I would not let myself get on

1 the phone and lose focus. That is just not the way I'm
2 trained.

3 Mr. Weaver. How much radioactivity was there in the
4 control room?

5 Mr. Miller. There were periods of time that we had
6 respirators on. I had my head physics guy, who's experienced.
7 He came out of the Naval program. When we got above, I guess,
8 MPC. --

9 Mr. Weaver. What's that mean?

10 Mr. Miller. That's permissible concentration -- we put
11 the respirators on. If the wind stopped, which it did that
12 day, the wind blew. If you had to imagine this scenario
13 from a side standpoint, the wind did not blow that day very
14 much. It would go up to 10, to 20, to 30, and come back down.

15 Mr. Meyers. What? 30 what?

16 Mr. Miller. Millirem per hour. Part of your emergency
17 plan is to break out your dosimeters and kits. We have a meter
18 up there. We have a pocket dosimeter you can read. You could
19 read a temporary device that is not totally accurate, but it
20 is a good indicator of whether you are getting too much.

21 Most of the time, for instance, the emergency control center
22 in Unit 1 became very high. High to me being probably 50- to 70
23 MR per hour, and we evacuated that and brought them to another
24 place. We kept moving people around to get them out of this.
25 No, we never got to a point where we considered evacuating the

bw34

1 control room, because we weren't that high. And the system
2 in the control ventilation system has a recirculating ability
3 where it goes through filters. You should be able to live
4 through this.

5 Mr. Weaver. What would happen if the control room had
6 gotten so hot that you would have to evacuate?

7 Mr. Miller. That would be hard to imagine.

8 Mr. Weaver. I will ask you that next.

9 Mr. Miller. You would have to go to a separate panel,
10 where we have some indication, vital indications, and operate
11 from there.

12 Mr. Weaver. You can operate someplace else?

13 Mr. Miller. You can operate some basic parameters from
14 another room.

15 Mr. Chaney. Where's that.

16 Mr. Miller. It is a cable room below the control room.

17 Mr. Zewe. Right underneath the control room we have
18 an auxiliary panel.

19 Mr. Miller. I might say again that the control room
20 ventilation systems goes through charcoal filters, so we could
21 have gotten up to the radiation level in there, and we would
22 have circulated and that should have removed it.

23 Now, if we had some situation that says evacuate the
24 control room, we would have gone down below, that would have
25 made it harder. Now we have a little less indication

bw35

1 and a lot more places to run and look at things, but that
2 could have been done.

3 Mr. Cheney. Is that room sheltered within the control
4 room?

5 Mr. Zewe. Not really.

6 Mr. Miller. It is a different location. It might have
7 less radiation. It is in a different room.

8 Mr. Weaver. If both were impossible to stay in, then you
9 have no control anymore, although the plants still could
10 possibly go into cold shutdown all by itself, couldn't it?

11 Mr. Miller. I would not leave the control room in this
12 situation.

13 Mr. Weaver. I understand.

14 Mr. Miller. You can't get me in a situation where I would
15 leave. You could not walk away from this thing, and say it's
16 going to shut itself down. It wouldn't do anything immediately.
17 You would have to make provisions to get back in later. That
18 would be your goal if you had to leave for some reasons; but
19 you remember none of us had experienced very significant
20 radiation doses. If you look at our film badges, we got
21 hardly anything, so I could have stayed up even if the reading
22 had gotten pretty high. I would have stayed up there for a
23 long time and switched crews to minimize health risk.

24 That would have been the way I would have gone. I would
25 have never left the control room from a radiation standpoint.

1 Mr. Weaver, I understand; Now the possibilities of
2 the control room getting that hot are not very strong; are they?

3 Mr. Miller. I don't feel they are, because the system is
4 designed with charcoal filters and ventilation and
5 recirculation. In other words, we are releasing and it is
6 laying on the site, because there is no wind.

7 This system is designed to go into a recirculation
8 internally, so you don't pull that in from the outside. That's
9 why I'm saying that.

10 Mr. Weaver. Oh, you're pulling radioactivity in from
11 outside, so when there's no wind, you're getting more in
12 the control room?

13 Mr. Miller. Except you go into recirculation, and you
14 don't have to. In other words, normally the air intake
15 sucks from the outside on the site. It is a cement thing
16 which is designed against airplane damage. If we're releasing
17 radioactivity and it's going on the site, which is what
18 happened to us that day, and we would have stopped that
19 and gone into recirculation, but we did not have to pull
20 out there, and it would have helped us minimize it, and we
21 did that.

22 Mr. Zewe. We were on that from almost the beginning of
23 the problem from site emergency.

24 Mr. Cheney. Would it be fair to say that if it got hot
25 enough in the control room, so you had to evacuate, that you

bw37

1 you were already beyond the hand of what's happening in the
2 containment vessel?

3 Mr. Miller. I guess so. You could imagine me into that,
4 I guess. I would not leave.

5 Mr. Cheney. Well, I am not suggesting you would have.
6 I understand that. If the dose were high enough --

7 Mr. Miller. But I cannot imagine it getting high enough,
8 so that I couldn't switch crews often enough to keep people
9 in there.

10 Mr. Cheney. Even if the containment vessels ruptured?

11 Mr. Miller. I can't, no. If the containment vessel
12 ruptured, I would rather stay there, because I would think I was
13 safer right there.

14 Mr. Weaver. I'm trying to prevent a core meltdown, you
15 see. I'm not concerned about core meltdown. I'm trying to
16 understand, can you get that kind of radioactivity without a
17 core meltdown?

18 Mr. Miller. No.

19 Mr. Weaver. Well, once you get core meltdown, you're
20 done anyway.

21 Mr. Miller. I don't even know if that's true.

22 Mr. Weaver. My point is, I'm trying to prevent a core
23 meltdown.

24 Mr. Miller. So was I. In the scenario you're describing.

25 Mr. Weaver. And I'm just trying to see if you get the

1 radioactivity in the control room at such a level.

2 Mr. Miller. The control room design is that if one of
3 these pipes breaks doubled-ended with fuel damage, you get
4 radioactivity in that building in a very high level -- you
5 get 60 pounds of pressure, and you can live up there in that
6 control room and control it. That's the way the design is.
7 That's why I'm saying that.

8 Mr. Weaver. I don't understand that.

9 Mr. Miller. The plan is designed so that if one of
10 these big pipes falls down, the plant goes to -- this big
11 building goes to 60 pounds. You have radiation in the
12 building, and you stand outside the building in that control
13 room and cool it down.

14 Mr. Weaver. It's containing the radioactivity?

15 Mr. Miller. Right. It's containing it, and it's designed
16 to leak a very small amount like .1 percent, and you actually
17 test this building at that 60 pounds every three years, and
18 what I'm saying is you can stand outside in the control room.

19 That is my basis for saying that, it just isn't my gut
20 feel, it's my basis from the design.

21 Mr. Chaney. If you would like at the whole accident at
22 this point, when we talk about in terms from our perspective,
23 trying to ascertain whether we've got the incident resulted
24 from design error, for example, you might look at the fact
25 that you can read the pressurizer level and get a wrong

bw39

1 conclusion from that pressurizer level as to how much water
2 there is in the reactor, that that might constitute a design
3 error, where you've got mechanical errors like the pressurizer
4 valve fails to close, how do you assess at this point
5 recognizing it is a subjective judgment as to where the
6 fundamental flaw was that led to this particular accident.

7 Mr. Miller. In my mind, it was just that the operator did
8 not have enough information.

9 Mr. Cheney. Is that a design error?

10 Mr. Miller. In my mind, it is.

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 Mr. Cheney. The system failed to provide them with
2 enough information.

3 Mr. Miller. The way I look at it, if these operators had
4 shut that valve at 5:00 o'clock, that would have never happened.
5 They would have been just as lucky as they were unlucky. In
6 other words, they needed more information in my mind, and I
7 don't say that from a selfish standpoint. The guys looked at --
8 you look at the computer printouts. They kept looking at the
9 discharge temperature on that pipe, which means they were
10 looking for a problem.

11 If there had been a flow indication or a more positive
12 temperature indication, they would have shut the valve. But
13 that is also said as an operator.

14 Mr. Cheney. Do you have any idea why the temperature
15 indication on the tail pipe off the pressurizer valve gave the
16 wrong reading?

17 Mr. Miller. The only thing I can come up with is an
18 external thing on the pipe, and possibly due to the amount of
19 water being shoved through that valve, they might have some,
20 due to expansion, some cooling actually occurring.

21 Mr. Cheney. Discharging cooler water?

22 Mr. Miller. Well, the expansion across the valve could
23 have caused some cooling physically. I haven't looked at it
24 enough.

25 Mr. Cheney. But you see that as the fundamental flaw?

1 Mr. Miller. Personally, I think he just didn't have
2 enough information. He was looking for more information. If
3 he had had a little more information about that valve and that
4 pipe, he would have shut the valve.

5 Mr. Weaver. Let me ask you this. In one instance we
6 have an instrument malfunction, in effect, when you didn't get
7 the reading that the pressure valve was open, right? In
8 effect, it was an instrument malfunction?

9 Mr. Miller. Do you mean that the signal said it wasn't
10 closed? It was closed.

11 The thing you've got to remember is that light is only --
12 it is not actual --

13 Mr. Weaver. I understand that. Nevertheless, you're
14 doing your damn best, but the information you're getting was
15 wrong.

16 Mr. Miller. The information he is getting is not telling
17 what is going on.

18 Mr. Weaver. That's what I'm saying. When I say an
19 instrument malfunction, I mean you're being sent the wrong
20 signal.

21 On the other hand, you've got a correct signal from the
22 pressure charge containment when you've got that 28 pound
23 spike. So on one you believed the system and on one you didn't
24 believe the system.

25 Do you follow me?

1 Mr. Miller. Well, let's look. In the afternoon, we had
2 a pressure spike. The pressure spike was instantaneous. It
3 happened very quickly and then it went away. And there was
4 no difference in any of the system parameters other than that.
5 We didn't see anything that would have knocked that up. We
6 did not see anything that told us that the building had a
7 pressure in it.

8 Mr. Reis. Are there other instruments that you would
9 have looked to? If you had been watching it, would you have
10 seen that? Or are there other permanent instruments that would
11 have shown that, that could corroborate?

12 Mr. Miller. Normally when you see -- and Bill, you can
13 say if you disagree with me. But if this building pressure
14 instrumentation is to look for a pressure in the building
15 which normally occurs due to the energy release when the water
16 is freed through a pipe break, that normally occurs over a
17 period of minutes and hours.

18 Now, looking back, everybody's saying, hydrogen burning.
19 Yes, I understand it now. But at the time we would have looked
20 for a physical break or a physical problem in the system, and
21 we saw nothing. So therefore we said, all right. That's not
22 unusual to see instrument error.

23 I don't want to get into how many instrument errors you
24 have. But it was the only thing we had and it didn't get
25 fouled up and we did not have any other indicators, and that

1 is why.

2 Mr. Reis. Would you have, given what you knew at almost
3 2:00 o'clock, did you know enough about perhaps the condition
4 of the core that you might have thought hydrogen was around?
5 Why would you not have? And I don't mean to indicate that
6 you should have. But why would you not have thought, hmmm,
7 maybe that was hydrogen, maybe there's hydrogen in the contain-
8 ment?

9 Did you know enough about the core situation at that
10 time to suggest hydrogen?

11 Mr. Zewe. I was monitoring the reactor building pressure
12 at the exact instant that we were cycling the electromatic
13 relief valve. Fred, I believe, was actually waiting to
14 operate the valve, based upon my command. And I was looking
15 at the RC pressure. We were trying to not exceed four pounds
16 in the building and have isolation at that four pound value,
17 when the pressure was somewhere around two pounds.

18 So Fred was cycling the electromatic valve. And I said,
19 all right, Fred, open it now. As soon as he hit it, that
20 instantaneous spike came up and came right back down. At
21 that point, the building spray pumps started, too, and they
22 started on a 30-pound signal.

23 So we all considered this for a couple of minutes on why
24 we had that spike. No one knew. At that point I did not know
25 that we had got as hot as we did as far as the reactor core

1 goes. It takes at least 2200 degrees Fahrenheit to have
2 water reaction to release hydrogen, to have it in the contain-
3 ment.

4 If we had known -- and I didn't at this point in time,
5 nor did anyone that I was with, and there was in the neighbor-
6 hood of eight to ten people that had seen that, too -- we
7 didn't know that the temperature was that hot. The highest
8 temperature that I had seen was about 780 degrees. That was
9 the highest temperature I knew of, which was far below the
10 point at which we could have the zirc-water reaction for the
11 release of the hydrogen.

12 And since we had just operated an electrical valve, we
13 thought that there was some way that we malfunctioned and
14 caused an electrical upsetting or imbalance to affect the
15 pressure indication.

16 Mr. Cheney. What is it you operated that led to the
17 spike?

18 Mr. Zewe. The electromagnetic relief valve, the same
19 one that stuck open. We were cycling it open to reduce the
20 pressure in the reactor coolant system and sent it right to
21 the RC drain tank.

22 Mr. Cheney. Are we working with the safety valve that
23 we think malfunctioned or are we downstream?

24 Mr. Zewe. No, on that valve itself, the valve that had
25 failed open. We had unisolated it and we were opening that

1 valve up, cycling it to reduce the pressure in the system and
2 venting it right into the containment.

3 Mr. Cheney. But I'm curious as to whether you were using
4 the backup valve.

5 Mr. Zewe. No, the automatic valve that had failed.

6 Mr. Cheney. Is now working?

7 Mr. Zewe. We could still operate it from the console.
8 We could open it up, but it would not shut all the way. Even
9 on command, the valve would not shut completely. We could
10 open it up, how far open we don't know. But we could open it
11 up.

12 So we had unisolated the valve that we had shut previously
13 to block it. We opened it up, and then we opened up on our
14 manual control for that valve, to reduce the pressure. And
15 the instant he did that was when we had the spike.

16 Mr. Cheney. In retrospect now, would that look like that
17 was as a result of releasing the hydrogen?

18 Mr. Zewe. I think the hydrogen was already there, and
19 that spark from the electrical solenoid provided the ignition.

20 Mr. Weaver. It is inside the containment?

21 Mr. Zewe. Yes.

22 Mr. Miller. The electrical energy he used to open the
23 valve might have sparked it, which would have ignited the
24 spark to the hydrogen, looking back.

25 Mr. Zewe. But we didn't know why and we did not suspect

1 hydrogen at a high concentration at that point in time at all,
2 because we did not know we had ever achieved those higher
3 temperatures to create the zirc-water react on.

4 Mr. Cheney. You talked earlier about, when I asked you
5 if you could sort of subjectively judge what specific event
6 was most significant here, you talked about the lack of good
7 information being available to the operators. Are there two
8 or three things you would recommend by way of improvements on
9 the reactor design that would have made life a lot easier that
10 day?

11 Mr. Zewe. Yes. I would like to have actual limit switch
12 type indication for that valve's actuation, so when the valve
13 moves it trips a limit switch showing the valve is open, and
14 when it shuts it trips a separate one saying that it is shut.
15 The only light that we have right now is the electrical signal
16 telling it to open or not to open.

17 Mr. Cheney. But that was put on after it failed once
18 before?

19 Mr. Zewe. Yes, that was put on in '78.

20 Mr. Cheney. The fix was inadequate, in other words?

21 Mr. Miller. But that is because physically the valve is
22 a canned valve and it would be very hard to get to it physically,
23 without a different kind of designed valve.

24 Mr. Cheney. Is there any other thing you would like to
25 see?

1 Mr. Miller. In my mind, you know, we were looking at
2 something specific, so we were probably going to come up with
3 specifics on that. But somehow look at maybe some more
4 instrumentation as to what is going on in the core. From my
5 standpoint during the day, it was hard, starting off with
6 bubbles in those legs, to evaluate whether the core was
7 covered, to evaluate it physically.

8 We did all of the things. We had the steam generator
9 steaming. We had water going in. We did everything physically
10 we knew how to do. But you know, you are still thinking
11 whether that was covered.

12 Mr. Weaver. Well, it wasn't covered.

13 Mr. Miller. Yes, it was, during the day. Making sure.

14 Mr. Weaver. When it was covered, you didn't know if it
15 was.

16 Mr. Miller. From 7:00 in the morning to 8:00 at night,
17 with increasing radiation readings, convincing yourself that
18 that was covered was hard.

19 Mr. Reis. When did you know that it had been uncovered?

20 Mr. Miller. I don't think I ever realized it until the
21 next day.

22 Mr. Weaver. But you were worried it was uncovered.

23 Mr. Miller. I was worried that I wasn't keeping it
24 covered from 7:00 in the morning on, same as he was. I was
25 worried until we got to a stable point, which would be a

1 pump running or decay heat. Those are the points that are
2 stable and known to be stable.

3 Mr. Scoville. If you had known about the hydrogen at
4 the time you saw the spike, how would your procedures change?
5 What would you have done differently?

6 Mr. Miller. I don't think I would have done anything
7 differently, to be honest with you. One of our consultants
8 the next day told me that was the best thing that happened,
9 was we were burning it up in that condition, because other-
10 wise you would have had one heck of a problem figuring out
11 what to do with it. You just can't get rid of it.

12 Mr. Scoville. This got rid of it?

13 Mr. Miller. This got rid of it. I could have seen us
14 talking for two weeks on how to get rid of it.

15 Mr. Weaver. So in other words, you started to get lucky?

16 Mr. Miller. I don't know if that's the right word.
17 Somebody said, if you had known. I don't know what I could
18 have done. I don't know what I could have done different if
19 we had known there was hydrogen in the building. We would
20 have probably gone and deenergized all the electrical breakers
21 we knew of. We would have probably minimized any electrical
22 equipment starts.

23 It would have put another variable in the problem and
24 made it more difficult.

25 Mr. Weaver. That indeed is what we did do.

1 Mr. Zewe. We would put in the hydrogen recombiner to
2 reduce the concentration.

3 Mr. Miller. But that takes a longer time.

4 Mr. Weaver. Did anybody think, when you had the hydrogen
5 bubble, of burning it?

6 Mr. Miller. Do you mean after?

7 Mr. Weaver. Yes. We've got the hydrogen bubble in
8 there now.

9 Mr. Miller. You mean after the next day?

10 Mr. Weaver. Yes, Friday morning.

11 Mr. Zewe. In the core or in the building.

12 Mr. Weaver. I'm sorry. Forgive me, Jim.

13 Mr. Cheney. You talked about knowing whether or not
14 the valve was open or closed, and the water level inside the
15 reactor.

16 Mr. Miller. More indications in the vessel, because in
17 my mind -- and Bill, you can disagree from your experience.
18 But in my mind, we never imagined the core becoming uncovered.

19 Mr. Weaver. Before.

20 Mr. Miller. That's right. Now we end up with bubbles
21 in those hot legs and the core was uncovered, and we know that
22 today. And we ended up in a situation trying to collapse
23 this thing and go solid. And the indication available to go
24 from where I started to where we ended up was a design -- the
25 only thing I can think of is more indication of what you had

1 in the reactor.

2 Mr. Cheney. Do you have a lot of familiarity with other
3 kinds of pressurized water reactors?

4 Mr. Miller. Some. For instance, the submarines are
5 pressurized water. The carriers are pressurized water. The
6 cruisers are pressurized water.

7 Mr. Cheney. Is their design better than this one from
8 the standpoint of managing this kind of problem?

9 Mr. Miller. Well, number one, a submarine is like a
10 tenth of this thing or less. And number two, the pressurizer
11 is higher than the loops in most of the ones I know of.

12 Mr. Cheney. Is that a significant factor?

13 Mr. Miller. To an operator, we probably would like it
14 higher than the loops, physically higher.

15 Mr. Cheney. Because you're less likely to be able to
16 get --

17 Mr. Miller. If you're going to get a bubble, it's going
18 to get there first if it's highest.

19 Mr. Cheney. I thought that was the theory behind this
20 one?

21 Mr. Miller. That is the theory behind this one, except
22 when you get those candy canes higher than the pressure
23 reactor, once you get the bubble outside that pressurizer and
24 get it in those candy canes, you are going to have a hard time,
25 with the pressurizer being lower, ever getting it back.

1 Mr. Cheney. I would call that, then, a fundamental design
2 flaw.

3 Mr. Miller. But you asked what else I would do. One of
4 the other things is put vents in those candy canes, so you
5 could vent it off. And in fact, I think Duke has those vents,
6 I have learned subsequently. But they weren't put there for
7 that reason; they were put there for another reason. But they
8 would have helped.

9 Mr. Cheney. Is that also a B&W reactor?

10 Mr. Miller. Yes.

11 That would help us. We had no way of venting the system.
12 If we could have vented the highest point, we could have
13 filled it up with water to that pump and run the pumps sooner.

14 Mr. Cheney. But obviously nobody thought of this when
15 it was designed.

16 Mr. Miller. Starting out, nobody thought about us getting
17 to there.

18 Mr. Zewe. We have vents and everything. But that is
19 just manual valves operated from inside the containment itself.

20 Mr. Cheney. There's nothing you can do from outside?

21 Mr. Zewe. That's right, there's nothing you can do from
22 outside it to operate it.

23 Mr. Reis. Well, we've heard that a fundamental flaw
24 dealing with the pressurizer outlet or inlet coming off, that
25 is so low here and you end up with a problem. Do you think

1 just having the level indicators in the core would take care
2 of that, or is that more fundamental than you would be able
3 to get around with the level indicators in the core.

4 Mr. Miller. I don't mean to say not having level
5 indicators in the core is a design problem. The question was
6 asked, what would I have liked to have had in order to get
7 out of this, and I would have liked to have had more instru-
8 mentation over where the water level was. I didn't say it
9 was really a design flaw.

10 The other problem is probably more fundamental, if you
11 agree to this. It is a design flaw -- I just haven't thought
12 about that. It is just something I would rather not say
13 without thinking on and looking at the whole system.

14 Mr. Weaver. And we don't mean to have you characterize
15 this.

16 Now let me go over this again. You styled the earlier
17 situation as unlucky, and then you had a burn, probably
18 triggered or possibly triggered by the spark when you sent
19 the signal to open the relief valve and the burn occurred as
20 what was a good thing to have happened. So you got lucky.

21 Mr. Miller. I said one of my consultants styled it that
22 way. Like Bill said, we didn't imagine the zirc-water
23 reaction. Had we known the building had that much hydrogen
24 in it, then that would have been another hard variable to
25 deal with.

1 Mr. Weaver. Now we're down to where you've got a
2 hydrogen bubble. Would you describe just very generally --

3 Mr. Miller. Let me say one thing. The hydrogen bubble
4 that I think we're talking about--subsequent to the first days,
5 this first day or day and a half, now we ended up with a
6 reactor coolant system pressurized with some hydrogen on the
7 dome of the head, not in the reactor building. The burn
8 occurred in this building. The burn occurred in the building.

9 Mr. Weaver. Of course it did. I keep forgetting that.

10 Mr. Miller. The hydrogen bubble that we're talking about
11 is in the top of the reactor vessel.

12 Mr. Weaver. The burn occurred in the containment.

13 Mr. Miller. That's right.

14 Now, the next days we had this hydrogen bubble within
15 the reactor vessel. And by this time, we had also assembled
16 a pretty sizable amount of technical competence from outside
17 to help deal with that.

18 Mr. Weaver. Would you briefly describe, then, what you
19 did to try to handle the hydrogen bubble in the reactor?

20 Mr. Miller. In all fairness, you should get that
21 description from a lot better qualified people than me. But
22 what we did, basically, was, number one, we used the pressurizer,
23 we used the physical parts of the system to calculate the size
24 of the bubble. And then, by spraying water into that
25 pressurizer, we were able to spray it, get it to dissolve in

1 the water and get it out in the water and vent it.

2 Mr. Weaver. You're spraying inside?

3 Mr. Miller. In other words, if you get a pump running
4 inside you can strip it off. It is soluble to some extent in
5 water. And you can, by spraying in the top of that pressurizer,
6 you can strip some of it off and then vent the pressurizer off
7 slowly. So then you can take it out of the system.

8 Mr. Weaver. You're taking it out of the core, into the
9 pressurizer.

10 Mr. Miller. And into the reactor building.

11 Mr. Weaver. Is this dissolved hydrogen you're taking
12 out of the core?

13 Mr. Miller. You dissolve it. That's part of the design
14 of the system.

15 Mr. Zewe. You put it back into the water, and then you
16 spray it and it comes out of the solution again, and then you
17 vent it.

18 Mr. Miller. In other words, you take it, you get it in
19 solution in the water which is going in the pipe, then you
20 spray it in the top of this vessel. Now you've got it into
21 steam space, and then you vent the steam space off, and that
22 takes it away and puts it in the building.

23 Mr. Weaver. And that's actually what you did?

24 Mr. Miller. That's what they did.

25 Mr. Scheimann. The more you take off through the steam

1 space, as the water comes back into the reactor vessel, the
2 more you can absorb from that steam space in the reactor
3 vessel into the coolant and then back up to the pressurizer.

4 Mr. Miller. And you can, by taking the water level and
5 an inventory of the system, you can calculate, because the
6 gas acts different than steam, you can calculate the size of
7 the gas bubble, which is what we did. And we were able to
8 calculate it was gone, essentially by that method.

9 Mr. Reis. How did you -- if it's up here in the head of
10 the reactor vessel, how did you get it into this pipe?

11 Mr. Miller. We were circulating water.

12 Mr. Reis. So that was dissolving it.

13 Mr. Miller. You dissolve it in the water and it goes
14 with the water. And as you spray, that tends to physically
15 strip it off.

16 Mr. Weaver. By "strip it off" --

17 Mr. Miller. It comes back out of solution, like a steam
18 bubble does.

19 Mr. Weaver. You're putting it into solution, you're
20 dissolving it by increasing the pressure.

21 Mr. Miller. The pressure-temperature relationship.

22 Mr. Zewe. Your water, for any set of conditions, will
23 hold a certain amount of hydrogen.

24 Mr. Weaver. Sure. •

25 Mr. Zewe. If I remove some of the hydrogen over here,

1 when it comes back it can absorb more, and I'll remove it over
2 here.

3 Mr. Weaver. I understand that. I just wonder, what were
4 you doing to enhance the hydrogen dissolving in the water?

5 Mr. Miller. Just keep circulating and spraying. You
6 keep venting it off, so now your ability of your water keeps
7 removing it.

8 Mr. Weaver. So in other words --

9 Mr. Miller. Time. Time and venting it to the building.

10 Mr. Weaver. You could not increase the dissolving.
11 There was nothing you could do?

12 Mr. Miller. You are physically limited by the ability
13 of the system.

14 Mr. Zewe. You can raise pressure and force the gas into
15 solution better. But then you have a physical limitation as
16 to how high you would like to maintain pressure for the
17 condition. So we held a pressure band which said, all right,
18 at this set of pressure and temperature conditions the water
19 could only absorb so much of the gas, hydrogen. But you had
20 to keep degassing it.

21 Mr. Weaver. You had to keep the pressure in the core,
22 because otherwise the hydrogen would have expanded.

23 Mr. Miller. That plus you want to physically keep the
24 pressure there normally. I would tell you that normally this
25 plant has hydrogen in it. We put hydrogen in it purposefully,

1 because you have oxygen in the water, and with this reactor
2 and the gamma flux in the reactor, by putting hydrogen in you
3 keep that oxygen down. It keeps corrosion down. So you
4 normally do run this plant with some hydrogen in it.

5 Mr. Cheney. Actually in the reactor?

6 Mr. Miller. Yes. All these plants do that to maintain
7 low oxygen levels, because you see, water does disassociate
8 in this reactor. So you get hydrogen and oxygen, and you get
9 an excess of hydrogen to make sure you keep making water rather
10 than make oxygen.

11 Mr. Weaver. Now there was some problem about you were
12 putting lead up? The recombiners?

13 Mr. Miller. We were venting this to this big building,
14 plus the waste gas tanks which were accumulating some of the
15 gas that we were getting had a lot of hydrogen in them. And
16 we put those into this big building.

17 Now the problem is, what do you do with the hydrogen in
18 the big building? There is a device called a hydrogen recom-
19 biner that attaches itself to the ventilation system on that
20 building, and you just take air out and put it back in the
21 building, and this combiner takes the hydrogen and burns it
22 and forms water.

23 Mr. Weaver. But what was your problem in doing that?

24 Mr. Zewe. You are bringing out this atmosphere, which
25 is highly contaminated.

1 Mr. Miller. It's got xenon in it, for instance, which
2 is radioactive.

3 Mr. Zewe. You're bringing it out to this unit, which
4 is in the fuel handling building right next to the auxiliary
5 building. So to keep from the increased radiation levels
6 out here, you will shield the piping, the hydrogen recombiner
7 itself and the lines going back in, so that you won't have
8 radiation dosage problems to the people that are operating the
9 unit.

10 Mr. Weaver. The reason you've got the hydrogen recombiner
11 here without such protection is that you did not anticipate
12 it to be radioactive?

13 Mr. Miller. It wasn't designed to be operated with the
14 building -- with that many fission products in it.

15 Mr. Scoville. Was the recombiner down at the time of the
16 incident.

17 Mr. Miller. The design of the plant is, you have so
18 many days to hook it up and run it on a maximum pipe break
19 with one percent fuel damage. If we had higher than that
20 amount of fuel damage, with more fission products in the
21 atmosphere, this shield had to go in. That is better technical
22 detail.

23 We could have run it without the shielding. But we had
24 to put some lead in.

25 Mr. Zewe. And it isn't anything that you have to have

1 done right away. You can plan for this.

2 Mr. Thurber. Could I ask one question? Had you known,
3 for example, from all these indications in that spike -- let's
4 assume that there was hydrogen present. How would that have
5 affected your notification to the state or to any condition
6 relative to the emergency?

7 Mr. Miller. If we would have known that the hydrogen
8 in the building, if I had known I had a lot of it?

9 Mr. Thurber. Yes.

10 Mr. Miller. It would have probably caused me to seek a
11 lot more senior technical advice as to what to do with it.

12 Mr. Thurber. If you knew -- in other words, what I'm
13 saying is, if you had real positive indications of hydrogen,
14 would you have gone to the state officials in some sort of
15 an alert situation and say to them that, we now believe that
16 we have this, and let them make some judgment?

17 Mr. Miller. If I had known we had hydrogen in the
18 building, then I might have, from my standpoint, made a dif-
19 ferent recommendation on evacuation, for instance, if I had
20 known all that. But I would have told the state people what
21 I was dealing with, that I had hydrogen in the building, also.

22 I would have, additionally, if I had the B&W guy there,
23 I would have asked B&W to give me some idea of the percentage
24 in the building. I would have been trying to put it into a
25 percentage to understand what I had. If somebody said I just

1 had some hydrogen in the building, that doesn't tell you enough.
2 What percentage have I got? Is it 4 percent? 8? 18? That
3 would tell a guy who knows something about hydrogen what the
4 probability of explosion was.

5 And if somebody had just said they had some hydrogen, then
6 the next question would have been to seek more technical
7 advice. If we'd had a lot of hydrogen, then I would have
8 personally said we should evacuate around the area.

9 Mr. Thurber. Are there any specs on that?

10 Mr. Miller. On hydrogen in the building?

11 Mr. Thurber. Yes.

12 Mr. Zewe. There is an explosive range for hydrogen and
13 air. Hydrogen and air, from 4 percent up to about 94 percent,
14 is explosive range. If you get purer than that, above
15 94 percent, hydrogen won't burn; lower than that, there isn't
16 enough oxygen.

17 Mr. Miller. To my knowledge there's not a hydrogen
18 specification for the building. This plant, design for a
19 loss of coolant accident, you would expect some hydrogen. It
20 is a long-term thing, though, and that is why the recombiner
21 is there, to get it out.

22 Mr. Thurber. That's based on LC LOCA?

23 Mr. Miller. Right.

24 Mr. Thurber. That's not what we have here. Of course,
25 we don't have a lot of things.

1 Mr. Miller. I don't have a specification covering it.
2 But if I had had it, I would have used it.

3 Mr. Thurber. You would have had to make an independent
4 judgment?

5 Mr. Miller. I would have made an independent judgment
6 myself. But I was talking to enough groups that I would also
7 listen to a lot of people.

8 Mr. Cheney. Do you have any idea what the capacity of
9 the containment vessel would be in terms of containing, without
10 significant leakage, a hydrogen explosion?

11 Mr. Miller. The containment building would have contained
12 all the hydrogen we could make.

13 Mr. Cheney. In terms of explosion?

14 Mr. Zewe. It depends on what the pressure would be from
15 the explosion.

16 Mr. Cheney. Do you have any idea what the stress factors
17 are on the containment vessel?

18 Mr. Miller. I know the containment is designed for an
19 earthquake. I know it's designed for a 707 going so many miles
20 an hour hitting it. I know all that. I know it's got four
21 foot of concrete. But I don't know about the explosion.

22 Mr. Zewe. I guess they could probably calculate what
23 percentage hydrogen.

24 Mr. Miller. I don't believe that calculation's been
25 made. I could be wrong. I just don't believe we have made

1 that assumption in calculations that I remember in the analysis.
2 We could find that out. But I'm not the guy to ask that
3 question.

4 Mr. Zewe. We did not realize we had it until after we
5 had burned it. So then, since we didn't add any more to it --

6 Mr. Miller. If we had to have hydrogen anywhere in the
7 system, I'd rather have it in that big building.

8 Mr. Cheney. That's understood. But it seems to me that
9 one of the risks in this particular accident--obviously, the
10 containment vessel worked and there was no problem. There
11 would have been if there had been a breach on the containment
12 vessel.

13 Mr. Miller. That's true.

14 Mr. Cheney. If you had any kind of a breach at all,
15 given the levels of radioactivity that have been measured
16 internally, they obviously would have been very serious, and
17 it strikes me that the most serious point in terms of potential
18 leaks was that point at which there was the hydrogen explosion.
19 That's the only time we came remotely even close, conceivably,
20 to breaching the containment vessel.

21 Mr. Miller. If you had to pick a point where you came
22 the closest, not arguing what "close" means, that's true.

23 Mr. Weaver. Let me ask you this. Can you see the flag?
24 That's the Rayburn House Office Building across the way. Can
25 you see the flag on it? It's right in the middle over there.

1 Mr. Miller. I can't see the flag.

2 Mr. Weaver. Well, it's right up there. I watch it
3 frequently and I love it very much.

4 But during this period of time -- Friday, Saturday,
5 Sunday -- my office is right up there. We watched that flag
6 constantly to see which way the wind was blowing.

7 And I want to ask you this: Knowing everything you know,
8 and suppose you had been -- you know everything, but you're
9 not on this job. You're not involved with Three Mile Island,
10 okay. But you are this knowledgeable, very knowledgeable,
11 highly trained person. Would you have been as concerned? And
12 your information is coming from the newspaper. The hydrogen
13 bubble is in there and all.

14 Would you have watched that flag?

15 Mr. Miller. I don't know the answer to that. I just
16 don't know the answer. I can tell you this. I have a daughter
17 that lives ten minutes away from that plant and I never moved
18 her.

19 Mr. Scheimann. My family also lives within 15 miles of
20 the plant and I never moved them.

21 Mr. Weaver. Of course, you would have never left the
22 plant yourself.

23 Mr. Miller. But I certainly would not hurt my daughter.
24 That's the best way I can describe it. If I thought there
25 was danger, then I certainly would have. If I had, in my own

1 mind, from what I have been trained and known, if I had been
2 sitting where you were -- my parents were calling me trying
3 to find me because of the kind of things that were printed in
4 the newspaper. I was inside, communicating what I thought was
5 accurate information. But none of it got out.

6 Mr. Weaver. But you said yourself --

7 Mr. Cheney. None of it got out through the press?

8 Mr. Miller. The context that I read days later disap-
9 pointed me.

10 Mr. Weaver. Well, there's no question about it that
11 it is an imperfect system. It's hard to make judgments on
12 that.

13 But you said a little while ago that if you had known
14 that there had been hydrogen in the containment, that you
15 would be more concerned.

16 Mr. Miller. That's right. It would have been another
17 problem that day which would have had to have been assessed
18 and had to have been dealt with, and I would have dealt with
19 it.

20 By 2:00 in the afternoon I had the ability to talk to
21 people in Lynchburg or anywhere else, and I would have been
22 talking to them.

23 Mr. Weaver. Now, the danger of the hydrogen in the core,
24 in the reactor core, was that it could expand down below,
25 push the water down so that it revealed the core; is that the

1 danger?

2 Mr. Miller. If you had depressurized the system at that
3 time, if you had dropped the pressure, then it would have
4 expanded and possibly put a gas bubble over the core. And
5 again, you would have had -- you see, it's still making heat
6 and you would not have been taking the heat away. The core
7 would have heated up again.

8 Mr. Weaver. Now how about an explosion in the reactor
9 vessel?

10 Mr. Miller. I never detected that that was a serious
11 concern, personally. I didn't know how it was going to
12 initiate. I heard discussions. I think we were more concerned
13 from depressurization and uncovering standpoint.

14 Mr. Weaver. What would an explosion have done to the
15 core; do you have any idea?

16 Mr. Miller. Well, I don't know where we're going to get
17 the explosion internally. We have no oxygen. If you want to
18 go in and put a bomb in there and explode it, yes, that is a
19 concern. But that is the context.

20 Mr. Weaver. I'm talking about the hydrogen in there.

21 Mr. Miller. The concern on the hydrogen was that it
22 would expand and uncover the core again, not an explosive
23 concern, therefore. But we knew we could strip it out. We
24 knew it would take time, and that was the context of that
25 concern.

1 Mr. Weaver. Well, if you were not afraid of an explosion,
2 why didn't you burn it out?

3 Mr. Miller. You can't. You've got to have oxygen.

4 Another thing. You can get it out of the reactor system
5 by taking gas out of the reactor system. It's something we
6 do, we know how to do. We do that in operations. I just
7 told you we put hydrogen in. When we take a plant down for
8 maintenance, we do take the gas out of it normally. So that
9 is not an abnormal operator action. So we knew we could
10 degas it. Our concern was to do that without depressurizing,
11 so it did not uncover.

12 Mr. Cheney. Who did you talk to in terms of making the
13 decision as to whether or not to recommend an evacuation?
14 Was that strictly your own decision?

15 Mr. Miller. During the day of the 28th, after the night
16 of the 28th, I had a pretty senior management structure that
17 had taken effect. In other words, the vice presidents of two
18 of our companies were helping me or had taken charge of the
19 overall operation.

20 They had taken control of the ultimate decisionmaking
21 from me by that night. That day I dealt with my health
22 physics guy, who was coordinating all of the off-site teams.
23 And he was using the Environmental Protection Agency guidelines
24 and the emergency plan guidelines, which give you action
25 levels at certain readings, to take action. You go indoors,

1 you stop eating food, this type of thing.

2 He was dealing with the state radiological health people
3 direct, Zuruski -- I don't know the titles -- and Rally,
4 Margaret Rally, who we deal with normally on this type of
5 thing. And then we would say we did not recommend an evacua-
6 tion, and then they would concur with that decision.

7 Mr. Cheney. And your decision not to recommend an
8 evacuation, is that a judgment call or is that based upon
9 procedures that are spelled out?

10 Mr. Miller. It's based upon procedures that are spelled
11 out, plus judgment.

12 Mr. Cheney. You get a certain numerical reading?

13 Mr. Miller. If I get 5R whole body projected dose, then
14 I'm told to evacuate. If I get .5, I tell people to go
15 indoors. But that's my recommendation to the state. It is
16 their responsibility to decide that.

17 Mr. Cheney. They decide whether or not to evacuate?

18 Mr. Miller. That's their decision. It's their decision
19 as to whether or not they move people. I'm supposed to give
20 them all the information I can and make a recommendation.

21 Mr. Cheney. But your recommendation is almost automatic?

22 Mr. Miller. It's based on action levels in the guide.
23 But the judgment part is based upon what I know the plant is
24 doing. So I've got to give them input into whether I think
25 the consequence in the plant is going to get severely worse

1 quickly. So that is the judgment, if you call it that.

2 The other part says that I have done these off-site
3 surveys that give me this level of radiation. The Environmental
4 Protection Agency says that if you're going to get beyond 5R
5 or 25R thyroid, you do this, and that is the basis of moving
6 people.

7 Mr. Cheney. And you never came close to that?

8 Mr. Miller. We never came anywhere near that. We were
9 a thousandth of that.

10 Mr. Cheney. What was your reaction when the Governor
11 made the decision to evacuate children and pregnant mothers?

12 Mr. Miller. That was not made on the 28th.

13 Mr. Cheney. I know. That was much later.

14 Were you involved in that at all?

15 Mr. Miller. I thought it was precautionary, and it was
16 a personal decision on his part. He's the Governor of the
17 state and he's got different concerns than I do. I did not
18 think it was necessary. But he lives in a different world.

19 Like I told him, I did not move my daughter and I wouldn't
20 move her.

21 Mr. Cheney. How old is she?

22 Mr. Miller. Ten.

23 Mr. Scoville. This goes back to the issue of the hydrogen
24 bubble and its danger, the hydrogen bubble in the reactor
25 cooling system. Although you said there was no particular

1 concern in your mind regarding the explosion of that bubble
2 over the weekend, Saturday and Sunday, were you aware of
3 discussions that oxygen was being produced by radicalysis?

4 Mr. Miller. There was discussion there could possibly
5 be production of oxygen, that's right.

6 Mr. Scoville. Did you believe it?

7 Mr. Miller. There were an awful lot of technical people
8 on the site at this time, and there was a senior group making
9 decisions and deciding which data and which assumptions were
10 going to be taken as the ones to go on. It was hard to decide
11 because of the number of assumptions there are in deciding
12 that.

13 Mr. Weaver. Let's stop for a moment and go off the
14 record.

15 (Discussion off the record.)

16 Mr. Miller. When you get beyond the 28th and start
17 talking about the number of calculations being made about
18 various things, there were so many people making them that
19 I wasn't aware of all of them. And I was an in-plant guy at
20 that time, and my opinions aren't the ones you should take to
21 make a judgment.

22 Mr. Weaver. We're taking them all.

23 Mr. Scoville. I guess the point of my question was
24 really this: When you were deciding which procedure -- you
25 said there were many procedures you could pursue to get rid of

1 the bubble. Was the fact that it was contemplated by some that
2 oxygen was being produced and the bubble might explode a
3 significant factor in making the determination as to what
4 procedure you were going to follow?

5 Mr. Miller. No. You would take gas out with the same
6 procedure, take it out using that system the way Bill and I
7 described.

8 Mr. Scoville. To your knowledge -- and I understand you
9 may not know this -- was the theory of producing something
10 that Met Ed came up with or did it come from the NRC?

11 Mr. Miller. I don't believe it came from either. I think
12 it came from a separate consultant that they both had talked
13 to personally, possibly an expert on hydrogen and oxygen.

14 Mr. Scoville. Thank you.

15 Mr. Meyers. Were you concerned that water in the
16 containment or the fact that sodium hydroxide had been sprayed
17 might have caused equipment -- or degradation of equipment, of
18 instruments, such that you might lose control at some point?

19 Mr. Miller. No. The reason for that would be that we
20 were designed to pump that whole tank into the building.

21 Mr. Meyers. Pump the tank into --

22 Mr. Miller. If you had a loss, a LOCA, a loss of coolant
23 accident, the whole 500,000-gallon tank goes in the building.
24 You have a safety tank on the outside of the building with
25 boric water in it. You put that water in to keep the core

1 down, keep the core cool. You would pump 500,000 gallons of
2 water right into the building.

3 Mr. Meyers. But with the water going into the contain-
4 ment, would that cause disruption of the 480 volt power supply
5 or cause equipment failures or whatever?

6 Mr. Miller. You would have had enough instrumentation
7 left to operate what you needed to at that point.

8 Mr. Meyers. So you were not concerned that the conditions
9 in the containment, whether by rising water levels or the fact
10 that sodium hydroxide or the fact of radiation or temperature
11 or whatever, might cause loss of instruments or equipment?

12 Mr. Miller. If I had to pick, we could have lost pres-
13 surizer level and steam generator level, which would have
14 complicated the operation for us.

15 Mr. Meyers. That is one reason why I think some people
16 were concerned, if you lost control of that equipment inside,
17 that then you would know less of what was going on and you
18 wouldn't be able to --

19 Mr. Miller. That's true. At the time, during the day
20 on the 28th, though, we had only pumped 20 feet of that tank
21 into the building, and we didn't feel we were at a level -- I
22 didn't feel where we were at a level where we were going to
23 cover those instruments yet on the 28th.

24 Subsequent to that, we had small leakages which accumulate
25 over hours and months to the point where the building had

1 more and more water in it, and then the concern became a lot
2 more of a concern, because we now were controlling the thing
3 or reading those instruments, and we were looking at backup
4 ways of telling what those levels were.

5 On the 28th, though, we had not put enough water in where
6 I had that concern that day.

7 Mr. Meyers. Did you know where the equipment was, so
8 that at what level the water might be where it would start
9 to interrupt certain things?

10 Mr. Miller. Yes.

11 Mr. Cheney. One other question, if I might. When we
12 toured the facility -- I gather it was last Monday -- we were
13 told, I believe, as I recall, that one of the condensate pumps
14 tripped and that that started the whole sequence of events.

15 Mr. Miller. I don't know that we have determined that.
16 I don't think we have determined the source.

17 Mr. Cheney. What the initiating trip was?

18 Mr. Miller. That's right. I know the feed system stopped
19 pumping water. We know that the main feed pumps both tripped.

20 Mr. Weaver. What you're saying is something there may
21 have tripped before that?

22 Mr. Miller. Or a valve.

23 Mr. Zewe. Something resulted in that condensate pump
24 causing it to trip.

25 Mr. Cheney. What was suggested to us was the possibility

1 of some kind of a break in the power supply.

2 Mr. Zewe. That isn't true, to my knowledge.

3 Mr. Miller. Remember, from the plant design standpoint,
4 this equipment is in the non-nuclear portion of the plant.
5 It does not have the quality assurance because it is not
6 safety-related.

7 We know we lost the feed system, and the plant should
8 have been able to handle that from a reactor standpoint. I
9 don't think the company has gone back and decided what the
10 really initiating point was.

11 Mr. Cheney. So in your mind, we really don't know that?

12 Mr. Miller. That's right.

13 Mr. Zewe. They are still looking today at it. They are
14 still trying to gather information and postulate just why
15 that condensate pump tripped and what the motor failure was
16 that initiated it.

17 Mr. Weaver. As to Henry's last question about the possi-
18 bility of instrumentation being eroded by the various chemicals,
19 we read in the paper that days before you were supposed to get
20 into the final cold shutdown, that the last instrument failed.
21 That was the quote in the newspaper.

22 Mr. Miller. On the day of the incident, like I told you,
23 that was not a concern. In the following days, we had a
24 level in this pressurizer. We had a level in there and we
25 wanted to keep a level in there, because you could keep steam

1 on top and maintain pressure.

2 The level instrument that says how high the level is in
3 there, they failed one at a time, and we eventually had the
4 last one fail.

5 Mr. Weaver. Why did they fail?

6 Mr. Miller. They failed because of either radiation or
7 liquid level in the building. They are down in the basement.
8 But we had anticipated that could occur and we had made
9 evaluations of what we would do with the system. We had alter-
10 nate ways of looking at that level other than the direct
11 reading.

12 Mr. Weaver. But it does bring out what Henry said.
13 Instruments did fail because of it.

14 Mr. Miller. But we by that time had devised backup ways,
15 and also, we could have taken that vessel solid again and
16 still maintained the coolant.

17 So the concern was that, okay, we're going to have to --
18 it's going to be a little harder to operate.

19 Mr. Meyers. But if you had kept it solid, would you have
20 continued -- at that point, would you have continued to pump?

21 Mr. Miller. We might have. We might have shut it off
22 and used natural circulation. Natural circulation probably
23 would have been better because that is one more piece of
24 equipment. The pump could have failed, too, and then you
25 would have had to have used natural circulation.

1 Mr. Weaver. Gentlemen, I want to thank you very, very
2 much.

3 Mr. Cheney. It's been very, very helpful.

4 (Whereupon, at 3:55 p.m., the hearing was adjourned.)
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25