

Transcript of Proceedings

UNITED STATES OF AMERICA

PRESIDENT'S COMMISSION ON THE ACCIDENT AT
THREE MILE ISLAND

DEPOSITION OF: ROGER J. MATTSON

Bethesda, Maryland

August 6, 1979

Acme Reporting Company

Official Reporters

1411 K Street, N.W.
Washington, D. C. 20005
(202) 523-4888

8001280527

T



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 13, 1979

Rec'd 8/14 pm
RJM

TO: *Roger Mattson*
FROM: Richard S. Mallory, OGC

RSM

Enclosed is a copy of the transcript of your deposition before the President's Commission on the Accident at Three Mile Island.

Please read through the transcript carefully and correct any errors (other than unimportant punctuation errors) in black pen on this copy. Correct any errors you can identify in the questions, as well as in your answers. This copy will not be retyped, but will be reproduced as you have marked it, so your corrections should be dark and legible. If you cross out words in the transcript, draw only a single line through them, so that they can still be easily read when the transcript is copied; do not obliterate them.

After you have corrected the transcript, please sign and date the certificate at the end, and type your name under your signature.

You may wish to make a copy of the transcript for yourself before returning the original to me. When you return the transcript, please indicate if you object to making your transcript available to the Commission or to the Commission's investigation of Three Mile Island. Because of Commissioner interest, we would appreciate receiving your corrected copy by c.o.b. Tuesday, August 14, if possible.

no
object

The President's Commission on Three Mile Island will also be sending you a copy of your transcript with a request to make an "errata sheet" and sign a signature page. Please make up an "errata sheet" based on the copy of the transcript that you have retained and return the errata sheet and signature page to the President's Commission as requested in their letter.

If you have any questions or problems, do not hesitate to call me or the attorney who represented you at the deposition.

Enclosure: Transcript

CERTIFICATE

I certify that I have read this transcript and corrected any errors in the transcription that I have been able to identify, except for unimportant punctuation errors.

Date: 8/16/79

Roger J. Mattson

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
PRESIDENT'S COMMISSION ON THE ACCIDENT AT
THREE MILE ISLAND

DEPOSITION OF: ROGER J. MATTSON

Room 1102
New Phillips Building
7920 Norfolk Avenue
Bethesda, Maryland

August 6, 1979
9:30 o'clock a.m.

APPEARANCES:

On Behalf of the Commission:

KEVIN P. KANE, ESQ.
Associate Chief Counsel
DWIGHT H. REILLY
Technical Staff
2100 M Street, N.W.
Washington, D.C. 20037

On Behalf of NRC:

MARK CHOPKO, ESQ.
Office of General Counsel
1717 H Street, N.W.
Washington, D.C.

I N D E X

<u>WITNESS:</u>	<u>DIRECT</u>	<u>CROSS</u>	<u>REDIRECT</u>	<u>RECROSS</u>
-----------------	---------------	--------------	-----------------	----------------

Roger J. Mattson	3			
------------------	---	--	--	--

E X H I B I T S

<u>NUMBER:</u>	<u>FOR IDENTIFICATION</u>
----------------	---------------------------

Mattson No. 1	5
---------------	---

Mattson Nos. 2 & 3	245
--------------------	-----

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

P R O C E E D I N G S

1
2 Whereupon,

3 ROGER JOSEPH MATTSON

4 having been duly sworn, was called as a witness herein,
5 and testified as follows:

DIRECT EXAMINATION

6
7 BY MR. KANE:

8 Q Would you state your full name for the record,
9 please?

10 A Roger Joseph Mattson.

11 Q Have you ever had your deposition taken before,
12 Mr. Mattson?

13 A No.

14 MR. KANE: Let me briefly explain what we are
15 doing here today. You have been sworn, and although we
16 are sitting in the relative informality of your offices,
17 you should be aware that the testimony you are giving here
18 today has the same force and solemnity as if you were
19 testifying in a court of law.

20 My questions and your answers are being taken
21 down by the court reporter here. They will be later
22 reduced to a booklet form. You will be presented with a
23 copy of that booklet and given an opportunity to make any
24 corrections you deem necessary.

25 On the other hand, to the extent that you make

1 corrections in matters which we deem to be significant,
2 we may comment upon those changes and those comments
3 may be adverse to your credibility.

4 For that reason, it is important to avoid the
5 necessity for changes as much as possible by being as
6 accurate and as precise as we can be now.

7 In that connection then, I would ask if at any
8 point in this deposition if you don't understand the
9 question, if you feel something needs clarification or
10 elaboration, please feel free to stop to indicate that and
11 we will make the elaboration or clarification on the record
12 at that time.

13 Last, let me advise you of the two basic
14 groundrules in a deposition. First is that you respond
15 audibly to my questions since the reporter cannot take
16 down a nod of the head or a gesture and secondly, please
17 allow me to finish my questions before you respond even
18 if you know what the question is going to be because the
19 reporter cannot take us both down at the sametime.

20 Do you have any questions about that?

21 THE WITNESS: No. I understand.

22 BY MR. KANE:

23 Q Fine. Have you brought with you here today a
24 resume which briefly states your educational and employment
25 background, Mr. Mattson?

1 A Yes.

2 Q I have here a document entitled "Professional
3 Qualifications, Roger J. Mattson."

4 Is that that resume?

5 A Yes, it is.

6 Q Does this accurately reflect your educational
7 and employment background to date?

8 A Yes.

9 MR. KANE: Let's have this marked as Exhibit 1
10 to the deposition.

11 (Mattson Exhibit No 1 was
12 marked for identification.)

13 BY MR. KANE:

14 Q Mr. Mattson, you have been Director of the
15 Division of Systems Safety in the NRC since July of 1977.
16 Would you generally describe the duties of the Division of
17 Systems Safety and your duties as Director of that Division?

18 A The Division of Systems Safety performs most of
19 the engineering and technical review of construction permit
20 applications and operating license applications for
21 nuclear power plants.

22 It is organized into ten technical branches for
23 the conduct of that review. In addition, the Division is
24 responsible for a number of NRC's unresolved safety issues,
25 ~~for~~ ^{for} research coordination, for standards coordination and

1 for the analytical support of nuclear power plants/
2 ~~performance for~~ ^{safety reviews by} the Division of Operating Reactors, in
3 addition to the Division of Systems Safety.

4 Besides the analytical support for the Division
5 of Operating Reactors, we also provide other technical
6 support upon request by the Director of that Division.

7 There are other day-to-day responsibilities, but
8 those are the major areas as Director of the Division that
9 I am responsible for--managing the resources, maintaining
10 the planning and program coordination for those activities,
11 and as a technical decision maker in appeal of decisions
12 that are not reached below me, probably I need to fill in
13 some words there, by and large, the day-to-day technical
14 decisions are delegated within the Division to assistant
15 directors and branch chiefs who use the Standard Review
16 Plan and regulatory guides in the performance of their
17 review of CP and OL applications.

18 As new problems arise, decisions on the technical
19 solutions for those new problems are generally carried
20 all the way through to the office director level if they
21 do not require rule making and through to the Commission
22 if they do require rule making, so I am involved as a
23 technical decision maker in part of the line organization
24 chain.
25

1 On incidental things that arise in the
2 interpretation of the standing guidelines and documents,
3 oftentimes licensees will appeal staff positions as being
4 too stringent. Those appeals are brought up the line
5 and if not resolved at the assistant director level, then
6 I sit on the appeal and make a technical decision on the
7 matter.

8 Q In the event that the technical person within
9 the Division of Safety Systems comes across a potentially
10 generic safety problem dealing with reactor systems, would
11 that be passed up through the chain to you?

12 A Yes. As a matter of fact, before he can do
13 anything generic about its solution, it is required that
14 the top management of the office approve the method that
15 the staff intends to use to solve this new problem, so it
16 would come to me. I would transmit it to the Regulatory
17 Requirements Review Committee if the solution were known.

18 If the solution were not known, and it wasn't
19 ready for top management to approve, then it would be
20 identified as a generic issue for consideration by the
21 technical activities steering committee and identification
22 as such and assignment of resources and what have you.

23 Q Would it be fair to say that insofar as there
24 is one location within the NRC where there is a
25 concentration of technical expertise, it would be the

1 Division of Systems Safety?

2 A Yes. That is fair. We have no project managers
3 in the Division, so the people, the professionals here are
4 all technical specialists or systems specialists. They
5 have counterparts in the Division of Operating Reactors,
6 but they also have a project management function in the
7 Division of Operating Reactors, so the concentration of
8 technical resources is not as high.

9 Q Okay. Who has overall responsibility within
10 the Division of Systems Safety for systems integration or
11 systems engineering for a given project?

12 A Well, there is no single individual anywhere in
13 the Office of Nuclear Reactor Regulation who has
14 responsibility for overall integration of systems engineer-
15 ing. I take that in the technical sense, in the sense
16 that an architect/engineer like Bechtel would have an
17 overall systems engineer on a project usually a senior
18 systems specialist who performs that integrating function.

19 We perform that integration through the Standard
20 Review Plan or at least that has been the intent since the
21 Standard Review Plan was issued in 1975, and in addition,
22 there is an integration that occurs at a subsystem level,
23 that is, major portions of the nuclear power plant are
24 integrated in the Reactor Systems Branch, the Containment
25 Systems Branch, the Power Systems Branch, the Auxiliary

1 Systems Branch, and the Instrumentation and Control
2 Systems Branch, so if you take those titles you can see
3 the major building blocks of systems integration.

4 ^{I and C}
the ~~IN~~ Branch, for example, integrates
5 instrumentation and controls as a subsystem of the overall
6 nuclear power plant.

7 The Reactor Systems people integrate generally
8 the nuclear steam supply system, scope of supply, while
9 the Auxiliary Systems Branch and the Power Systems Branch
10 would be the integrators of the balance of plant.

11 Q But there is no single office within the NRC
12 that does system integration as such, in other words, would
13 occupy the regulatory equivalent of say Bechtel or someone
14 like that, is that correct?

15 A No. I think you misunderstand what I am saying.
16 Bechtel also organizes itself into these subelements, not
17 precisely the same ones that I have described for NRR,
18 but it is usual in an architect/engineering firm to have a
19 systems integration ~~by either~~ across the entire scope of
20 supply of that architect/engineer, ^{by} either a senior
21 individual or a small group.

22 That counterpart does not exist in NRR, as I
23 understand it; although I wasn't part of the decision-
24 making process, I have been part of explaining it before.
25 As I understand it, the decision to not do that was made

1 when the Standard Review Plan was issued. That is, the
2 Standard Review Plan provided that integration of the
3 various systems elements.

4 Now there has been an unresolved safety issue
5 identified for two or three years called systems
6 interaction that the ACRS identified. It has been under
7 study and work for the last couple of years. It ~~was~~ ^{has}
8 ~~represented~~ ^{representatives} from the Division of Systems Safety and
9 all of the systems branches that I advise, and that is
10 one of the things that is being considered in that
11 unresolved safety issue is how does the integration of
12 systems engineering effects occur ~~most~~ in the design
13 process ~~than~~ ^{and} in the review process, ~~but~~ ^{it} is possible
14 that out of that problem, the solution of that problem, would
15 come some changes in the way NRR is organized.

16 Q What is the unresolved safety issue in systems
17 interaction?

18 A The unresolved issue is to what extent are failure
19 modes and effects in one system considered for their
20 possible interaction, deleterious interaction, with other
21 systems?

22 For example, a classic I guess is could the
23 air conditioning system failure cause equipment in an
24 ancilliary system to fail, then causing a safety system to
25 fail in ways not considered in the design of the safety

1 system because the systems I just described as an
2 example were handled as discrete packages by three discrete
3 engineering organizations.

4 Q And that very scenario would lie outside the
5 normal mode of analysis used in SPR which is single
6 failure analysis?

7 A Yes, and clearly outside the scope of NRC's
8 review of nuclear power plants heretofore.

9 Q It has not been felt within the NRC that that
10 issue could be resolved by the use of the Bechtel-type of
11 analogy of a single person or a single group of persons
12 whose overall responsibility is system interaction?

13 A No. I don't think we have dismissed any
14 solution. Through the last couple of years, we have paid
15 higher and higher attention to these system interactions
16 effects. That is, what are the possible intereactions that
17 could have been overlooked in previous designs, ~~and~~ the way
18 we have chosen to do it, lacking proof of a better way, is
19 to expand the cognizance of the system branches, that I
20 described earlier, of the possible deleterious effects of
21 supporting systems on a system that they normally review
22 and effects of this sort have been found. The one I just
23 described is an example.

24 Q Sure. I take it from the example that you just
25 gave that, of course, the whole systems interaction

1 question extends much beyond interaction of safety-related
2 systems. It would relate to all of the systems in the
3 plant really.

4 A Yes, in ways that Three Mile Island shows.

5 Q I wanted to come to that because we did have a
6 discussion during the interview we had prior to this
7 deposition about the Standard Review Plan and how
8 interacted or did not interact with the design and approval
9 of Three Mile Island 2.

10 I specifically asked you at that time I think
11 about the containment isolation criteria and the fact that
12 it is my understanding you had containment isolation
13 actuation based upon a single factor PSI in the containment
14 building.

15 A High pressure.

16 Q And that the requirement under the Standard
17 Review Plan for diverse actuation of containment isolation
18 on any two out of three factors--I think we discussed
19 at that time how it came about that Three Mile Island 2
20 simply did not wind up having that requirement imposed but
21 I would like to get that now in the record if I could.

22 How did it come about that Three Mile Island 2
23 did not have diverse containment isolation actuation as
24 required under the Standard Review Plan?

25 A Three Mile Island 2 was not reviewed according

1 to the Standard Review Plan. It was not required to
2 demonstrate conformance with the Standard Review Plan.
3 That may or may not explain why it did not have diverse
4 containment isolation actuation.

5 There may in fact be plants like Three Mile
6 Island 2 who obtained their CP's or OL's prior to the
7 fall of 1975 when the Standard Review Plan was issued that
8 still have diverse containment isolation actuation.

9 There it would have been a matter of a particular
10 designer or a particular reviewer insisting that there
11 be diverse actuation. That is, there was a growing or
12 changing state of technology frozen by the Standard Review
13 Plan by 1975 where in some cases there was diverse
14 actuation, in others there wasn't. I can't state for
15 certain how it came to be that Three Mile Island was a plant
16 that did not have diverse containment isolation.

17 Q The deadline date that you mentioned in 1975
18 was September did you say?

19 A I can look it up, the Standard Review Plan I
20 think states when it was first issued--September, 1975.

21 Q Okay. If I understand what you just said, the
22 approach that was taken was that any project which received a
23 construction permit prior to September, 1975 was not
24 subject to the requirements of the Standard Review Plan?

25 A That's right.

1 Q Now Three Mile Island did not obtain its
2 operating license until February of 1978. Why was it felt
3 that a Standard Review Plan which was effective as of
4 September, 1975 should not apply to Three Mile Island 2
5 or other plants like it because their construction permit
6 was obtained before September, 1975.

7 A Well, I can give you my understanding of the
8 philosophy that was applied. I cannot give you a firsthand
9 explanation of the logic of the decision makers who made
10 that decision. I was not employed in this office at the
11 time that decision was made, and I only have available
12 hearsay from others and a review of the records that are
13 available from that time.

14 Q At that time I guess in 1975 you were Director
15 of the Division of Siting Health and Safeguards Standards,
16 Office of Standards Development?

17 A That's right. As I understand the philosophy,
18 it was that the Standard Review Plan was a codification of
19 existing review requirements with some few exceptions.
20 Those few exceptions ~~involving~~ ^{involved} what we call ratchets in
21 the licensing process that were acknowledged to have been
22 put in the Standard Review Plan that went beyond then
23 existing review practice, but were thought by the drafters
24 of the Standard Review Plan and the people then in
25 positions of responsibility in the Office of Nuclear

1 Reactor Regulation to be justifiable ratchets, so with
2 those few exceptions, the philosophy was ~~to~~ ^{that the SRP} was a
3 statement of current practice, and that as a statement of
4 current practice, the plants that had been reviewed at
5 about the time of its generation, that is, in the period
6 say of 1973, 1974, 1975 when the Standard Review Plan
7 was being drafted, would have had approximately the same
8 requirements applied to them case by case by the then
9 existing technical review staff.

10 Hence it was not necessary to conduct a
11 systematic reappraisal of those plants according to this
12 document.

13 Now what we came to find in the years after 1975
14 was that there were significant differences, that there had
15 been significant variability plant to plant, case by case,
16 in the licensing review prior to the issuance of the
17 Standard Review Plan.

18 That has an element of good news and bad news.
19 The good news is that the Standard Review Plan had done
20 what it was supposed to do. It had achieved some
21 uniformity and consistency in the licensing requirements,
22 and the bad news, of course, was that there were plants
23 that had system designs that weren't as good as some other
24 plants.

25 Now shortly after the Standard Review Plan was

1 issued in 1975, there are three memos of interest in its
2 implementation. I previously supplied these to the
3 Commission staff at your request after my interview. I
4 don't remember ~~their~~ ^{the dates of the} office letters from NRR and I don't
5 recall the specific numbers, but ~~they are~~ ^{there is} a supplementary
6 memorandum to one of those office letters.

7 Generally they say that plants, they start out
8 by first saying that all plants will be reviewed
9 according to the Standard Review Plan, whether they are
10 OL's or CP's, and then they subsequently say that a
11 class of facilities will be grandfathered from the Standard
12 Review Plan, that is, grandfathered from a requirement
13 for the license applicant to demonstrate conformance with
14 the Standard Review Plan.

15 Instead, the license review staff, the technical
16 staff of the NRC, is required to identify any deviations
17 in a license application relative to the Standard Review
18 Plan, obtain from the licensee justification for those
19 deviations, and then document the rationale for allowing
20 or not allowing the deviations in the safety evaluation
21 report.

22 Now there were two sets ~~of~~ ^{of} stages of grand-
23 fathering. One stage required no documentation of
24 deviations. The second stage required staff identification
25 and rationalization of the deviations, and then finally

1 there really is a third stage which is a non-grandfathered
2 plant, those plants in which the applicant must identify
3 any deviations relative to the Standard Review Plan.

4 Three Mile Island 2 falls in the class of
5 plants which had no identification of deviations relative
6 to the Standard Review Plan.

7 Q What was the rationale behind committing certain
8 projects to the, if you will, entirely grandfathered
9 under the SRP without even providing any documentation for
10 deviations?

11 A Well, the rationale must have been their
12 advanced state of construction and licensing review.

13 Q Why wouldn't it be deemed--let me ask this. Were
14 the provisions of the SRP, the Standard Review Plan,
15 based upon a consensus within the NRC as to what the
16 desirable safety features of a nuclear power plant should
17 be?

18 A I am not sure what the word consensus means to
19 you. Let me explain how they were written. To me, I
20 think consensus is right, but it may mean something
21 different to you.

22 The review plans were integrated in a draft form
23 by each of the review branches to describe what they
24 customarily did to a construction permit and an operating
25 license application--what they reviewed, what criteria they

1 applied to it, and what findings they reached, and then
2 a listing of resources or references of an historical
3 nature that were associated with that review.

4 They were then subject to management review
5 within what was then the Directorate of Technical Review
6 in the Office of Regulation. The director of that
7 directorate at that time was the present Chairman of the
8 NRC, Joe Hendrie.

9 After the line management review of the input
10 written by the individual branches, and it wasn't a one-way
11 street, there was a lot of iteration back and forth
12 over a period of more than a year; then Dr. Hendrie left
13 NRC and returned to Brookhaven National Laboratory under
14 contract ^{by} ~~to~~ Brookhaven, to the then AEC, he completed the
15 final editing and systematic review of the Standard
16 Review Plan from Brookhaven, submitted it to the
17 regulatory staff of the AEC in 1975, so by then it had
18 become the NRC, for promulgation.

19 It was approved and promulgated by the Director
20 of NRR who would have been Ben Rusche, in September, 1975.

21 Now that process says that the technical experts
22 in each of the disciplines had input to and iterated upon
23 the contents of the Standard Review Plan.

24 Q Is it fair to say then, Mr. Mattson, that the
25 Standard Review Plan reflects the official position of the

1 NRC as to those safety features which should be included
2 in the design of a nuclear power plant?

3 A Yes, if you understand that the staff has for
4 sometime operated under a philosophy that you may want more
5 for a new plant than what you think is required for an
6 old plant.

7 Q Yes.

8 A That is, the Commission's generally worded
9 regulations allow some flexibility in interpretation,
10 and the staff has used that flexibility down through the
11 years to require more of new plants than it has been willing
12 to accept as providing a minimal meeting of the Commission's
13 regulations for old plants.

14 Q That is the philosophy I wanted to try to
15 focus on, Mr. Mattson. It seems to me what you are saying
16 is that over the years, the operating experience with
17 plants and the development of technology has brought to the
18 attention of the NRC certain aspects of plant design which
19 are safer than other aspects which can be made more
20 acceptable from the point of view of safety, and that
21 eventually those have found their way into the Standard
22 Review Plan and reflect the current thinking on that
23 matter, but that for older plants, the determination was
24 made that for one reason or another, they would not be
25 called upon to comply with at least some of those safety

1 provisions.

2 You were asked about this when you testified in
3 front of the Presidential Commission on June 1st, 1979.
4 Specifically you were asked about backfitting the Standard
5 Review Plan to older plants, which is I take it what we
6 are talking about.

7 You said at that time that the decision to not
8 backfit the Standard Review Plan was a conscience decision
9 on the part of the Nuclear Regulatory Commission that was
10 made sometime in 1975.

11 What did you mean by a conscience decision?

12 A What I had in mind when I was testifying were
13 the letters of Mr. Rusche that I have previously supplied
14 to the Commission. There was office letters that I was
15 describing here a few minutes ago which ~~consciously~~
16 chronicled the conscious decisions ~~to~~ to first apply it,
17 and ~~the~~ ^{then} not to apply it during 1975 and 1976.

18 Q What kind of factors entered into determining
19 whether or not the Standard Review Plan should be applied
20 to a plant like TMI 2, for example?

21 A I think I have just described them. I will
22 summarize them succinctly. One, the philosophy that it was
23 a codification of existing review practice. If you
24 accept that judgment, then it is not necessary to backfit it.

25 Q Before you go on, I am not sure I understand the

1 point you made there. It is a codification of existing
2 review practice. I understand that. The existing review
3 practice presumably is based upon safety considerations,
4 is that right?

5 A That's right.

6 Q And the NRC is not reviewing the plant for any
7 other reason?

8 A That's right.

9 Q It is based on safety considerations. Now the
10 determination is made that that is a current practice and
11 that I take it by the way you say that you are inferring
12 that, therefore, there is no reason to apply it in a
13 backfitting sort of way to older plants, and my question
14 is why not?

15 A I think we are having some difficulty in
16 communicating. I was speaking to the backfit of plants
17 under construction, and I think you are speaking to the
18 backfit of plants already in operation. Let's try to
19 break it into two phases and see if we can understand it
20 better.

21 I don't know of a basis for not systematically
22 backfitting the Standard Review Plan to plants in operation
23 other than it would be expensive and a judgment that a
24 good job had been done on safety on those old plants.

25 Everyone knows that those plants were reviewed

1 by a handful of people compared to the kind of review that
2 is done today. They were reviewed without the operating
3 experience that is available today, and there was no
4 systematic assessment of whether the Standard Review Plan
5 ought to be backfit to them, not in 1975.

6 There has been since then in the genesis of the
7 systematic evaluation program which does go back and start
8 with the 11 oldest plants to bring them up to some
9 assessment according to current review practices.

10 Now the plants under construction at the time
11 the Standard Review Plan was issued in 1975 had been
12 reviewed for their CP's in the few years before 1975--1973,
13 1974, 1975. Since the Standard Review Plan was thought
14 to be a codification of the practice that was going on in
15 those years, then it was judged upon second thought to
16 not be necessary to apply ^{it} uniformly and rigorously in the
17 OL reviews for those plants.

18 I emphasize the word second thought. First
19 thought according to those early office letters in 1975
20 appears to have been that the Standard Review Plan would
21 be used in the OL review for plants then under construction,
22 but then a subsequent letter said no, we will not do it
23 that way. We will not apply the Standard Review Plan
24 to a whole set of plants, to another set of plants. The
25 burden for ^{justifying} the deviations will be on the staff, and then

1 finally down the road a few years, the burden will be on
2 license applicants. Make sure you understand that that
3 burden shifted to license applicants for OL's for the first
4 time in this calendar year, 1979. The first OL's were just
5 filed for whom the burden is on the applicant to justify
6 the deviations.

7 Q Why place the burden as an initial matter on
8 the staff?

9 A Well, I think I understand why it was done. I
10 won't defend it, but I think I understand why it was done.
11 First, the Director of NRR said the burden is on the
12 licensees and then the industry reacted and said wait a
13 minute. We don't know the basis for some of your
14 requirements in the Standard Review Plant. They are not
15 written there, and we don't know why you have required
16 certain things. How can we in industry justify a deviation
17 if we don't know what it is you are trying to achieve by
18 the requirement?

19 Therefore, the burden, the industry said, ought
20 to be on the license reviewers to justify the deviations,
21 at least for those plants that were not reviewed according
22 to the Standard Review Plan at the construction permit
23 stage.

24 Let me finish. The Director of NRR agreed with
25 that logic and exempted the industry from making that

1 justification of deviations in two stages, placing
2 finally the burden upon the licensees for those plants
3 that are making OL applications here in 1979, that is,
4 those plants that were getting CP's at approximately the
5 same date as first issuance of the Standard Review Plant.

6 Q Wasn't the NRC at the time that issue came up in
7 the position to explain, to demonstrate the reason why
8 certain things were being included in the SRP on the basis
9 of increased safety?

10 For example, we have been talking about
11 containment isolation actuation. The TMI 2 scenario has
12 certainly demonstrated I think that containment isolation
13 for 4 PSI in the containment building only is an unsafe
14 way to approach containment isolation, and I take it that
15 is why diverse containment isolation actuation is required
16 under the Standard Review Plant.

17 A No. Let me interrupt you. It is not unsafe.
18 That is too simple. It is not as reliable. It doesn't
19 cover as many eventualities, as many "what if's," and like
20 many things that we do, judgments have to be reached as to
21 whether even though it is not perfect, it may be good
22 enough.

23 Now as I testified on the first of June, I doubt
24 that anyone in 1975 specifically concentrated his attention
25 on diverse containment isolation. I have to agree with you.

1 It looks like something that should have been there. I
2 was surprised it wasn't there in some of the older designs,
3 and it ought to be there. It is a rather minor thing to
4 provide, and it should be there.

5 I have to believe that if people had concentrated
6 on that specific one in '75 they probably would have
7 ~~backfitted~~ ^{backfit it,} ^{not} but that is how the decision was reached. It
8 was reached on the whole thing, so the argument on is there
9 a justification ^{or} ~~for~~ what is the basis for some of these
10 requirements that the regulators had was a general argument,
11 and it is fair to say generally the Standard Review Plan
12 does not say why the requirements are there. It says what
13 the requirements are. It says how you review to ascertain
14 that they have been met, and it states the findings, and
15 then it gives some reference documents that if you research
16 them, all you would get is a feel for the reason that the
17 requirement was there.

18 This is not unusual. The Commission's regulations
19 have no statement of basis. ^{there is no statement of} That is what they were trying
20 to do, to solve in the regulations, until very recent years
21 similar to the regulatory guides issued by the AEC, and
22 the NRC has no statement of basis until recent years.

23 Q Do you know if any other plants of the vintage
24 as TMI 2 as they came through the review process were
25 required to have diverse containment isolation actuation?

1 A I know the answer to the inverse question. There
2 are others that do not have it. I do not know the answer
3 to the question of were there some that had it. My best
4 guess would be since it was codification of existing
5 practice, and I don't believe this specific one was thought
6 of as a ratchet, that there probably are some plants of
7 the same vintage as TMI 2 or even earlier that do have
8 diverse containment isolation.

9 Q It was a situation where some plants were coming
10 through with that feature, some where not, and the NRC
11 was taking the position pursuant to the provisions you
12 just talked about before that in any event, for the plants
13 of that vintage, that type of diverse actuation would not
14 be required?

15 A That's right.

16 Q Okay. If I understood what you said, that was
17 based primarily upon an assessment of the cost of the
18 backfitting versus the increments and safety to be achieved
19 by forcing the utilities to incur that cost and the judg-
20 ment apparently was made that the provisions of the SRP
21 across the board en masse for some types of plants was
22 simply not worth the trouble and the cost?

23 A I don't agree with the use of the word cost. I
24 don't believe a cost assessment was done. I think burden
25 is the proper word, assessment of the burden associated

1 with a review and documentation according to the Standard
2 Review Plan as opposed to review and documentation against
3 earlier documentation requirements.

4 Q What is the one chief objection that the utilities
5 have to assuming that kind of burden?

6 A I am not quarreling with ^{the fact that} the costs were there.
7 I am quarreling with your use of the word costs. Surely
8 costs are the bottom line, but no cost analysis was done
9 by NRC to my knowledge--some general understanding that it
10 was a burden, some requirement certainly existed.

11 Q To that extent, there was a recognition of cost?

12 A Yes.

13 Q I am not talking about a formal cost benefit
14 analysis.

15 A Okay. That was how I understood you to be using
16 the word. Those cost benefit analyses are done today for
17 backfitting decisions. They weren't done then.

18 Q I was about to say it actually bothers me more
19 that no cost benefit analysis was done under these
20 circumstances.

21 If I understand your testimony, it was that the
22 determination was made across the board?

23 A That is right, to the best of my understanding.

24 Q All right. Coming back to this question of
25 systems interaction, it is also a subject of some interest

1 as to the question of interaction of operating capability
2 and training, or training vis-a-vis equipment design.

3 Is there any office within the NRC that looks
4 at the man-machine interface, if you will?

5 A No.

6 Q That is not done in the Division of Systems
7 Safety?

8 A No.

9 Q Do you view that as a significant lack within the
10 NRC at the present time?

11 A Definitely.

12 Q Has that been addressed at all in the lessons
13 learned task force work?

14 A To a minor extent by our short term recommendations;
15 it is the task force's conviction that this is a major
16 gap in previous regulatory practice and has to be corrected.

17 We are working on some alternative approaches
18 to address the problem We have not made long-term
19 recommendations in that area yet.

20 Q You are the team leader on the lessons learned
21 task force, is that right?

22 A Director.

23 Q I did want to ask you about that. I have looked
24 over the lessons learned interim report and out of
25 approximately 95 pages in that publication, there is about

1 three and a half pages on operating, training and management,
2 and I was curious as to whether or not that was an area in
3 which the lessons learned task force intends to place a
4 good deal of emphasis or is that considered a secondary
5 matter?

6 A I think you have given it improper focus. We
7 broke down our work into two principal areas, design and
8 analysis and operations and clearly the operations area
9 after Three Mile Island is an area that is the biggest gap
10 in what we did previously. It may take more words to
11 describe what needs to be done in design and analysis
12 simply because it is of a more detailed engineering nature.

13 That is the recommendations that we are making
14 at this stage; three and a half pages out of 95 is not
15 fair. That is not a fair assessment of the emphasis that
16 we believe should be placed on the operations aspect of,
17 not only the design, but also the regulatory oversight of
18 nuclear power plants.

19 Q You do anticipate that in the further work of
20 the lessons learned task force greater emphasis will be
21 placed in that area in terms of further publications or
22 further changes within the NRC?

23 A Yes.

24 Q Both within the organization and content of the
25 review and the formulation of requirements, all right.

1 Dr. Mattson, there has been a great deal of
2 discussion in connection with this investigation by the
3 Presidential Commission of a series of documents that have
4 been referred to as the Michelson reports. There are two
5 handwritten versions of it and one typed version.

6 Are you familiar with those documents?

7 A I have read the typed version. I have scanned
8 the handwritten versions. Yes, to that extent, I am
9 familiar with them.

10 Q Okay. When did you first become aware of the
11 existence of those documents?

12 A Sometime between the 1st of April, 1979 and the
13 14th of April, 1979, when I was told in a telephone
14 conversation from Three Mile Island that such documents
15 existed.

16 Q All right. There has been a report issued by
17 the Office of Inspector and Auditor within the NRC
18 relating to the Michelson report and the events and levels
19 of review concerning that documentation.

20 Have you read this report?

21 A I have not seen it. I wasn't aware it had been
22 issued.

23 Q I have here a copy which I will be happy to make
24 available to you. It is an extra copy. The report purports
25 to quote the contents of interviews conducted with a number

1 of individuals from the NRC, one of them being you,
2 apparently an interview conducted on June 22, 1979. The
3 summary of that interview appears on pages 12 and 13 of
4 the report.

5 I wanted to ask you about that. If you would
6 turn to page 12 under information obtained from Roger J.
7 Mattson, in the second paragraph, the second to the last
8 sentence in that paragraph, it says that generally
9 describing your beliefs about what impact the Michelson
10 report might have had upon the thinking within the NRC.
11 It stated that, you stress that the intensity of any review
12 would be colored by the manner in which the draft was
13 received, referring to the draft Michelson report in
14 September of 1977. And it states that, keeping with this
15 qualifier, you said the copy of the draft which was
16 informally furnished to Israel, that is Sandy Israel of
17 the NRR, was handwritten, undated, untitled, had
18 no table of contents, and no indicated author, as is
19 indicated in this report. And I was previously under the
20 impression, it seems that the report that was submitted
21 to Sandy Israel in fact did have a title page, a table of
22 contents, a date, and the initials at least of the author,
23 and I was wondering if you had seen some different version.

24 A Yes. I have the version that was supplied to me
25 by Mr. Israel.

1 Q I see. Okay.

2 A I have a copy of it. I think we are probably
3 into an area of document authentication difficulties
4 because there are several versions of this floating around.

5 Q Right. I am aware of three--the handwritten one
6 in May of '77, the handwritten one in September of '77,
7 and the typewritten one or the typed one in January of '78,
8 but I guess you have got somewhat the third version or
9 the fourth version.

10 A That is not the right one. I am going to refer
11 to the letter that you have seen because we have discussed
12 it before, which is my letter to Dr. Myers of the Committee
13 on Interior ^{and} Insular Affairs of the House of Representatives,
14 the letter of May 24th, 1979, and my recollection as to
15 what I was given in assembling this letter--I may just
16 disprove my own previous words. Let me sort it out here.

17 Enclosure 2 of that letter is what we are calling
18 here the typewritten version of the Michelson report.

19 Q That is the one dated January, '78.

20 A Enclosure 3 of that letter is a draft of that
21 report which was provided to the staff in April of 1979,
22 and that has the initials CM, evidently Carl Michelson, up
23 in the upper righthand corner, a date, a title, and a
24 table of contents.

25 Enclosure 4 is the draft for the Combustion

1 Engineering Design, also initialed CPM and dated 5/15/77
2 in the upper righthand corner.

3 Enclosure 5 is a set of figures that went with
4 that.

5 Enclosure 6 is the copy of the report, the draft
6 Michelson report for B&W, and Combustion, and the figures
7 provided to me by Sandy Israel, and he said this is the
8 information supplied to him by Jesse Ebersole, and it is
9 that document which has no cover, no initials, no author,
10 no date, and in fact you will see that the first page
11 starts at page 3 and goes through. That is the B&W report.
12 If we look at where the Combustion Engineering report
13 starts, it has got a little title up at the top. It
14 has got no title page, no author, no date, and it also
15 starts at page 3, so that is what I meant when I talked to
16 the inspector.

17 Q Okay. There appears to have been some differences
18 between the September, 1977 report which Mr. Michelson
19 had and the version of that that was transmitted to Sandy
20 Israel.

21 A At least the first two pages seem to be gone, yes.

22 Q Looking back again at the Inspector and Auditor's
23 report, on page 13 at the very top it is stated that,
24 "Mattson said that it was his firm belief that formal
25 evaluation of the Michelson report would not have prevented

1 TMI. He feels that of greater relevance to TMI than
2 formal review of the Michelson report is the fact that
3 applicants can develop and implement emergency operations
4 for conformance with accident analysis reports in the
5 absence of either regulatory review or vender review."

6 Does that accurately summarize a portion of your
7 interview with the Inspector and Auditor? More importantly,
8 does that accurately reflect your thoughts on the matter?

9 A Well, it is a very succinct summary of my
10 thoughts, but I will not change them. I believe those
11 things.

12 Q What did you mean by the second sentence there,
13 the fact that the applicants can develop and implement
14 emergency operations for conformance with accident analysis
15 reports in the absence of either regulatory review or
16 vender review is of greater relevance to TMI?

17 A Would it help your understanding if after the
18 word operations you inserted the word procedures?

19 Q Emergency operations procedures? I still am
20 not sure I understand what you meant in that sentence.

21 A What I mean is that prior to TMI there had been
22 no let me call it technical review of utilities' emergency
23 procedures by the licensing organization of NRC. There
24 had been some review by the Inspection and Enforcement people
25 of several types--one, more technical in nature conducted

1 during plant startup, and another less technical in nature,
2 more of an audit nature during the operations of these
3 plants, but as a general matter, no thorough going,
4 technical review in the licensing process of emergency
5 procedures.

6 Q What was it about the emergency procedures which
7 you feel was of greater relevance to TMI?

8 A For example, since the accident at Three Mile
9 Island, we have found that there are or there were in none
10 of the emergency procedures for any of the operating
11 B&W reactors descriptions of the intermittent natural
12 circulation cooling that would follow a very small break
13 loss of coolant accident.

14 . That information has been developed in the form
15 of emergency or operations guidelines and transposed into
16 operating procedures at all of the B&W reactors now as a
17 condition for their restart. That information did not
18 exist in their procedures before, yet the analytical
19 capability to provide information of that sort certainly
20 existed at B&W prior to Three Mile Island, and potentially
21 had there been regulatory oversight of that aspect of
22 operations prior to Three Mile Island, the staff would
23 have assured that it had been provided to the operations
24 ~~criteria~~ ^{organizations} in the form of training or procedures.

25 Q Is that consideration, would that aspect of

1 operating procedures be related to what appears to have come
2 out of TMI in the form of an over-reliance by operators
3 upon pressurizer level indicator to assess the state of the
4 inventory in the core?

5 A Not that particular one, no.

6 Q But you are talking about the mode of circulation
7 within the reactor coolant system, primary system during
8 a small break LOCA, aren't you?

9 A Yes.

10 Q A small break LOCA can be such a thing as a
11 PORV sticking open?

12 A Yes.

13 Q And under those circumstances as we have seen
14 at TMI, you can have a situation where the pressurizer
15 level hangs up, increases perhaps even off scale high?

16 A That is true.

17 Q In the context of an operator belief that the
18 pressurizer level indication is an accurate indication of
19 the state of inventory in the core, that would then lead
20 to a misunderstanding as to the current status of
21 circulation within the core?

22 A I agree. They are indirectly related. It is
23 possible that you could start from a review of the analysis
24 of small break loss of coolant accident in the top of the
25 pressurizer and come to that conclusion.

1 Q Okay. As a matter of fact, Chairman Hendrie
2 testified before the Senate committee that has been
3 investigating this matter on April 10th, 1979, and he was
4 asked to, I believe he gave a prepared statement as to
5 the six main factors that caused and increased the severity
6 of the accident.

7 There were two factors that I was interested in.
8 One was the pressurizer electromatic relief valve which
9 opened during the initial pressure surge failed to close
10 when the pressure decreased below the actuation level.
11 This failure was not recognized and the relief line closed
12 for sometime.

13 That certainly was one crucial factor in the
14 TMI 2, wasn't it?

15 A That is the small break, yes.

16 Q Then another one was following rapid
17 depressurization of pressurizer, the pressurizer level
18 indication may have led to erroneous inferences of high
19 level in the reactor coolant system. The pressurizer
20 level indication apparently led the operator to prematurely
21 terminate high pressure injection flow even though
22 substantial voids existed in the reactor coolant system.

23 That also was a major factor in the TMI 2
24 scenario, wouldn't you say?

25 A That is true.

1 Q Okay. This relates again to the erroneous
2 inferences on the basis of high level in pressurizer level
3 indication?

4 A Yes.

5 Q Coming back then to the inspector auditor's report,
6 you do make the statement here that it was your firm belief
7 that formal evaluation of the Michelson report would not
8 have prevented TMI.

9 Why don't you think that that would have
10 prevented TMI?

11 A That is why I said it was a little succinct. I
12 did give him more words. We discussed this at some length.

13 The reason is that formal review of the
14 Michelson report since TMI has led to the conclusion that,
15 A, Michelson was right, and B, the detailed computer codes,
16 the one that B&W uses called CRAFT, were accounting for
17 the features or the phenomena described by Michelson in
18 his report, and that the analysis by those codes of the
19 performance of the emergency core cooling system have
20 accounted for those effects and shown that the ECCS was
21 acceptable, ^{Those analyses} would probably have led to a dismissing of the
22 report by Michelson.

23 If the same mind set that has evidently been here
24 down through the years of not coupling those detailed
25 theoretical analysis with the very practical operating

1 procedures and training had continued to exist when that
2 document was reviewed, I think it may very well have
3 continued to exist.

4 It took the accident at Three Mile Island to
5 break that mind set. I don't think the single report from
6 Michelson had it been formally reviewed, had it been
7 submitted formally by the ACRS, been charged to people,
8 had it been scheduled and resources assigned to it, all
9 those things that happened ~~for~~ for a formal review, I think it
10 would have been the same kind of answer we see with a lot
11 of ECCS-related questions, that is, yes, the codes account
12 for that. Yes, it is okay, the ECCS accommodates that,
13 and the concern is then dismissed because the focus of the
14 report, although it is in there and in hindsight you can
15 see it, the focus of the report was not on what the
16 operator knows and is it proper. I don't believe so.

17 A These calculations you are talking about by B&W,
18 are those the Appendix K bounding calculations?

19 A Yes.

20 Q Isn't one of the basic tenants of the Michelson
21 report that bounding calculations for small break LOCA's
22 are not sufficient to adequately assess the consequences
23 of very small break LOCA's such as the ones addressed in
24 the Michelson report?

25 A That is true. Maybe my previous answer was too

1 quick to your question. The analyses that have been done
2 subsequently have taken out the traditional conservatism
3 and tried to use the code in a realistic manner, to address
4 the realistic nature of the concerns raised by Michelson,
5 and it is those analyses that show that he is right, but
6 the ECCS has plenty of margin to account for those realistic
7 phenomena. That probably would have happened ~~before~~^{prior} to
8 Three Mile Island.

9 We make realistic analyses and conservative
10 analyses with these codes pretty much as a matter of
11 routine. They are run against experiments and what have
12 you in realistic versions, and then they are run with
13 another deck of cards in conservative versions for licensing
14 calculations.

15 Q So is your point that even if the Michelson report
16 had received formal review within the NRC and even if the
17 recognition had been made, that pursuant to Mr. Michelson's
18 concern, the bounding calculations for small break LOCA's
19 were not applicable to adequately assess the consequences
20 of very small break LOCA's and even if the further
21 calculations had been done then as suggested by Mr.
22 Michelson, that the conclusion would still have been that
23 the ECCS had the capability to deal with the situation?

24 A Absolutely. Whether they were conservative or
25 realistic or anything inbetween, the conclusion would have

1 been then as it is today, the ECCS design is fully capable
2 ^{accomodating}
of that break.

3 Q I think I understand that point.

4 A The accident taught us that the procedures for
5 telling the operator how to deal with that break were
6 inadequate.

7 Q Okay. Let's come to that. Is it your testimony
8 also then that a formal evaluation of the Michelson report
9 would not have indicated to anyone in the NRC with enough
10 responsibility to deal with the situation that there was
11 a strong possibility of operator error based upon a
12 misleading pressurizer level indication?

13 A I think that is a close call and I wouldn't argue
14 with the judgment either way.

15 Q Okay.

16 A It has been my judgment that recognizing the
17 mind set before Three Mile, probably it wouldn't have been
18 realized. However, there is strong evidence that it might
19 have been, and that is the Israel memorandum of January,
20 '78 where out of very general reasoning Mr. Israel came to
21 the same conclusion.

22 Now had it been subjected to formal review, that
23 is, the Michelson report simultaneously with Israel's
24 general conclusions that led to the Novak memorandum, then
25 it is possible that the judgment would have been reached

1 that more needed to be done in the procedures and training
2 area. I won't quarrel with whichever way the judgment is
3 made. My own judgment is I doubt it.

4 Q I was beginning with the thought that it was
5 your firm belief that formal evaluation of the Michelson
6 report would not have prevented TMI. However, I can
7 understand why that is a subjective matter.

8 However, let me direct your attention to the 28th
9 page, and these pages are not numbered. It would be
10 better if you counted from the back, 7 pages from the end
11 of the typed Michelson report of January, 1978, it has a
12 paragraph that begins toward the top of the page with this:
13 "A full pressurizer may convince the operator to trip the
14 HPI pump and watch for a subsequent loss of level." I
15 think you may need to go back another page. I'm sorry.
16 It is several more pages back. I must have fewer pages in
17 mine than you do. It is right above Section 4.6.

18 Right. You have that sentence there. Then if
19 you look down under Section 4.6 under pressurizer level
20 indication, it says, "The modes of decay heat removal
21 discussed in Section 3.0 point out that pressurizer level
22 is not a correct indicator of water level over the reactor
23 core," and then it follows down a few lines, "Further,
24 therefore, pressurizer level is not considered a reliable
25 guide as to core cooling conditions. No other primary side

1 level indication is provided," and then if you flip over
2 to the next page, skipping down one sentence, it says,
3 "A full pressurizer may convince the operator to trip the
4 HPI pump and watch for a subsequent loss of level; although
5 this response appears desirable, a full pressurizer may
6 not always be a good indicator of high water level in the
7 reactor coolant system."

8 Mr. Mattson, is there any possibility in your
9 mind that someone with a technical background in the NRC
10 reading that language would not have concluded that
11 Mr. Michelson was expressing a concern about possible
12 operator error based upon pressurizer level?

13 A I don't quarrel with the statement you have just
14 made at all. What I quarrel with was how would the staff
15 have reviewed and concluded if this thing had been
16 submitted and reviewed formally, and it may very well have
17 been that the staff would have said that the ECCS if allowed
18 to do what it is designed to do, even accounting for
19 single failure, would make this problem go away because there
20 is no operator role.

21 Q But there clearly is an operator role.

22 A There clearly is. There clearly was. It was
23 clearly a role that was carried out incorrectly in the
24 course of the accident, and training would have helped that.
25 No question about that.

1 The question you are asking me to judge is would
2 we have caught it had we formally reviewed it, and the
3 answer I said, I don't really care whether your answer is
4 yes or no. I know a little bit more about what our mind
5 set was than you do, and I don't want to quarrel with you
6 or anybody who wants to reach the judgment that we would
7 have caught it.

8 My considered opinion is we may not have caught
9 it.

10 Q And it was because of a mind set, as you say?

11 A Yes.

12 Q I have spent quite a bit of time over the last
13 two weeks deposing people in the NRC, and I understand the
14 pre-TMI and post-TMI thinking.

15 On the other hand, I am impressed with the fact
16 that you have got some very sophisticated, intelligent
17 people in the Division of Systems Safety, and I read that
18 language, and it only seems to say one thing--possible
19 operator error based on pressurizer level, and I take it
20 you are not really disputing that. It is just you are
21 disputing what significance those words would have carried
22 for someone in the Division of Systems Safety reading that
23 language in 1978?

24 A Yes.

25 Q Okay.

1 *This is*
2 A A division that historically has not reviewed
3 operator actions and operator training and ~~operator~~ ^{operating}
4 procedures, only assured that systems design^s be automatic
5 to accomplish their safety functions early after an
6 accident; others in the agency may have caught it, but
7 I don't think the Division of Systems Safety with its
8 pre-TMI 2 orientation, mind set, would have.

9 Q In terms of operator action, what was that mind
10 set, that the operator would always do what the design
11 called for to bring the reactor under proper control? Is
12 that a fair way of characterizing that mind set as to
13 operator action?

14 A No. I think a mind set that the operator was
15 a force for good, that if you discounted him, it was a
16 measure of conservatism. If you tried to account for all
17 of the things that he could do, you might have to give
18 away some things in the design because he was a synthesizer
19 and an integrator that went beyond the design, and the
20 oversight that ~~raises~~ ^{implies}, of course, is the capability of the
21 operator to intervene in the operation of safety systems.

22 Now that is why this is a strong argument that
23 this would have been caught in a formal review and a staff
24 would have said wait a minute, that is a difficulty with
25 an operator we never understood before. He will be told
 to intervene with that safety system. We ought to do

1 something about that.

2 It may have been that these very clear words in
3 the final version of the Michelson report would have caused
4 that threshold, that trigger level to have been reached
5 in the ~~mind set~~^{minds} of DSS reviewers.

6 Q It is possible?

7 A Possible.

8 Q Let me take you through--of course, I suppose
9 one point to be made and we should make it, it is my
10 understanding that the report I have just read from the
11 January, 1978 typed Michelson report did not as far as we
12 know find its way into the hands of anyone within the NRC
13 prior to March 28, 1979.

14 Is that your understanding, the typed Michelson
15 report?

16 A I don't know about the date you have given me.
17 I don't remember that specific date. I can tell you what
18 my knowledge is.

19 Q What I had understood was that--

20 A I first saw a copy of that on April 17th, 1979, by
21 memo from Eisenhut who says that report was given to us,
22 whoever that is, for review and comment earlier this month.

23 Q Right. You certainly didn't see the typed
24 Michelson report prior to March 28, 1979?

25 A I never saw it prior to April 17th, 1979.

1 Q Do you have any knowledge that anyone else within
2 the NRC saw the typed Michelson report prior to March 28,
3 1979?

4 A No.

5 Q You do know, and it seems pretty clearly
6 established now, that the handwritten one, handwritten
7 version of the Michelson report, was passed by Jesse
8 Ebersole to Sandy Israel within the Division of Systems
9 Safety, is that right?

10 A That is what Mr. Israel has told me.

11 Q Okay. Let's come to that version which is the
12 version that is dated in September, 1977.

13 A I don't believe that I have that knowledge. The
14 one that I believe was handed to him is undated.

15 Q Okay. It appears to be the same from what I
16 can see there except for the absence of the first two pages.
17 It has also some handwriting on top that says the title
18 B&W, but the first paragraph is entitled, "Introduction"
19 and it begins with page 3.

20 Let's see if it does have some of the same
21 language. Let's flip to page 9 and I am looking at the
22 first full paragraph on that page which says, "Operation
23 in Mode 4," which is one of the various codes that Mr.
24 Michelson talks about in that report, "...appears reasonable
25 to achieve, although the reactor operator will be unaware

1 of what is happening to the reactor vessel level. Note
2 the presence of a pressurizer level is not an indication
3 that adequate core coverage is being achieved."

4 Let's flip to page 16 where this paragraph
5 appears. "Adding to these concerns is the uncertainty
6 associated with unknown vessel level, the adequacy of
7 emergency operating instructions, and operator training
8 for this event, and the consequences of the unstable slug
9 flow conditions which are predicted to develop in the piping
10 and safety valves as a consequence of certain operating
11 situations."

12 These very small break LOCA's considerations
13 appear to be generic for pressurized water reactors,
14 although it may be more severe for B&W 205 fuel assembly
15 plants because of the once through steam generator
16 configuration.

17 Lastly, let me direct your attention to page 34
18 where this language appears. "Pressurizer level continues
19 to increase as remaining steam bubble pressurizer cools
20 and is compressed to reactor vessel steam bubble pressure
21 while the hot water drawn from the hot leg pipe into the
22 pressurizer loop seal piping is allowed to cool."

23 On page 35 in paragraph 4, the statement appears,
24 "Reactor vessel level decreases due to fluid loss through
25 the break in excess of makeup capability until makeup

1 capability exceeds fluid loss through break."

2 Looking at all of that language again, do you
3 feel there is any question that a technical person with
4 a good deal of sophisticated background in the Division
5 of Systems Safety in reading that would not realize what
6 Mr. Michelson was addressing was the possibility of operator
7 error based upon a misleading pressurizer level reading?

8 A Off the record.

9 (A discussion was held off the record, and the
10 pending question was read by the reporter.)

11 THE WITNESS: Yes, I believe that the reviewers
12 in DSS would understand that.

13 BY MR. KANE:

14 Q - All right. If you had read that language in
15 1978, would you have understood that?

16 A Yes.

17 Q And presumably if someone in DSS had read that
18 and understood it, would they have taken some action on it
19 to see to it that operators were advised with the correct
20 information as to what to do under these circumstances?

21 A Yes, but recognizing they would have had to
22 change some things that were then existing review practices.

23 Q They would recognize that?

24 A They would recognize that.

25 Q Would it be customary under those circumstances

1 for whoever recognized that to bring it to the attention
2 of superiors within the NRC so that appropriate instructions
3 could be disseminated to licensees and incorporated into
4 operator training?

5 A It would probably take a little bit different
6 track. It would take the track of the staff going to
7 licensees to ascertain whether such instructions existed.

8 Q And if they determine that they did not?

9 A Requiring that they be generated.

10 Q I think your testimony before was to the effect
11 it is now being ascertained that those procedures did not
12 cover this situation?

13 A That's right.

14 Q I take it then that it is no longer then your
15 firm belief that formal evaluation of the Michelson report
16 would not have prevented TMI?

17 A May not.

18 Q If the proper instruction for operators under
19 these type of small break LOCA considerations had been
20 disseminated and if those operators had followed those
21 instructions, would the TMI 2 accident have happened?

22 A No, not in my judgment.

23 Q All right. Something I asked you about in our
24 prior interview, Mr. Mattson, related to the Davis-Besse
25 transient of September 24th, 1977. That, as you know, is

1 something that has come up quite a bit, and it has been
2 identified in prior depositions and in some hearings that
3 this Commission has already held as being a precursor
4 of TMI 2.

5 Are you familiar with the facts relating to that
6 transient?

7 A I recall the review of the transient. I recall
8 reading some documentation associated with the transient.
9 I didn't personally review it.

10 Q What do you understand happened in that transient
11 at Davis-Besse on September 24th, '77?

12 A There was a loss of feedwater. There was a
13 degraded performance of auxiliary feedwater. There was
14 degraded performance of the power operated relief valve.
15 There was voiding in the primary system. There was a
16 fairly rapid recognition of the PORV degraded performance,
17 and a closing of the ~~blocked~~^{block} valve.

18 The transient was initiated at 9 percent power.
19 There was a beginning of ~~live~~^{life} core, not a three-month
20 old core as in the case of Three Mile Island. Consequences
21 to the reactor were none.

22 Q Was there a PORV that stuck open?

23 A No. It fluttered. It opened and closed and
24 opened and closed.

25 Q What was the final result after all that fluttering?

1. It fluttered and then what did it do? Did it stick open?

2 A I don't understand the thrust of your question.

3 Q It is my understanding it fluttered, it opened
4 nine times, fluttered if you will, and then stuck open open.

5 A That is my understanding also.

6 Q Okay. It did eventually stick?

7 A I don't know when it stuck compared to when it
8 was isolated and whether that was significant compared to
9 the coolant loss during the fluttering. I don't know the
10 answer.

11 Q What did the pressurizer level do?

12 A I believe it stayed up.

13 Q Yes. It was on an increasing mode. It dropped
14 slightly, and went into an increasing mode. What did
15 the operator do based on that pressurizer level?

16 A My understanding is he intervened with the high
17 pressure injection system.

18 Q Terminated the high pressure injection system
19 three and a half minutes into the event. When did he
20 turn it back on again?

21 A I don't recall.

22 Q I don't recall that either. When did he
23 discover the PORV was open and activate the block valve?

24 A It was a few minutes into the transient. I don't
25 believe it was as soon as three minutes.

1 Q About 20 minutes into the transient; when did
2 you first become aware of the facts related to this
3 transient?

4 A In this detail that I have just described, after
5 Three Mile Island.

6 Q When did you first hear about the transient at
7 all?

8 A In the fall of 1977.

9 Q How did that come about?

10 A It must have been, we are talking about a
11 transient that occurred in September of 1977, late in the
12 month I believe, the 27th of September.

13 Q The 27th of September you became aware of that
14 transient?

15 A No. I believe it occurred on the 27th.

16 Q The 24th.

17 A So it would be my estimate that sometime in
18 October is when I first became involved, and I became
19 involved when I was asked to attend a meeting ^{held} by my staff
20 and the Assistant Director for Reactor Safety.

21 Q Who was that?

22 A That was Dr. Ross, who was the AD at the time.
23 Mr. Tedesco ^{is now} ~~was~~ the assistant director, ^{The meeting was} ~~of that AD~~ with
24 Mr. Novak and Mr. Mazetis, who was a section leader in the
25 Reactor Systems Group--a meeting with the Office of

1 Inspection and Enforcement, and the principal representative
2 of that office was Carl Seyfert. The subject of the meeting
3 was to resolve a dispute over who should have the lead
4 responsibility for responding to the Davis-Besse transient.

5 My staff felt that they should, and the Office
6 of Inspection and Enforcement felt that they should.

7 Q Before you go any further on that, I am curious
8 because that whole situation strikes me as a gargantuan
9 response to a transient. It would be unusual to have this
10 much involvement over a single transient, wouldn't it?

11 A No.

12 Q Really?

13 A Not a transient of this nature; this is the sort
14 of thing that happens with transients.

15 Q Was this considered a major transient, a
16 significant transient?

17 A Significant, yes; I don't know if it was considered
18 major--significant.

19 Q What was significant about this transient? You
20 pointed out that there was no damage to the plant. It
21 was brought under control in a relatively short period of
22 time. Operator action appears to have been timely in
23 terms of detecting the PORV.

24 What was significant about the transient?

25 A Well, I can tell you what was significant in the

1 minds of the people at the time that the NRR staff wanted
2 to be involved because I have a piece of paper that says
3 what was important in their minds, if you will give me a
4 moment to find it.

5 Q Sure.

6 A This is a handwritten document entitled "Trip
7 Report." It has got the name Mazetis in the upper right-
8 hand corner. Have you seen it?

9 Q Yes, as a matter of fact, I have. Why don't
10 you explain on the record what that is?

11 A Well, it is Jerry Mazetis' summary of his trip
12 to Davis-Besse and his review of the information that was
13 available, and in the summary which begins on page 1 of
14 this trip report, he summarizes what the event was, talks
15 about the system which malfunctioned, and then lists four
16 key areas of concern which I believe must be the things
17 that the technical staff thought were the distinguishing
18 features of this transient which made it an interesting
19 or significant transient as we were just discussing.

20 Q Where does he list those four key areas?

21 A The bottom of page 2, there is a list of four,
22 continues on over to page ³ 3--the auxiliary feedwater system,
23 turbine governors, effect of excessive cooldown rate on
24 primary side. The third is stresses on ^{the} steam ^{generator} ~~generation~~,
25 especially steam generator 2 which the applicant believes

1 went dry, and four, dynamic effect of vapor formation in
2 the coolant system during the transient, cavitation and
3 seal effects.

4 It is interesting that in summarizing he doesn't
5 talk about the level indicator at all.

6 Q I see.

7 A And he doesn't talk about steam ^{generation}~~generator~~, the
8 void formations' possible effect on core cooling. He
9 talks about void formation effects on ^{the} reactor coolant pump
10 and its seals.

11 Q Let me see if I understand. This is a document
12 prepared by Mr. Mazetis at the time he went to Davis-Besse
13 to do an inspection trip in connection with the transient
14 that occurred on September 24, 1977.

15 Mr. Mazetis has already testified that he took
16 that trip on September 30th, 1977. I believe he has
17 testified that he took it upon direct order or direction
18 from you to go out and inspect that site. Is that true?

19 A I don't recall. Be careful of the word inspection.
20 I may have asked or it may have been his assistant
21 director. I don't recall. He was asked to go to meet with
22 the people at Davis-Besse and understand the facts of the
23 transient and to interface with the I&E inspectors.
24 Mr. Mazetis is not an inspector.

25 Q As a matter of fact, at the end of this document,

1 the third and fourth page from the end, are a roster
2 apparently of a meeting that was held on September 30,
3 1977 at Davis-Besse by Mr. Mazetis with some
4 approximately 32 individuals from Toledo Edison, from NRC,
5 from B&W, and from Bechtel Corporation, and I see that the
6 NRC representatives were Mr. Engel--

7 A He was the project manager.

8 Q Mr. Legho is a supervisor engineer in DSS.

9 A I'm sorry.

10 Q That is the name that is next to his name.

11 A I don't know.

12 Q That is the title next to his name on the list.

13 A And Mr. Szusiewicz is a reactor engineer, and
14 then there is Jerry Mazetis.

15 Q Then there is Mr. Ragan, a mechanical engineer
16 from NRC. Then there is Mr. Harpster from Region 3 of
17 NRC, and Mr. Little from Region 3 of NRC.

18 A That is not an excessive NRC contingent to be
19 present--~~X~~² people from the regional office to make sure
20 they were up to speed on what was happening with the
21 folks from Washington coming out to find out, and Mr.
22 Mazetis who was a reactor systems expert; Mr. ~~Stusiewicz~~^{Szusiewicz}
23 who is a containment system branch--I'm sorry, he is
24 Instrument and Control System Branch; Ragan would be the
25 mechanical engineer^{ing} branch, somebody who understood the

1 thermal stress effects on the steam generator; J. T.

2 ~~Seang~~ Liang--I don't know.

3 Q Okay.

4 A Engel was the project manager.

5 Q I wasn't suggesting it was an excessive number.
6 It does strike me, however, that whenever you get 32 people
7 together on a given event, it is recognized that that event
8 has a high degree of significance, particularly under
9 these circumstances.

10 Wasn't it your understanding at the time that
11 this was a significant transient?

12 A Yes, but I do not put the word high in front of
13 high significance. We pay attention to a lot of safety
14 things and some of these things take a lot of people.
15 The number 32 doesn't cause me to use the superlative.

16 Q Is it fairly customary for representatives of
17 DSS to go out on these kinds of trips?

18 A For significant events, yes.

19 Q How many times in a year do representatives of
20 DSS go on these kinds of trips, to an on-site situation to
21 sit down in a group of as many as 30 people to evaluate a
22 transient?

23 A A couple of times a month. I would guess that
24 is roughly what it is, yes.

25 Q I see that the second factor which was listed

1 out of the four that you said Mr. Mazetis was focusing on
2 was effect of excessive cooldown rate on primary side.

3 Do you know what he meant by that?

4 A Yes. The injection of cold water and the boiling
5 off of the secondary side causes the primary side to cool
6 rapidly when it stays ~~at~~^{at} pressure which creates a potential
7 overstress condition in the primary coolant system in
8 violation of the temperature pressure curves in the
9 Commission's regulations. It is a thermal stress problem.

10 Q The third aspect was stress on steam generators,
11 especially SG 2, which the applicant believes went dry.
12 I take it he means there that the steam generator boiled
13 dry?

14 A Yes.

15 Q Was there any reference to the fact that this
16 was a once through steam generator utilized by B&W in
17 its design?

18 A That is common knowledge for everyone in the
19 division.

20 Q Was there focus at this time upon the boilout
21 rate for the once through steam generator in the event of
22 a loss of feedwater as opposed to the boilout rate of the
23 recirculation steam generator?

24 A No specific focus that I recall.

25 Q In any event, Mr. Mazetis prepared these notes

1 based on his trip to Davis-Besse on September 30th, and
2 then there was a meeting a few days thereafter?

3 A Yes.

4 Q I think you say at that meeting Denny Ross was
5 present?

6 A I believe Dr. Ross would have been there--
7 Mr. Novak, Jerry Mazetis, probably Frank Schroeder, my
8 deputy, and me.

9 Q Was Ashok Thadani also present?

10 A I wouldn't be surprised. He is with the Reactor
11 Systems Branch, and he is pretty good at these things.

12 Q How about Thomas Novak?

13 A Novak is the branch chief. I said he would
14 probably have been there.

15 Q Was Sandy Israel there?

16 A May have been.

17 Q So you had this meeting that was two or three
18 days after this trip by Mr. Mazetis on September 30th?

19 A I don't recall how many days.

20 Q Sometime in October of 1977; what was the purpose
21 of that meeting?

22 A To resolve who had lead responsibility for
23 reviewing the Davis-Besse transient.

24 Q Was there any discussion at that meeting of
25 Mr. Mazetis' trip report?

1 A Yes. He presented it.

2 Q Was it looked over at that time and read?

3 A In the sense of those are good concerns, those
4 are things we ought to follow up on, those are the kinds
5 of things that the transient raises as questions--the
6 conclusion of the meeting was that I&E would keep the
7 lead and would assure that Mazetis' questions were spoken
8 to.

9 Q Did you read this trip report at that time?

10 A I did not recall seeing this trip report until
11 after Three Mile Island. I went to Mr. Mazetis and I
12 said there is going to be some interest in the Davis-Besse
13 transient--I see from Mr. Tedasco's ^{0560 - -}~~0060~~ did you keep
14 any document from the time of the review, and I don't
15 recall the conclusion of the concerns that we raised when
16 I&E took the lead and he gave me a copy of this document.
17 That would have been some time in May.

18 Q You hadn't seen the copy of this document before
19 then?

20 A Not that I recall; it may have been handed out
21 at the meeting and I didn't retain a copy. I remember the
22 briefing at the meeting spoke to these subjects.

23 Q If you had been provided a copy of this document,
24 where would you have put it?

25 A I probably wouldn't. I would have probably

1 thrown it away. I would have listened to the briefing,
2 made the decision that was required of me that day which
3 was to see where the subject was to be assigned for
4 followup, and left it at that.

5 Q How long did this meeting last?

6 A Several hours.

7 Q During the course of that several hour period,
8 it was attempted to analyze the various aspects of the
9 transient to determine who should have lead responsibility
10 for it?

11 A Yes.

12 Let me direct your attention to page 6 of this
13 document that we have identified as Mr. Mazetis' trip
14 report. The language appears there "The operator secured
15 ECCS (turned off) HPI pumps and 4 and a half minutes
16 after manual SCRAM he observed a restoration and increasing
17 pressurizer level. At about 20 minutes after the manual
18 SCRAM, the operator concluded that the RV was stuck open
19 and closed a remote manual block valve from the control
20 room, thereby terminating the primary side blowdown."

21 Do you recall reading that language at the time
22 of this meeting?

23 A No.

24 Q Was there any discussion at this meeting of the
25 fact that the operator had secured ECCS, turned off HPI

1 pumps based upon an increasing pressurizer level?

2 A I don't recall.

3 Q Was there any discussion about whether or not any
4 operator error did occur in connection with this transient?

5 A I don't recall.

6 Q Do you keep a file on Davis-Besse?

7 A No.

8 Q During the course of this entire meeting, what
9 was discussed about the transient?

10 A Well, I recall the conversation focused more on
11 the kind of things that are summarized at page 2 and 3.
12 I remember quite a lot of discussion about the amount of
13 debris generated in the containment sump, and another
14 discussion about the jet impingement on insulation materials
15 caused by the rupture of the disc in the quench tank and
16 the assessment by Mr. Mazetis as to the effect of that
17 quench tank rupture on other systems inside of containment.

18 As I recall, the meeting was more a hardware
19 oriented meeting, and I recall no discussion of operator
20 error. There may have been some and my memory doesn't
21 serve me.

22 Q That may have been a function of the same mind
23 set you were talking about before, a mind set which focuses
24 on equipment and design specifications and on design
25 performance rather than upon operator interaction with

1 those designs?

2 A In this division, yes, sir.

3 Q You say there was a discussion with Carl Seyfrit.
4 Who is Carl Seyfrit?

5 A At that time he was a senior manager in the
6 Office of Inspection and Enforcement, headquarters staff.
7 He is now the Director of Region 4 in Dallas I believe.

8 Q I see. Okay. Mr. Seyfrit was there because
9 there was some question about whether or not this matter
10 should be handled by DSS or by I&E?

11 A Yes.

12 Q I am curious in that regard. I have been trying
13 over the last three weeks to get a feel for what the various
14 components in NRC do.

15 As was reflected in the question I asked you
16 before, my impression was that the central repository, if
17 there is one, for technical expertise in the NRC is largely
18 DSS, and that the capabilities for inspection, for police
19 work, surveillance on what is happening in the field, is
20 with I&E, but that I&E does not have very extensive
21 technical capability.

22 Is that right?

23 A I think you underrate their technical capability.
24 They are graduate engineers. They are knowledgeable in
25 nuclear technology. It is fair, however, to say that when

1 they believe that technical problems require a depth of
2 attention or study that is beyond their staff capability,
3 that they transfer the matter to NRR for action.

4 Now in an operating reactor, that ^{transfer} would
5 customarily be to the Division of Operating Reactors. In
6 the case of Davis-Besse, the transfer of the reactor
7 from the Division of Project Management to the Division of
8 Operating Reactors had not occurred, and so DSS was in a
9 bit of an unusual situation. We don't normally review
10 operating experience and assess its significance for the
11 safety of that plant, but since it hadn't transferred, we
12 still had technical support responsibilities in its
13 licensing, and the interface between us and I&E was a
14 somewhat-unique interface in this regard.

15 I was also somewhat unique in having just taken
16 my job, and Mr. Seyfrit and I thought we probably better
17 have a meeting and iron this difficulty out. He didn't
18 think it needed to be transferred to NRR for resolution.
19 My staff had some concerns. They thought it needed to be
20 addressed.

21 We sat down and decided that my staff's concerns
22 had been well articulated. I&E could factor them into
23 their review and they could handle it.

24 Q Why didn't Mr. Seyfrit feel that there should
25 be any transfer of responsibility for this away from I&E?

1 A That his people were capable of addressing the
2 problem.

3 Q Does I&E have the technical capability to deal
4 with highly unusual types of transients, very much out of
5 the ordinary?

6 A No.

7 Q In October of 1977 was the phenomenon of a
8 pressurizer level rising and pressure in the reactor
9 coolant system itself dropping under the circumstances of
10 a very small break LOCA a highly unusual transient?

11 A Today, yes; then, I am not sure we understood
12 that.

13 Q But whether or not you understood it at the time,
14 it certainly was highly unusual, wasn't it, in 1977?

15 A I don't understand how the two statements make
16 sense.

17 Q I have heard all along that the kind of situation
18 that occurred at TMI 2 was incredible, was beyond anyone's
19 expectation, was something the operators had never seen
20 before or been trained for. It was an extremely unusual
21 situation.

22 Davis-Besse on September 24, 1977 has in some
23 respects been identified as a precursor of that event.
24 To the extent that it had those features in common with
25 TMI 2 on March 28, 1979, wasn't it a highly unusual

1 transient to that extent?

2 A Your premise is your statement, not mine, and I
3 am not sure I agree with you there.

4 Q My question is, is the situation of pressurizer
5 level rising, pressure in the reactor coolant system
6 dropping under the circumstances of a very small break LOCA
7 a highly unusual transient?

8 A If you understood that those two things were
9 going on simultaneously and that the operator was not
10 trained to understand that they could go on simultaneously,
11 then you would say it is a very unusual transient, but I
12 am not certain, certainly I didn't and I don't think the
13 technical staff at that time attached that significance
14 to it, so it was a significant transient, but more from a
15 standpoint of boiling a steam generator dry and having
16 a rapid cooldown than from deception by the pressurizer
17 level indicator.

18 Q I am looking again at page 6 of Mr. Mazetis'
19 trip report where he says, "The operator secured ECCS,
20 turned off HPI pumps."

21 A You have read that once before. I see that, but
22 I also see on page 2 and 3 his summary of the significant
23 features of the transient, and that is not one of them,
24 and that tends to reinforce what I am saying.

25 The staff recognized that the pressurizer level

1 indicator did what it did while the reactor vessel did what
2 it did, but didn't attach the significance to it that you
3 are attaching to it today.

4 That may have been an error and poor technical
5 judgment, but it is fact.

6 Q Let me ask you something a little more specific.
7 Was it recognized at that meeting that the operator had
8 secured ECCS during this transient?

9 A I suspect it was. I don't specifically recall
10 it; since it is in his summary and the summary was written
11 contemporaneous with the meeting, I assume it was
12 discussed. I don't recall it.

13 Q All right. Was it also recognized--let me ask
14 you this. Would your response be the same as the subject
15 matter of an increasing pressurizer level during this
16 transient?

17 A Yes.

18 Q Okay. To that extent then, with 20-20 hindsight
19 we can recognize it as a highly unusual transient, but I
20 think your testimony is to the effect that was not
21 recognized at the time.

22 A ^{Unusual}~~Unusual~~ connotes low probability. Very significant
23 transient, with 20-20 hindsight, I would agree.

24 Q To that extent of being highly infrequent as
25 transients go?

1 A No. Unfortunately, it appears that it is not
2 highly infrequent.

3 Q It is your understanding that this type of
4 phenomenon of a very small break LOCA pressurizer level
5 increasing, pressure in the primary system dropping, is a
6 fairly usual occurrence?

7 A Well, one out of every 50 operations of the PORV
8 is the operating history with B&W reactors, as we
9 understand it today.

10 Q And that has been happening once out of 50 times,
11 that whole phenomenon?

12 A Yes.

13 Q In any event, at that time in October, 1977,
14 you say it wasn't recognized as unusual and it was turned
15 over to Carl Seyfrit?

16 Was it felt at that time that I&E had the
17 capability to adequately assess the technical aspects of
18 this transient?

19 A With the understanding that Mr. Mazetis was
20 available to advise and consult on the concerns that he
21 had enumerated in the meeting on that day, yes.

22 Q And you agreed with that particular decision?

23 A Yes. I made it.

24 Q Was any determination made at that time that
25 you should follow up with Mr. Seyfrit to find out what the

1 resolution of these concerns were?

2 A There must have been. I do not recall the
3 details of it.

4 Q Did Mr. Seyfrit after this meeting ever report
5 back to you as to his resolution of the concerns involved
6 in the Davis-Besse transient of September 24, 1977?

7 A I don't recall that he did.

8 Q Did he report back to anyone else within the
9 Division of Systems Safety?

10 A I do not know.

11 Q If I understand correctly, you did not go back
12 to Mr. Seyfrit and say how about it or something to that
13 effect?

14 A I did not.

15 Q Would it be customary for you to turn over or
16 has it been customary for you in the Division of Systems
17 Safety to turn over to I&E a technical problem dealing
18 with a transient and to not require some followup to be
19 reported back to you by I&E?

20 A You missed the point entirely. I&E by definition
21 has an initial responsibility for all operating experience.
22 I&E must make a decision to transfer it back to NRR.

23 Under ordinary circumstances that would be to
24 the Division of Operating Reactors, never to the Division
25 of Systems Safety directly. We often get problems referred

1 to us by I&E for plants under construction, seldom for
2 plants in operation.

3 Q On the other hand, you did say that Davis-Besse
4 at that time was still within the Division of Project
5 Management and to that extent then looked to DSS rather
6 than DOR for its technical backup?

7 A That's right. That is why it was unusual.

8 Q As to the extent that Mr. Seyfrit would have
9 been doing anything relating to that project, he would have
10 been reporting it back to at least the project manager,
11 wouldn't he?

12 A He doesn't report to anyone in NRR. It would
13 be his own line organization. Other than preliminary
14 notifications and casual conversation, there is no
15 requirement for him to report any of that back to NRR.

16 Q Is what you are saying, Mr. Mattson, that after
17 this was turned over to Carl Seyfrit at the end of that
18 meeting as far as you were concerned you were done with
19 it? You had washed your hands of it?

20 A That is true, except that it wasn't turned over.
21 It was never taken away from him. It was his responsibility
22 at the beginning, and continues to be his responsibility.
23 Mr. Seyfrit does not report to me.

24 Q So if I understand it correctly then, a problem
25 which your staff has been called upon to evaluate, with

1 the determination made that I&E has the lead responsibility,
2 at that point, your staff work is done, you have nothing
3 further to do with the problem?

4 A That's right.

5 Q And you make no effort to follow up to see how
6 the problem has been resolved?

7 A That's right.

8 Q Okay. Do you know today how this problem--

9 A However, on this particular example, I do recall
10 that Mr. Mazetis was concerned that his concerns be
11 factored into the I&E work. That was the purpose of the
12 meeting. That was the purpose of his summarizing his
13 concerns, and there must have been at the end of that
14 meeting some kind of an agreement as to how Mazetis would
15 provide consulting and other services to the I&E
16 investigators in the conduct of their review. I do not
17 recall what they were.

18 I find it hard to believe that we walked out of
19 that meeting without agreeing on some feedback mechanism
20 from I&E to the DSS technical staff because they were
21 interested in this transient.

22 Q Well, it is my understanding from the deposition
23 of Mr. Mazetis which I didn't take that he did have no
24 further contact with Mr. Seyfrit about this particular
25 transient, so I don't know what happened in there, but

1 apparently it went into I&E and did not in any way get
2 back into DSS.

3 Did it ever go to the ACRS, that we don't know,
4 but we will be taking Mr. Seyfrit's deposition tomorrow.

5 A Someone told me that there was a presentation by
6 I&E to the ACRS on the Davis-Besse transient which means
7 if there was, it is in a public record transcribed
8 somewhere.

9 Q That was a presentation to the ACRS concerning
10 the September 24, '77 transient?

11 A That is my recollection as to what I was told
12 within the last several months by someone that I don't
13 recall.

14 Q Do you know when that presentation was made to
15 the ACRS?

16 A I would think it would have been in either the
17 October meeting or the November meeting is where I would
18 look.

19 Q Of 1977?

20 A Yes. If I didn't find it there, I guess I would
21 ask the ACRS staff.

22 Q There is this meeting then about the Davis-
23 Besse transient in early October of 1977, at which time
24 they confirm that Mr. Seyfrit will have lead responsibility.

25 Mr. Ebersole has testified that it was also just

1 about this time in October, '77 that he gave to Sandy
2 Israel the handwritten copy of the Michelson report we
3 have been discussing, and it is my understanding that
4 this Michelson report in part engendered the Novak
5 memorandum that you made reference to before dated
6 January 10, 1978.

7 A The Michelson report did?

8 Q Yes. I believe Sandy Israel's testimony at this
9 point is to the effect that he is not sure whether or not
10 the--

11 A I was going to say that Sandy told me several
12 months ago that he tended to think it was the Davis-Besse
13 transient that led to the memo, but it may have been the
14 Michelson report. They occurred approximately the same
15 time.

16 Q As a matter of fact, he makes reference to the
17 Davis-Besse memorandum in the Novak memorandum or the
18 Davis-Besse transient. It is my understanding that Sandy
19 Israel drafted the Novak memorandum for Novak's signature.

20 Is that your understanding?

21 A That is my understanding.

22 Q This is a document dated January 10, 1978. It
23 has been previously attached as Exhibit No. 3 to the
24 deposition of Sandy Israel.

25 Is this the document you have seen which you

1 recognize as the Novak memorandum?

2 A It is. It has got my handwriting on the bottom.
3 It says Enclosure 7. That would have been the enclosure
4 to my letter to Henry Myers.

5 Q And if I understood your testimony before, do
6 you feel that this memorandum sort of hits it on the head
7 as to what happened to TMI 2 on March 28, 1979?

8 A It certainly describes what happened to the
9 pressurizer level indicator.

10 Q Does it also address the question of operator
11 error based upon that pressurizer level?

12 A You will have to give it back to me.

13 Q I would specifically refer your attention to the
14 second to the last paragraph where this language appears.
15 "Although the safety analyses do not require termination
16 of the makeup system, operators would control makeup flow
17 based upon the pressurizer level as part of their normal
18 procedures. As a result, under certain conditions where
19 the pressurizer could behave as a manometer, the operator
20 could erroneously shut off makeup flow when significant
21 void occurs elsewhere in the system or loss of inventory
22 is continuing."

23 A It certainly does.

24 Q It appears to address operator error based on
25 pressurizer level, doesn't it?

1 A Yes. You know, that is an anomaly in this
2 memorandum. It stresses operator error, but then look
3 what it does in the next paragraph, and there is the mind
4 set again. What does it say to do? The basis for the
5 design requirement be studied carefully for all CP reviews
6 for the object of determining if the loop seal can be
7 eliminated. OL review procedures should be reviewed.

8 Q To ensure adequate information before the
9 operator terminates makeup flow.

10 A No procedures are reviewed in the Reactor
11 Systems Branch, and so the emphasis is again in the
12 design.

13 Q Where are procedures reviewed?

14 A The kind of review that ought to be done,
15 nowhere; they are not reviewed by the industry. They are
16 not reviewed by the utility. They are not reviewed by us.
17 They are being reviewed right now, and it is a start in
18 the right direction.

19 Q I realize I am approaching this as a layman,
20 relatively unsophisticated in these areas, and certainly
21 unsophisticated by the NRC and where it has come from,
22 but the very idea that NRC licenses mechanical devices
23 which are out there in the country to perform, and does
24 not examine the procedures to be utilized in operating
25 those devices strikes me as very anomalous at the very

1 least.

2 How did that come about?

3 A You have said it too all encompassing; first of
4 all, there is some review, not of the type described here,
5 but there is some review.

6 Q What is that review?

7 A Review to ascertain that the procedures for the
8 anticipated events, the transients, and the accidents
9 described in Chapter 15 of the safety analysis report,
10 exist.

11 Q Now how they are implemented, just that they
12 exist?

13 A Let me finish. That they exist; second, during
14 startup of each reactor, the Office of Inspection and
15 Enforcement goes through those procedures, and I suspect
16 there ^{is} ~~are~~ some spectrum ^{is} ~~of~~ the goodness of that quality
17 assurance review, but they do go through the procedures,
18 and in the past there has been one additional point of
19 interaction between the procedures and NRC, and that has
20 been the use of the procedures by the operator licensing
21 staff of NRC in the conduct of its examinations of operators.

22 Q That would be--

23 A The kind of review that has not been done, ^{is} ~~to~~
24 take the detailed systems reviewers and designers and
25 analyzers of the type that exist in DSS and couple them

1 with the people oriented reviewers that exist in the
2 Operator Licensing Branch and in the Office of Inspection
3 and Enforcement. That is a mistake, that is, but it is a
4 fact.

5 Q Okay. If I understand it correctly, if we are
6 talking about a fairly esoteric technical question, one
7 that really has not been considered before at PSAR or FSAR
8 or a given project, or that has not been addressed in
9 terms of the on-going work on unresolved generic safety
10 issues, if we are talking about that kind of issue,
11 something really new, it is in DSS that it is likely to
12 get the most sophisticated treatment, is that right?

13 A Yes.

14 Q So if you had a new idea, something that really
15 hadn't been focused on before concerning pressurizer level
16 and how it functions under certain types of small break
17 LOCA conditions, it would be to DSS that you would want to
18 address that issue for evaluation, wouldn't you?

19 A Yes.

20 Q Okay. In fact, in having the Michelson report
21 pass Sandy Israel, in having Sandy Israel prepare this
22 Novak memorandum that we have been talking about, wasn't
23 this issue of the behavior of pressurizer level indication
24 under certain small break LOCA conditions presented to DSS?

25 A Yes.

1 Q What happened to that presentation after it came
2 to DSS?

3 A I think you have already said what happened.

4 Q If I understand it, the Novak memorandum did not
5 go beyond the Reactor Systems Branch. What we are able to
6 ascertain is that he simply went into the files of the
7 various respective people who received it. They kind of
8 mentally earmarked it for possible use in further reviews
9 of B&W plants, and that's all.

10 Is that your understanding?

11 A With the exception of Mr. Ignatonis who was the
12 reviewer on the Sun Desert construction permit application,
13 ^{He} phrased a question for that Westinghouse design along the
14 ^A same lines to ascertain (I suspect all that, I haven't
15 spoken to him) whether the same kind of problem could exist
16 in the Westinghouse design.

17 That question went to the Division of Project
18 Management and was not mailed to Sun Desert, ^{the plant} ~~and that~~ was
19 cancelled.

20 Q That project, as I understand it, never went
21 anywhere because of other problems that came up in
22 California relating to the construction?

23 A The project was cancelled, yes.

24 Q Okay. However, in all of that activity within
25 the Reactor Systems Branch relating to the Novak memorandum,

1 nowhere do I find any recognition that the problem
2 addressed in the Novak memorandum or the problem addressed
3 in the Michelson report was of generic concern. Is that
4 right?

5 A The Novak memorandum on the next to the last
6 sentence recommended that the design requirements be
7 studied carefully for all CP reviews.

8 Q Doesn't that mean if that is a generic recognition,
9 it also applies for existing nuclear power plants?

10 A It does to me.

11 Q It apparently did not to the people that
12 received this at the time, if you can judge their thoughts
13 from their actions since there was no word put out to DOR
14 or to existing licensees concerning this matter at this
15 time, was there?

16 A Not to my knowledge.

17 Q In fact, the memorandum, the Michelson report
18 that we made reference to before states also that it
19 appears that these very small break LOCA conditions are
20 generic to pressurized water reactors, although it may be
21 more severe in the case of B&W plants.

22 What is your understanding today as to why the
23 generic implications in that sense of these concerns
24 raised in the Novak memorandum, in the Michelson report,
25 were not recognized and acted upon by DSS at the time?

1 A I believe that the technical people who had
2 knowledge of the things you have described judged the
3 effect to be a small one perhaps because of their
4 conviction that for a small break loss of coolant accident
5 there was a reliable emergency core cooling system which
6 required no operator action of the sort that would depend
7 upon pressurizer level.

8 Q There was simply no recognition of that you
9 feel?

10 A Yes. I must say that I have read the internal
11 memoranda from B&W which speak to the same point evidently
12 from about the same time period, and they reach a somewhat
13 different conclusion than that, and so in giving my
14 answer, I think I am saying that the people of the NRC
15 staff were not as insightful on this particular problem
16 as the people at B&W were.

17 Q When you say that you say you have seen some
18 B&W calculations which have indicated they did consider
19 it--

20 A No, no. I am speaking of the Bert Dunn memoranda.

21 Q We know how B&W handled that situation.

22 A I am simply saying that the B&W analysts
23 comparable to the DSS analysts who apparently were studying
24 the same problem at the same time, understood it
25 differently than the DSS analysts.

1 Q I wondered about that because you do make
2 reference to the B&W analyst, and I am aware that Mr. Dunn
3 of B&W did recognize this problem, but I am curious in that
4 the Michelson report, the handwritten version which was
5 provided to Sandy Israel by Jesse Ebersole in October of
6 1977 has attached to it two appendices, those being
7 Appendix B, which is small break LOCA analysis by Babcock
8 and Wilcox dated in March of 1976, and then it has
9 attached as an Appendix C the NRC evaluation of B&W small
10 break LOCA analysis.

11 Now I can tell you that we have deposed
12 Mr. Michelson, and we have gone through this entire report
13 with him and have asked him about these appendices. He
14 assures me that neither Appendix B or Appendix C, that is
15 the B&W analysis, which speaks of these concerns, and the
16 NRC evaluation of B&W's analysis in any way address his
17 concerns.

18 Now again, is there any way that this could have
19 been provided to DSS, that it could have been redundant
20 and yet not understood that these considerations were not
21 at that time at least being addresssed by either B&W or
22 the NRC?

23 A Well, I don't understand your question at all.
24 The report you refer to by B&W is written in March, 1976,
25 a year and a half before the draft Michelson report was

1 handed to Sandy Israel, and the summary and conclusions
2 page is dated 1975, which is even older, and Appendix C
3 is written in January, 1975.

4 Q '76.

5 A You're right, 1976--I don't see how they could
6 have been expected to address Mr. Michelson's concern if
7 he was looking for an answer to the specific things he
8 said.

9 Q It is my understanding from Mr. Michelson that
10 as of September, '77, this was the best existant evaluation
11 that he could find that approached the kind of concerns
12 he was addressing in the September, '77 handwritten
13 memorandum.

14 A I suspect that is true.

15 Q Okay. My only question is how could it be
16 possible for someone in DSS in reading that document,
17 including the appendices, to not realize that these concerns
18 being addressed by Mr. Michelson had not been addressed
19 by B&W and the NRC in its prior analyses of the problems?

20 In other words, isn't it an inevitable conclusion
21 in looking over this report that these are new concerns?

22 A Yes.

23 Q Okay. Something else that I wanted to ask you
24 about in connection with pressurizer level at this meeting
25 that was held in early October relating to the Davis-Besse

1 transient, was there any discussion of ECCS actuation?

2 A You asked me that already.

3 Q Right.

4 A I said there must have been because it is part
5 of the summary, but I don't recall it.

6 Q I didn't ask you that. I asked you about
7 operator error in connection with ECCS.

8 A You asked me about both I think.

9 Q Was there any discussion about coincident logic
10 for ECCS actuation?

11 A Not that I recall.

12 Q Are you aware that coincident logic is utilized
13 at a large number of operating nuclear power plants in
14 the United States for ECCS actuation?

15 A Not any more.

16 Q Right, but as of March 28, 1979 I am informed
17 there were approximately 25 such plants, is that right?

18 A However many Westinghouse designs there were.

19 Q This is a common Westinghouse feature?

20 A Yes.

21 Q If I understand coincident logic, at least in
22 connection with ECCS actuation, one facet of it is that it
23 is often tied to pressurizer level and pressure in the
24 reactor coolant system such that the ECCS will not actuate
25 unless a set point for pressurizer level and a set point

1 for pressure in the reactor primary system are reached,
2 is that right?

3 A Basically right.

4 Q So that in the circumstances of the phenomena
5 pressurizer level goes high or stays high and pressure in
6 the reactor coolant system drops, the ECCS will not
7 automatically actuate?

8 A That could be.

9 Q And those would be circumstances under which you
10 would very much want the ECCS to automatically actuate?

11 A That is true.

12 Q In connection with this meeting that was held
13 in early October dealing with the Davis-Besse transient
14 of September 24, '77, was there any recognition that the
15 phenomena being looked at at that time posed a problem
16 for coincident logic ECCS actuation?

17 A No. As a matter of fact--no, not that I recall,
18 and as a matter of fact, to go to one step further, I don't
19 believe that there was that problem in many people's minds
20 even in the first few weeks or months after Three Mile
21 Island because the pressurizer level difficulty with the
22 B&W design was being largely attributed to the loop seal
23 arrangement in the B&W design, but in the course of the
24 last month or so, the possibility of countercurrent steam
25 water flow problems in the pressurizer for both Westinghouse

1 and Combustion Engineering designs has been shown to be
2 another method for causing the pressurizer level to hang
3 up for a break in the steam space in the pressurizer, ^a small
4 break.

5 Q Are you saying it was thought at first that this
6 problem of the loop seal would be applicable only to B&W
7 plants and would not pose a problem for Westinghouse or
8 CE plants?

9 A That's right.

10 Q All right. Wasn't it recognized that totally
11 aside from loop seals, you could have the kind of small
12 break LOCA phenomenon described by Mr. Michelson in his
13 reports occurring at Westinghouse and CE plants as well as
14 B&W plants?

15 A Yes, but the deception in the pressurizer level
16 indicator was not appreciated from that standpoint.

17 Q Again, I hate to keep coming back to it, but
18 page 16 of the handwritten report provided by Jesse Ebersole
19 to Sandy Israel makes reference to the fact that these very
20 small break LOCA considerations appear to be generic for
21 pressurized water reactors, although the problem may be
22 more severe for B&W plants.

23 A You are reading that very narrowly, and I don't
24 believe that statement is intended to be read narrowly.
25 That means this general problem of more decay heat being

1 generated than can be removed by the discharge out the
2 break, not necessarily the very specific thing of an
3 anomalous pressurizer level indicator.

4 There are a couple gems of wisdom in the
5 Michelson report and you have got to be careful which one
6 you are reading about.

7 Q That sentence immediately comes after a sentence
8 which says, "Adding to these concerns is the uncertainty
9 associated with unknown vessel level, the adequacy of
10 emergency operating instructions, and operator training
11 for this event, and the consequences of unstable slug flow
12 conditions which are predicted to develop," et cetera.

13 It is talking about operator training, emergency
14 operator instructions, and the uncertainty associated with
15 unknown vessel level based upon a misleading pressurizer
16 level reading.

17 Now that is what the report seems to be referring
18 to, so when he talks about the fact it is generic to
19 pressurized water reactors, although it may be more
20 problematic for B&W reactors, isn't he making it clear,
21 Mr. Michelson, that he is concerned about this problem
22 across the board, not just at B&W reactors?

23 A That is true.

24 Q Okay, so it would appear to be applicable to the
25 Westinghouse situation?

1 A That is true.

2 Q Again, if I understand your answer, it is simply
3 that the implications of this hangup in pressurizer level
4 were simply not appreciated at the time the Davis-Besse
5 transient was being evaluated in terms of who was going
6 to have responsibility?

7 A I think they must have been very shortly there-
8 after because that meeting was early October evidently,
9 and the Israel draft of the Novak memorandum of January 10,
10 1978, two or three months later that he is writing about
11 it; I think there must have been such a connection.

12 Q Made between the pressurizer level and pressure
13 performance and the problems with coincident logic ECCS
14 actuation?

15 A No.

16 Q That was my question.

17 A Okay. To go back to that specific thing,
18 evidently it was not, that connection was not made until
19 after Three Mile.

20 Q Does I&E have the technical capability to make
21 that kind of connection?

22 A Yes, if they see it clearly, but evidently they
23 not only didn't see it clearly, but we didn't see it clearly
24 because we didn't make the connection here.

25 Q Is I&E in the business of trying to see those

1 kinds of connections? The reason I ask that is because
2 we have spent some time examining people from I&E, and
3 the impression I get is that I&E is very much burdened
4 with very specific and very routine types of specifications,
5 regulations, requirements, that must be met by the
6 licensees, and that when they go out to do an inspection,
7 they are by and large devoted to making sure that those
8 requirements have been met. They have little time, if
9 any, for creative thinking or creative connections among
10 safety problems.

11 Is that correct?

12 A I know people in I&E whose minds don't work the
13 way you have described and who are quite creative. As a
14 general matter, I suspect that what you have described is
15 closer to the norm than what I would characterize as what
16 some I&E inspectors have demonstrated to me that they are
17 capable of doing.

18 Q Again as a corollary to that, that to the extent
19 that a problem would be new, something not experienced
20 before with any degree of frequency, it would be DSS and
21 not I&E that would have the real technical sophistication
22 to fully evaluate that situation, wouldn't it?

23 A For the operating experience brought to our
24 attention, yes.

25 Q All right. Fine. In any event, I gather the

1 upshot of this October meeting was that the matter was
2 entrusted or was left I guess is the correct word with
3 Mr. Carl Seyfrit and I&E, and that there were no specific
4 arrangements that you can recall being made at that time
5 for Mr. Seyfrit to report back to DSS or to let you know
6 what he had done, is that right?

7 A That's right.

8 Q Do you have a personal opinion as to Mr. Seyfrit's
9 competence to address generic safety issues relating to
10 nuclear reactors?

11 A No. May we take a break?

12 MR. KANE: Sure. Let's take a short recess.

13 (A brief recess was taken.)

14 BY MR. KANE:

15 Q Mr. Mattson, I want to come back again to
16 Mr. Seyfrit just briefly since he was the one to whom this
17 matter of the Davis-Besse transient was, with whom it was
18 left.

19 At the conclusion of your meeting in October, '77
20 there was a transient on March 29th, 1978, after this
21 meeting on Davis-Besse, after the Michelson report is
22 gone into and Mr. Israel, after Mr. Israel has generated
23 the Novak memorandum, and then this transient in March of
24 1978, a PORV stuck open, and at that time there was an
25 evaluation of what was necessary to prevent operator

1 ignorance as to the position of the PORV, there was no
2 indicator available at that time on the control board at
3 TMI 2 for the position of the PORV. Do you recall that
4 transient?

5 A No. I recall the discussions of it since the
6 Three Mile Accident, but I recall no knowledge of that
7 transient prior to the accident.

8 Q Was it recognized in March of 1978 as common
9 knowledge that pressurized water reactors utilize PORV's?

10 A Oh, yes.

11 Q That was why the note. Was it widely know there
12 was not a position indicator for the operator in most
13 control rooms relating to the PORV?

14 A Had I been asked prior to the accident at the
15 Three Mile Island, I would have not known the answer to
16 that question. I don't know what was in the minds of the
17 staff.

18 Q Isn't the reason you would not have known that
19 that the PORV is not a safety-related piece of equipment
20 and therefore is not something that DSS focuses upon?

21 A That is probably the reason, yes.

22 Q I would like to cover that point with you.

23 A I may also be giving my answer to that question
24 that I personally hadn't ever focused on that element of
25 the design.

1 Q But DSS only focuses on safety-related aspects
2 of the design, doesn't it?

3 A That is true.

4 Q It doesn't get into the other stuff in the plant?

5 A That's right.

6 Q So as a matter of professional assignment you
7 wouldn't get into PORV's either?

8 A No, not necessarily, because I have looked at
9 PORV's from a safety standpoint as I was in that time
10 period, and that would be in connection with their use in
11 the event of an anticipated transient without SCRAM, the
12 unresolved generic issue.

13 Q In connection with that, did you look at the
14 situation of the reliability of PORV's?

15 A No.

16 Q Did you look at the question of PORV's occasionally
17 sticking open?

18 A Yes.

19 Q Did you look into the history at that time of
20 how often PORV's had stuck open in the past?

21 A No, and maybe I answered too quickly. We were
22 looking, in that time period, my staff was looking in that
23 time period at the capability of PORV's to withstand slug
24 flow and whether they could be relied upon for high pressure
25 two phase and solid water discharge in the event of an

1 anticipated transient without SCRAM.

2 We had not looked at them, to my recollection,
3 from the standpoint of their function in normal service,
4 but rather their utility and reliability for this beyond
5 normal service application. That is, what mitigating
6 capability would they bring to anticipated transients
7 without SCRAM?

8 Q What timeframe are we talking about for this
9 examination by your office?

10 A Of ATWS, starting about 1970.

11 Q About 1970, so during this 1977 period when you
12 had this meeting about Davis-Besse and on through the
13 Michelson report being transferred to Sandy Israel and the
14 generation of the Novak memorandum, and even up to the time
15 of this transient of March 29, 1978 at TMI 2 with the
16 PORV sticking open, your office was looking in on an
17 on-going basis, into anticipated transients without SCRAM
18 and in that connection with the performance of PORV's in
19 some respects?

20 A Yes.

21 Q In any of that evaluation was there any
22 consideration of how the operator would tell what the
23 position of the PORV was under any given circumstances?

24 A Not to my recollection.

25 Q Something we have talked about before is this

1 distinction which comes up again and again in conversations
2 I have had with persons within the NRC on safety-related
3 equipment and non-safety-related equipment, and Appendix B
4 to 10 CFR, Part 55, the first time that was brought
5 to my attention--

6 A Not 55.

7 Q Part 50, excuse me--the first time that was
8 brought to my attention I thought I could go to Appendix B
9 and find a listing of each little valve and each little
10 pin and whatever that is safety related.

11 Of course, I found out that is not the case. I
12 gather Appendix B is a broader, more general definitional
13 type of guidance for the licensees, and if I understand
14 correctly where the licensing process works is that the
15 licensee in the PSAR designates those items in the plant
16 that are considered safety related. Those items are then
17 reviewed by the NRC and presumably at some point approved.

18 Is that right?

19 A That is true.

20 Q Is the PORV a safety-related device?

21 A It has been judged not to be a safety-related
22 device.

23 Q I am curious about that. It was also my
24 understanding it was judged in the past that anything that
25 constitutes the boundary of the primary pressure system

1 is safety related.

2 A That is true.

3 Q And as I understand it, in normal configuration,
4 the PORV constitutes a portion of the boundary of the
5 primary system.

6 A That part of it has to meet the code requirements,
7 the ASME code requirements, for pressure retaining
8 capability, but the functioning of the valve itself opening
9 and closing and its operability is not a safety function,
10 only its pressure retaining capability, so for example,
11 its body must meet the requirements of the ASME code, but
12 its actuator and position indicator and those sorts of
13 things ~~do~~ ^{need} not meet the other ^{requirements such as} single failure, diversity,
14 redundancy, testability, seismic capability, so on and so
15 forth.

16 Q I am curious about that. Why is it that anything
17 that forms a portion of the boundary of the primary
18 pressure system is safety related? What is it about that
19 type of thing that makes it safety related?

20 A The answer to me is obvious. Let me pause for
21 a minute.

22 Q I think it is obvious to me, too, but I would
23 like to get your answer.

24 A Because the primary boundary, that is, the
25 reactor vessel and the primary piping, is a safety function.

1 It is necessary to continue the cooling of the core.

2 Q And it is also necessary to prevent radioactive
3 water from leaking out?

4 A Right, yes.

5 Q If the PORV jams open, you are having radioactive
6 water leaking out somewhere out of the primary pressure
7 system, aren't you, so under those circumstances, wouldn't
8 the performance of the PORV be a safety-related consideration?

9 A Yes. That is an interesting way to come at the
10 definition, and there are people who are coming at it that
11 way. It was not the way that it was come at before. It
12 was not the way we looked at it before.

13 Before we would have said there are three
14 layers of defense in the sense of keeping radioactivity
15 away from people, the first being the fuel cladding, the
16 second being the primary boundary, and the third being
17 the containment boundary, and for anticipated moderate
18 frequency events, the requirement was that the first
19 boundary, that is, the cladding, not be violated.

20 For accidents, the requirement was that the
21 primary boundary not be violated except those accidents
22 that were by definition a violation of the primary boundary.
23 That is a failure of the primary boundary, in which case
24 the requirement was that the containment not be violated
25 up through a certain class of design accidents, ~~not~~ including

1 ^{basis accidents, but}
all design ~~and~~ not including all possible accidents.

2 Now your logic says, and I think it is probably
3 a good logic but it wasn't the logic that was applied
4 before, your logic says that you preserve each boundary
5 for any kind of event. That is a non-mechanistic approach
6 which is ~~the~~ theory the better approach to defense in depth
7 as we have had it through the years.

8 It turned out that in its application we haven't
9 been that non-mechanistic. We have tended to be more
10 mechanistic, so mechanistically we would say there is a
11 block valve on the PORV, and if ~~X~~ ^{the PORV} fails ~~X~~ open, then the
12 block valve can be closed.

13 Unfortunately, we didn't follow the mechanistic
14 argumen through to its logical conclusion which would
15 have said then is there proper indication? It is reliable?
16 It is redundant? It is safety grade? Instead the line
17 between safety grade and non-safety grade was interposed
18 there for some historical reasons that I don't know and I
19 doubt are documented anywhere.

20 Q The line being there was a block valve which
21 could be activated in case it jammed open. Doesn't that
22 mean the block valve has to be safety related and safety
23 grade because now that is the primary boundary that you are
24 relying upon in the event the PORV jams open?

25 A In a sense of its pressure retaining capability,

1 it is.

2 Q Safety related?

3 A Yes.

4 Q What about in terms of a position indication for
5 the block valve?

6 A Well, what about its emergency power? The line
7 was drawn in a poor way.

8 Q If I understand it, what you just told me, the
9 line was not drawn at the PORV and its performance because
10 of it jammed open, you had a block valve.

11 On the other hand, if the full operation of the
12 block valve was not considered safety related, and I
13 take it that is because there was a PORV?

14 A Yes.

15 Q That is right?

16 A That is my best understanding of what must have
17 been historical reasons why PORV's and block valves seem
18 to have escaped proper categorization and review and what
19 have you as safety equipment.

20 Q Do you think if it had been safety related,
21 there would have been more attention to the generic
22 implications of problems with PORV's?

23 A Oh, yes.

24 Q I want to come back to that March 29, 1978
25 transient at Davis-Besse.

1 A March 28th?

2 Q The 29th, 1978, one year to the day I guess, or
3 less a day.

4 A Not at Davis-Besse.

5 Q I'm sorry. I mean Three Mile Island, March 29,
6 1978; it is my understanding that there was an action item
7 control form submitted by Metropolitan Edison, or excuse
8 me, submitted by I think this must have been done internal
9 at the NRC, concerning a review of the adequacy of the
10 design approach in connection with the PORV at Three Mile
11 Island.

12 I have here a document which is entitled "Action
13 Item Control Form" and I want to ask if you have ever seen
14 that before?

15 A No.

16 Q Do you know what that is?

17 A ^{I have} No--never seen the form before.

18 Q I see. It does appear to be something internally
19 used within the NRC to deal with these problems.

20 A If I read it, perhaps I could tell you what it
21 is.

22 Q Sure. Okay.

23 (The witness read the document.)

24 THE WITNESS: It is assigned to a man by the
25 name of Woodruff in the Office of Inspection and Enforcement.

1 Having not seen it, I must conclude that it is an I&E
2 internal form, and it refers to a memo to Seyfrit, to SN
3 I&E. I don't see any indication here that it comes to the
4 Office of Nuclear Reactor Regulation.

5 BY MR. KANE:

6 Q I see. Okay.

7 A But there may be. There is some coding.

8 Q It seems to involve Mr. Sternberg as well.

9 A I don't know that name.

10 Q He is with I&E. There was a follow up this
11 memorandum which is dated March 31, 1978. This is a
12 memorandum for Mr. Seyfrit through Mr. McCabe from
13 Mr. Sternberg, all within I guess this is Region 1.

14 Mr. McCabe is Region 1, and Mr. Seyfrit is I&E
15 headquarters. It refers to this event which occurred on
16 March 29, 1978. It states that the cause of the reactor
17 trip was the loss of a vital bus caused by an inverter
18 failure, and the cause of the inverter failure is understress
19 by the licensee.

20 It did, however, relate to this blowdown which
21 was caused by a PORV opening, and it states that the relief
22 valve does not appear to be safety grade component. It
23 requests that the adequacies of the design approach be
24 reviewed on an expedited basis, the design approach being
25 identified as valve failing open and loss of control power.

1 Have you seen that document before?

2 A No.

3 Q You know what a bus is, of course?

4 A Yes.

5 Q Until I started this investigation, I thought a
6 bus was something you rode to work, but it is my
7 understanding now that it is a type of electrical circuitry?

8 A Yes.

9 Q If I understand what the situation was at TMI 2
10 on March 29, 1978, it was that as long as energy was in
11 the bus relating to this PORV, the PORV remained closed.
12 If the energy failed, power was lost to the bus, the PORV
13 would fail open.

14 Does that sound right?

15 A Sounds like a very interesting design. I was
16 not aware of that.

17 Q It strikes me as a bad design to the extent
18 that what it means is that if power is lost, the PORV
19 fails open. Does that strike you that way also?

20 A Yes. It is not a good design.

21 Q It is also my understanding that as a result of
22 this event of March 29, 1978, the circuitry was reversed
23 at TMI 2 such that it took power in the circuitry to open
24 the PORV and that when power was lost, it became de-energized.
25 Then the PORV would remain closed.

1 Are you familiar with that situation at TMI 2?

2 A No.

3 Q Okay. That strikes you as a better design,
4 though.

5 A Yes. Off the top of my head it does. I really
6 shouldn't reach judgments that quickly. There may be
7 situations where that wasn't good, but I am not aware of
8 any.

9 Q All right. Do you know if that type of circuitry
10 I just described in unchanged state where it requires
11 energy to keep the PORV closed and if energy is lost to the
12 circuitry the PORV fails open, do you know if that kind of
13 circuitry is the circuitry that is followed for PORV's
14 in operating reactors around the country now?

15 A I do not.

16 Q If that were the situation, you would have some
17 concerns?

18 A I certainly would look at it, yes.

19 Q There was a further memorandum prepared here in
20 connection with this incident of March 29, 1978 at TMI 2
21 from Mr. Seyfrit to Mr. Brunner.

22 Do you know who Mr. Brunner is?

23 A No.

24 Q He is the Chief of the Reactor Operations in the
25 Nuclear Support Branch in Region 1. It references that by

1 memorandum dated March 31, 1978, which is the second
2 memorandum I showed you, the region requested that we
3 review the adequacy of the control system for the subject
4 valve and it refers to the TMI 2 pressurizer relief valve.

5 It states that failure in this position, that is,
6 failing open position, is covered in Section 7.4.1.1.6
7 of the FSAR. "We conclude that additional review is not
8 warranted."

9 Have you seen that document?

10 A No.

11 Q Okay. That is apparently Mr. Seyfrit's
12 determination that no further review of the problem is
13 required. It is my understanding that at that time, the
14 command signal indicator was installed at TMI 2 on the
15 control board, and that that was considered then to be an
16 appropriate solution for the problem along with the reversal
17 of the circuitry.

18 What I want to ask is why to your knowledge was
19 there no appreciation of the generic considerations of this
20 problem relating to PCRV indication?

21 A I have no idea.

22 Q It does appear that Mr. Seyfrit did not appreciate
23 the generic considerations of the problem, does it not?

24 A It appears that he took no action on the generic
25 implications in these memoranda.

1 Q Okay. Based on what you know today, are there
2 generic implications concerning PORV indicators for the
3 position of the PORV?

4 A Definitely. There are also safety implications
5 about the failure mode.

6 Q Mr. Mattson, are you aware of any transients
7 which have occurred outside of the United States involving
8 nuclear reactor plants in which PORV's have stuck open?

9 A One.

10 Q When was that one that you are aware of?

11 MR. CHOPKO: Objection.

12 THE WITNESS: You are worried that this is
13 classified?

14 MR. KANE: There has been some concern in that
15 regard. We are anxious, however, to get the information if
16 we can. We have been informed that the transient was in
17 1974.

18 MR. CHOPKO: Objection.

19 THE WITNESS: Somebody told me today that--I can
20 satisfy your concern. There has been a public version of
21 a report describing the events to which you refer just
22 re^Cently made available to your people, or about to be
23 made available to your people.

24 MR. KANE: We don't have any problem on this
25 then?

1 THE WITNESS: I am not sure whether it answers
2 your question.

3 MR. REILLY: I think it is just that one statement.
4 I don't know.

5 MR. KANE: All I am asking is when did the
6 transient occur.

7 MR. CHOPKO: Until we see the statement, I would
8 prefer not to have anything on the record at all to avoid
9 an unauthorized disclosure of classified information.

10 THE WITNESS: I am perfectly willing to discuss
11 that with you, but I am bound by restrictions on classified
12 information.

13 All I know about that transient is contained in
14 classified memoranda, classified by others; by law I am
15 required, Kevin, to honor that.

16 MR. KANE: Okay.

17 BY MR. KANE:

18 Q When did you find about about this transient?

19 A Since Three Mile Island.

20 Q How did you find out?

21 A Mr. Thadani came to me in late spring, early
22 summer, in the context of his work on the bulletins and
23 orders task force. He normally works in the Reactor
24 Systems Branch and reports to me.

25 Q He told you about this transient?

1 A He told me they had just learned of such an
2 event. He sought my counsel on how to proceed with
3 gaining further information. I gave it to him.

4 Q Was this transient at a Westinghouse plant?

5 A I don't know what is classified any more on this.

6 MR. CHOPKO: That particular one is not classified.

7 THE WITNESS: If he advises me that it is not
8 classified, then I will go with that. It was a Westinghouse.

9 BY MR. KANE:

10 Q When did Westinghouse find out about this transient?

11 A I don't know.

12 Q Do you have any information as to whether or not
13 Westinghouse was aware of this transient prior to March 28,
14 1979?

15 A I have a lingering suspicion, but I have no
16 direct information.

17 Q Why don't you give me your lingering suspicion.

18 A Yes.

19 Q What leads you to that lingering suspicion?

20 A I recall being told that there were reports not
21 available to the AEC or NRC, but describing this event,
22 that were in the United States.

23 Q I'm sorry. Could you repeat that?

24 A There was a report describing this event that
25 was in the United States.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Q Who submitted that report?

A I don't know.

Q Who told you about this report?

A It must have been Mr. Thadani and the people in the task force, the bulletins and orders task force who were researching this event.

Q This is a report dated prior to March 28, 1978?

A It is my recollection that there was written information of some sort available in the United States prior to March 28, 1979.

Q Was that information in the hands of the NRC?

A I said no.

Q I'm sorry. I didn't hear that. Who had that written information?

A I don't know that either.

Q Who had that written information prior to March 28, 1979?

A I do not know that. I said I had a suspicion.

Q Okay. What form did that written information take? Was it a report of some kind or a memorandum or what?

A My recollection may fail me entirely here, but I recall someone mentioning ~~to me~~ about the time I first learned of this event, late this spring or early this summer, that a report existed.

Q Do you know who prepared that report?

1 A No.

2 Q Do you have any reason to think it was a
3 Westinghouse report?

4 A No.

5 Q Do you have any idea how or when this report was
6 available?

7 A No.

8 Q Except that you know it was available or you
9 have heard it was available prior to March 28, 1979?

10 A Yes.

11 Q Your best recollection as to who told you is that
12 it was Thadani?

13 A That's where I would start.

14 (A discussion was held off the record.)

15 MR. KANE: Back on the record.

16 BY MR. KANE:

17 Q It is my understanding from previous testimony
18 we have taken, Mr. Mattson, and also some references you
19 have made, that coincident logic ECCS actuation has been
20 in the past a common feature of Westinghouse plants, is
21 that right?

22 A That is true.

23 Q Would knowledge of the full details of the
24 transient we have just been discussing prior to March 28,
25 1979 have been of material assistance to the NRC in
evaluating the safety of coincident logic ECCS actuation?

1 MR. CHOPKO: I am going to object to that. It
2 relies on assumptions some of which are going to be
3 classified.

4 MR. KANE: I am not asking for him to disclose
5 the assumptions.

6 MR. CHOPKO: Your question assumes it. I will
7 object to the form.

8 MR. KANE: All my question is directed to is
9 would the full knowledge of those facts which have not
10 been disclosed on the record here have assisted the NRC
11 in evaluating the safety of coincident logic ECCS
12 actuation as a general design feature?

13 MR. CHOPKO: I am going to object.

14 MR. KANE: I am not relating it to any specific
15 plant, just as a general design feature.

16 MR. CHOPKO: Renewed objection.

17 MR. KANE: I don't know what the objection is
18 based upon. I am not asking for any specific information
19 about anything that is covered by any confidentiality
20 agreement.

21 MR. CHOPKO: You are asking based on knowledge
22 of this overseas event, and you are linking it to specific
23 factual information, and you are basing that again on
24 assumptions.

25 MR. KANE: I am not linking it to any specific

1 factual information because the specific factual information
2 has not been disclosed here.

3 THE WITNESS: I appreciate what you are saying,
4 and I appreciate your side of the argument. Let me give
5 my answer because I think it moots the point.

6 I don't know. I would have to review the
7 information and look at again coincident logic. It is
8 not a question I asked myself when I saw the information,
9 and I don't know the answer to your question.

10 BY MR. KANE:

11 Q Is it your understanding that the situation
12 relating to coincident logic ECCS actuation has now been
13 changed at operating reactors in the United States?

14 A Whether it has been physically accomplished or
15 not I don't know. There are people certainly working on
16 it.

17 Q Did I&E bulletin 7906 address that situation?

18 A I believe it may have.

19 Q All right; 7906, as I understand it, directed
20 operators at plants that had coincident logic ECCS actuation
21 to manually turn on the high pressure injection upon the
22 pressure set point being released, being reached, regardless
23 of the level set point.

24 Does that comport with your recollection?

25 A That does.

1 Q And 7906 went out to all licensees, didn't it?

2 A Some of those numbers went only to Westinghouse
3 and some to Combustion. I could tell you in a minute.

4 Q Yes. Could we check on that?

5 A I have a copy of it right over here.

6 Q If you could check on 7906 as well.

7 A Yes.

8 (The witness checked the document.)

9 THE WITNESS: Went to all PWR's other than B&W .

10 BY MR. KANE:

11 Q All right. That is the direction to manually
12 turn on the HPI when pressurizer level set point is reached
13 regardless of whether or not the pressurizer level set
14 point calls for automatic initiation of ECCS?

15 A That is right.

16 Q And 7906A only went to Westinghouse licensees,
17 is that right?

18 A That is true.

19 Q And 7906A directs Westinghouse licensees to adjust
20 level trip point such that ECCS actuates on pressure alone,
21 is that right?

22 A That is true.

23 Q Is it only at Westinghouse plants that they
24 have coincident logic ECCS actuation?

25 A That is my recollection. I haven't been involved

1 in the detailed review of this aspect of the bulletin^S and
2 orders, but it is my recollection that Combustion did not
3 depend upon coincident logic.

4 Q So as far as you know, there is no coincident
5 logic ECCS actuation at CE plants, for example?

6 A That's right. If there were, I think they
7 would have been fixed by the same thing.

8 Q I was curious as to why 7906 talking manually about
9 turning on HPI went to all licensees if you only had that
10 situation of coincident logic ECCS at Westinghouse plants?

11 A Well, because all licensees had level indicator^S
12 and for the problem that the level could stay up when you
13 had a small break, they wanted it manually initiated.

14 Q I think that was addressed in 7905, as a matter
15 of fact, under the specific circumstances.

16 A These bulletins ~~are~~^{were} coming out rather fast and
17 furiously with technical staff kind of dispersed between
18 here and Pennsylvania, and there was some repetition, and
19 some lack of clarity^t in the initial bulletins.

20 Q I see. What is the rationale for coincident
21 logic ECCS actuation? Why have that?

22 A Well, I guess--I don't know specifically what
23 the historical reason was. It is couched in a much more
24 difficult question than appears on the surface.

25 You have got a lot of engineering safety feature

1 actuation signals and a lot of engineered safety features
2 and you are protecting against a number of transients and
3 accidents, and each design is different.

4 The ECCS high pressure ECCS for B&W, for example,
5 is a full pressure ECCS. It goes all the way to full
6 operating pressure and it utilizes pumps that are
7 identical to the normal makeup pumps.

8 Westinghouse's design is much different than
9 that. It does not use normal makeup pumps ^{for ECCS;} ~~and~~ it uses
10 high pressure safety injection pumps which are not capable
11 of full operating system pressure. None of them are in
12 normal service, and in fact won't operate at high pressure,
13 won't discharge anything ~~under~~ ^{at} the reactor coolant system
14 ~~pressure~~ ^{pressure} that is above their shutoff head.

15 Down through the years, the way those systems
16 ~~are~~ ^{were} integrated and their overall performance for transients
17 and accidents determined what their initiation signals
18 would be.

19 I don't remember the specific reason, but it
20 probably had something to do with the fact that ^{the} high head
21 systems on a Westinghouse design is of a lower shutoff
22 pressure than it is on a B&W design.

23 Q If ECCS actuation were only tied to pressure in
24 the reactor coolant system rather than to level in the
25 pressurizer as well, how would that pose a problem for the

1 high head injection pumps at Westinghouse plants?

2 A I don't know the answer to your question. I
3 could sit down and go through the logic. It would take me
4 sometime to do it.

5 Q In fact, if it is tied just to pressure, the
6 pressure drops to a certain point, and the ECCS comes on?

7 A Yes.

8 Q High pressure injection comes on, presumably it
9 brings the pressure back up in the primary system to the
10 point where the high head pump would no longer function?

11 A Right, yes.

12 Q It would keep it up to that certain point,
13 wouldn't it?

14 A Yes, but the logic must have had something to
15 do with protecting the reactor system from overfilling
16 and overpressurization by too much high head delivery.

17 Q Wouldn't the situation also have to do with the
18 voiding the situation of spurious or unnecessary ECCS
19 actuation?

20 A Oh, yes. I am sure that that is part of the
21 reason.

22 Q By tying ECCS actuation to two factors, level
23 and pressure, rather than just to one, you are minimizing
24 the number of unnecessary ECCS actuations?

25 A That is probably a factor.

1 Q And you are doing that as I understand it at
2 the expense of having more of a hair trigger ECCS actuation
3 system where you would be more likely to have an ECCS
4 actuation?

5 A Yes, you are probably doing it when you are
6 making that kind of argument from the traditional
7 concentration on the larger breaks rather than the
8 concentration on the possible intricacies of small breaks.

9 Q Okay. Isn't that also the situation, minimizing
10 spurious activation of the system, the rationale for
11 having containment isolation tied only to PSI in the
12 containment building?

13 A . Yes.

14 Q In other words, if you tied it to ECCS actuation
15 and high pressure injection actuation as well, you would
16 have more containment isolations occurring?

17 A Not necessarily; you would have more, but not
18 as often as your words imply.

19 For example, you might put it on receipt of the
20 engineered safety feature actuation signal rather than
21 upon initiation of the high pressure pumps, so for example,
22 simple manual actuation of high pressure safety injection
23 pumps would not necessarily isolate containment, but *an*
24 automatic call for those high pressure pumps would, so it
25 would be more frequent, yes.

1 Q Again then the tradeoff that is being made is
2 between having more spurious or unnecessary actuations of
3 containment isolation as opposed to tying containment
4 isolation to a factor which will give you fewer such
5 unnecessary actuations?

6 A That is true. Now in the case of high pressure
7 injection into the primary system, there are safety reasons
8 to want to keep the number of spurious actuations down to
9 ^{avoid putting}
~~put~~ cold water into a hot system.

10 Q Puts strain on the system?

11 A Puts strain on the system; in the case of contain-
12 ment, it is not that obvious.

13 Q But obviously it also creates a situation, for
14 example, in connection with ECCS actuation phenomenon
15 not previously concentrated on at the time that the design
16 was set up that can occur where the actuation will not
17 take place when it is most needed?

18 A That's right.

19 Q And in talking about the ECCS, we talk about
20 one of the most basic safety systems in a nuclear reactor,
21 aren't we?

22 A Yes, we are.

23 Q We mentioned containment isolation being tied
24 to 4 PSI. Are you aware that there was an estimate made
25 in connection--let me ask you, are you familiar with the

1 Pebble Springs licensing proceedings?

2 A Yes.

3 Q Are you aware that in the context of those
4 licensing proceedings there was a question raised, question
5 No. 26, that dealt with the system response to a transient
6 which involves loss of auxiliary feedwater?

7 A Question No. 26 by whom?

8 Q I believe it was by the ACRS.

9 A By Mr. Ebersole I believe?

10 Q Right. It deals with loss of auxiliary feedwater.

11 A I don't recall that specific question. I can
12 walk over here.

13 Q Can we pull that out?

14 A Yes, I think so.

15 Q The specific reason I am asking, Mr. Mattson,
16 is that I am informed that the applicant's response to
17 question No. 26 in the Pebble Springs licensing includes
18 a time scenario of the system response that indicates that
19 HPI would commence at about 10 minutes upon containment
20 pressure activation signal 4 PSI, so I assume the containment
21 isolation would occur within that timeframe.

22 At TMI 2, as you know, it took about four and a
23 half hours for containment isolation to occur on that basis.
24 The question arises then why is there such a large
25 difference between what happened at TMI and what was

1 predicted at Pebble Springs, which is a similar plant I
2 am told.

3 A I have the question here in front of me. I
4 have to admit I haven't read it in that light before. Let
5 me look at it quickly.

6 Q Sure.

7 (The witness reviewed a document.)

8 THE WITNESS: The answer is probably something
9 like the following--they did an analysis where all
10 feedwater was lost, loss of main feedwater and loss of
11 auxiliary feedwater.

12 Recall that at Three Mile, that auxiliary feed-
13 water was turned back on at 8 minutes, so part of the
14 answer is the extra 2 minutes of discharge at decay heat
15 rate in the case of the Pebble Springs reactor would have
16 given more discharge into containment, and hence higher
17 pressure. That may be sufficient to get to the 4 PSI.

18 At Three Mile, it went up a couple of pounds
19 and didn't go to 4. Another difference perhaps is that in
20 doing a calculation of this sort, the models of discharge
21 through the safety valves would have probably been
22 conservative in the sense of overestimating the discharge
23 rate from a safety valve. Both of those things would be
24 in the direction of an earlier receipt of the 4 PSI
25 containment overpressure signal.

BY MR. KANE:

1
2 Q If I can paraphrase your answer, your suspicion
3 is the consequences of a very small LOCA simply were
4 not considered in connection with this analysis for the
5 10 minute actuation?

6 A Yes, were not considered in the realistic vein
7 in which they probably should have been. One of the
8 lessons from Three Mile is that there are some accidents
9 where what is realistic and what is conservative may not
10 be what is obvious on the surface from previous
11 concentration on large break loss of coolant accidents.
12 This is one of them.

13 Q I am curious as to what has been done by NRC in
14 connection with technical fixes that may be incorporated
15 into plants around the country, or specifically into TMI.

16 Are you familiar with the analysis performed by
17 the NRC regarding the reactor system response to transients
18 like TMI 2 when the NRC is considering technical fixes
19 and do you know what computer codes are used in that regard?

20 A I believe we are using two. One is RELAP. I
21 don't know which version of RELAP; I ^{suspect} ~~suggest~~ it is from
22 ~~a suspected~~ RELAP 5, and we are using the code called the
23 TRAC, RELAP being ~~a Rancho~~ ^{an INEL T} code, and RAC being a Los
24 Alamos code.
25

1 Q Would it be possible for us to get copies of
2 those computer codes made available to our technical staff?

3 A Yes, I'm sure it is. They are available in code
4 libraries I believe.

5 Q Do you think they are available in the public
6 document room of the NRC?

7 A I will tell you the person to get them from
8 the quickest is Dr. Tom Murley, Director of ~~the~~ Reactor
9 Safety Research. They are versions of RELAP running
10 down the hall there.

11 A Has the NRC run the TMI 2 transient on a code
12 like that?

13 A Yes--not the entire transient, the initial portions
14 of it.

15 Q Who specifically did that?

16 A ~~It~~ ^{INEL and} at Los Alamos are running ~~see~~ calculations.

17 There is a document if you want to pause for a moment.

18 There is an interesting summary written by a member of my
19 staff as to all the calculations that are going off.

20 MR. KANE: Excellent. Let's go off the record
21 for a moment.

22 (A discussion was held off the record.)

23 BY MR. KANE:

24 Q This document you are referring to references
25 the results of running the TMI 2 transient on a code like

1 this?

2 A In a summary fashion, yes.

3 Q Would Dr. Tom Murley have the detailed results?

4 A Yes.

5 Q We would like to arrange if we can to obtain
6 those results for the technical staff of the Commission.
7 Is there any problem with that do you think?

8 A You may run afoul of the fact that those
9 calculations are being done for the NRC special inquiry
10 and what their status is and what have you, they are sort
11 of in an independent posture. I have specially sent you
12 to Murley because the people they are using nor^mally
13 report to him, but they are currently reporting to the
14 Rogovin people. I can't speak for what Murley can or cannot
15 do in that regard.

16 The results of the B&W calculations using CRAFT
17 are available. They have been submitted and are publicly
18 out. They are the best I have seen so far. They get it
19 to run longer and do better.

20 Q What other cases has the NRC analyzed concerning
21 perturbations to TMI 2 which may include proposed fixes?

22 A I don't know of any that we have run. I do know
23 that one of the requirements that has been placed upon the
24 four vendors is to run permutations and combinations of
25 events of the sort normally analyzed in Chapter 15 of the

1 safety analysis report, and whether the intent is to
2 include permutations ^{and} ~~X~~ combination^s of the TMI 2 sequence
3 I don't know for the small break loss of coolant accident.

4 There have been several ~~perturbations~~ ^{permutations} and
5 combinations of TMI 2 events already analyzed by Westinghouse,
6 Combustion and B&W, and it is through those analyses that
7 the operating guidelines and operating procedures for
8 small break LOCA's are being implemented in operating
9 plants today.

10 That sort of analysis, the person to talk to is
11 ^{Zoltan} ~~Col~~ Rosztoczy. He is ~~the Director~~ the Chief of the
12 Analysis Branch.

13 Q He is familiar with these other studies that
14 are being done?

15 A The ones that are being required of the vendors,
16 yes. He probably is knowledgeable of what is being run
17 by research since it is his field.

18 Q He would have those results to the extent they
19 are available?

20 A Yes.

21 Q I am curious. There are several references in
22 the lessons learned interim report that has come out,
23 ^{NUREG} ~~new reg~~ 0578, to containment isolation and certain facets
24 of that situation, but there is no estimate that I can
25 find in there of type 2 containment isolation under certain

1 circumstances.

2 Why not? Isn't that something that has come up
3 in connection with TMI 2?

4 A Yes. That is one parameter that clearly is
5 important, but it is highly variable. It depends upon
6 the kind of accident you are talking about, the kind of
7 transient with degraded auxiliary system performance.
8 It varies very much.

9 I believe where you may be headed is shouldn't
10 there be isolation on radiation, and I think that is
11 treated in the discussion there. As we said, yes, we think
12 maybe there should be, but we are not ready to require it.

13 Q I am more curious as to the calculations that
14 were related to containment under various proposed types
15 for containment isolation actuation under different types
16 of circumstances of very small break LOCA's.

17 Is that going to be done?

18 A Probably not. I think that by tying it to
19 engineered safety feature actuation, that you have clearly
20 got containment isolation before you have got difficulty
21 with the core.

22 Q As long as you also have--wait a minute. You
23 were talking about tying it to the actuation of engineered
24 safety features?

25 A Yes.

1 Q Which might or might not include high pressure
2 injection?

3 A Would include. There is a way to defeat that.
4 We were talking about ~~here~~ ^{ATWS}. It is not in the design basis
5 today, and it has historically been fought very hard to
6 keep it out of the design basis by the industry, which is
7 ATWS.

8 It may be possible to have a very damaging low
9 probability anticipated transient without SCRAM that would
10 lead to prompt failure of the primary coolant boundary
11 prior to either high pressure in the containment or
12 initiation of engineered safety features, and might be
13 able to contrive enough things to find a way that you
14 ought to use radiation.

15 Q Suppose you also have coincident logic ECCS
16 actuation? Wouldn't that mean that you won't have this
17 containment isolation occurring on the basis of activation
18 of engineered safety features?

19 A Yes, could be.

20 Q Again that is something that needs to be
21 changed and has been addressed in those I&E bulletins we
22 talked about?

23 A Yes.

24 Q You mentioned before that you are somewhat
25 familiar with the Pebble Springs licensing process. Are

1 you familiar with question No. 6 that was drafted by
2 Jesse Ebersole in connection with the Pebble Springs
3 licensing?

4 A All of those questions were drafted by Jesse
5 Ebersole. I have it in front of me.

6 Q Question No. 6 asking if the applicant knows
7 that time dependent level will occur in the pressurizer
8 steam generator and reactor vessel after a relatively
9 small primary coolant break which causes coolant to
10 approach or even partially uncover fuel pins.

11 Jesse Ebersole has already testified in the
12 deposition we have taken that this question was prompted
13 by the concerns that were communicated to him by
14 Mr. Michelson.

15 The second part of the question asks whether or
16 not, or what the operator proposes to do in light of
17 those circumstances.

18 It is my understanding that the applicant's response
19 the response by PG&E, does not really address the issue
20 of time dependent pressurizer level indication or what
21 they propose to instruct the operators to do under those
22 circumstances.

23 The question is why doesn't it address that?

24 A ^{You}~~X~~ will have to ask PG&E and the ACRS. They were
25 there, and to my knowledge, the staff performed no technical

1 review of those questions and answers.

2 Q If I asked you then what followup was done on
3 this by the NRC, would your answer be you don't know?

4 A Oh, I know--none.

5 Q Are ACRS questions that bear on an applicant
6 like this routinely routed to the Division of Safety
7 Systems at the time that they are propounded by the ACRS
8 to the applicant?

9 A Yes.

10 Q Routinely what does DSS do with those questions?

11 A Well, usually it works a little bit differently
12 than that. The ACRS' subcommittee would have a particular
13 interest in a particular plant and would convey those
14 interests to the staff and the applicant, and the staff
15 would assure that in the course of the licensing review
16 of the facility, the documentation and the answer and the
17 review of the answer and what have you was completed.

18 In this particular case, there is another
19 anomaly in the usual communications between the ACRS
20 and the staff; it seems that with the Michelson report
21 there were several anomalies. This is another one. I
22 recall these questions. They came to the attention of the
23 Division of Systems Safety very late in the review of
24 Pebble Springs.

25 Our review was done. We had issued an SER,

1 Safety Evaluation Report, and within a matter of a very
2 few days before the full ACRS meeting, the project manager
3 for the Pebble Springs facility or his branch chief, I
4 don't recall which, brought a copy of these questions to
5 my office and told me that the chairman of the Pebble
6 Springs subcommittee, Mr. Ebersole, had phrased these
7 questions.

8 I looked at them. There were a large number.
9 I didn't do a detailed review but I looked at them enough
10 to ascertain that they were well beyond the kind of
11 questions customarily asked in the course of a CP review
12 under the Standard Review Plan. That is, they go well
13 beyond the Commission's regulations.

14 In fact, if my staff were to ask me if they
15 could ask those questions, I would say no in the main.

16 Q You wouldn't feel that DSS could even raise
17 questions such as question No. 6?

18 A No. 6, maybe we could raise; No. 26 we could not--
19 failure of all feedwater is not a design question. Instead
20 we would say demonstrate the reliability of the emergency
21 feedwater is acceptable. That kind of question we could
22 raise, but the kind of questions phrased in terms of assume
23 you lose all feedwater despite what they have required
24 you to design for and tell us what the consequences are
25 is not allowable.

1 Q Why not?

2 A Because office practice is you stick to the
3 Standard Review Plan and if you want to ask questions or
4 generate requirements beyond that, you go to the ratchet
5 committee and get approval to ask those questions and
6 go beyond it.

7 Q In other words, the DSS is not free to pose
8 whatever questions in the licensing process it feels
9 relates to the legitimate safety concerns? It must stick
10 to the SRP?

11 A That is true. I won't say it quite as strongly
12 as you do because we do ask questions. We don't state
13 requirements beyond the SRP, but we do ask questions, but
14 fishing expeditions as large as one which says fail all
15 feedwater and tell me the consequences are just too big
16 a fishing expedition. The staff is not allowed to ask
17 those kinds of questions.

18 Now the question No. 6 may have been a legitimate
19 question in terms of standard operating procedure of the
20 office, but let me go back to the story.

21 A large number of questions were brought to my
22 office several days, less than a week is my recollection,
23 before the full committee meeting, with an oral request
24 as I understood it from the subcommittee chairman for the
25 staff to develop answers and come prepared to speak to
the full committee on these questions.

1 I stated that wasn't possible, that staff
2 assigned to Pebble Springs had long ago finished their
3 work. They were working on other things, that these
4 questions in the main were beyond the pail of the Standard
5 Review Plan, and that if answers were needed by the ACRS,
6 they ought to go to the plant directly and get those
7 answers.

8 That is what they did. I believe when the full
9 committee meeting was held, that my staff was present and
10 listened to the presentations. I don't know whether they
11 were asked to comment on the answers that were given. I
12 suspect to some extent they were, and when the committee,
13 the ACRS wrote its letter approving the construction
14 permit application for Pebble Springs, I am quite certain
15 that the assumption was that the committee was satisfied
16 with the answers they received.

17 Q Have you had an opportunity to read the answer
18 to question No. 6 provided by the applicant?

19 A When NUREG 0560 was published and ^{it was} contained
20 in there, yes.

21 Q In reading it over, did you find any portion
22 of that answer that responds to the question about what
23 they proposed to instruct the operator to do under these
24 situations where they have a time dependent level in the
25 pressurizer?

A I had earlier noted the same deficiency you have
Acme Reporting Company

1 noted.

2 Q There was no response?

3 A Recognize that this is a construction permit
4 application, and their answer may have been well, we have
5 got plenty of time to do that before we go into operation.

6 Q They didn't give that response, did they?

7 A They did not. They may have under oral
8 questioning at the committee meeting.

9 Q We don't know. You don't know.

10 A There is a transcript. I haven't read it.

11 Q Okay, but apart from that possibility, it appears
12 there was no response to this question.

13 Who is responsible to follow up to make sure
14 that an applicant responds adequately to ACRS questions,
15 on a pending license application?

16 A The ACRS.

17 Q Does the NRC have any role to play in that
18 regard?

19 A When they ask us to, yes.

20 Q When they ask you to?

21 A Yes. Usually early on they would pose areas of
22 interest in the course of their review, and we would usually
23 agree with those. I don't know of examples where we
24 disagree, and so we would be following up on the same kind
25 of things they are following up on, but for something

1 anomalous like that, this set of questions propounded late
2 in the review, the circumstances I described were the ones
3 that were followed.

4 Q Doesn't the project manager for a given project
5 have the overall responsibility to assure that the
6 issuance of a CP or an OL for a project is justified
7 based on compliance with all safety requirements and other
8 concerns raised during the licensing process?

9 A Safety requirements, yes; concerns, no.

10 Q Safety concerns?

11 A Safety concerns of the NRC staff, yes.

12 Q How about safety concerns of the ACRS?

13 A . To the extent that the ACRS needs the staff to
14 follow up for them, I'm sure we do.

15 Q If the ACRS poses a safety concern in a question
16 to an applicant--

17 A And does not get an adequate answer, the ACRS
18 has never been timid about saying so.

19 Q That isn't what my question was. My question was
20 if the ACRS has propounded a safety related question to
21 an applicant, it gets no response, the project manager is
22 made aware of that situation, is the project manager
23 entitled to sign off on an OL or CP for that applicant under
24 those circumstances?

25 A I would suspect it has happened yes.

1 If it is a concern raised by the ACRS in their letter,
2 that is a different breed of cat. Recognize that the ACRS
3 is 10 or 15 fellows, all of them with different interests,
4 not all of them alike, and questions raised by one are
5 not ^{necessarily} supported by the majority, so it is the role of the
6 project manager to see that the ACRS concerns are addressed.

7 When an individual member of the ACRS speaks or
8 writes or raises issues, I think that that is stretching
9 the role of the project manager a little bit.

10 Q These were 26 questions propounded by the ACRS,
11 weren't they?

12 A No.

13 Q Oh. Now I wasn't aware of that. These 26
14 questions were not propounded by the ACRS in connection
15 with the Pebble Springs licensing process?

16 A No. They were Jesse Ebersole's questions, ^{but}
17 ~~recognizing~~ ^{recognize} that he was chairman of the subcommittee of
18 the ACRS on Pebble Springs, so he had special stature
19 in this review.

20 Q Were these questions posed to the applicant on
21 behalf of the ACRS?

22 A I don't know the form of the transmittal letter
23 or who signed it. I am sure the applicant thought of them
24 as ACRS questions.

25 Q Did the NRC think of them as ACRS questions?

1 You seem to be trying to lay it on to Jesse Ebersole.

2 A I am not trying to lay it off on Jesse Ebersole,
3 so you misunderstand what I am saying. The ACRS is a
4 collegial body. It does not usually propound questions of
5 an applicant.

6 Q But in this case it did?

7 A They hold meetings and individual members ask
8 questions.

9 Q In this case they did?

10 A They reach collegial conclusions, and they write
11 them as a collegial body. This is an anomalous situation.
12 the chairman of the subcommittee very late in the review
13 comes forward with a large number of questions. I suspect
14 he did it as chairman of the subcommittee. They were
15 communicated to the licensee, the licensee applicant, and
16 he responded.

17 The staff did not, to my knowledge, offer a filing
18 as to whether the answers were acceptable or unacceptable.

19 Q You say offer a filing?

20 A Yes--did not state a position, did not offer
21 a judgment on whether the answers supplied by the applicant
22 to these questions were acceptable.

23 The reason for that is fairly simple. Most of
24 the questions went beyond the Commission's regulations.

25 Q And yet the staff is called upon ultimately, the

1 head of the staff is called upon ultimately to issue the
2 CP or OL, the licensing for which or in the context of
3 which these questions are being raised, is that right?

4 A That's right.

5 Q And if I understand from a rather lengthy session
6 I had with Harry^l Silver, the entire focus of the
7 licensing process is safety, is it not?

8 A Yes, whether the filing and the documentation
9 and the analysis conform with the Commission's regulations.

10 Q Which may or may not be the same thing as focus
11 on safety?

12 A Let me take an extreme example, to try to
13 illustrate the point.

14 If somebody comes to the FAA and says tomorrow
15 that an earthquake at O'Hare Airport of the magnitude of
16 12 on the Richter scale would kill everybody on the runway,
17 no matter what airplane they were in, and they didn't
18 have time to get off the ground, would you expect the
19 director of the FAA to close O'Hare Airport tomorrow? I
20 think he would say no, that is beyond the realm of our
21 requirements. If we should consider that, we ought to do
22 it thoughtfully and we will go back and research the risk
23 from that sort of thing and the cost benefit and all those
24 other things, and we can decide whether our regulations
25 ought to reach that event.

1 That is an extreme event I think, an absurd one,
2 but between here and there is lots of gray matter.

3 Q Let's see if we can explore the gray matter a
4 little. Let's say the situation is such that an application
5 is being submitted for permission to construct O'Hare
6 Airport, hasn't been done yet, and in the context of that
7 application, questions are raised such as you just mentioned.
8 Should the licensing, the permission to proceed with the
9 construction of the airport go forward and the construction
10 actually begin while that other question is still pending
11 and is unresolved in connection with this specific project?

12 A Yes, but these questions could be asked of any
13 plant ever reviewed.

14 Q Was your answer yes or what?

15 A I am not going to answer your question.

16 Q I won't press you on that one, Mr. Mattson, but
17 it is analagous to the situation with a project coming
18 up for CP approval. Nothing has even been done yet as I
19 understand of breaking ground, and they are asking
20 permission to construct a plant, and the ACRS poses a
21 safety-related question. No response is given to that
22 portion of that question, and nobody follows up.

23 I guess what I am trying to get into is shouldn't
24 it be the responsibility of the project manager or someone
25 within the NRC to follow up on this?

1 A If it were to be that responsibility, then the
2 Commission would have to say as a matter of policy that
3 it ~~was~~^{was} because the Commission fairly clearly in my
4 judgment says to the staff ["]implement our regulations." Don't
5 go beyond them. The entire focus of licensing review, the
6 time I have been in it; in the last two and a half years,
7 has been stick to the Standard Review Plan, the existing
8 regulatory guide^s and the existing regulations.

9 If you want to go beyond them, take them to the
10 Regulatory Requirements Review Committee and do ~~them~~^{that}
11 divorced from individual licensing proceedings.

12 Q I see. If ACRS asks a question that goes beyond
13 them, and gets no response, it is not the business of the
14 NRC?

15 A I don't know what you mean by not the business.

16 Q Not the responsibility.

17 A No, no on that case.

18 Q Not your responsibility, okay.

19 A The ACRS would say as a collegial body having
20 reviewed the information supplied in response to these
21 questions, we are not satisfied with the response to
22 question No. 6. We, the ACRS, advise the Commission as to
23 something you ought to consider, eventhough it is beyond
24 your regulations, and get a satisfactory answer to it, and
25 we want to review it or are willing to trust it to the staff

1 to conduct the review and reach the proper judgment
2 which they take either of those alternatives, depending
3 upon the instance, and they do it on every letter. Then
4 the staff would follow it.

5 Q How often does the ACRS meet?

6 A Once a month.

7 Q For how long?

8 A Three days.

9 Q Three days once a month, I see; we have already
10 taken Mr. Ebersole's deposition and asked him why this
11 response to question No. 6 was not followed up. What he
12 explained to us was that about the time the question was
13 propounded, he had a number of personal problems in his
14 family and he was paying very little attention to ACRS
15 work as a result, and therefore he did not personally push
16 it, that the general situation within the ACRS is something
17 along the lines you described before. Everybody has their
18 own interests.

19 This was a strong interest of his, and not of
20 some of the other members of the ACRS, and therefore as a
21 body, the issue was not pushed because he was not there
22 individually to push it.

23 Given that situation, given the fact that ACRS
24 meets as seldom as it does, once a month for three days or
25 so, doesn't it make more sense for the agency that has

1 day-to-day responsibility for licensing and supervision
2 of the operating of reactors and the licensing of reactors
3 in the country to have responsibility to follow up on
4 ACRS questions to be sure that some adequate response is
5 provided?

6 A Yes.

7 Q Okay.

8 A Even if the answer is, it is our judgment that
9 this is not important, that it goes beyond the regulations,
10 we don't intend to follow it through to a conclusion,
11 it ought to at least be formally stated that that is the
12 case, and I go back to what I said at the start of this
13 series of questions.

14 I don't believe the staff formally said anything
15 about these questions or the response offered to them.

16 Q As far as we can tell, as far as I know, this
17 particular concern just kind of dropped into the cracks
18 somewhere.

19 A Yes. There probably is no record of whether the
20 staff thought some of these were good, bad, or indifferent
21 responses.

22 Q Okay. We have been talking about this review
23 of designs relating to plants.

24 Does your organization in any way review designs
25 of systems that are not safety related on the secondary side

1 of the plant or the balance of plant type of thing?

2 A Some, and the scope of the word safety related
3 has been slowly increasing over the years.

4 Q Mind you I am focusing on pre-TMI 2 learning in
5 that regard.

6 A We have been getting into control systems to a
7 greater degree in the new designs than we did in the old
8 designs, and ^{another} a good example is the emergency feedwater
9 system.

10 In the early designs, it is not safety related.
11 ^{In} The Standard Review Plan^f, it is safety grade. In certain
12 cases, we have gotten more and more into what the word
13 safety grade means for the emergency feedwater system.

14 Q The auxiliary feedwater system?

15 A Yes.

16 Q How long has the auxiliary feedwater system been
17 considered a safety related system?

18 A Now there are two terms we are using inter-
19 changeably here, and I am not sure they are. Safety related
20 and safety grade--safety related I suspect "aux" feedwater
21 has been treated in that sense since the beginning. Safety
22 grade requirements were not imposed, to my understanding,
23 until the Standard Review Plan was issued.

24 Q Okay. Does your office on a regular basis look
25 for interactions between safety related systems or components

1 and non-safety related systems or components?

2 A Some.

3 Q When you say some, what do you mean?

4 A ^{The} Control system is not safety grade, and there is
5 a requirement in the Standard Review Plan that interactions
6 that could degrade or defeat safety systems not be allowed
7 in the design of the control system. That is one example.

8 I can think of one specific example that is
9 probably indicative of some thinking that has gone on in
10 the last several years, as we get into the system interaction
11 thing and that is the example I used several hours ago
12 which was the air conditioning system for assuring that the
13 environmental qualifications of instrumentation or controls
14 ^{that} were necessary for ancilliary equipment, for safety equipment,
15 couldn't go on the fritz and defeat safety systems when
16 you needed them.

17 Q Is there any requirement in your office or
18 anywhere within the NRC that there be notification of
19 licensee changes to non-safety related hardware or
20 procedures?

21 A Requirements are generally stated that the
22 licensee must conduct a review and make a finding that
23 his change is not an unreviewed safety question, and ~~the~~
24 ~~was~~ there are procedures that he is required to follow
25 and document, and if he reaches a decision that it is not ^{an}

1 unreviewed safety questions, his files have to say so.
2 He doesn't have to tell us.

3 Q Would those files be subject to any NRC review?

4 A It is my understanding that they are audited by
5 the Office of Inspection and Enforcement.

6 Q What they do is they look over these files to be
7 sure some justification has been inserted therein by the
8 licensee for the change?

9 A I suspect it is more than that, that they spotcheck
10 to see whether they make any sense.

11 Q It is just a spotcheck?

12 A Yes.

13 Q If DDS, for example, is not regularly informed
14 of those kinds of changes, how can the NRC in this way
15 evaluate the effects of those changes in the non-safety
16 related system upon safety-related systems?

17 A Well, DSS would not be routinely informed in any
18 event because we don't have the direct responsibility for
19 operating plants, but your question is equally germane for
20 the Division of Operating Reactors, and the answer is that
21 the system of regulation depends upon the judgment of the
22 licensee.

23 Q That continues to be the situation today, does
24 it not?

25 A Of course, ^{and with} the size of the agency that you

1 have in front of you that you are investigating, that
2 will continue to be the case. There is no human way
3 possible to do it any differently with the people and
4 resources assigned to licensing.

5 Q I want to ask you about that resources question
6 because it has come up at several points that I&E, for
7 example, does not have any I&E inspectors who are walking
8 around looking for work to do. They have an awful lot
9 of requirements they have to meet and a lot of things
10 they have to check out in their plant inspections.

11 I have gotten the impression throughout the NRC
12 that most people have got plenty to do in their jobs, and
12 certainly it is not a situation of sitting around thinking
14 of how they might dream up safety questions that don't
15 come across their desk in some fashion or have some
16 recommendations to relate.

17 However, in deposing Harvey Silver, the project
18 manager for TMI 2, he pointed out the applicants have not
19 been required in the past in the licensing process to
20 submit any history of failure on even safety related
21 equipment, a history of the device, how it has performed,
22 the operating experience, and that the NRC in effect is
23 left to learn of that itself through through LER program,
24 I&E inspections, et cetera.

25 Why do it that way? Why not put the burden on

1 the applicant to give you that information.

2 A Ask the Commission. They have had a proposal
3 in front of them for some years.

4 Q Do you know if any action has been taken on
5 that proposal?

6 A Meetings.

7 Q But nothing to implement it?

8 A No.

9 Q What is the objection to that proposal?

10 A Burdensome.

11 Q That it is a burden on the industry you mean?

12 A Yes.

13 Q Again, when talking about burden, we are talking
14 about cost, aren't we?

15 A Yes.

16 Q So far the determination has been made to leave
17 that burden with the NRC?

18 A Yes.

19 Q Is there any reason to think the NRC is in a
20 better position than the industry to develop that kind of
21 information and provide it?

22 A If the NRC does ^{it,} there will be less of it.

23 Q Because the NRC doesn't have the manpower and
24 resources to do as thorough a job as the industry could?

25 A That is why I state the conclusion I state, yes.

1 Q Okay. Your lessons learned report, NUREG 0578
2 has some interesting points. Item 2.1.1 on page 6 says,
3 "Safety systems are called upon to work more often than
4 previously expected."

5 Had anyone in the NRC prior to TMI 2 been
6 responsible for tracking reactor operation experience in
7 that or similar areas to see if the assumptions used in
8 writing the regulations were valid based on operating
9 experience?

10 A Not to my knowledge.

11 Q That would be to the extent it is a function at
12 all, a function of I&E I guess?

13 A . No. We had started down that road curiously
14 with high pressure safety injection systems and auxiliary
15 feedwater systems in this division, and had discovered
16 that the people in the probabilistic assessment[^] staff in
17 the Office of Research had also started down that road.

18 We had contracts ourselves that were going to
19 start this fiscal year, and I believe ~~there~~^{they} are already
20 going, ~~the~~^{the} idea was to obtain failure rate data for
21 these kinds of systems for real plants.

22 Q Do you know how far that has gone?

23 A I don't know its current status.

24 Q That was a program within I&E?

25 A No, no--research.

1 Q Let me ask you a broader question. We have been
2 talking about the PORV.

3 A It is a very important question, something that
4 ~~is~~ needed to have been done. It doesn't appear to me that
5 you would have gained that much from it by starting years
6 ago. It might have been better to start at a year ago or
7 two years ago, but the body of data to be synthesized and
8 put together is only now beginning to generate sufficient
9 quantity statistically to be useful, in my judgment.

10 MR. KANE: Let's go off the record a moment.

11 (A discussion was held off the record, and the
12 deposition was recessed at 1:10 p.m., to reconvene at
13 1:40 p.m. the same day.)
14
15
16
17
18
19
20
21
22
23
24
25

AFTERNOON SESSION1:50 p.m.

MR. KANE: On the record.

Whereupon,

ROGER J. MATTSON

having been previously duly sworn, testified further
as follows:

DIRECT EXAMINATION (Resumed)

BY MR. KANE:

Q Mr. Mattson, we have been discussing off the record for just a few moments here Section 15.6.1, of the Standard Review Plan which is entitled, "Inadvertent Opening of a PWR Pressurizer Safety/Relief Valve."

Is this the section of the Standard Review Plan that prescribes the review to be given during the licensing process to a PORV and its use in a pressurized water reactor?

A Yes

Q I note that this procedure is some five pages long, and it appears to call for some fairly detailed analysis and testing of the PORV.

Is this section followed as a regular practice in licensing plants that have PORV's?

A Yes.

Q I don't find anything in here, however, which talks about the situation of a PORV sticking open under

1 circumstances where there is a loss of all feedwater.

2 A That's right.

3 Q Why isn't that situation considered?

4 A Well, it is a compounding of events. Perhaps
5 the more germane thing would be to ~~let's~~ understand
6 first the two events that are analyzed.

7 The loss of feedwater is analyzed as an
8 anticipated operational occurrence, and the cladding is
9 required to maintain its integrity for such an occurrence.

10 In that event, in the analysis of that event,
11 the PORV is assumed to not open as it is designed to open
12 because that conservatively bounds the pressure peak that
13 occurs during that transient for loss of feedwater, and the
14 analysis has never been done, never been required to be done, ^{different}
15 I don't know if it has ever been done where the PORV
16 opens as intended and it sticks open. ^{Rather, the} ~~it is a~~ failure
17 that ~~has been~~ ^{is} postulated, ^{is} the failure to open.

18 The other accident that is analyzed is the
19 inadvertent opening of a relief or safety valve. I don't
20 know specifically, but I wouldn't be surprised to learn that
21 the valve that is opened in the case of the B&W machine
22 is the safety ^{valve} because it is larger than the PORV and
23 probably yields more severe thermal hydraulic consequences
24 in the reactor.

25 Those are the two that have been treated. They

1 have not been compounded. Obviously you could take the
2 30 events that are in Chapter 15 of the safety analysis
3 report and add various combinations of them and create new
4 design basis events.

5 The design basis events grew up over the years
6 as a statement of an acceptable set of events for the
7 design analysis and they have been subject to some
8 probabilistic assessment as probability techniques have
9 matured over the past few years, and there has been ^a general
A feeling for a couple of years that we ought to reclassify
10 some events, perhaps moving some of them out of the
11 moderate frequency category because operating history
12 shows that they don't happen that often, and perhaps move
13 some others into the moderate frequency category.

14 TMI 2 tells us that we ought to create a new
15 event, that is, a combination of loss of feedwater plus
16 a stuck open valve, as ^{an} anticipated event or accident. I
A don't think we know yet. We didn't do them in the past.

17 Q Who verifies that this section has been complied
18 with by the licensee?

19 A Reactor Systems Branch.

20 Q I see. How do you go about that?

21 A The licensee is required to submit in the safety
22 analysis report information concerning the inadvertent
23 opening of the PWR pressurizer safety relief valve, and to
24
25

1 show through analysis that the acceptance criteria are met
2 using codes, analysis codes, techniques that have been
3 reviewed and found acceptable by the staff.

4 Q Do any of the analyses that are discussed in
5 connection with this section relate to actuation of ECCS?
6 Do they contemplate that?

7 A Well, yes, I'm sure they do.

8 Q Because I do also make note of the fact that
9 in Part 3, under review procedures, page 15.6.1-3, there
10 is the statement, "The sequence of events from initiation
11 until stabilized condition is reached is reviewed to
12 ascertain..." then there are a number of things listed.

13 One of them is the extent to which operator
14 actions are required. Another is the operation of engineered
15 safety system that is required.

16 A Yes.

17 Q Again, if I understand it correctly, however,
18 the circumstances of a small break LOCA resulting from a
19 PORV sticking open are not analyzed in connection with
20 operator action or ECCS actuation, is that right?

21 A Not quite; what this says is that you review
22 the analysis. You determine how much the engineered safety
23 system is required, that is, accounting for single failures
24 and the like, that you have still got adequate ECCS
25 capability, and you look at the extent to which operator

1 actions are required; if action is required within the
2 first 10 minutes, you would generally not allow it. You
3 require the design to accomplish its function without
4 taking credit for operator action for 10 minutes.

5 You wouldn't look at the question of are the
6 procedures and is the training and those things associated
7 with operator action adequate. That is the omission that
8 you will find systematically throughout here.

9 Q There wouldn't be any concern then or any
10 consideration in connection with this portion of the SRP
11 of operator training to avoid going solid, for example?

12 A Not in this section, no.

13 Q Did TMI2 submit an analysis in connection with
14 this section of the SRP?

15 A I'm sure they did. Well, I shouldn't speak so
16 quickly. The stuck open valve has been a requirement for
17 sometime. How far back exactly it goes I guess I can't
18 say. ^{With a little} Research can find out.

19 I suspect that they did analyze it, but notice
20 acceptance criterion 1A, consequences of the transient are
21 less severe than consequences of another transient that
22 results in a decrease of reactor coolant inventory and has
23 the same anticipated frequency classification.

24 It is possible that they were able to show by
25 qualitative reasoning that this particular accident was

1 less severe than another one analyzed in Chapter 13 of
2 their SER, in which case they may not have done it in
3 detail.

4 Q The bounding calculations approach?

5 A That is true.

6 Q As we know from Michelson's report, under the
7 circumstances of a very small break LOCA, that reasoning
8 may not be valid.

9 A If you would like to pause a minute, I have got
10 a copy of Three Mile Island's SER back there on the table.
11 We could look.

12 The supplement I have here doesn't have it.

13 Q We were talking before about the application of
14 the Standard Review Plan to TMI 2. I got the impression
15 from the overall conversation that TMI 2 was not required
16 to comply with the provisions of this Standard Review Plan.

17 A That is right.

18 Q So insofar as these are requirements under the
19 Standard Review Plant, isn't it conceivable they were not
20 applied to TMI 2 at all?

21 A It is conceivable, but the list of required
22 transients and accidents to be analyzed in Chapter 13 of
23 the safety analysis report has been a pretty consistent
24 list down through the years, and was previously required
25 under a regulatory guide that didn't speak to the

1 acceptance criteria, and the methods of review.

2 It just required that such an event be analyzed.
3 I think this is one that goes back well before the
4 Standard Review Plan.

5 Q Were there any problems with TMI 2's submission
6 of the analysis called for by this section of the Standard
7 Review Plan?

8 A I wasn't in this office when TMI was reviewed.

9 Q You are not aware as of today that there were
10 any such problems?

11 A No.

12 Q Do you think it was probably in a supplement,
13 however, to the SAR--I'm sorry, the SE?

14 A No. I just looked in the SER and I didn't find
15 it in the SER, so it must be in a supplement if it is there.

16 Q Why would it come about that it would be in a
17 supplement and be brought up later on in the process?

18 A Often the staff will issue an SER that has open
19 items in it to be filled in at a later date, and the SER
20 is taken to the ACRS for its review, and supplement 1 to
21 the SER is usually the response to the ACRS review, and
22 subsequent supplements address the open issued as they
23 are closed.

24 Q I see. In your lessons learned task force short-
25 term recommendations, of course, you do have a whole

1 section on performance testing for PORV's, and that sounds
2 like a recommendation that should be called for on the
3 basis of what happened at TMI 2, but as I am sure you are
4 aware, one of our concerns is why the situation was the
5 way it was prior to March 28, 1979, so I would like you to
6 if you can tell us what was wrong with the NRC system of
7 review that it didn't recognize the large number of PORV
8 failures that had occurred prior to TMI 2 and resulted
9 in a similar recommendation of what is being made now.

10 A Well, there weren't a large number of failures.
11 There were three.

12 Q You made reference to the fact that on the basis
13 of frequency, PORV's sticking open was not an uncommon
14 occurrence.

15 A Three times it stuck open out of 150 roughly
16 that it was called upon to function, so it is a failure
17 frequency of 1 in 50.

18 I am not sure that anyone had evaluated operating
19 experience to the extent of characterizing the failure
20 frequency of PORV's, that is, the failure to close, prior
21 to TMI.

22 If they had, they certainly hadn't communicated
23 it in the kind of terms that it was communicated after
24 Three Mile Island, that is, one in 50 ^{was} ~~has~~ the likelihood
25 of a small break loss of coolant accident, which is certainly

1 a higher probability than ^{the} previously understood ~~the~~ probability
2 of ^a small break loss of coolant accident, that is the kind
3 of probability estimated in the reactor safety study which
4 are in the 10 to the minus third to 10 to the minus fourth
5 per year range, so the failure of regulation there I guess
6 is to one, analyze the failure frequency of such components,
7 and two, to understand that failure frequency in the
8 context of the overall regulatory basis as the basic
9 assumptions about failure frequencies like a loss of
10 coolant accident.

11 Q If I understand the situation correctly, prior
12 to March 28, 1979, the NRC did not have any formal program
13 for compiling the operating history of such devices as,
14 for example, the PORV in terms of LER's having been
15 submitted in the past, and that data then being used to
16 try and track the performance history of these devices?

17 A People were making progress in that area. Over
18 the last several years there has been more and more
19 attention being paid to LER's and many alternative methods
20 of analyzing operating history have been suggested, and
21 several of them were under trial use.

22 I spoke earlier today about the research and DSS
23 joint interest in researching operating experience for
24 ECCS, and auxiliary feedwater systems. Those are typical
25 of growing recognition of the need to make better use of

1 operating data.

2 There was a program in the--off the record a
3 minute.

4 (A discussion was held off the record.)

5 THE WITNESS: Back on the record. There was a
6 program in MPA for accounting of the operating experience
7 and some trending analysis. That was more of a straight
8 bookkeeping rather than an engineering evaluation of
9 operating experience, and those things, I think there were
10 several yearly reports of that sort issued in the last
11 couple of years, but again, a general recognition that that
12 was not adequate.

13 ACRS ~~formed~~^a ~~the~~ subcommittee on LER's, ~~that~~
14 ~~we~~ people were generally reasoning together to find a better
15 way to evaluate operating experience.

16 Q Are you aware of any recommendations for
17 upgrading or qualifying PORV's prior to March 28, 1979?

18 A Yes.

19 Q What efforts are you aware of in that regard?

20 A Yes.

21 Q What efforts are you aware of in that regard?

22 A In connection with ATWS that we talked about
23 earlier, the staff of the Reactor Systems Branch, and in
24 fact NUREG 0460, the latest report on ~~ATWS~~^{ATWS}, that we
25 issued here in DSS last spring or last winter, spoke to

1 the need to do qualification testing of PORV's for slug
2 flow, ^{that is two} ~~and to~~ phase ~~flow~~ flow, and solid water discharge ^{from}
3 ~~on~~ PORV's.

4 Q Was anything done on the basis of that
5 recommendation?

6 A The Office of Research was surveying and has
7 completed a survey of the facilities in the world for
8 conducting such tests. I believe there are facilities
9 under construction in Germany, France and Japan. There is
10 no such facility in the United States.

11 Q Is it anticipated that those recommendations will
12 be implemented at those facilities?

13 A No. These are facilities to conduct the tests.
14 These facilities are capable of generating a enough steam
15 at high enough pressure to conduct such tests of valves.
16 You don't conduct the test on the reactor. You take the
17 valve and put it on a conventional boiler and blow down
18 steam and water through the valve.

19 Q Was there any other activity in that regard
20 concerning recommendations to upgrade qualified PORV's
21 prior to March 28, 1979 besides ATWS?

22 A Probably. The one I would be aware of in a
23 larger context is a general program for pump and valve
24 operability standards, which was to be a three-party
25 arrangement between the ASME, the NRC, and the industry, pump

1 and valve operability standards have been developed over
2 the course of the last few years and are about to be
3 issued by the American National Standards Institute.

4 There has been some concern about how they ought
5 to be phased in their implementation to allow for the
6 development of test facilities because some of these valves
7 and some of their flow conditions are unique and large, and
8 the full test capabilities do not exist in this country
9 just as in the instance here of safeties and PORV's, but
10 the problem is generally much bigger than safeties and
11 PORV's, and I am sure they were discussed in that context.

12 Q Okay. Are you familiar with regulatory guide
13 1.33? It concerns keeping as is blueprints current at
14 nuclear power facilities.

15 A I am aware there is such a regulatory guide.

16 Q Did Metropolitan Edison agree to comply with that
17 guide as a condition for the issuance of its CP or its OL?

18 A I don't know.

19 Q Is there any way we could find that out?

20 A That might be in the SER.

21 (The witness reviewed a document.)

22 THE WITNESS: They are required to state it in
23 I believe Chapter 1 of their SAR and Chapter 1 of our SER,
24 I don't find any statement.
25

BY MR. KPNE:

1
2 Q Is that something that the licensee is required
3 to agree to as a condition of the issuance of a CP or OL?

4 A You mean to agree with it, to meet the regulatory
5 guide?

6 Q Yes, in terms of keeping blueprints current.

7 A Well, this depends upon the age of the plant.
8 Each regulatory guide has an implementation section in it,
9 and that implementation tells you to which plant it is to
10 be backfit, if it is to be backfit at all, and I don't
11 recall whether this was one. The number you say was 1.33,
12 right?

13 Q Yes. I think it is 1.33.

14 A ^{Revision}
~~Reg 1~~ wasn't issued until January 1 of 1977, and
15 the copy doesn't tell me when ^{revision} ~~the reg~~ zero was ^{issued.} ~~initiated.~~
16 Let me read here just a second. It appears not. It
17 appears that that was only applied to people who docketed
18 OL applications after September 1, 1977.

19 Q Only for OL applications docketed after that time?

20 A Yes. That is what it says, but that is ^{rev.} ~~reg~~ 1,
21 and it doesn't indicate how ^{rev.} ~~reg~~ zero might have been
22 applied. It may have had a reach that was earlier than
23 that.

24 Q Again, what would be the thinking behind not
25 applying a requirement like this for upcoming OL applications?

1 A This was OL applications, OL applications docketed
2 after September 1, '77.

3 Q Right. What I meant was not OL applications, but
4 I guess OL issuances coming up, what would be the rationale
5 behind not requiring this kind of thing, the obligation
6 to keep blueprints on the plant, as is blueprints. in
7 current condition?

8 A Well, the rationale in this particular case
9 probably had something to do with the difficulty of
10 generating those drawings after they were used as opposed
11 to keeping copies of those drawings as they were used for
12 future plants. In other words, for the older plants once
13 you used them and stored them or destroyed them or whatever
14 you did with them, it would be harder to go back and
15 regenerate them than in the case where you knew in advance
16 you were going to have to save them and keep them at the
17 plant. You could plan a document storage facility and
18 retrievability and that kind of thing. I suspect that was
19 the kind of thinking.

20 In hindsight, having seen the utility of such
21 documents at Three Mile Island, and having lived through
22 not having them available when they were needed, we said,
23 lessons learned has said that they ought to be available
24 ^{the} at site.
 _h

25 Q Prior to March 28, 1979, wasn't it perceived that

1 having those kinds of documents in that kind of condition
2 could be very necessary under certain circumstances?

3 A If people had thought very hard about what would
4 be needed in the event of a major accident in a nuclear
5 facility, then they would have had such thoughts.

6 Q I guess what you mean is that people didn't
7 think that hard about it?

8 A People didn't believe it.

9 Q All right. There appears to be a total lack in
10 what I understand of the licensing process, a total lack
11 of involvement by either the Environmental Protection
12 Agency or HEW particularly in the areas of worker
13 protection and public health and welfare standards to be
14 implemented.

15 One of the commissioners on the Presidential
16 Commission is very interested in that area, and he really
17 would like to know why the NRC does not more fully utilize
18 the resources that could be available to them from the
19 Environmental Protection Agency and HEW.

20 A HEW has no, well, let me think a minute. EPA,
21 let's start where there has been a lot of involvement, EPA,
22 of course, is in charge under its federal regulatory
23 council authorities, that it inherited when it was formed,
24 for worker protection standards; occupational health
25 standards are set by the Environmental Protection Agency, not

1 by NRC, and they have had an occupational health standard
2 group working down through the years to revise the current
3 standards.

4 EPA is also very much involved in the as low as
5 practicable routine emission work, and pursuant to 10 CFR,
6 Part 50 of our regulation, they were involved in review
7 and comment on that.

8 Subsequently they put out their own regulation,
9 40 CFR 190, which is the 25 millirem per year per individual
10 from all sources in the nuclear fuelcycle which is the
11 overriding federal standard on routine emissions from a
12 nuclear plant, so their involvement in the area of normal
13 emissions has been very important, a big role.

14 In accidents, their role has been in the
15 emergency preparedness area, and in being the lead agency
16 for setting or issuing emergency preparedness guidelines,
17 protective action criteria, general form and content of
18 emergency procedure criteria for state governments and
19 what have you.

20 ^{It is}
Now under an interagency group that I can't say
21 the name of, I am not working in that field today, but EPA
22 I think has been a leader in the emergency protective action
23 guideline field down through the years.

24 I think it is unfair to say they haven't been
involved or ^{that the work} is devoid of their involvement. Bill Rowe
25

1 was a major actor in this arena down through the years.

2 Q What role does EPA play in the plant-by-plant
3 licensing process?

4 A None. They have no legislative mandate for such
5 a role. They are a standard setting organization under
6 their FRC authority, and the general environmental criteria
7 kind of authority.

8 Q There is an EIS which is prepared usually on a
9 nuclear power plant project, isn't there?

10 A That is a NEPA environmental impact statement.
11 That has some summary kind of information on the safety of
12 the plant, but it has, really in terms of the accident
13 impact made in the past, very high reliance on reactor
14 safety study kind of thinking, and concentrated in its
15 environmental effects on routine emissions, radioactive
16 emissions.

17 MR. KANE: Off the record a minute.

18 (A discussion was held off the record.)

19 BY MR. KANE:

20 Q While off the record, you mentioned the involve-
21 ment of EPA in water quality standards.

22 A The non-radioactive aspects of water--thermal
23 heat, chemicals and other pollutants governed by the
24 Water Control Act.

25 Q What about HEW? Do they have any involvement in

1 the plant-by-plant licensing process?

2 A No involvement there, and very little in the past
3 in the standards area. NIH was becoming interested under
4 some prodding over the last couple of years in the
5 epidemiological aspects of radiation standard setting,
6 and of course, in the last year, President Carter has had
7 a thorough-going interagency study of radiation standards
8 and HEW has aspired to a leadership role in that work.

9 What the conclusions of that have been I don't
10 know. Its conclusions were coming due about the same~~time~~
11 as Three Mile Island happened.

12 Q I see. The reason I asked is that I am curious
13 as to whether or not it wouldn't be an appropriate forum
14 within the licensing process for CP or OL issuance to have
15 a situation whereby HEW's concerns about worker protection
16 or public health could be raised and analyzed in the context
17 of a specific plant.

18 A Well, that would say that you are going to abandon
19 uniform standards for workers across the country and go
20 in and set individual standards in individual plants.

21 You can certainly do it that way. It would be
22 very inefficient and I don't know why you would want to
23 do it. I think you would be on a better basis, a health
24 impact basis if you have acceptable standards and require
25 every plant to be designed to meet that standard, and that

1 is the case today. The role for HEW that I see, and I
2 think there is a very strong, positive role they can play,
3 I think it is about time that that element of government
4 was brought into this question to integrate radiation
5 health effects with other health effects.

6 EPA seems to have been singularly incapable of
7 accomplishing that, and perhaps HEW can do that, and I
8 think that is a very important role that needs to be
9 served, but I would concentrate on the standard setting area
10 and leave the case-by-case review of design measures to
11 meet those standards up to one agency.

12 Q All right. What sort of retraining--

13 A For one thing. every time you set a standard in
14 the occupational health area, you have to ask yourself
15 what does it do to the offsite risk, and every time you
16 take a step for offsite risk reduction, you have to ask
17 what does it do for onsite risk increase. so a good example
18 is if you are worried about failure probability of pressure
19 vessels, that it might be too high, one thing you might
20 do is more in-service inspection ^{of} ~~for~~ pressure vessels to
21 decrease the risk to people offsite of unacceptable
22 consequences from pressure vessel failure.

23 When you do that, you very dramatically increase
24 the risk of the worker who has to do that, do the in-
25 service inspection of the pressure vessel. You have got

1 that tradeoff. That really has to be done by a person
2 who understands both sides of the question, and it is hard
3 to bring another agency into a particular case and say
4 review the worker protection unless you also give them a
5 full picture about the public protection question.

6 Q I see. You would have to integrate all of that
7 then?

8 A Yes.

9 Q That kind of effort has not been followed up to
10 this time by the NRC?

11 A Oh, sure.

12 Q In the licensing process?

13 A Of course.

14 Q I thought the point that you were making was
15 that the standard provisions which had been promulgated
16 by HEW and EPA were being followed in the plant-by-plant
17 licensing process.

18 A They are.

19 Q But the kind of more specialized review you are
20 talking about of looking at the overall worker protection
21 program that is devised by an applicant for a specific
22 plant has not been directly brought to the attention of
23 HEW or EPA for this kind of review on a plant-by-plant
24 basis?

25 A No, but it is done by NRC.

1 Q Internally?

2 A Yes.

3 Q I see. Okay.

4 A Without the involvement of HEW or EPA on the
5 case-by-case level, only at the standard level, and not
6 HEW in the past because they haven't been involved in
7 radiation standard setting.

8 Q Okay. What sort of retraining was required of
9 B&W operators right after TMI 2?

10 A It started very specific and was concentrated
11 on the specific sequence of events of TMI 2. It grew
12 fairly rapidly to include training for small break LOCA's
13 in general, and as you read A0578, there is a program, a
14 three-phase program, starting with small break LOCA's
15 going to core uncover, and then ending in reanalysis of
16 the Chapter 15 events, all with a realistic perspective
17 intended to improve and increase the capability of operators
18 to intervene in accidents.

19 Q The more immediate situation right after March 28,
20 1979, as I understand it, there were hearings on whether
21 or not to close all B&W plants, and in fact all B&W plants
22 were temporarily closed during that period of time,
23 weren't they?

24 A That's right.

25 Q And there was consideration at that time of the

1 retraining of B&W operators at those plants, was there
2 not?

3 A Not B&W operators--there is no such thing.

4 Q Operators at plants supplied by B&W.

5 A Yes.

6 Q What was the program that was devised at that
7 time for the retraining of those operators?

8 A Well, initially it started out to be retraining
9 on the TMI 2 sequence of events on the B&W simulator.

10 Q Was there an entire program set up that would
11 call for simulator training?

12 A Yes.

13 Q Did it also call for retraining of the operators
14 in the TMI 2 type of scenario?

15 A Yes.

16 Q Did it also call for oral and written examinations
17 at the ending of that training program?

18 A I believe it did.

19 Q Was that program in fact carried out?

20 A I understand it has been, and it has been
21 increased and broadened considerably.

22 Q Did the operators have to take written examinations?

23 A It is my understanding they did.

24 Q We had some conversation with Mr. Skovoholt about
25 this situation, and what he explained to us at the time

1 was that there is a tremendous pressure that built up
2 here because the utilities could not afford to wait for
3 such a substantial period of time in keeping these plants
4 closed while these operators were retrained, and that as
5 a result, the determination was made that the operators
6 would only take the oral examination immediately, and
7 that further retraining would be scheduled as could be
8 conveniently accomplished.

9 A That is possible. I was not involved in the
10 decisions on restart that came out of the bulletins and
11 orders task force, but I know that Mr. Denton raised the
12 passing score for those retraining exams, and I understood
13 that had to do with the written--I am probably mistaken.
14 Mr. Skovholt is in a better position to know than I am.

15 Q Mr. Mattson, do you favor a national training
16 program for operators?

17 A Yes. There are some good aspects to that. I
18 will reserve on a final judgment for the work of the task
19 force. We are going to speak to that, I think, ^{but} maybe not
20 in exactly those terms.

21 Q Do you think some type of uniformized training
22 program is going to be addressed by the lessons learned
23 task force?

24 A The need for one, yes.

25 Q In fact, at the present time, each utility is

1 left to its own responsibility in developing training
2 programs, is it not?

3 A Under very general guidance from NRS^c.

4 Q Right. Do you think that something like a
5 national program is a real possibility, could be done?

6 A Yes. I think the principal attractiveness to
7 that is that there are utilities that do a consistently
8 better job at some things than other utilities do, and
9 it would be useful to take advantage of the people who
10 know how to do it better and get everybody up to the same
11 standard.

12 It is a sort of best achievable technology
13 approach that you can accomplish on a national level that
14 you can't do with 100 different training organizations.

15 I am taking your word national to not mean
16 federal necessarily.

17 Q No, but in any event, something like a college
18 or a school that operators go to from around the country
19 and obtain the training on a uniformized basis such that you
20 know or can have reasonable assurance that operators at
21 Rancho Seco have been trained the same as the operators at
22 TMI 2, for example.

23 A Except you don't want them to all be exactly the
24 same because every one of them has got a different machine
25 and a different control room, so you still have to

1 accomplish the transition from the central place back to
2 the specific place.

3 Q As a matter of fact, that was something else
4 that I wanted to ask you about at some point, and I guess
5 this is as good as any.

6 Standardization of nuclear--as I understand it,
7 there is some four or five different kinds of nuclear
8 power plants at the present time in operation, and beyond
9 that, every plant has unique features about it, particularly
10 in terms of balance of plant aside from the primary system
11 because there are so many AE's.

12 A There are no two plants in this country alike.

13 Q Do you think that is a good thing?

14 A No.

15 Q How has it come about that there has been so
16 little standardization of nuclear power plants?

17 A The utility industry has not been convinced
18 somehow that it is in their best interest. The vendors^o
19 have responded fairly well over the last few years and
20 have developed standardized plant options that make sense
21 and could be used.

22 The response by the utility industry has been
23 poor, disappointing, words like that. Even when there are
24 standardized plants for them to buy, they make changes to
25 the standardized designs when they purchase them and submit

1 them as ostensibly standardized designs, but they are
2 not really.

3 Q What are the problems with lack of standardization
4 in nuclear power plants?

5 A Well, you have to start over in each plant and
6 review it from the ground up over and over and over again,
7 and instead of being able to concentrate resources by the
8 designer and by the regulator on a particular standardized
9 design, you have to spread your resources over half a
10 dozen designs for a given vender, and you don't have
11 the time and the opportunity to get into as much detail
12 and have as much understanding about a design.

13 Q Has it also posed problems for I&E in terms
14 of the differences between plants?

15 A I'm sure it does, in the same sense it does for
16 license reviewers.

17 Q Make it more difficult to carry out the inspection
18 and enforcement function, doesn't it?

19 A Yes.

20 Q Does it also lead to a situation where it is
21 more difficult to see generic safety problems that may
22 apply to more than one plant because each plant is different?

23 A It makes it more difficult to see their solutions.
24 You can see the problems. Conceiving of the solutions is
25 much more difficult.

1 Q Given the fact then that some of the problems
2 with lack of standardization relate to some basic safety
3 type of concerns, why hasn't it been the position of the
4 NRC that they won't grant a license to a utility which
5 does not standardize at least to an acceptable degree its
6 plant design?

7 A There has been growing enthusiasm for that
8 thought over the last couple of years. I have espoused it
9 myself. The reluctance appears to be an unwillingness to
10 interject the government in that free enterprise choice,
11 and lacking concrete, specific examples of why it is counter
12 to safety to have a custom design when you have got 150
13 of them either in operation or under construction already,
14 it is kind of hard to say they are unsafe, thou shalt only
15 consider standard designs.

16 It seems to be difficult for the government to
17 make that choice. I have recommended on the last couple
18 of supposedly standardized design applications that they
19 be rejected. They weren't standard plants. They shouldn't
20 be reviewed as standard plants.

21 Q Were your recommendations followed?

22 A No.

23 Q Has anyone ever analyzed how effective the two-
24 step CP and OL process for licensing really is? What I
25 mean is doesn't issuance of a construction permit and

1 compliance by the utility and following up the actually
2 built plant virtually mandate issuance of an operating
3 license?

4 A Yes, it does.

5 Q What is the function of the OL review as a
6 separate component from the CP review? Everybody knows
7 the utility is going to get the OL, don't they?

8 A That is not the function of the review. The
9 function of the review is to ascertain that the design
10 is up to snuff, whatever it was, and you make the changes
11 that are required to meet the regulations.

12 Q Is it true that at the OL stage the hearings
13 that are held only concern the intervenors' objections
14 and they don't give any de novo consideration of the more
15 detailed FSAR that is submitted?

16 A That is what the Atomic Energy Act says, yes.

17 Q Is that do you think a proper approach to the
18 question of evaluating the FSAR which as I understand it
19 is much more detailed than the PSAR?

20 A If you are going to have a two-step licensing
21 process, it makes sense. That doesn't make sense today.
22 It ought to be a one-step licensing process. There
23 ought to be frozen designs. They ought to be standardized.
24 They ought to review them at final design stage. It is
25 not quite the same detail as the FSAR. It has clearly got

1 restraint of trade difficulties with it, but it is
2 clearly a solvable problem if there are going to be more
3 nuclear power plants. The agency said that two years
4 running in proposed legislation.

5 Q I wasn't aware of that. There was proposed
6 legislation two years ago?

7 A Yes. The last two sessions of Congress have
8 had licensing reform legislation by the Carter Administration
9 largely drafted by the NRC which said essentially that.

10 Q Something else I wanted to ask you about, too,
11 you are undoubtedly familiar with WASH 1400, otherwise
12 known as the Rasmussen Report.

13 Are you aware that WASH 1400 stated that too
14 much emphasis was being placed on large break LOCA analysis
15 and that it really is necessary to look at more small break
16 analysis?

17 A Yes.

18 Q One thing that has come to our attention, for
19 example, in connection with the hydrogen question is the
20 low capacity of hydrogen recombiners to deal with large
21 amounts of hydrogen in the containment building.

22 For example, it is my understanding that the
23 reason that low capacity was considered sufficient is that
24 it was always anticipated there would be large break LOCA's
25 which would generate not that much hydrogen in the containment

1 building, and the recombiners would have the capacity to
2 deal with that.

3 Is that right?

4 A No.

5 Q Why wasn't it considered that the recombiners
6 would not have the capacity to deal with large amounts of
7 hydrogen in the containment building?

8 A Because it was concluded that protection that
9 was provided for the core, that is, the alternative cooling
10 mechanisms for the core, were sufficient to prevent the
11 generation of hydrogen--small break, large break, any break.

12 Q So there wouldn't be any hydrogen in the
13 containment building?

14 A Very small amounts generated during the loss
15 of coolant accident.

16 Q Whether this is a small break or large break?

17 A That's right. Small breaks are even better than
18 large breaks. They still are.

19 Q Except under the TMI 2 situation?

20 A Except where you turn off the emergency core cooling
21 system, and then there isn't any protection.

22 Q Did B&W supply to NRR on March 29, 1979 the day
23 after the accident, an analysis of the hydrogen/oxygen
24 situation?

25 A At TMI 2 post-accident?

1 Q Yes, or during accident, if you will.

2 A You mean as part of the accident management
3 thing?

4 Q Exactly; work they had done on the situation
5 at TMI 2 that would relate to the hydrogen/oxygen problem.

6 A Submit in writing?

7 Q Yes. In other words, transmitted in some fashion
8 to someone in NRR.

9 A No, not that I saw.

10 Q You were in charge of a team that was working
11 on the hydrogen/oxygen problem, were you not?

12 A Yes.

13 Q And the members of your team were getting their
14 information from a number of sources, weren't they?

15 A Yes.

16 Q Do you know whether or not any members of your
17 team contacted B&W in that regard?

18 A Oh, yes. We were on the phone with B&W quite
19 a lot on Thursday.

20 Q Did they supply anything in writing relating to
21 hydrogen/oxygen calculations to your team?

22 A On Thursday?

23 Q Yes.

24 A No, not to my knowledge.

25 Q Did they on Friday?

1 A Not to my knowledge.

2 Q Or Saturday or Sunday?

3 A Not to my knowledge.

4 Q Okay.

5 A Maybe late Sunday or early Monday is when the
6 thing started to get a little more formal from B&W; by
7 that time I had left Washington, so I am not sure quite
8 what might have been provided. I have never seen anything
9 in writing from B&W.

10 Q On March 30th or 31st, did you provide any
11 specific data or information to the NRC Commissioners
12 relating to the hydrogen/oxygen problem?

13 A On the 31st I did.

14 Q Do you have that data written down anywhere that
15 we can take a look at it?

16 A No.

17 Q Was it just done verbally?

18 A Well, let me show you what I have given to you
19 already and you tell me whether you want more. This is a
20 question that was asked on April 26th ^{of} Chairman Hendrie.
21 That took some time to get answered, and you remember
22 there were some harsh words back and forth.

23 This is question Roman Numeral 4, provide
24 definitive analysis on the hydrogen bubble problem that
25 occurred at TMI. There is a short answer. It says other

1 than what we did at the time of the accident, we haven't
 2 done much more, but here is everything we have.

3 Enclosure ¹ is ^a ~~that~~ summary by Tom Murley of the ~~the~~
 4 ^{Research staff} involvement in the bubble thing--what did we know then,
 5 know now, who did we talk to, and what did they tell us,
 6 and there are a couple of attachments to his enclosure 1.

7 Enclosure 2 is a set of handwritten notes and
 8 some typewritten notes that I compiled from my files, from
 9 Bob Tedesco's files, from the file cabinet at the
 10 Command Center at Three Mile Island, and from the records
 11 from the Incidence Response Center, ^{I also assembled} ~~that we were talking~~
 12 ^{the notes of} ~~to~~ Warren Minners, ~~We also talked to~~ Vic Stello, Darrel
 13 Eisenhut, and whoever, and they are in chronological order,
 14 and it says who said what to whom, when, when they wrote
 15 it down, and the other thing that is of interest is the
 16 transcript from Saturday, the 31st, of the Commission
 17 meeting, which Professor Pigford referred to I think when
 18 he was questioning me in my testimony on ^{June} ~~the~~ 1st, and it is
 19 an unfortunate transcript because it has got a lot of
 20 garbles in it. There is a lot of it that was lost, but
 21 that was the principal communication between the staff and
 22 the Commission on the explosion potential of the hydrogen
 23 bubble prior to the information being made public and the
 24 ensuing difficulty.

25 Q I believe you stated that this documentation that

1 you have been referring to, which is about three, four
2 inches in thickness, was transmitted to the Presidential
3 Commission?

4 A Yes.

5 Q It is my recollection from talking to Professor
6 Pigford that his problem is that he is not sure in all of
7 this stack of information exactly which data was relied
8 upon to communicate to the Commissioners your task force's
9 conclusions relating to the oxygen/hydrogen problem, and
10 specifically I wonder if it is possible to reconstruct
11 what data was used to come to the computation as to the
12 oxygen generation rate and what that conclusion was?

13 A Yes. Let me pause for a minute.

14 Q Surely.

15 (The witness reviewed a document, and a
16 discussion was held off the record.)

17 MR. KANE: Back on the record.

18 BY MR. KANE:

19 Q Mr. Mattson, before we took the break, what we
20 were discussing was the request by at least one of the
21 Presidential Commissioners, Thomas Pigford, that you be
22 called upon to designate the specific computations used by
23 your team during the time of the TMI 2 accident to come
24 up with an oxygen generation rate in connection with the
25 hydrogen/oxygen problem, and to specifically give the

1 numbers that were utilized in that regard.

2 During the break you have had an opportunity
3 to look over some materials and notes that you have. Have
4 you been able to identify the specific numbers used by
5 your team in coming to a computation on oxygen generation
6 rate?

7 A Yes. First of all, let me straighten the record
8 out on a couple of things. I didn't head a team doing
9 calculations. I was either in charge or in a deputy position
10 ^{in charge} of the NRR involvement in the Incidence Response Center,
11 on the day of interest for the hydrogen explosion question,
12 that is, Friday night, late, the 30th, and all day
13 Saturday, the 31st.

14 In that capacity, I was responsible for the
15 hydrogen bubble and for a number of other things
16 associated with the NRR involvement in the TMI accident.

17 The point I want to make is the hydrogen bubble
18 was just part of it. What I did in the discharge of this
19 responsibility was to ask two groups of people to look at
20 the question of the hydrogen combustion potential for the
21 hydrogen that was in the reactor coolant system.

22 That question was asked of me at about 2 o'clock
23 a.m., Saturday the 31st of March. It had been asked of
24 others in the Response Center about four hours earlier,
25 and various questions had been addressed and some preliminary

1 work was started before the question was asked of me at
2 2 o'clock in the morning.

3 That early Saturday morning all we succeeded
4 in turning on in the way or technical problem solving was
5 to ask B&W to calculate the explosive force of ~~an~~^a stoichiometri
6 mixture of hydrogen and oxygen in the reactor coolant
7 system.

8 That is a very conservative first question to
9 ask, but people wanted to bound ~~X~~ the problem. B&W was
10 asked that question sometime in the course of the morning,
11 early Saturday morning. I am not sure when. I left at
12 3 o'clock in the morning. They answered at 5:30 that
13 morning, and said that the result of a stoichiometric
14 mixture exploding in the reactor coolant system, if it
15 was 1,000 cubic feet at 1,000 PSI and 280 degrees Fahrenheit,
16 would be a pressure in the reactor coolant system of
17 14,000 PSI.

18 When I returned that morning at 9 o'clock, I
19 obtained briefings from the people who had worked earlier
20 on a number of problems, including this one, and by 10:30,
21 had a conversation with the Chairman where he re-emphasized
22 the importance of obtaining an answer to this question in
23 a timely way.

24 There was no answer when I came back to work that
25 morning. I turned on two groups of people at that point.

1 The first group was headed by Robert Tedesco, assistant
2 director for reactor safety in the Division of Systems
3 Safety. He worked with his own staff; a Mr. Shapakar,
4 Mr. Butler, Mr. Millstead; and they in turn worked with
5 the Knolls Atomic Power Laboratory, and Knolls did some
6 calculations of the rate of generation of oxygen by
7 radiolysis in the TMI 2 environment, and the staff did
8 some calculations.

9 I will tell you a little bit about what those
10 numbers were, but I would rather do it in chronological
11 sequence.

12 Q Please.

13 A The work of Millstead, Buttler and Shapakar and
14 Tedesco is chronicled in a July 9, 1979 memorandum to me
15 which I asked them to write, and I passed on to Mr. Gorensen
16 of the President's Commission. It is a fairly good summary
17 memo of what they calculated, by what methods, where,
18 in addition to another memo I supplied on July 2nd, written
19 by these same people--I'm sorry. I did not supply it on
20 July 2nd. The Chairman did. It is probably worth getting
21 that straight on the record; so let me find it.

22 Q Was that Chairman Hendrie?

23 A Yes. Chairman Hendrie supplied to Mr. Kellney on
24 July 5th, 1979 another memorandum, this one signed by
25 Mr. Butler dated April 25th, which has good summary

1 information on the radiolysis calculations supplied by
2 the staff, so between this April 25th memorandum from
3 Butler and the July 9 memorandum ~~of~~ Millstead, there is
4 a good explanation of what the staff did and ~~what~~ ^{what} they
5 relied upon ^{from} KAPL, to supply ^{answers} on the hydrogen combustion
6 question on the 31st, and then subsequently on the first.

7 The second group of people I turned to was ~~Saul~~ ^{Saul}
8 Levine, Tom Murley, and Bob Budnitz from the NRC Office
9 of Research, who in turn went to other people for analysis
10 of the hydrogen combustion question.

11 They went principally to a Mr. Bob Ritzman at
12 SAI. I can't say what SAI stands for--Systems Analysis,
13 Incorporated, and to the Idaho National Engineering
14 Laboratory. Those were the two sources that reported to
15 me that they had consulted on this subject.

16 I subsequently have learned some months after
17 the accident they ^(RES) also consulted with the Brookhaven
18 National Laboratory.

19 Q Okay.

20 A Now what they obtained from Brookhaven, Ritzman,
21 INEL, is quite well summarized in written memoranda in
22 the stuff that we supplied in response to that question
23 before I talked about it earlier. It is buried, but you
24 can find it. It is in succinct summary fashion.

25 It is mid-morning, the 31st of March. I have

1 turned on those two principal people, Tedesco and Levine.
2 At 1:10 p.m. Saturday afternoon I got my first answer
3 back. Prior to 1:10 p.m. Saturday, I did not know the
4 answer to that question. I am not an expert in that field,
5 and I attempted no calculations of my own.

6 Others had. The staff had not other than the
7 ones I had turned on.

8 Q You say others had. Which others?

9 A I am not completely certain. I have tried to
10 research the transcript of telephone conversations and
11 Commission meetings to ascertain who the others were. I
12 am not completely satisfied that I know.

13 The Chairman had done calculations of his own
14 Friday night, and he told me that when he called to ask
15 the question at 2 o'clock in the morning, Saturday morning.
16 He said he had done calculations. He was concerned with
17 the answers.

18 The Commission transcript of late morning
19 Saturday morning alludeⁿ to 10 percent oxygen. ~~As~~
20 Commissioner Gilinsky refers to that number. I have
21 never heard that number before.

22 Q Did Chairman Hendrie tell you where he had gotten
23 the data to do the computations he said he had done?

24 A No.

25 Q Did he tell you what the computations were, I

1 mean the numbers?

2 A No. He said he was calculating the rate of
3 radiolysis ^{and} ~~X~~ the generation of oxygen and if it were
4 staying in solution, that is, it was not recombining with
5 the hydrogen, then he was concerned that it could be
6 rapidly accumulating, potentially leading to a combustible
7 mixture.

8 I said I didn't know. It was a good question.
9 I would have to ask some others.

10 At 1:10 p.m. I got the first answer to the
11 question I asked, and the answer came from ^{Saul} ~~Sal~~ Levine. He
12 told me that he had spoken to Bob Ritzman of SAI who was
13 then estimating that there was 2 to 3 percent oxygen then
14 present in the hydrogen bubble. He thought it could be
15 10 times higher than that, but he didn't believe it. He
16 didn't think it would ignite until it reached 8 to 9 percent
17 oxygen, and it wouldn't detonate until it was higher than
18 8 to 9 percent by a factor of 2 or 3. That information is
19 contained in my notes.

20 Levine had also talked to Sid Cohen of INEL.
21 Cohen's statement was there would be 5 percent oxygen in
22 four to five days, that 900 degrees Fahrenheit was required
23 for spontaneous detonation in a wet environment, and it
24 would be expected to burn before it exploded.

25 At 2:06 that afternoon, Tedesco indicated that

1 he has^d talked to Westinghouse and to KAPL. They had not
2 done calculations by that time, but they had some
3 ~~quantitative~~ ^{qualitative} answers. The notes indicate that Westinghouse
4 believes^d that the oxygen would stay in solution, and at
5 the low temperatures that were then present in the reactor
6 coolant system, the recombination of hydrogen and oxygen
7 was not likely.

8 KAPL's initial response was that they could not
9 preclude free oxygen in the bubble at that time. The
10 oxygen/hydrogen generated by radiolysis would not be
11 ^klikely to recombine if there was boiling in the core.

12 My notes indicate Tedesco gave me that
13 information shortly after he received it from Westinghouse
14 and KAPL, so at 2 o'clock Saturday afternoon, I had an
15 estimate that there was oxygen being generated from four
16 independent sources, all with known credentials in this
17 field. The estimate of how much oxygen varied, but all
18 estimates said that there was considerable time, a matter
19 of several days, before there was a potential combustible
20 mixture in the reactor coolant system.

21 Q On that basis of that information, what did you
22 report to the NRC Commissioners?

23 A My monologue will take you right through it. It
24 is interesting to note that at 2 o'clock Chairman Hendrie
25 and Mr. Case were in a Saturday afternoon press conference.

1 They had not received this information from me prior to
2 that press conference. They did not address this question
3 in any detail in a press conference.

4 At 3:27 that afternoon, there was a recorded
5 Commission meeting in the Incident Response Center, or
6 nearby, of all five Commissioners. This is the garbled
7 Commission meeting I told you earlier that the tape was a
8 poor tape and there is much of the quantitative information
9 that is missing.

10 I do recall discussing the numbers I had received
11 from INEL and Ritzman through Levine and telling the
12 Commission of the qualitative information supplied by
13 Westinghouse and KAPL.

14 The bottom line of that conversation that is
15 in the transcript was that there were several days
16 required to reach the flammability limit, although there
17 was oxygen being generated, and I expressed confidence
18 that we were not underestimating the reactor coolant system
19 explosion potential, that is, the estimate of two to three
20 days before reaching the flammability limit was a
21 conservative estimate.

22 Said another way, we told them it would be at
23 least that long³.

24 At 4 o'clock that afternoon after the Commission
25 meeting, I talked to Tedesco who had just talked to KAPL

1 and received the first quantitative information from KAPL.
2 He had also been in conversation with a Mr. Irv Pinkel
3 of NASA. The man he talked to at KAPL was Ernie Vernes.

4 KAPL had agreed that a conservative estimate
5 of the hydrogen and oxygen generation rate by radiolysis
6 calculated by the staff on Friday and Saturday of 28 to 39
7 cubic feet per day was acceptable, ^{That is} about 13 cubic feet of
8 oxygen per day.

9 KAPL agreed that the hydrogen/oxygen concentration
10 was now approaching flammability. This is Saturday
11 afternoon at 4 o'clock. That is, there was about 5 percent
12 ~~more~~ mole fraction of oxygen and 4.7 ~~more mole~~ ^{percent mole} fraction of steam,
13 in ~~a~~ ^{the} hydrogen bubble.

14 They didn't suspect we would reach a detonation
15 limit at those generation rates for ten days to two weeks
16 in the future.

17 My notes indicate Tedesco's statement to me on
18 the basis of what KAPL told him, that the oxygen probably
19 won't recombine under the conditions in the TMI reactor
20 coolant system. It will stay free. There might be some
21 recombination due to gamma flux, and their estimate of the
22 consequences of combustion were 20 percent over pressure
23 in the reactor coolant system if burned at flammability
24 limit, but they added that they had run a number of
25 experiments in closed containers with steam, oxygen, ^{and} hydrogen

1 mixtures, and they had never seen spontaneous ignition
2 at the 3 percent oxygen concentration.

3 This is after the Commission meetings. I do
4 not recall passing this information to the Commission. I
5 viewed it as confirmatory of what we had been saying to
6 them about an hour earlier, that is, there were several
7 days before we had a problem. The KAPL numbers were a
8 bit more negative than the Ritzman and INEL numbers that
9 I had received from Levine, but they were very positive
10 on the no spontaneous combustion question.

11 Based on that information, we took no further
12 action on the bubble that evening. At 6 o'clock, there
13 are some notes from Tedesco where KAPL and he talked again.
14 They talked about some new number based on the most
15 recent measurements of the size of the bubble, 880 cubic
16 feet at 875 PSI.

17 The results of their calculations were 5.8 percent
18 ^{mole} ~~mol~~ fraction of oxygen, and a 4.3 percent ^{mole fraction} ~~mol~~ of steam,
19 and according to the flammability limit curve that they
20 had sent by telephone at 4 o'clock that afternoon, that was
21 right at the burn threshold, but again KAPL's advice was
22 they had never seen spontaneous ignition at the flammability
23 limit, that being much lower than the detonation limit.

24 At 6:45, my notes indicate a call from Vince
25 Noonan who is branch chief in the Division of ^{Operating} ~~Nuclear~~

1 Reactors in charge of engineering analysis. He would be
2 the expert on what the explosion, if it were to occur, would
3 do to the reactor coolant system. He had been in touch
4 with a consultant by the name of Merriman who also did a
5 stoichiometric burn calculation which yielded a 20,000 PSI
6 overpressure ^{in the} reactor ~~to~~ coolant system.

7 Noonan also had been back in touch with B&W
8 who had accounted for the effect of water vapor on the
9 explosion, and that had decreased the overpressure to
10 7,850 PSI. It is not an overpressure, a total pressure,
11 and accounting for the effect of an enriched hydrogen
12 environment, they were able to reduce the total pressure
13 to 3,000 to 4,000 PSI.

14 That was fairly positive news. We know that the
15 primary coolant system of PWR can take pressures, dynamic
16 pressures in the range of 3,000 to 4,000 PSI as a result
17 of ATWS analyses that had been done.

18 Noonan said that his estimate of the failure
19 ~~of~~ the bolts in the reactor coolant system, the pressure
20 vessel head would occur at about 12,000 PSI--I'm sorry--
21 11,000 PSI. and ~~will~~ ^{it would} take 12,000 PSI to fail the head
22 itself.

23 I didn't know it at the time, but there was--
24 and it is obvious in notes I got ~~in~~ ^{from} the Incidence Response
25 Center ~~of~~ a conversation with Jim Taylor of B&W at

1 11 o'clock Saturday night saying they felt that
2 recombination was taking place, there was no oxygen being
3 generated. That information did not get to me.

4 At 11:30 I had a conversation with ^{Saul}~~Sam~~ Levine
5 who updated the INEL estimate. They were now estimating
6 2 percent oxygen in reactor coolant system, but there was
7 an anomaly. They were saying it was being generated at
8 1 percent a day, and given we were three days into the
9 accident, that number didn't comport.

10 They were using data from the Cooper Nuclear
11 Station startup test, which is a boiling water reactor,
12 scaled it to the TMI 2 decay power level, estimated 12
13 days to reach a 6 percent oxygen level, again inconsistent
14 with the 1 percent per day.

15 Ritzman was reported to be working with
16 AVCO at that point with no further information from him.

17 I ought to go back and note ^{that}~~what~~ Tedesco said
18 he talked with Irv Pinkel of NASA. I can't figure out what
19 NASA told him. It isn't in his notes, and no one seems to
20 recall what NASA's role was. The name is mentioned but in
21 no specific environment.

22 I left work Sunday morning at 3:00 a.m., returned
23 at 9 o'clock. I had a meeting with Levine, Budnitz, Murley,
24 ^{and} and out of the meeting were Commissioners Hendry, Gilinsky
25 and Kennedy. It was at about 9 o'clock that morning. The

1 purpose was to reach an NRC. Bethesda staff judgment
2 on the hydrogen explosion potential.

3 Everyone in the meeting cautioned that there
4 was a lot of information coming from a lot of experts,
5 and it didn't all agree, they didn't all agree with one
6 another, but ~~that~~ the Chairman and I were leaving for the
7 site. It was our best opportunity to give advice to
8 Denton and Stello at the site, and the President was due
9 to arrive there in two hours.

10 Recognizing the uncertainties in what we had
11 heard, we agreed upon the following numbers. Murley has
12 recorded them slightly different than me in his note to
13 the file. I will read them both.

14 We agreed on the basis of talking to the
15 experts that I have described that 5 percent oxygen was
16 a realistic flammability limit; 11 percent oxygen was a
17 realistic detonation limit, that there could be no
18 spontaneous combustion below 900 degrees Fahrenheit, that
19 the oxygen production rate was approximately 1 percent per
20 day, and that the present oxygen concentration in the
21 bubble was 5 percent.

22 Murley says we agreed on the three limits--
23 5 percent for flammability, 11 percent for detonation,
24 and 13 percent for combustion, and for the ^{life} ~~time~~ of me, I am
25 not sure what those three things mean.

1 I know what the two limits mean. I don't know
2 what the three means. Tom will have to answer that question.

3 Q Tom being again?

4 A Dr. Murley . The Chairman and I left for the
5 site. We passed this information to Mr. Denton and
6 Mr. Stello. Mr. Denton summarized it for the President
7 in his briefing at about 11:00 a.m. that morning. Mr.
8 Stello's initial reaction upon hearing the information was
9 that it was wrong, and that we had miscalculated the
10 radiolysis rate, and that in any event, the oxygen
11 generated by radiolysis would recombine. He was convinced
12 it would. ^{He} ~~he~~ couldn't prove it, didn't have an expert to
13 back him, but he knew we were wrong.

14 Q What was Commissioner Hendrie's reaction?

15 A He was not involved in most of that briefing.
16 I did it alone. The briefing with the President was
17 finished about noon. Mr. Stello and I returned to the
18 Command Center at the observation site across from the
19 reactor. He got on a phone with General Electric and the
20 Bettis Laboratory. I got back on the phone with the people
21 in Bethesda, told them we have to have a better answer
22 on recombination; by 3 o'clock that afternoon, as the record
23 notes indicate, all but a few of the experts had agreed
24 to ^{the conclusion that there was no} ~~that~~ net oxygen generation, and by the next morning,
25 they had all agreed.

1 Now the specific role of KAPL in that is
2 confused. They say it one way. We say it another way.
3 I tend to rely upon what Mr. Millstead and others recall
4 they understood KAPL to say.

5 I point~~ed~~ it out because KAPL says it slightly
6 differently in their documentation of what information
7 they supplied, and somebody other than me will have to
8 resolve those differences if they are important.

9 Those are the numbers we relied upon. The
10 documents I have described in the course of the chronology
11 say how the people calculated those numbers, and I think
12 that should answer the question.

13 Q Okay. I do have one other question. At what
14 point during that entire process did you recommend
15 evacuation?

16 A Not at all through that process; I recommended
17 no evacuation on the basis of the explosion potential of
18 the hydrogen in the reactor coolant system. I wasn't
19 convinced we had a problem.

20 We recommended to the Commission they had days
21 before they had to make up their minds. It got a little
22 more negative Sunday morning. For some reason, my six
23 hours off changed it from 2 to 3 days until it was flammable
24 to it was flammable now, but it didn't change the story
25 that we still had many days until detonation and there had

1 never been any observed spontaneous combustion at the
2 flammability limit, so my advice consistently throughout
3 the concern over the hydrogen combustion potential was
4 to not evacuate.

5 There were Commission^{ers}, not the Commission, but
6 individual Commissioners who were concerned with the need
7 to evacuate, but our advice to them was to not be
8 concerned with evacuation because of the hydrogen explosion
9 potential.

10 Q In fact, at some point during the accident you
11 did recommend evacuation, didn't you?

12 A On Friday morning, the 30th.

13 Q What was the basis for that recommendation?

14 A Two bases--there had been observed that morning
15 a 1200 milli-R plume reportedly caused by occasional
16 venting from the vent header in the waste gas system, a
17 header between the makeup tank and the waste gas decay
18 tank caused by the transfer of gases from the makeup tank
19 to the waste gas decay tank, said transfer having to occur
20 periodically in order to maintain the makeup system, the
21 venting occurring because of a relief valve that was popping
22 at a pressure lower than its design pressure, that is,
23 80 PSI instead of 100 PSI.

24 The waste gas decay tank capacity was diminishing.
25 I was told, as were the rest of the people in the incident

1 Response Center in Bethesda, that ^{there} was one and one half
2 hours of gas decay tank capacity left, at which point the
3 discharge from the vent header would become continuous.

4 Had it become continuous, it would have beer
5 a sizable increase in the 1200 MR plume, ^{We were told} that there was
6 no alternative, because of that diminishing waste gas
7 decay storage capacity, to depressurizing the primary
8 coolant system and attempting to use the decay heat removal
9 system.

10 We believed at that time, and no one has shown
11 us to be wrong to date, that ^{use of the} ~~that~~ ^{heat removal system} decay would have
12 uncovered the core by causing the, or that depressurization
13 would have uncovered the core by causing the bubble to
14 expand, and the core would have been severely damaged, with
15 the significant possibility of melting it down.

16 Faced with those two alternatives, I recommended
17 that they take advantage of the hour and a half they had
18 before they were about to turn off the cooling of the core.

19 Q Why was depressurization at that point a
20 necessary step?

21 A The licensee said that there was no alternative
22 to depressurizing if they were unable to keep the makeup
23 system running because they in essence had to open it to
24 the atmosphere when they lost their waste gas storage
25 capacity.

1 Now when I said the licensee said, you have to
2 recognize that I was receiving that information through a
3 telephone link that involved passing information through
4 three or four or five, maybe even a half a dozen different
5 people before it reached me, and you in your Commission
6 have testimony that says ~~the~~ ~~information~~ information that I relied
7 upon, and that the rest of the people in the Incident Response
8 Center relied upon, was not good information.

9 What turned out was that in an hour and a half,
10 they had found a way to control the makeup system without
11 causing a continuous release, even in view of the fact
12 that they had diminished storage capacity for waste gas,
13 and the way they did that was to lower the water level in
14 the makeup tank.

15 They may have known that all along, and our
16 understanding that they were going to continuous
17 release may have been faulty. If I understand the
18 testimony that has been given to your Commission by the
19 operators, that is probably the case. I didn't hear the
20 testimony. I read it in the newspaper.

21 Q During a prior appearance that you did make
22 before the President's Commission, Mr. Mattson, it was
23 suggested by Commissioner Pigford that the NRC could have
24 adequately analyzed the oxygen generation question using
25 data already available to the NRC, and specifically data

1 from ordinary conditions in operating boiling water reactors
2 and pressurized water reactors regarding net oxygen
3 production from radiolysis.

4 Have you had any opportunity to confirm if that
5 is true?

6 A That is probably true.

7 Q Why wasn't that kind of data available or brought
8 to the surface in the course of this chronology you have
9 just given us of the hydrogen/oxygen treatment?

10 A Crisis.

11 Q Crisis? It simply wasn't realized that was
12 available?

13 A A failure to use the information that should
14 have been standard, and I can only explain that because of
15 crisis.

16 Recall that I said that INEL used the data from
17 the Cooper boiling water reactor startup test to get its
18 oxygen generation rate by radiolysis. Why INEL didn't
19 realize the way they defeat that oxygen generation is
20 by putting hydrogen overpressure on boiling water reactors
21 I don't know.

22 You recall I turned to Mr. Tedesco for the
23 staff calculations, one of the staff's leading experts
24 on boiling water reactors, who turned to people in his
25 Containment Systems Branch who understand these things also.

1 The staff's familiarity with that information
2 from boiling water reactor routine operations was
3 either insufficient or the staff because of the crisis
4 failed to extend that knowledge to the unique situation
5 at Three Mile Island. The answer lies in there somewhere,
6 and I am not certain I can attribute it.

7 I had no personal knowledge of how you control
8 radiolysis in a boiling water reactor. If that is a fault,
9 so be it. That is not an aspect of reactor operations
10 with which I was familiar.

11 Q Do you know if you had used this data that was
12 otherwise available within the NRC itself whether or not
13 the results would have come out with more oxygen being
14 generated than could actually have been the case at TMI 2?

15 A Maybe we are not communicating. Had we used
16 what Professor Pigford suggests, we would have said what
17 we eventually said--there was no oxygen being generated.

18 Q I see. You come to the conclusion which in
19 fact--

20 A Which we eventually came to after there had been,
21 unfortunately, misinformation put on the street, and a
22 fair amount of panic ensuing from that misinformation.

23 Q I would like to go back to the question to what
24 extent has the NRC requested B&W to do analyses concerning
25 aspects of the TMI 2 transient? Has there been any of that,

1 or has that all been NRC generated and carried out?

2 A We have required B&W to benchmark their computer
3 code, CRAFT, against the information plots and data from
4 the TMI 2 sequence.

5 Q Have those results been made available to
6 the NRC?

7 A Yes, they were a condition of the restart of the
8 B&W plant.

9 Q Does the NRC independently verify those results?

10 A Yes.

11 Q By using the same code?

12 A No--by using the code RELAP at Idaho.

13 Q - I see. That was done as part of the startup
14 procedure again from B&W plants?

15 A Some of that information was available in that
16 timeframe. Whether all of it was I am not certain.
17 Dr. Ross would be the one who would know the answer to
18 that question.

19 Q Denny Ross?

20 A Yes.

21 Q I am curious on the question of the lessons
22 learned plan, there was a minority view relating to
23 recombiner capability for post-accident containment hydrogen
24 control.

25 If I understand the situation, there are 46

1 operating plants that currently do not have a recombiner
2 capability, and instead have opted to in the past handle
3 the hydrogen problem and containment via venting, and the
4 minority view in connection with lessons learned is that
5 those 46 plants should be required to have a recombiner
6 capability.

7 Why is that a minority view of the lessons
8 learned rather than a majority view?

9 A There were only four of us that felt that way, out
10 of 22.

11 Q You were one of them?

12 A Yes, and we felt it sincerely enough that we
13 wanted to push it forward as a minority view. There were
14 other recommendations of the task force that were not
15 unanimous and many that had less or had more than four
16 dissenting votes. We only required two thirds majority
17 to pass a recommendation, but they were not seriously
18 enough held for the people who favored them to push forward
19 with any formality.

20 Q That means you had 13 people out of 22 who did
21 not feel these 46 plants should have recombiners. Why not?

22 A They thought that the need for recombiners should
23 be considered in context with the long-term work of the
24 task force as to how the hydrogen design basis is to be
25 changed, and if ^{the} hydrogen design basis, for example, ought
A

1 to be changed to 50 percent metal water reaction, the
2 recombiners aren't the answer.

3 Q Because there would be too much hydrogen for
4 them to handle?

5 A Too much too fast.

6 Q Is there technology for recombiners with greater
7 capacity?

8 A No, but there are other solutions to the problem.

9 Q Besides recombining?

10 A Yes.

11 Q What would be some other possible solutions?

12 A Inerting--that is what is done on all boiling
13 water reactors.

14 Q Why hasn't that technology been pursued in PWR's?

15 A It was pursued in boiling water reactors because
16 a very small percentage of metal water reaction takes you
17 into the flammability range because they are very small
18 containments, and in fact it takes you into the detonation
19 range very quickly, and they have rather small pressure
20 capability, whereas the large dry containments have a
21 greater volume so they can take more metal water reaction
22 and produce a smaller concentration ^{of} hydrogen, and they also
23 have higher design pressures so they can take an explosion
24 better.

25 Q If I understand the situation at present, 46

1 plants in the United States should they have a LOCA
2 situation in which they have a substantial generation of
3 hydrogen in the containment building, they are going to
4 have two choices. They can vent it, or they can try at
5 that point to acquire some recombiner capability and get
6 one hooked up?

7 A They can detonate it.

8 Q That third choice would be highly undesirable,
9 wouldn't it?

10 A Three Mile Island evidently detonated quite a
11 lot with no adverse public consequences as a result of
12 that detonation.

13 Q But that wasn't an intentional act?

14 A No.

15 Q Under those circumstances, you wouldn't recommend
16 detonation, would you?

17 A I don't know how to do it intentionally. It
18 happens unintentionally because of sparks.

19 A But even if you had the capability you wouldn't
20 recommend that, would you, detonation of hydrogen in the
21 containment building?

22 A ^I Might recommend burning it; one of the solutions
23 _A might be to install internal flame recombiners of high
24 capacity. Such designs might be possible.

25 Q What is being done in dealing with the hydrogen

1 danger at these 46 operating plants?

2 A There isn't that much hydrogen danger. Three
3 Mile Island said you can take a large amount of hydrogen
4 generation, explode it, and not damage the containment.
5 For the large dry containments, that is substantial
6 protection.

7 It took a 50 percent metal water reaction, and
8 did not damage the containment.

9 Q They did have a 28 PSI pressure spike?

10 A In ^a containment designed for 60 PSI, and that
11 is the same way with all the rest of the large dry
12 containments.

13 Q Have any calculations been done that guarantee
14 you can't have a hydrogen burn under those circumstances
15 that would exceed 60 PSI?

16 A Yes. That is an easy calculation. You just do
17 the stoichiometric combustion of that much oxygen--I'm
18 sorry--that much hydrogen in an oxygen rich environment,
19 and calculate the overpressure.

20 The large dry containments will withstand it.
21 The worry you have is not the containment. It is damaging
22 equipment inside a containment that is not environmentally
23 qualified for the burning environment. There is a worry.
24 I don't mean to make it go entirely away. Recombiners
25 don't solve it. A decision has to be reached on whether it

1 is safe enough to do a better job of preventing large
2 amounts of metal water reaction by training operators, by
3 improving emergency systems, et cetera, or whether no
4 matter what you do to improve the prevention of large
5 amounts of metal water reaction, you still ought to design
6 for it.

7 If you ought to design for ~~them~~^{it}, then you have
8 ~~quite~~ two alternatives. I don't think venting is an
9 acceptable alternative. I didn't think so before Three
10 Mile Island. I don't think so today.

11 Q Because venting necessarily would involve
12 release of some radioactivity?

13 A - It is purposeful release of radioactivity. I
14 believe that ought to be controlled to as low as reasonable
15 achievable levels.

16 Q I see a recommendation in here that plant operators
17 demonstrate a capability to install recombiners.

18 A Yes.

19 Q Was that a majority recommendation in lessons
20 learned?

21 A No. That is the minority view.

22 Q Does that recommendation include capability for
23 a hydrogen recombiner on the basis of adequate shielding
24 being available to deploy the recombiners?

25 A Yes. That is covered in another recommendation, a

1 shielding review.

2 Q Does the FSAR review that is conducted by NRC
3 include a detailed evaluation of the shielding system in
4 the plants that are under review?

5 A I am having trouble with the word detailed.
6 There is an evaluation of shielding provided for worker
7 protection. That is a review done by the occupational
8 health standard people or the occupational health people
9 in another division, not mine, and there are requirements
10 that where equipment would be needed for accident mitigation
11 over the long term, that the design include consideration
12 of maintenance of that equipment, and that should implicitly
13 include shielding review for things outside of containment.

14 Having seen the capability of Three Mile Island
15 Unit 2 in that regard, the task force wasn't satisfied
16 with it and have called for a re-analysis of the shielding
17 provisions for safety systems and non-safety systems in
18 all plants.

19 Q What is your understanding of why--let me ask you,
20 was it your observation that TMI 2 during the course of
21 the accident at least initially did not have sufficient
22 shielding capability to properly deploy the recombiners?

23 A Well, they may have thought they didn't need it.
24 The design probably didn't contemplate an auxiliary building
25 that was already severely contaminated by other sources,

1 and the thinking at the time it was decided to put the
2 shielding in there, as I understood it, was that they did
3 not want to contribute to the access difficulties they
4 already had in the auxiliary building. There ~~was~~ ^{were} very
5 few places they could get ^{access to.} by putting recombiners in service,
6 they were going to make it even tougher, so they ought to
7 shield them before they did that.

8 They had some time, and they put the shielding
9 together in quick order.

10 Q But they didn't have that shielding readily
11 available? It had to be brought in?

12 A That is true.

13 Q If I understood what you were saying, isn't it
14 the requirement of the FSAR that they have adequate
15 shielding available?

16 A Not that I know; I am not certain.

17 Q Aren't hydrogen recombiners safety-related
18 equipment?

19 A Yes.

20 Q So the shielding that is necessary to deploy
21 them would also come under the rubric of necessary safety-
22 related equipment, wouldn't it?

23 A Not if not required to maintain them, and you
24 can get access to the other safety-related equipment;
25 under the design basis, the answer would be no. ^{Suppose}
The
A

1 recombiner had a long pipe and ~~sat~~^{sat} two miles out on an
2 island in the river. You didn't need to be around it.
3 If for some reason you weren't worried about atmospheric
4 releases, you wouldn't shield it, right?

5 Q Yes, but that is not the situation, correct?

6 A Right.

7 Q Under the circumstances that we were faced with
8 at TMI 2, it was necessary to bring in shielding from
9 offsite in order to be able to use the recombiner at all?

10 A I tried to explain that. I think the reason,
11 I am not certain, but I think the reason was that although
12 they could operate without shielding, you couldn't get
13 close to them, which meant you were denying access to a
14 large portion of the auxiliary building by placing them
15 in service.

16 If the auxiliary building was already contaminated
17 from other sources of radiation, that meant you were
18 making a bad situation even worse, so they decided to
19 shield them. It may have been in the original design
20 review, it was decided not to shield them because you had
21 plenty of access to the other areas in the auxiliary
22 building because they weren't expected to be contaminated.

23 Q Then the determination was made that adequate
24 shielding would not be necessary because you could stay
25 away from the recombiners?

1 A Right. I don't know how you answer the question
2 of maintenance if maintenance were necessary in the post-
3 accident environment.

4 Q Why would you want to stay away from the
5 Wouldn't it be better to have the shielding
6 available so that you don't have to stay away from them
7 while they are in operation?

8 A It would seem so, yes.

9 Q Okay. Is the reliability of non-safety related
10 systems that may require use of emergency or backup
11 systems considered in the design review of a plant?

12 A Well, to a certain extent. We talked about that
13 this morning when I said that the control system is
14 required to be designed so that its failure does not
15 challenge or diminish the safety system, but the degree to
16 which that review has ever been conducted is limited.
17 That is why ~~now~~ ^{now} B&W is required to do a failure mode ^{and}
18 effects analysis for the integrat^{ed} ~~ed~~ control system.

19 Q That was another question I had. Prior to
20 March 28, 1979, was failure mode and effect analysis activity
21 utilized to ascertain which systems should have a high
22 reliability or for which special quality controls should
23 be specified?

24 A Well, yes and no; no design to my knowledge
25 ever had all of its systems subjected to failure mode and

1 effect to prioritize what systems should have what quality
2 assurance controls. Rather by judgments over a period of
3 years the definitions of safety system were derived. Those
4 were required to meet the special requirements on QA
5 and testability and be gold plated, as we call them.

6 Over the years it has been recognized that
7 following that approach leaves the possibility that
8 you are subject to systems interaction that you wouldn't
9 have contemplated by doing a review another way, and steps
10 have been taken to try to decrease that risk.

11 Q Which organization in NRC does that type of work
12 that you have been describing? Is that DSS?

13 A Probably three organizations--DSS, DOR, and
14 Research, the Probabilistic Assessment Staff in the Office
15 of Research, principally DSS.

16 Q That was my next question. Is there any office
17 which gives more of an overall view to that question?

18 A DSS. Most of the failure modes and effects
19 analyses have been confined to safety systems, not defined
20 by failure modes, ^{and effects analysis,} but reviewed by failure mode and effect
21 analysis. ^{Safety systems are}

22 Q I think you have also told me in the course of
23 this morning's testimony that DSS has very little to do
24 with the operator training programs, is that right?

25 A Very little.

1 Q There is no evaluation of the adequacy of operator
2 training programs in light of design of certain types of
3 machinery within the plant, is there?

4 A None, ^{(before TMI-2).} There is today, not as a formalized
5 institutional way of working, but there is as a way of
6 conducting the review by the bulletins and orders task
7 force that is going on today.

8 Q That has been since March 28, 1979?

9 A Yes, sir.

10 Q Is there any intent in this regard to look at
11 control room design in connection with operator training?

12 A Certainly.

13 Q . Specifically what I have in mind in asking that
14 question is something that has come up again and again
15 relating to the ability of the TMI 2 operators on March 28,
16 1979 to have ascertained the PORV was stuck open.

17 One of the things that has been cited quite often
18 is the quench tank pressure and level indicator, and I
19 gather one of the problems with that was that the quench
20 tank level and pressure indicator is on the back of the
21 control panel at TMI 2, whereas according to the testimony
22 we have, the primary focus and attention of the operators
23 during the transient understandably enough was focused on
24 the front of the panel.

25 Did anyone prior to March 28, 1979 consider that

1 placing the quench tank level and pressurizer indicator
2 on the back of the panel was an inappropriate location
3 given the necessity for that information during that kind
4 of transient?

5 A We don't review control rooms.

6 Q As far as you know, no one did?

7 A That's right.

8 Q Is there any post-TMI wisdom on that particular
9 subject that indicates that you now will review control
10 rooms?

11 A Yes.

12 Q Okay. Will control rooms be reviewed in their
13 entirety or just something that you will carve out in
14 that respect?

15 A We are going to have to look at the control rooms
16 that are already in operation and the control rooms that
17 are under construction and decide what ought to be done to
18 change them, to provide display and diagnostic information
19 to aid operators that is better than what is there today,
20 but coupled with operators that are probably better
21 qualified than the ones that are there today, so I see
22 changes occurring on those two fronts over the next year
23 or so that will have to be coordinated.

24 Q I notice that there was a reference that you made
25 which was reported in the "Nucleonics Week" for July 19th.

1 1979, relating to reactor operations management, and
2 specifically this was a presentation you gave to the ACRS
3 concerning the work of the lessons learned task force,
4 and you made referenced to the fact that there was a feeling
5 that there should be a shift safety engineer which would in
6 effect be the same as a senior reactor operator, but
7 someone who had engineering capability. He would be on
8 the normal engineering staff of the utility. He would be
9 a person who could assume the hat of shift safety engineer
10 during a transient.

11 Is this the current thinking of the lessons
12 learned task force, that there should be such a person?

13 A 0578 recommended a shift technical adviser.
14 We changed his name a little bit and said he ought to have
15 engineering qualifications, ought to be on shift, and what
16 other things he ought to do besides be on call for crises.

17 Q When you say engineering qualifications, do you
18 mean a bachelor degree in engineering?

19 A Yes.

20 Q And do you mean any further formal training
21 beyond that?

22 A Yes.

23 Q What kind of formal training?

24 A Design ^{and} layout of the plant, capabilities and
25 limitations of what is in the control room, specific

1 training in the plant response characteristics and analyses
2 that have been done of the plant response for off-normal
3 conditions.

4 Q And this person during a non-transient situation
5 would you, you envision to be a senior reactor operator?

6 A No.

7 Q What position would he normally occupy?

8 A An engineering position in the operations
9 organization, dedicated to safety considerations of both
10 a short term and long term nature, long-term things like
11 maintenance policy, equipment procurement policy, what have
12 you, from the safety engineer point of view, and in a
13 short-term basis, the review of operating experience from
14 his plant and plants of like design to understand the
15 implications of that operating experience for his design
16 and for his operations organization, whether his operators
17 and senior reactor operators and his procedures ought to
18 be retrained and rewritten in light of operating experience.

19 He, for example, would have been the person at
20 Three Mile Island who would have reviewed the Davis-Besse
21 transient, would have understood its import, would have
22 seen that there was better training for his operators,
23 and at the time of the accident, he and one of his peers
24 would have been on shift.

25 Q On the other hand, do you mean really in light

1 of everything we have seen about how the Davis-Besse
2 transient was evaluated both within the NRC and I guess
3 elsewhere, for example, Mr. Michelson stated he had heard
4 of the Davis-Besse transient, do you really think that the
5 shift safety engineer at a nuclear power plant would have
6 had any greater success in learning the lessons of Davis-
7 Besse prior to TMI 2 than NRC itself did?

8 A Probably not prior to Three Mile Island, but
9 since Three Mile Island he certainly will have a new
10 perspective.

11 Q Again, doesn't that suggest that a shift safety
12 engineer is not going to be in a better position than DSS
13 is to day to be able to learn the lessons of new and unusual
14 phenomenon that occur in terms of pressurizer level
15 performance?

16 A Are you a pessimist or an optimist? If you are
17 a pessimist, you throw in the towel now and say shut them
18 down. If you are an optimist, you say we can learn from
19 the mistakes, and I think you can learn.

20 Q Again, it depends on what mind set you happen to
21 have when you are viewing the problem?

22 A Prior to the accident at Three Mile Island, the
23 mind set was that accidents wouldn't happen. The mind
24 set after Three Mile Island has to be that accidents have
25 happened.

1 Q I have had that explained to me in a curious
2 sort of way. Let me see if you agree with this. I forget
3 which of the many deponents I have spoken to in the last
4 two weeks who brought this point out, but someone brought
5 up the point that the original beginnings of design
6 analysis for reactor plants was that accidents will happen
7 and we need to design against them, so the original idea
8 was that we must design to prevent accidents. The entire
9 thrust of design analysis was to prevent accidents.

10 That eventually led to the point where it was
11 built into the analysis that accidents would not happen
12 because of all the previous design analysis that had
13 already taken place, and you built up to a point where it
14 was simply anticipated that certain types of accidents
15 particularly could not and would not happen given the
16 prior history of design analysis and performance I suppose
17 to that extent.

18 One specific example that was cited to me was
19 the fact that in the original design analysis, a large
20 break LOCA was, of course, anticipated in the containment
21 building, and that it was therefore designed to withstand
22 the consequences of that type of accident.

23 However, as time went on, it was not anticipated
24 that you would have a situation where the LOCA accident
25 would be of sufficiently small proportions that you would

1 not have, for example, containment isolation on 4 PSI,
2 and that you would have, as you did at TMI, an automatic
3 sump pump arrangement which would pull water out from the
4 sump that was running off into the auxiliary building, and
5 as you said before, contrary to people's expectations,
6 severely contaminate the auxiliary building.

7 A That isn't what did it.

8 Q It was my understanding that what happened was
9 the tanks overflowed.

10 A That isn't where the radiation came from. That
11 is where water came from, but it was uncontaminated water.

12 Q ~~How did it flood~~ ^{What contaminated} the auxiliary building?

13 A The vent header in the makeup system, but the
14 water was all over the auxiliary building, and once the
15 contamination came out, it got spread all over the building.

16 Q That is the current school of thinking? In
17 any event, the point that was made was that having
18 originally designed against the accident, you reached a
19 point where you no longer take those accidents into
20 consideration in further design and improvements or changes.

21 Do you agree with that analysis of the history
22 of the design analysis?

23 A No.

24 Q You don't think that has been the case?

25 A No.

1 Q You don't think the reason that it was simply
2 not anticipated that certain accidents would happen was
3 because originally those accidents were designed against?

4 A No.

5 Q Why has it become the situation then that certain
6 types of accidents are simply not anticipated or designed
7 against today?

8 A I think it is because the people mouth the word
9 to a certain extent that these machines were designed
10 to not have accidents.

11 If these machines were designed to not have
12 accidents, the PORV would have been analyzed for failure
13 to close. People would have understood the consequences of
14 the PORV opening during a transient ^{staying} ~~open~~ ⁱⁿ which ~~during~~
15 ~~which is~~ ^{safety} was dependent upon ~~that transient~~ ^{its closing.}

16 If they really believed they designed to prevent
17 accidents, they would have qualified that valve before it
18 was procured for that situation. They did not. Instead
19 people believed evidently in providing safety systems,
20 well engineered, well designed, well analyzed safety
21 systems, and the fault was they believed so much on the
22 infallibility of those safety systems, they forgot about
23 the people who could stand by and defeat them if they
24 didn't have the right training.

25 They forgot about the excellence that was needed

transcription
gabled

1 at all phases of the operation ^{and} the design.

garbled
 2 See, the PORV didn't stick during a transient
 3 upon which it was dependent. The ECCS did a pretty good
 4 job on that. They worked heck out of that for 10 years.
 5 It worked pretty well. The operator didn't work very well.
 6 Why? Because he wasn't prepared to work very well, not
 7 because he was dumb or because he was incapable compared
 8 to other operators.

9 He was in a situation that nobody told him
 10 how the thing would look when it got into that situation.

11 Q Wasn't he in fact trained to take certain action
 12 which was, under the circumstances he was faced with at
 13 that time, diametrically opposed to the right thing?

14 A No. He was trained to protect against going
 15 water solid for a system without a hole in it.

16 A By throttling back the HPI?

17 A For a system without a hole in it--this system
 18 had a hole in it. He had a lot of indications that it had
 19 a hole in it. The combination of the training and procedures
 20 and ~~and~~ ^{requirements} for that combination of events failed him.

21 Q Was he trained to anticipate a hole in the system
 22 when he had a rising pressurizer level?

23 A No.

24 Q So in other words, under those circumstances, his
 25 pressurizer level told him he couldn't have a hole in the

1 system, didn't it?

2 A I think you have to separate it into two stages.
3 Early in the transient, there was a lot of, he had to
4 make some tough choices very fast--very trying. The
5 transient went on for 16 hours.

6 Q Okay. Early he should have caught on.

7 A There were a lot of people with a lot of
8 expertise.

9 Q Hasn't it been estimated that most of the core
10 damage took place during the first three hours?

11 A There certainly was a lot of damage caused early
12 in the accident, but the core stayed partially uncovered
13 for a long, long period of time. It was over 2,000
14 degrees evidently between 8 o'clock and 9 o'clock. There
15 was severe damage caused by that happening. How long it
16 stayed up there, I don't think we know.

17 Q But to come back to my question, hasn't it been
18 estimated that most of the core damage was done during the
19 first three hours? I am really trying to recall if that
20 is correct.

21 A Some people have said that, yes.

22 Q You have heard that statement made?

23 A From EPRI, yes.

24 Q Okay. Fine. EPRI is good enough for me.

25 A Not for me.

1 Q You mentioned the fact that the operator had to
2 make some choices pretty fast in the course of that
3 transient.

4 Why did he have to act so quickly under the
5 circumstances of that transient?

6 A Might be because his initial reactions were
7 wrong and it was also the need for ~~some~~^{fast} action was
8 exacerbated by the failure to have those valves open.

9 Q Is there anything about the B&W design that
10 calls upon the operator to act very quickly in the event
11 of a loss of feedwater?

12 A Certainly.

13 Q What is that?

14 A We have spoken to the ~~sense~~^{sensitivity --} that we as an agency
15 have spoken to the sensitivity of the design. It dries
16 out faster, the fact that its volume swings on secondary
17 side upsets are larger than the pressure and volume swings
18 from other PWRs. It is well documented in the B&W shutdown
19 orders.

20 Q All of that was pretty well documented prior to
21 the B&W shutdown, wasn't it?

22 A Do you mean prior to the accident?

23 Q Yes.

24 A Was that knowledge available, yes, yes, it was
25 available.

1 Q Was known prior to the accident that the boilout
2 rate of a once through steam generator under the
3 circumstances of loss of all feedwater was about two
4 minutes?

5 A That number certainly is amenable to calculation,
6 yes.

7 Q And was it known generally prior to the accident
8 that the same circumstances, the boilout time for the
9 recirculation steam generator was as much as 30 minutes?

10 A Yes.

11 Q Was it recognized then within the NRC prior to
12 March 28, 1979 that under those circumstances, the operator
13 would be called upon to respond much more quickly by a very
14 significant magnitude in the circumstances of a loss of
15 all feedwater under the B&W design as opposed to a
16 Westinghouse design, for example?

17 A Yes.

18 Q How could it come about that a system that
19 places so much more reliance on the operator, that requires
20 so much quicker response time, could still be considered
21 sufficiently safe by the NRC for purposes of licensing?

22 Why have a once through steam generator? Why
23 allow it?

24 A Well, you have to look at historical precedent
25 because it certainly plays a role in that question. The

1 sensitivity when they were first licensed was probably
2 not understood in that same light, and once you licensed
3 a couple, you started requiring more and more reliable
4 feedwater systems, ^{at that point} and ~~they haven't~~ ^{hadn't} generated all that
5 much operating experience to establish definitively what
6 you say is true.

7 It is still quite possible the once through
8 steam generator is completely acceptable for the future
9 with a reliable system and reliable control rooms, and
10 sufficiently good operator training, operator qualifications.

11 Q Well, you know, I still keep coming back to
12 that it sounds like what you are talking about is training
13 the operators up to the requirements of the once through
14 steam generators instead of opting for a design of steam
15 generator which does not place those kinds of demands on
16 the operators to begin with.

17 A Don't you support there were similar differences
18 between the 707 and the 747?

19 Q I really don't know.

20 A Of course there were.

21 Q All I am asking is why. You can think of lots
22 of reasons why the once through steam generator is not a
23 good idea. I have difficulty thinking of the reasons why
24 it is a good idea, and that is what I am asking.

25 Why have a once through steam generator? What

1 is the justification?

2 A Well, they are--you can make justifications.

3 Q As I understand the thermal efficiency of a once
4 through steam generator as opposed to recirculation is
5 on the order of 1 or 2 percent greater. Is that right?

6 A Must be something on that order.

7 Q So it is a very marginal improvement in terms
8 of the output. Are there other financial considerations?

9 A Not that I am aware of.

10 Q There is one. Now that I think of that, I think
11 it was explained that apparently the once through steam
12 of a steam generator producing superheated steam--but it
13 is extremely dry steam?

14 A That has to do with its efficiency.

15 Q And it does not require a further device which
16 the recirculation steam generator requires?

17 A That is just the economy. That is the same
18 reason as your first reason.

19 Q We are back to cost. Is there anything else
20 besides cost that makes the once through steam generator
21 better than the recirculation steam generator?

22 A Not to my knowledge.

23 Q We have got a situation then where again to be
24 as simple as possible, whereas one device which is less
25 efficient gives the operator as much as 30 minutes to react

1 in the event of a loss of all feedwater, and another device
2 which as I understand it even with the improvements that
3 have been made now, certain adjustments that have been
4 made since March 28, 1979, gives the operator as much as
5 5 minutes in the event of loss of all feedwater?

6 A No, no. You misunderstand. You can lose all
7 feedwater indefinitely on the B&W machine because of its
8 significant capability in the emergency core cooling system.
9 If he leaves the emergency core cooling system on, he
10 needn't use the auxiliary feedwater system.

11 Those analyses also show if you leave the
12 emergency core cooling system and the auxiliary feedwater
13 system both off for 20 minutes, you don't get into
14 difficulty, as long as you turn one of them on at the end
15 of 20 minutes.

16 Don't make it worse than it is. They boil dry
17 in 5 minutes. They won't go to hell in 5 minutes.

18 Q What I am referring to is the consequent emphasis
19 that this situation leads to in the operating procedures
20 for the operator to do something once he loses all feed-
21 water.

22 I have seen the emergency operating procedures
23 for TMI 2, for example, and I have been amazed at the
24 amount of the extent they are called upon to perform within
25 the first 30 seconds, the first minute.

1 Now perhaps operators can be trained to do that.
2 What I am wondering is why even consider the necessity of
3 training them to do that if the design doesn't need to be
4 set up that way?

5 A Well, you are suggesting a sort of best
6 achievable technology, and that is not the system of
7 regulation we have had. The words say no undue risk.

8 Q Okay. Why isn't it considered undue risk when
9 you could give the operator up to 30 minutes in reaction
10 time and instead you opt for a design that gives him much
11 less in terms of normal attempts to bring the plant back
12 to operating condition? Why have that situation? Isn't
13 that an undue risk? It is not necessary to incur it,
14 right?

15 A It is a different risk.

16 Q Okay. It is an unnecessary risk, isn't it?

17 A Depends on whether you are a B&W owner or not.

18 Q Are you aware of any reason why B&W couldn't
19 adopt a recirculation steam generator in its design?

20 A No, but I haven't really studied the question.

21 Q Okay. Maybe there is some reason. Maybe it is
22 patented or something, but I am not aware of any and it
23 comes back to the question of man-machine interface,
24 doesn't it? Once through generator works fine if the
25 operator is well trained enough to work with it, but it

1 can pose this situation.

2 What if you put a passive feedwater system on a
3 once through steam generator, a big accumulator. I suppose
4 that would solve the boilout problem, would it?

5 A Yes.

6 Q And give much longer boilout time?

7 A Yes, but also drastically increase the propensity
8 to overflow the secondary side, which also has difficulties.

9 Q It doesn't pose the same difficulty of saturation
10 in the primary system and uncovering the core, though, does
11 it?

12 A Not unless it breaks the secondary system and
13 you have got an uncontrolled discharge from primary and
14 secondary, and then you haven't got anything.

15 Q The reason I ask these questions is because it
16 comes back to the best illustration of it in the TMI 2
17 incident. Eight minutes into the event the operators
18 discovered that the valves for the auxiliary feedwater
19 system were closed, and they opened them and they got
20 this auxiliary feedback, as I understand it.

21 If they had a recirculation steam generator with
22 a 30 minute boilout time, they would have made it, wouldn't
23 they? It would have gotten the auxiliary feedback?

24 A Not if it sat there for 16 hours with the PORV
25 open.

1 Q They would have gotten it before they had a
2 boil dry in that situation, right, in the steam generator,
3 and therefore isn't it likely they wouldn't have challenged
4 the PORV to begin with?

5 A No.

6 Q Hasn't that been the experience in the Westinghouse
7 plant, that they have had almost no challenges to the
8 PORV's compared to B&W plants?

9 A They don't use them for the maneuvering mechanism
10 to the same extent that B&W does with the integrated control
11 system. The PORV doesn't open because the steam generator
12 boils dry.

13 PORV's have opened in B&W plants a total of 150
14 times because they are used as a maneuvering device in
15 conjunction with the integrated control system.

16 Q What do you mean by maneuvering device?

17 A To avoid SCRAMming the reactor upon ^{loss} ~~SCRAM~~ of
18 the secondary side.

19 Q This is another aspect of it, isn't it? The
20 B&W design philosophy up until now has been to not have an
21 anticipatory reactor SCRAM upon a turbine trip?

22 The Westinghouse philosophy has been to have the
23 anticipatory reactor SCRAM upon turbine trip?

24 A Hence fewer challenges of the PORV.

25 Q And more reactor SCRAMs?

1 A That's right.

2 Q Okay. It is obvious from the TMI 2 situation
3 and the steps that have been taken since then that
4 presumable the NRC now recognizes that the Westinghouse
5 philosophy in this particular area is more desirable from
6 a safety point of view?

7 A I think so.

8 Q Okay. Again, the question becomes why was that
9 fact not appreciated prior to March 28, 1979? Again wasn't
10 it clear that that type of situation, no anticipatory trip,
11 placed the operator in a situation where he could have his
12 steam generator boil dry and he could have his reactor
13 not trip for a certain period of time after his turbine
14 did trip as a result of the boildry situation, and therefore
15 again be faced with a situation where his PORV is going
16 to be challenged and get a break in the preliminary system?

17 A It wasn't put together that way by anyone I know.

18 Q Okay. All right. Just so I can leave that
19 subject, what is your best explanation for why it wasn't
20 put together that way?

21 A I am not sure why the designer didn't put it
22 together that way. The staff had never reviewed the
23 integrated control system, the PORV, or the operating
24 history with bad PORV performance, and had never systematical
25 put all those things together, hadn't studied them

1 individually, let alone put them together systematically.

2 Q Let me ask you this. The OL was issued for
3 TMI 2 in February 8, 1978. If in connection with that OL
4 issuance say toward the middle or say the end of 1977
5 B&W was, had been required to submit a history of the
6 operation of the PORV in its plants of the once through
7 steam generator and of its boilout rate and things of that
8 nature, complete documentation of the history of these
9 various devices as they had previously performed in B&W
10 plants, wouldn't that have indicated that something should
11 be done about this design, based on what you know today?

12 A The OL review was finished significantly in
13 advance of the time the OL was finished.

14 Q Six months.

15 A More than a year.

16 Q A year before?

17 A Oh, yes. What is the date on the SER?

18 Q September of '76, something like that.

19 A That is when the OL review was done except for
20 picking up a few loose ends, two years before.

21 Q Doesn't that create a situation where you have
22 that kind of time lag between the safety analysis or safety
23 evaluation and the actual issuance of the OL that further
24 events have occurred, the knowledge and data have become
25 available that indicate something should be done in

1 connection with that OL issuance for the conditions, for
2 the requirement, something like that?

3 A Yes. I agree with that.

4 Q And yet they are not incorporated because of
5 safety evaluation, something done earlier? Why is the SER
6 prepared so much in advance of the OL issuance?

7 A We tried to gear the SER to be finished at the
8 time they are ready to operate, and you do the best you can
9 to review everything you can get in there between now and
10 whenever that end date is.

11 Q Why isn't it possible to require the applicant
12 to submit a supplemental FSAR to cover that time lag period
13 between the SER and OL issuance?

14 A For long delays, that has become the standard
15 practice. Salem 2, for example, was significantly delayed
16 beyond Salem 1, and the staff did another review, with
17 Salem 2 not yet complete. As a matter of fact, Salem 2 is
18 ready to operate, and that review is not done.

19 Q When you say for long time lags, we are talking
20 about the difference between September, 1976 and February,
21 1978. That is about 14, 15 months. That would not qualify
22 as one of those long periods of time?

23 A No, still wouldn't, not today, not under current
24 practice. I am not arguing with your proposal. That isn't
25 where I would start. It is a decent proposal.

1 Q Where would you start in terms of the licensing
2 process?

3 A Something like all OL's to be issued after
4 January 1, 1990 shall have a full demonstration of
5 conformance to the Standard Review Plan and reasons why not,
6 plus anything that has been added to the plant as a result
7 of Three Mile Island.

8 Q You would say that regardless of when the
9 facility obtained its construction permit?

10 A That's right.

11 Q So that could lead to a situation in which the
12 utility has invested millions of dollars building a plant
13 according to the construction permit obtained in 1970,
14 and now comes along and submits its application, has the
15 bad luck I guess from their point of view to submit their
16 application after January 1, 1980. and you require them
17 to backfit all that stuff from the Standard Review Plan
18 or otherwise justify it?

19 A That's right.

20 Q Wouldn't that place a tremendous economic burden
21 on the utility?

22 A Tremendous.

23 A But you would at this point elect to incur that?

24 A Lacking some other approach. Then after it was
25 in operation, I would do the suggestion that you made about

1 ten minutes ago.

2 Q Which one was that?

3 A Require every vender to consider requiring every
4 vender to go back through the performance history of his
5 design, all safety and non-safety aspects of the design,
6 and demonstrate conformance with some sort of overall
7 reliability criteria involving frequency of challenge to
8 safety systems and performance of safety systems.

9 Q You don't think that all of that is going to
10 place a crushing burden on the nuclear industry?

11 A It may.

12 Q You say it may. Don't you think that somebody
13 has to give some careful consideration to that before
14 allowing that situation to occur?

15 A Lessons Learned is doing that right now.

16 Q In terms of the economic burden to be placed on
17 the industry?

18 A No--looking at what is necessary.

19 Q You don't see that as a function of the NRC, to
20 assess the financial burden to be placed on the industry?

21 A We can't do what we require blindly. We must
22 understand something of the practicality of what we propose.

23 Q Hasn't that been the view all along within the
24 NRC that you can't do it blindly and you have got to
25 consider burden on the industry, and as a matter of fact, I

1 think you were explaining to me that was the consideration
2 in regard to backfitting requirements of the SRP to plants
3 of the vintage of TMI 2, wasn't it?

4 A I am suggesting what was a burden before may
5 not be a burden today.

6 Q If nothing else, it is probably more of a burden
7 since probably it costs more today than five years ago to
8 do the same backfitting?

9 A The definition of what is a burden today is
10 different than what was a burden before.

11 Q Okay. The burden before was substantially
12 increased expense to the utility, wasn't it?

13 A - That plus some practical considerations about
14 what the staff was capable of reviewing itself.

15 Q Have those practical considerations as to what
16 the staff is capable of reviewing changed since then,
17 since say 1975?

18 A Yes, because in 1975 people still thought that
19 there would be a sizable workload from construction permit
20 applications.

21 Q And there hasn't been?

22 A Oh, yes, there has been, since 1975.

23 Q In terms of the capabilities of the staff to
24 deal with these problems in terms of lighter workload and
25 more time to devote?

1 A I think they are going to have more in the
2 future.

3 Q But that has not occurred since 1975; the
4 workload has gotten heavier, hasn't it?

5 A Not CP workload.

6 Q But OL workload?

7 A Definitely.

8 Q And there hasn't been any substantial increases
9 in the size of the NRC staff at that time, has there?

10 A Not substantial, not as many as are necessary.

11 Q Something else, well, I covered it in the
12 deposition I have already had with Harley Silver, which
13 was the issuance of an operating license for TMI 2 with
14 a number of open items designated in the OL. There are
15 some 13 to 15 items that were outstanding in connection
16 with TMI 2, and I was curious in that Mr. Silver's comments
17 were to the effect this is not unusual.

18 A That is a small number compared to what has been
19 standard practice since then.

20 Q Where has the concept developed from the NRC
21 of issuing an operating license for a facility which still
22 has open unresolved open items relating to safety?

23 A Well, some of them issue an OL in order to
24 permit fuel loading to go ahead because the issue that
25 they affect is only of safety significance when the plant

1 is at power. The plant is not at power when it is loading
2 fuel. There are some that fall into that category.

3 Some of them in just a basic sense of equity
4 were not found to be necessary until very late in that
5 plant review. An unresolved safety issue was included.
6 As an example, if they said widgets ought to be all painted
7 blue, and later OL's are all green, and all the operating
8 plants are green, well, here is this fellow with this
9 billion dollars invested, as you described, and the only
10 difference between him and an operating plant is that guy
11 is getting a return on his dollar and this guy is not.
12 It is going to take the same amount of time to paint them
13 blue. If you are not going to shut other guys down when
14 they paint, then why hold up the one fellow from operation
15 while he is painting his from green to blue, so you give
16 him a deadline and go into operation, and as soon as
17 practical, he accomplishes the change. That is the
18 concept. You don't have to argue with it.

19 Q I feel compelled to respond to your question
20 why hold that guy up. If the determination is made that
21 there is a safety factor in not having them all painted
22 blue, why increase it?

23 A There is a safety factor in everything we do.
24 There are gradations in it. There are some that are
25 important enough to shut a plant down, and some that are not.

1 We like the ones even though they are not important enough
2 to shut a plant down, so we require them to be done, we
3 give people a reasonable time to implement them. If you
4 give an operating plant a reasonable time to implement them
5 and you have got another plant that is finished
6 construction and is ready to operate, why shouldn't he have
7 a reasonable time if it can be shown there is no radiation
8 consequence to workers as a result of giving him the
9 opportunity to go into operation before the change is
10 accomplished?

11 Q That demonstration is required?

12 A That kind of review is conducted to make sure
13 you are not causing a problem ⁻⁻ that you don't foreclose
14 options by letting them go into operation. The options
15 are not foreclosed, and the decision usually is to let
16 them go into operation.

17 Q And so as a practical matter, the practice of
18 issuing OL's with open items relating to safety has become
19 standard practice?

20 A Yes. I might caution there that I have been
21 propounding that philosophy to the Commission on the lessons
22 learned and have run into a fair amount of static. It
23 surprised me. Gilinsky accused me of overturning the
24 regulatory precedent of the past where we always required
25 more of new OL's than we did of past OL's, and my answer

1 to that is yes, we do, but not when they are already
2 finished construction and they are ready to operate. Then
3 we tend to think of them as being an operating plant unless
4 we are going to foreclose an option by letting them go
5 into operation. They have got the same option as the
6 operating plants. Therefore, they are at the same risk
7 as the operating plant. My choice would be to let them
8 go into operation.

9 I understand there are people who don't feel
10 that way. You seem to be one of them.

11 Q I guess my attitude on that again is a very
12 simplistic one.

13 A If you can't allow them to stay in operation, if
14 you can allow them to stay in operation and be truthful
15 ^{that} it is not that important a safety problem, and if it is
16 ^A that important a safety problem, then be truthful and shut
17 them down until they get it fixed--all of them, not just
18 the one that is waiting to go into operation. I am arguing
19 for consistency.

20 Q I understand. On the other hand, I am not so
21 certain that consistency is necessarily what happens,
22 that is achieved here.

23 A It is when you are making a very judgmental
24 finding on safety because it is, by God, one of the few
25 yardsticks you have got when all you have ^{for legislation} ~~as evidence~~ is

1 ^{the words}
no undue risk.

2 ^

Q Let me ask you about something else.

3 A No undue risk is an historical judgment, and it
4 changes depending upon who is exercising it, and the best
5 yardstick I have got in making that judgment is what people
6 have done 20 years prior to my sitting at this desk. Take
7 that yardstick away from me and I haven't got much else.

8 Q We have been talking all day about the problems
9 with that yardstick, haven't we?

10 A Yes.

11 Q Okay. Let me ask you about something else you
12 mentioned before.

13 A - Don't make it worse.

14 Q Okay. Let me ask you in terms of the transfer
15 of TMI from the Division of Project Management to the
16 Division of Operating Reactors, what happens if that
17 transfer is not accomplished after the OL is issued for a
18 project?

19 It is my understanding that the TMI 2 facility
20 was not formally transferred from the Division of Project
21 Management to the Division of Operating Reactors right up
22 to the day of the accident, March 28, 1979, and I believe
23 Harley Silver told me that that has now either been
24 accomplished or will be accomplished very shortly, but it
25 was not done after the OL was issued in February of 1978.

1 In what position in terms of regulatory
2 supervision does that place a facility when it has got
3 its OL, but hasn't been transferred to DOR?

4 A It is in a diminished state, doesn't have the
5 full attention that DOR pays to a normal operating reactor,
6 nor does it have the full attention that DPM pays to a
7 normal plant under construction. The focus of DPM is the
8 granting of licenses and the priorities and resources are
9 set to meet those ends, so it is ~~in~~ⁱⁿ limbo. That is an
10 overstatement, but it is somewhere between full attention
11 in DPM or full attention in DOR.

12 To compensate for that, DOR people do begin to
13 take cognizance of a plant before the transfer occurs by
14 some months usually, plus DSS maintains its on-call
15 cognizance, that is, we solve technical problems that people
16 direct to us from the time that they first apply for a CP
17 until it is ~~decommissioned~~^{decommissioned} in theory. We never lose track of a
18 plant, but we are a step removed from those licensing
19 organizations.

20 Q Perhaps this relates to what we were just talking
21 about. If I understood Mr. Silver's explanation for why
22 the transfer did not occur, it had to do in part at least
23 with the nature and number of the open items that were
24 designated in connection with the OL at the time it was
25 issued and reluctance upon DOR to assume responsibility

1 for following up on a lot of those open items.

2 There was a question about how the work should
3 be allocated and that DOR felt a bit pressed at the time
4 and did not want to take all that added responsibility on
5 itself.

6 A We resolved that resource problem about a year
7 ago by agreement on my part to maintain responsibility
8 for closing the open items after the transfer had occurred.
9 That is, the technical review resources to finish the closing
10 of open items would come from DSS and not DOR. That was
11 DOR's reluctance several years ago at accepting transfer,
12 but that was something I recognized fairly early as solvable,
13 and something that we should retain responsibility for.

14 Q That is curious because when Harley Silver told
15 me this question would have come up around April of 1978,
16 which was about the time that there was a draft memorandum
17 prepared that was designed to--

18 A The resolution that I am referring to probably
19 occurred about a year ago now, last summer, early last
20 fall.

21 Q A few months after, I see.

22 A And the fact that TMI had not transferred at
23 that date along with some others was the genesis of reaching
24 that agreement.

25 Q To prevent that situation from occurring?

1 A My concern was the plant laying in this status
2 between full responsibility in DPM and full responsibility
3 in DOR.

4 Q Why did it come about that TMI 2 pursuant to
5 policy, was that transferred to DOR?

6 A I don't know.

7 Q Okay.



8 A Some others that were in that backlog were
9 transferred. I am not certain why Three Mile was not.

10 Q All right. Let me ask you one or two more things.
11 I am just about finished. We have received a summary of
12 Westinghouse responses to I&E bulletin No. 7906A prepared
13 by Mr. Anderson, the manager of the Nuclear Safety
14 Department at Westinghouse, and on the 16th page--that is
15 not numbered, but it has under No. 12 hydrogen gas
16 generation and control, and it states some limits, modes
17 for removing hydrogen and core cooling with a non-
18 condensible gas bubble in the upper head--it is a fairly
19 brief presentation.


20 I wonder if you could look at this and first
21 of all, have you ever seen this document before?

22 A I am sure a copy was given to me. I haven't
23 read it.



24 Q Okay. You see the reference up at the top to
25 50 CFR?



**IMAGE EVALUATION
TEST TARGET (MT-3)**



MICROCOPY RESOLUTION TEST CHART



1 A Ten CFR, 50.46.

2 Q Is that a reference to some very conservative
3 hydrogen computations that have been done in the past?

4 A No. That is regulation that governs the designs
5 of emergency core cooling systems.

6 Q In connection with hydrogen generation?

7 A It says that there shall be less than 1 percent
8 clad metal water reaction for all loss of coolant accidents.

9 Q All right.

10 A That is a limit on the performance of the emergency
11 core cooling system.

12 Q I don't find any reference in those pages to
13 recombiners being available. I wonder does that mean
14 Westinghouse is intending to proceed without recombiners
15 available in response to the hydrogen problem?

16 A Well, I can't believe that is true because
17 Westinghouse is the only design that provides recombiners
18 inside of containment, redundant, what have you.

19 Westinghouse does a good job with recombiners.
20 They provided a recombiner design before they were required
21 by AEC.

22 Q All right. I was just curious about that. Let
23 me ask you finally about two documents you previously
24 supplied here. One is a memorandum dated June 29, 1973
25 from Lawrence Phillips, Acting Branch Chief, Analysis

1 Branch, Division of Systems Safety, to Mr. Richard
2 Denise, Acting Assistant Director for Reactor Safety,
3 Division of Systems Safety.

4 The subject is documentation of TMI 2 benchmark
5 calculations.

6 Could you just explain for the record what this
7 document is?

8 A Well, there have been calculations done under
9 the cognizance of the Analysis Branch in DSS, some scoping
10 calculations within the branch, and other calculations by
11 computer codes ^{that} INEL did, and Mr. Phillips and his
12 memorandum are documenting for the record who performed
13 what calculations, and what they showed, and comparing
14 them with ~~the~~ calculations done by B&W using several of the
15 B&W codes.

16 He points out where there are inconsistencies
17 and consistencies, and points out the uncertainties in the
18 benchmark calculations.

19 Q Okay. I just wanted to get an explanation on the
20 record. I think this related to what we were talking
21 about before.

22 A You had asked earlier for what kind of analysis
23 had been done.

24 Q The other thing you have produced here today is
25 a memorandum dated July 7, 1979 from Warren Minners to

1 you, the subject being trip report, TMI systems thermal
2 hydraulic analysis meeting, July 11 and 12, 1979, Palo
3 Alto, California.

4 What is this memorandum and how does it relate
5 to what we have been talking about?

6 A Again, ~~this is~~ you asked for a summary of the
7 kind of analyses that we knew were going on ^{for} ~~at~~ the TMI 2
8 accident, and this is a report of a trip that Mr. Minners
9 took to a meeting with EPRI in July where results were
10 presented by the folks from NRC who were doing these
11 calculations for the special inquiry, and people from INEL,
12 ^{and} Los Alamos, presented the work that they were doing and
13 GPU and EPRI talked about some analyses that they were
14 doing, and it gives a summary, overview of the status of
15 those computations.

16 MR. KANE: Let's have this memorandum dated June
17 29, 1979 marked as Exhibit 2 to this deposition, and the
18 one dated July 17, 1979 marked as Exhibit 3.

19 (Mattson Exhibits Nos. 2 & 3
20 were marked for identification.)

21 MR. KANE: I have no more questions, Mr. Mattson.
22 Mr. Chopko, do you have any questions?

23 MR. CHOPKO: No questions.

24 MR. KANE: Let me say, Mr. Mattson, I have
25 appreciated your being available to us all day long, as

1 you have been today. This is an on-going investigation.
2 and although I have asked all my questions at the present
3 time, there may be facts that we will discover in the
4 future which will necessitate having to bring you in for
5 another deposition.

6 I certainly can assure you we will make every
7 effort to avoid having to do that. However, should it
8 prove necessary, we will be in touch with you again. For
9 that reason, we will adjourn the deposition rather than
10 terminate it with the thought that we may have to resume
11 it at some time in the future, and once again, I thank you
12 very much for your time.

13 THE WITNESS: You're welcome.

14 (Whereupon, at 4:42 p.m., the deposition of
15 Mr. Mattson was recessed.)
16
17
18
19
20
21
22
23
24
25

REPORTER'S CERTIFICATE

1
2
3
4 DOCKET NUMBER:

5 CASE TITLE: DEPOSITION OF ROGER J. MATTSON

6 HEARING DATE: August 6, 1979

7 LOCATION: Bethesda, Maryland
8

9 I hereby certify that the proceedings and evidence
10 herein are contained fully and accurately in the notes
11 taken by me at the hearing in the above case before the
12 PRESIDENT'S COMMISSION ON THE ACCIDENT AT THREE MILE
ISLAND
13 and that this is a true and correct transcript of the
14 same.
15
16

17 Date: August 8, 1979

18
19 *Rita Smith*
20 Official Reporter
21 Acme Reporting Company, Inc.
1411 K Street, N.W. Suite 600
Washington, D.C. 20005
22
23
24
25

PROFESSIONAL QUALIFICATIONS
Roger J. Mattson

SUMMARY

Professional experience ranges from mechanical engineering design and thermal-hydraulic analysis of research reactors and nuclear power reactors to senior line management positions in regulatory standards and power plant licensing. Activities have included routine interactions with officials of NRC, other Federal agencies, International Atomic Energy Agency, Congress, State governments, electric utility industry, commercial nuclear industry, professional societies, academic institutions, and consumer and public interest groups. Academic training through a PhD in mechanical engineering ranging from structural design and mechanical dynamics to advanced fluid mechanics and heat transfer.

EXPERIENCE

July 1977 to Present - Director, Division of Systems Safety, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Career executive position with senior line management responsibility for conduct of technical reviews and evaluations of applications for construction permits and operating licenses for nuclear power plants. Responsible for the development of regulatory requirements and policies for reactor safety, including membership on the NRC's Regulatory Requirements Review Committee and Technical Activities Steering Committee. Technical scope of the Division includes reactor systems, core performance, reactor analysis, containment systems, materials engineering, mechanical engineering, structural engineering, instrumentation and control systems, power systems, and auxiliary systems.

June 1975 to July 1977 - Director, Division of Siting, Health and Safeguards Standards, Office of Standards Development, U.S. Nuclear Regulatory Commission. Career executive position with senior line management responsibility spanning the nonengineering or software areas of the NRC standards development activities. Responsible for planning and direction of the development of regulations and other standards to protect employees of NRC licensees, the public, and the environment from the effects of activities regulated under the Atomic Energy Act, in conjunction with the National Environmental Policy Act. Technical subjects included in scope of responsibility were: energy facility siting, land use and regional planning, environmental modeling, effects of chemical and thermal effluents, emergency preparedness, economics of nuclear and other fuel cycles, geology, seismology, hydrology, meteorology, radiobiology, radiation health physics, physical security systems for sabotage and theft protection, and control and accounting of special nuclear material.

August 1974 to June 1975 - Assistant Director for Site and Health Standards, Office of Standards Development, U.S. Atomic Energy Commission until January 1975, then U.S. Nuclear Regulatory Commission. Mid-management position with scope including nuclear facility siting and environmental effects, radiation protection of workers and the public, transportation safety, and consumer product safety.

February 1974 to August 1974 - Technical Assistant to Commissioner William O. Doub, U.S. Atomic Energy Commission. Advised the Commissioner in connection with the formulation of AEC programs and policies. Acquired broad knowledge of nuclear and other energy producing fuel cycles, and of nuclear weapons, including detailed understanding of AEC policy, organization, procedures, and personnel with emphasis on the regulatory process, reactor safety, and safeguarding of nuclear materials against theft or sabotage.

February 1972 to February 1974 - Nuclear Engineer and then Section Leader, Reactor Systems Branch, Directorate of Licensing, AEC. General function was thermal and hydraulics reviews, analyses and evaluations of nuclear power reactors and associated safety systems. Responsibilities included administration of research programs. Experience led to in-depth, internationally recognized expertise in safety systems for light water power reactors, especially emergency core cooling systems.

September 1969 to January 1972 - Graduate Student and Research Assistant, Department of Mechanical Engineering, University of Michigan; on leave from AEC. Thesis in boiling heat transfer and multiphase flow for pressurized water reactors.

June 1967 to August 1969 - Reactor Engineer, Reactor Technology Branch, Licensing, AEC. Responsibilities included technical review and evaluation of nuclear power reactor safety systems and management of research programs, including emergency core cooling, reactor containment, auxiliary cooling, reactor core thermal-hydraulic design and shutdown cooling.

March 1964 to May 1967 - Technical staff member, Sandia Corporation, Albuquerque, New Mexico. Responsibilities included design of components and irradiation effects experiments for advanced research reactors and other facilities simulating nuclear weapons environment.

EDUCATION

PhD, Mechanical Engineering, University of Michigan, 1972
 MS, Mechanical Engineering, University of New Mexico, 1966
 BS with Distinction, Mechanical Engineering, University of Nebraska, 1964

HONORS

Meritorious Service Award, USNRC, October 1976 for management leadership in area of intergovernmental responsibilities for energy facility siting.
 Special Commendation from AEC Chairman for testimony in "nuclear moratorium" suit (Nader v. Ray), July 1973
 National Science Foundation Graduate Fellowship, 1971
 Pi Tau Sigma - Mechanical Engineering Honors Society
 Sigma Tau - Engineering Honors Society
 Pi Mu Epsilon - Mathematics Honors Society
 Sigma Xi - Scientific Honors Society

NRR. LESSONS LEARNED TASK FORCE _ DISTRIBUTION LIST

Roger Mattson, OSS	P-1102 ←
Robert Tedesco, RS	P-1122
Warren Minners, OSS	P-1102
Richard Ireland, RS	P-1122
Charles Long, PS	P-822
Tom Teleford, OOR	530
John Olshinski, RSB	P-1132
Jose Calve, PSB	P-832
John Vogelwede, CPB	P-1114
Bill Milstead, CSB	P-904
Harley Silver, OPM	116-C
Jim Conran, OPM	243
Rh Phillip Stoddart, ETSB	P-730
Harry Krug, RAB	P-712
Gary Holahan, AB	P-1030
Leo Beltracchi, ICSB	P-722
Jerry Holman, OLB	357
Larry Chandler, ELD	MN88 9604
Jim Milhoan, SD	P-1102
Bob Cudlin, RES	1130SS
Terry Harpster, IE	P-1102
Lake Barrett, OOR	238



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUN 23 1979

~~1/2 Inland~~
1/2 Inland
a) Dsc. Control
b) Issues to continue
Task Force
R

MEMORANDUM FOR: Richard P. Denise, Acting Assistant Director
for Reactor Safety
Division of Systems Safety

FROM: Laurence Phillips, Acting Branch Chief
Analysis Branch
Division of Systems Safety

SUBJECT: DOCUMENTATION OF TMI-2 BENCHMARK CALCULATIONS

Since the first few days after the TMI-2 accident, several calculations were performed in the Reactor Analysis Section of AB. The purpose of this memo is to document these calculations and to point out conclusions and questions which may be considered for further study by the task forces now assigned to the TMI-2 review.

(1) Core Uncovery Calculations

Based on studies of the plant process data which were plotted for the period immediately after the accident, it was concluded that core uncovery first occurred at 105 minutes after turbine trip. This was indicated by primary coolant temperature data and steam generator pressure data which indicated a loss of primary to secondary heat transfer, therefore inferring cessation of primary coolant circulation and condensation in the steam generator. Subcooling of primary coolant had ceased at approximately sixty minutes after the event, and all reactor coolant circulation pumps were turned off by 100 minutes.

Calculations were performed to estimate the necessary primary coolant mass discharge rate to achieve top of the core uncovery at 105 minutes. The calculations were based on the RCS pressure history and the assumptions which follow:

- (1) No HPI coolant after approximately eight minutes.
- (2) Mass discharge rate varied as the square root of the pressure times density product,
- (3) All liquid mass above the core exit elevation (including pressurizer) was discharged at 105 minutes.

Results of these calculations are indicated in Figure 1 and show that a mass discharge rate of 395,000 lbm/hour (rated @2250 psi) would be required. This compares to a rated steam discharge rate of 118,000 lbm/hour @2250 psi through the power operated relief valve (PORV).

Since the required mass discharge could not be achieved by steam flow through the PORV alone, the effect of varying the discharge quality using various critical flow models was studied. These results are indicated in Figure 2.

It was concluded that very nearly 100 percent liquid discharge and little or no HPI flow for the 100 minutes preceding core uncover would be required to explain the system mass loss by discharge through the PORV alone. Since the new HPI flow (in excess of letdown flow) is believed to have been 30 to 100 gpm or more during this period and since continuous discharge of very low quality coolant through the PORV for this entire interval is highly unlikely, a leakage source other than normal PORV discharge is inferred by these calculations. Additionally, later compilations of sequence of events data show that the Reactor Building Sump high level alarm (4.650 feet above the bottom of the sump) was received at about eleven minutes after turbine trip. Since the rupture diaphragm on the reactor coolant drain tank did not burst until fifteen minutes, PORV discharge does not explain the high building water level.

The core uncover calculation was continued based on steam generation as a function of the decay heat rate and the portion of the core covered. The predicted core steaming rate during the core uncover interval is given in Figure 3 based on (a) mass and energy conservation calculations and (b) mass and volume conservation calculations. The corresponding plots of core water level are given in Figure 4; an early B&W estimate of the core water level is also indicated on the plot. The plots indicate that the minimum core water level during this interval was no more than three feet and may have been below the bottom of the core.

Corresponding core heat-up calculations during the uncover interval were performed using TOODEE. These calculations indicate that the clad melting point occurred in advance of total zirconium oxidation. More details of the core heat-up results will be documented separately.

(2) Once Through Steam Generator Heat Sink Capacity

Calculations were performed to estimate the effects of PORV setpoint and reactor trip response on the response of once through steam generators to the Loss of Feedwater Transient, assuming that no auxiliary feedwater is available. Design data for the Midland plant were used as the basis for the calculations. Three cases are tabulated in Table I. Case 1 assumes pre-TMI setpoints for PORV pressure relief and for reactor trip. Case 2 assumes a reduction in the overpressure reactor trip setpoint to 2300 psig, versus a 2450 psig higher setpoint for the PORV which

may preclude its opening during the transient. Case 3 further reduces the time to reactor trip by providing a reactor trip on turbine trip.

An energy balance was performed for the first 110 seconds of the transient, which was the time required to boil the steam generator dry for Case 1. Steam generator heat transfer response and the minimum primary coolant temperature of 552F corresponding to secondary steam pressure control conditions were taken from B&W calculations of the transient. Decay heat rates are based on 1971 ANS data with a best estimate multiplier of 0.9. A feedwater coastdown of 10 seconds is assumed.

For Case 1, the primary heat sources including stored energy released when the primary system drops from 582F average temperature to 552F provide sufficient energy to boil dry the 109,000 pounds of mass in the steam generator and to produce 592F superheated steam at an assumed saturation pressure of 1020 psia. However, it is important to note that the steam generator dry out process has reduced the energy level of the system so that 538 seconds of decay heat would be required to return the primary system to initial average temperature of 582F. Therefore, initiation of auxiliary feedwater could be delayed up to nine minutes without rise in the primary system energy level above the initial level.

Case 2 results in about one second earlier trip time and corresponding reduction in the full power seconds generated after turbine trip. Three percent of the steam generator coolant inventory remains available at 110 seconds, and approximately 585 seconds of decay heat are required to restore the system to its initial energy level at 582F.

Case 3 results in instantaneous trip with less than one second at full power. The primary coolant system is reduced to the assumed minimum temperature of 552F (secondary saturation temperature is 547F) with 29 percent of the secondary coolant inventory remaining. Approximately 17 minutes of decay heat are required to boil the balance of steam generator coolant and restore the system to its initial energy level of 582F.

It can be concluded that the early trip time is equivalent to increasing the steam generator coolant inventory by: $.29 \times 109,000 = 31,610$ pounds. Typical steam generator coolant inventory and boil-off data were computed for loss of ac/dc Power Task Action Plan A-30 as follows:

<u>Plant</u>	<u>Type</u>	<u>Power (Mw)</u>	<u>S.G. Mass (lb.)</u>	<u>Time to Boil Dry*</u>
Midland	B&W	2552	92000	17 minutes
St. Lucie	CE	2570	253000	61 minutes
Zion	W	3238	357146	70 minutes

*Assumed 1971 ANS decay heat with no multiplier.

JUN 20 1979

It is clear that an early reactor trip setting is of little significance to the post-accident response of CE and W steam generators with large coolant inventory, even if auxiliary feedwater is not available. For B&W steam generators with low water inventory (probably less than the design value), an early trip would significantly delay the occurrence of steam generator dry out and provide more time for initiation of auxiliary feedwater.

It is also noteworthy that the steam generator coolant inventory depletion can be delayed by higher secondary pressure relief setpoints (CE vs. B&W). However, higher secondary pressure also limits the primary cooling at a higher temperature level, so that less time is required to reheat the primary system if the heat sink is lost. Therefore, there appears to be no ultimate advantage to higher secondary pressure relief setpoints.

(3) Evaluation of TMI-2 Benchmark Calculations

It was noted that both B&W and INEL benchmark calculations produced over-cooling of the primary system during the first two minutes of the transient. An energy balance based on plant process data was performed by hand calculations for the intervals (0-110) sec., (110-300) sec., (300-360) sec., and (360-540) sec., in order to better understand the indicated transient and reasons for the error in computer models.

Table II is a tabulation of the bases and results for the Reactor Coolant System (RCS) energy balance calculations.

The steam generator mass, including feedwater added during a linear ten second coastdown, was depleted during the (0-110) second interval. Mass inventory of 55,970 pounds was computed from the measured level of 160 inches based on a shell side flow area of 44.4 ft.² in each steam generator. This compares to a B&W reported mass of 97,000 pounds which is believed to have been used in their benchmark calculations. The difference of 41,030 pounds is believed due to the difference between actual heat transfer performance and design heat transfer performance. Better performance results in lower liquid level in a once through steam generator. The additional mass would correspond to an added heat sink of approximately 30,000 Mw-sec and would lead to an over prediction of the Reactor Coolant System cooldown during steam generator dry out. In fact, the LOFW analysis would look like Case 1 of Table I with the RCS cooled to 552F compared to the measured temperature of 577F. The sensitivity of safety analyses to assumed mass inventory of the steam generator should be considered in future review of plants having once through steam generators.

The energy balance during the first 110 seconds resulted in excess energy of 1495 Mw-sec. Decay heat energy is believed to be at least as great as the estimate and possibly 10 percent more. Uncertainty in the number of full power seconds or in the steam generator heat sink could account for

JUN 23 1978

the deficit. For the purposes of the tabulation, the amount of steam that could be generated by the excess energy of 13.6 Mwt each second is assumed to flash and discharge through an unidentified leak (e.g., a steam generator tube).

One peculiar aspect of the TMI-2 data is the mismatch in reactor coolant cold leg temperatures at the start of the transient. Loop A was at 563F while Loop B was at 557F. The control system would normally be expected to maintain a much closer match between these temperatures; e.g., ± 2 F, and the reason for this condition should be investigated.

The (110-300) second time interval should be ideal for an energy balance. During this interval, the HPI was known to be operating at full capacity and was the only heat sink other than normal heat loss to the containment. The RCS average temperature was nearly constant during this interval. The only heat sources were decay heat (estimated uncertainty of $-0 + 10\%$) and the reactor coolant pumps. This heat balance shows a large deficit of 6219 Mw-sec or 27.5 Mwt per second. The only plausible explanation of the deficit is flashing of the primary coolant. Since at least 10F subcooling is indicated during this interval, flashing could only occur at a leak location. Leakage through the stuck open PORV would be supplied by flashing in the pressurizer, which was analyzed separately from the RCS heat balance. Leakage flow rate for this energy deficit would be 47.3 pounds per second of steam, compared to 26.9 pounds per second for the deficit indicated during the first 110 seconds.

The balance was continued for the interval of (300-360) seconds when the RCS temperature rises to 562F and reaches saturation temperature. An energy deficit of 12 Mwt per second (equivalent steam leakage of 19.3 pounds per second) is indicated for this interval. However, there was greater uncertainty in the HPI coolant injection rate and in the energy supplied to the reactor coolant system during the reheating. A calculation performed for the six to nine minute interval with RCS at saturation and rising in temperature showed only a 3.6 Mwt/sec deficit, indicative of very little flashing during that period. The latter result is surprising and possibly indicative of lower quality leakage from the saturated system. However, the calculations may be in error after six minutes since the pressurizer cannot be properly separated from the RCS heat balance after saturation is reached.

Table III is an energy balance of the pressurizer to evaluate the calculated leakage and the calculated level based on the system pressure history during the first six minutes of the transient. Time intervals were chosen to match Table II except that no balance was made after six minutes when saturation temperatures was reached. An equilibrium pressurizer model was assumed with flashing energy supplied by all of the hot fluid in the pressurizer at the beginning of a calculation interval. RCS water was not included in the balance.

Steam relieving rates through the PORV were normalized to a discharge pressure of 2250 psi for comparison of discharge capacity during the three time intervals and for comparison to the rated relief capacity of 118,125 lbm/hr. Excellent agreement with rated capacity was obtained, particularly during the (110-300) sec. period when the calculational uncertainty is at a minimum. This tends to confirm that pressurizer leakage was via the stuck open PORV and an additional RCS leak is needed to explain the mass balance.

Also of interest is the computed liquid level versus the measured liquid level. The calculations indicate that the indicated level was too high by 35 inches at 110 seconds, 151 inches at 300 seconds, and 137 inches at 360 seconds. These calculations are believed to be reasonably accurate and indicative of substantial error in the liquid level reading during the first several minutes of the transient. The high indicated levels suggest flashing in the reference leg during the depressurization.

In summary, the following conclusions were reached from the benchmark calculations.

- (a) The 3&W computer model for CAODS benchmarking of TMI appears to have several deficiencies; e.g., too much water inventory in the steam generator; 3% heat demand to simulate HPI cooling effect from two to five minutes (this is too much); etc., which could be pursued to obtain a more acceptable benchmark.
- (b) The INEL model had several problems with improper handling of auxiliary feedwater being the largest error contributor. They are now aware of these problems and are making appropriate corrections.
- (c) All calculations seem to point to leakage in addition to that through the stuck open PORV.
- (d) A reactor trip on turbine trip has the same effect as additional inventory in the steam generator and appears to be of no value for plants having steam generators which reduce the primary temperature to near the secondary saturation temperature without boiling dry.

JUN 13 1979

Richard P. Denise

-7-

- (e) Safety analyses sensitive to steam generator coolant inventory should be reviewed carefully to assure that conservative water levels are used.
- (f) There remain sufficient questions about the TMI-2 response to warrant additional benchmarking analyses.

Laurence E. Phillips

Laurence E. Phillips, Acting Branch Chief
Analysis Branch
Division of Systems Safety

Enclosures:
Tables

- cc: F. Schroeder
- R. Tadesco
- V. Stallo
- S. Fabic
- I. Rosztoczy
- P. Morian
- F. Odar
- E. Throm
- N. Lauben
- B. Sheron
- G. Holahan
- W. Lyon
- J. Holonich
- Gordon Edison
- All TMI Task Force Chiefs
- R. Bernero, Task Leader, Task Group No. 5
4th Floor Arlington Road Building
- R. Vollmer
- R. Mattson
- D. Ross
- D. Eisenhut

TABLE I
PRIMARY COOLANT ENERGY RELEASE TO BOIL DRY
THE STEAM GENERATORS

Reference: Midland Data	CASE 1 (Pre-TMI)	CASE 2* (Post-TMI)	CASE 3** (Post-TMI)
PCRV Set Pressure (psig)	2340	2450	2450
Time to Reactor Trip (sec)	3.93	8.0	0
Time to Rod Movement (sec)	9.63	8.7	0.9
Feedwater Flow Rate (lbm/sec)	3500	3500	3500
Feedwater Added During Coastdown (lbm)	17000	17000	17000
Steam Generator Secondary Water (lbm)	92000	92000	92000
Total Coolant Mass Boiled (lbm @ 1035psig)	109000	109000	109000
Avg. Reactor Coolant System Temp. @ 0 sec. (°F)	582	582	582
Avg. Reactor Coolant System Temp. @ 110 sec. (°F)	552	552***	552***
Avg. Secondary Steam Pressure (psia)	1020	1020	1020
Estimated PORV Flow (avg. lbm/sec)	-	-	-
Power Level (Mwt)	2552	2552	2552
PRIMARY HEAT SINKS (Mw-sec)			
(a) Steam Generator	74157	74157	74157
(b) PORV		NEGLECTED	
PRIMARY HEAT SOURCES (Mw-sec) to 110 sec. after Turbine Trip			
(a) Full Power (2552 Mwt) Energy Input	24575	22202	2297
(b) Fuel Stored Energy (1350F → 550F)	12913	12913	12913
(c) System Stored Energy (582F → 552F)	25392	25392	25392
(d) Decay Heat to 110 sec.	9297	9297	10057
(e) Reactor Coolant Pumps (18 Mwt) to 110 sec.	1980	1980	1980
TOTAL ENERGY SUPPLY TO S.G. @ 110 sec.	<u>74157</u>	<u>71784</u>	<u>52539</u>
FRACTION OF STEAM GENERATOR COOLANT NOT BOILED	0	.03	.29
TOTAL DECAY HEAT FOR ADIABATIC HEATING OF THE SYSTEM TO 582F ENERGY LEVEL	34659	37062	56967
TIME (sec.) required to generate decay heat	538	585	1006

*Overpressure trip @ 2300 psig; S.G., would not be dry @ 110 sec.

**Reactor trip on turbine trip; S.G. would have substantial inventory @ 110 sec.

***Primary coolant temperature cannot be lowered below 552F due to limiting secondary saturation temperature of 547F which limits further heat transfer.

POOR ORIGINAL

TABLE II

TMI ENERGY BALANCE BENCHMARK

Basis: Plant Data Describing the Accident

	(0-110) sec	(110-300) sec	(300-360) sec	(360-640) sec
ORV Set Pressure (psig)	2,255	OPEN	OPEN	OPEN
Time to Reactor Trip (sec)	9	--	--	--
Time to Rod Insertion (sec)	10	--	--	--
Feedwater Flow Rate (lbm/sec)	3,180	NONE	NONE	NONE
Feedwater Temperature (°F)	463	--	--	--
Feedwater Added During Coast-down (lbm)	15,897	--	--	--
Steam Generator Coolant Inventory	55,970	NONE	NONE	NONE
Total Coolant Available (lbm)	71,870	NONE	NONE	NONE
Steam Superheat Temperature (°F)	592	--	--	--
Avg. Secondary Steam Pressure (psia)	1,035	950	865	825
Avg. Reactor Coolant Temp. 90 sec (°F)	582	582	582	582
Final Reactor Coolant Temp. Avg. (°F)	577	573	582	595
Avg. Primary Steam Press. (psia)	1,900	1,560	1,375	1,425
Estimated Leak Flow (Avg. lbm/sec)	25.9	47.8	19.8	6.1
PI Coolant Added (Gallons)	243	2,136	200	600
Core Level (Mwt)	2,688	--	--	--

PRIMARY HEAT SOURCE (Mw-sec)

a) Full Power (2628 Mwt) Energy Input	26,880	0	0	0
b) Fuel Stored Energy (1350°F - T Coolant)	12,590	0	-81	-212
c) System Stored Energy	4,250	-850	-2,300	-9,100
d) Decay Heat	9,792	13,290	3,504	9,970
e) Reactor Coolant Pumps (18 Mwt)	1,980	3,420	1,080	3,240
TOTAL ENERGY SUPPLY	55,492	15,360	1,804	3,398
Fraction of S.G. Coolant not boiled	0	--	--	--
TOTAL DECAY HEAT FOR ADIABATIC COOLING OF THE SYSTEM TO 582°F ENERGY LEVEL	14,042	--	--	--
Time (sec) Required to Generate Decay Heat	175 sec	--	--	--

PRIMARY HEAT SINKS (Mw-sec)

a) Steam Generator	52,610	0	0	0
b) PI Coolant Heating	1,167	10,261	961	2,382
c) System Heat Losses	220	380	120	360
d) Deficit	1,495	5,219	723	656
ENERGY Deficit per sec (Mwt)	13.59	27.47	12.05	3.64

For 100% quality leakage from the RCS (excluding the pressurizer) to compensate the energy deficit. Note that a lower average energy discharge indicates that lower quality coolant is being discharged.

POOR ORIGINAL

TABLE III


TMI-II PRESSURE VOLUME/ENERGY BALANCE

	(0-110) sec	(110-300) sec	(300-360) sec
PZR Pressure (psig)	2150 - 1745	1745 - 1400	1400 - 1355
Coolant Properties: V_g (ft ³ /lbm)	.1685 - .2275	.2275 - .2974	.2974 - .3094
V_f (ft ³ /lbm)	.0265 - .0245	.0245 - .0232	.0232 - .0230
h_g (BTU/lbm)	1123.3 - 1153.3	1153.3 - 1172.6	1172.6 - 1175.
h_f (BTU/lbm)	629.1 - 641.1	641.1 - 600.7	600.7 - 594.7
Electric Heater Input (Mw-Sec)	180.18	311.22	98.28
Pressurizer Volume per ft. Level Change (ft ³ /ft)	38.48	38.48	38.48
Reactor Coolant Average Temperature (°F)	582 - 577	577 - 573	573 - 582
Fraction of Hot PZR Fluid Flashed	.0937	.0706	.0103
LIQUID VOLUME (V_f), Ft ³	795.35 - 604.4	604.4 - 311.2	311.2 - 932.4
DELTA LIQUID VOLUME (V_f)			
RCS Shrinkage, Ft ³	-99.4	0	+99.4
PZR Shrinkage, Ft ³	-60.0	-32.1	-7.0
Liquid Flashed, Ft ³	-68.9	-40.4	-6.3
Liquid Boiled by Heaters Ft ³	-8.6	-12.6	-3.7
Liquid Added to RCS by HPI Ft ³	+45.9	+231.9	+37.8
STEAM VOLUME (V_g) Ft ³	704.65 - 895.6	895.6 - 638.8	638.8 - 567.6
STEAM MASS (M_g)			
Steam at Beginning of Interval lbm	4131.9	3936.7	2316.2
Added by Flashing, lbm	2812.6	1741.7	231.4
Added by Heating, lbm	350.	544.1	161.3
Steam at end of Interval, lbm	3936.7	2316.2	1834.6
Balance lost thru PORV, lbm	3407.8	3906.6	874.9
Steam Relieving Rate (lbm/Sec)	31.0	20.6	14.6

POOR ORIGINAL



TABLE III (Cont'd)

Equivalent Relief Rate (lbm/Hour) @ 2250 psi	134150	114502	92279
PZR LIQUID LEVEL: Measured (in)	220-195	195-376	376-400
Calculated (in)	220-160.4	160.4-224.9	224.9-262.7



POOR ORIGINAL

WATER LEVEL
VS TIME
CORRECTED FOR
THERMAL
EXPANSION



POOR ORIGINAL

JUL 17 1979

MEMORANDUM FOR: Roger J. Mattson, Director
TMI-2 Lessons Learned Task Force

FROM: Warren Minners

SUBJECT: TRIP REPORT - TMI SYSTEM THERMAL-HYDRAULIC ANALYSIS MEETING
JULY 11 & 12, 1979, PALO ALTO, CA

The meeting by EPRI with the objectives of 1) gaining additional technical insights on the TMI-2 system thermal-hydraulic response, 2) to assess the capabilities of current computer programs and 3) to identify the improvements in the computer programs. The meeting was attended by representatives of all of the organization (EPRI, OPU, ITI, INEL, LNL and NRC) analyzing the TMI accident data. An agenda listing of the participants is attached. Copies of the slides presented at the meeting are available in my file.

Two general approaches for evaluating the TMI-2 system response, data analysis and computer analysis, were presented.

Data Analysis

Both EPRI and OPU presented their analysis of the data. The majority of the discussion centered on the first 100 minutes of the accident, that is until shortly after the reactor coolant pumps were shut off.

EPRI concludes based on an energy balance on the relief valve drain tank that the relief valve failed in the full open position. However, the mass flow rate through the valve is sensitive to the steam quality and has not yet been determined. Based on their computer analysis, B&W calculates twice the mass flow rate estimated by EPRI. Both B&W and EPRI estimate the flow rate in the isolation line to be about 140 gpm based on a heat balance across the isolation line cooler. Therefore the isolation line flow is comparable to the flow from the relief valve.

However, B&W estimates that the net isolation line flow averaged a positive 35 gpm which sets the makeup flow at 175 gpm. EPRI believes such a high makeup flow should be revealed by the response of system parameters which they do not see. EPRI estimates the makeup flow to have been 40 gpm, which results in a negative net isolation/makeup flow of 100 gpm. There is a consensus that the water level in the RCS after the RCP were turned off was not above the pressure vessel hot leg nozzles.

POOR ORIGINAL

EPRI speculates that since the system appears to have begun to depressurize before the relief valve block was first closed, hydrogen may have been generated soon after the RCP were stopped. EPRI also speculated that a rapid 100°F increase in the cold leg temperature and similar 300 psi increase in system pressure at 3 hours and 45 minutes may indicate the time when the core collapsed. However, these increases can be also explained by increases in RPI flow, outflow from the pressurizer and re-wetting of the core. After generation of hydrogen little or no heat transfer through the steam generators occurred and cooling was due to flow of RPI injected water through the core. During the period between 11 and about 16 hours there was no significant heat removal from the core.

Computer Analysis

Computer analysis of the accident are being made to 1) evaluate the capability of the codes, 2) fill in gaps in knowledge of the accident and 3) investigate the effect of possible alternatives. The NRC representatives urged that the primary emphasis be placed on the last purpose, that is answer some questions of "what if".

The codes being used are RETRAN (CFU, ITI and EPRI), RELAP (INEL), TRAC (LASL) and CRAFT (BNM). The RETRAN codes used a detailed system model (about 100 volumes) including modeling much of the secondary system. The RELAP and TRAC models used half as many volumes (about 50) and much simpler secondary side models. Except for TRAC which had 3-D modeling of the vessel, the models were one dimensional.

The computer analyses generally predicted the trends of the parameters better than the quantitative values. The codes that attempted to model the secondary system in the most detail (RETRAN) made poorer predictions, than codes that used secondary conditions as boundary conditions to a reactor coolant system (CRAFT).

The time span calculated to date is short as shown by the following table.

<u>CASE</u>	<u>INVESTIGATOR</u>	<u>TIME SPAN</u>
RETRAN	CFU	3 min.
RETRAN	ITI	3 min.
RETRAN	EPRI	1/2 min.
RELAP	INEL	100 min.
TRAC	LASL	100 min.
CRAFT	BNM	100 min.

The calculations show that the relief valve mass flow is sensitive to the steam quality. All analyses over-predict the initial decrease in pressurizer level. The RCS flow rate drop due to void formation is under-predicted by the two codes (RELAP and TRAC) for which the parameters are available.

POOR ORIGINAL

In order to facilitate explanation of the analysis and comparison of the results a "standard" set of initial and boundary conditions was developed based on the best information available to date.

Original signed by
Michael Winners
Michael Winners

cc: LLTF Dist.
FOR
Z. Rosztoczy
D. Ross
H. Johnston
S. Fabic

ENCLOSURE:
Agenda

DISTRIBUTION:
CENTRAL FILE
NRR READING
DSS READING
Winners

POOR ORIGINAL

LLTF
Winners:sl
7/17/79