



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

JUL 28 1980

Docket No. 50-483
Docket No. 50-486

Union Electric Company
ATTN: Mr. John K. Bryan
Vice President - Nuclear
Post Office Box 149
St. Louis, MO 63166

Gentlemen:

Thank you for your interim report dated July 18, 1980, pursuant to 10 CFR 50.55(e) regarding out of tolerance conditions on anchor bolts and nuts. We will review your final report on this matter upon receipt.

Your cooperation with us is appreciated.

Sincerely,

A handwritten signature in cursive script that reads "Gaston Fiorelli".

Gaston Fiorelli, Chief
Reactor Construction and
Engineering Support Branch

cc: Director, RCI/II
Director, AEQD
Chief, OEB/MPA
IE Files

cc w/ltr dtd 7/18/80:
Central Files
PDR
Local PDR
NSIC
Regions I & IV
Ms. K. Drey
Mr. Ronald Fluegge, Utility
Division, Missouri Public
Service Commission

8008140293

S

UNION ELECTRIC COMPANY

1901 GRATIOT STREET
ST. LOUIS, MISSOURI

July 18, 1980

JOHN K. BRYAN
VICE PRESIDENT

MAILING ADDRESS:
P. O. BOX 149
ST. LOUIS, MISSOURI 63166

Mr. James G. Keppler, Director
Region III
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

ULNRC-366

Dear Mr. Keppler:


SUBMITTAL DATE EXTENSION
INTERIM REPORT - ANCHOR BOLTS AND NUTS
CALLAWAY PLANT UNITS 1 AND 2

On Friday, June 20, 1980, we provided Mr. H. M. Wescott verbal notification of a 10CFR50.55(e) report regarding out of tolerance conditions on major bolt diameters and minor nut diameters for material supplied by Industrial Mechanics, Inc.

An inspection program has been established and equipment is on order to complete the inspection.

Based on the time required for equipment deliveries, field inspection and evaluation of the data from the field inspection, we anticipate that the date of issue of our final report will be December 1, 1980.

Very truly yours,


John K. Bryan

WHZ/sla

cc: ~~H. M. Wescott, Region III~~
B. F. Grier, Region I
Victor Stello Jr., Director Office of I&E
K. V. Seyfrit, Region IV
W. A. Hansen, NRC Resident Inspector, Callaway Plant
Missouri Public Service Commission

JUL 23 1980

dupl
7254336

0030000336