

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 0 R T N P 1 1 0 0 0 - 0 0 0 0 0 0 - 0 0 0 4 1 1 1 1 1 4 5  
LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58 59

CON'T  
0 1 REPORT SOURCE L 8 0 5 0 - 0 3 4 4 7 0 7 0 8 8 0 9 0 8 0 6 8 0 9  
SOCKET NUMBER 18 19 EVENT DATE 24 25 REPORT DATE 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 NO 80-13: DURING PERIODIC LOCAL LEAK RATE TESTING, NINE VALVES WERE  
0 3 FOUND TO LEAK HIGH ENOUGH SO THAT THEIR LEAKAGE COULD NOT BE ACCURATELY  
0 4 MEASURED BY THE TEST INSTRUMENTATION. THE CONDITION OF THESE VALVES WOULD  
0 5 INDICATE LLRT LEAKAGE ABOVE THE ALLOWABLE TECHNICAL SPECIFICATION LIMIT.  
0 6  
0 7  
0 8  
0 9

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE  
K X 11 E 12 B 13 V A L V E X 14 X 15 X 16  
17 SER NO REPORT NUMBER 18 19 EVENT YEAR 20 21 SEQUENTIAL REPORT NO. 22 23 OCCURRENCE CODE 24 25 REPORT TYPE 26 27 REVISION NO. 28 29  
ACTION TAKEN 30 FUTURE ACTION 31 EFFECT ON PLANT 32 SHUTDOWN METHOD 33 HOURS 34 ATTACHMENT SUBMITTED 35 NRC-4 FORM SUB 36 PRIME COMP SUPPLIER 37 COMPONENT MANUFACTURER 38  
B 18 Z 19 Z 20 Z 21 0 0 0 0 41 Y 23 Y 24 A 25 Z 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

0 10 THE NINE VALVES HAD VARIOUS PROBLEMS SUCH AS DISLODGED SEAT, DEFECTIVE  
0 11 GASKET, UNEVEN SEATING, ETC. ALL VALVES WERE REPAIRED AND RETESTED  
0 12 SATISFACTORILY.  
0 13  
0 14  
0 15

0 16 FACILITY STATUS 17 POWER 18 OTHER STATUS 19 METHOD OF DISCOVERY 20 DISCOVERY DESCRIPTION 21  
H 22 0 0 0 0 23 NA 24 B 25 LOCAL LEAK RATE TESTING 26

0 17 ACTIVITY RELEASED OR RELEASE 18 CONTENT 19 AMOUNT OF ACTIVITY 20 LOCATION OF RELEASE 21  
Z 22 Z 23 NA 24

0 18 PERSONNEL EXPOSURES NUMBER 19 TYPE 20 DESCRIPTION 21  
0 22 0 23 Z 24 NA 25

0 19 PERSONNEL INJURIES NUMBER 20 DESCRIPTION 21  
0 22 0 23 NA 24

0 20 LOSS OF OR DAMAGE TO FACILITY TYPE 21 DESCRIPTION 22  
Z 23 NA 24

0 21 PUBLICITY PUBLISHED DESCRIPTION 22 NRC USE ONLY  
Z 23 NA 24

NAME OF PREPARER John C. Perry PHONE 503/556-3713, ext. 228

8008150386