

NRC PDR

In the Matter of:

WORKSHOP

EMERGENCY RESPONSE FACILITIES

NUREG-0696

DATE: August 20, 1980

PAGES: 1 - 238

AT: Chicago, Illinois

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 534-2345

8009050 397

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

U.S. NUCLEAR REGULATORY COMMISSION  
WORKSHOP  
EMERGENCY RESPONSE FACILITIES  
NUREG-0696

- - -

O'Hare Hilton  
O'Hare Airport  
Chicago, Illinois  
August 20, 1980

BEFORE:

BERT DAVIS, Presiding

PANEL:

WARREN MINNERS  
LEO BALTRACCHI  
STEVE RAMOS

- - -

P R O C E E D I N G S

(8:35 a.m.)

MR. DAVIS: Good morning, ladies and gentlemen.  
My name is Bert Davis. I am Chief of the Material Safety  
Branch of NRC Regional Office. I am pinchhitting for Jim  
Kepler today who is on vacation and was unable to provide  
the opening remarks.

I welcome you to Region III where we are hosting  
the NRC's Workshop on Emergency Response Facilities. As you

1 know, the investigations of the accident at Three Mile  
2 Island Unit 2 nuclear power plant identified the need for  
3 extensive improvements in emergency preparedness at nuclear  
4 power plants.

5           Some areas identified as deficient and in need of  
6 improvement included the organization of personnel to  
7 control, manage, assess, support and coordinate activities  
8 both on and offsite during an emergency; the facilities for  
9 these personnel; the availability of information needed to  
10 assess and manage the reactor; other sources of  
11 radioactivity; and active and potential radiological  
12 consequences; and the provision for disseminating accurate  
13 and timely information; warnings and instructions to local  
14 and state agencies, the affected population and the public  
15 in general.

16           An acceptable method of providing emergency  
17 response facilities is proposed in NUREG-0696, entitled  
18 "Functional Criteria for Emergency Response Facilities," and  
19 this is the subject of this workshop.

20           These facilities include an onsite technical  
21 support center, an emergency operations facility, a safety  
22 parameter display system, and a Nuclear Data Link.

23           Mr. Warren Minners, the Chairman of the  
24 Coordinating Committee of the Safety Data Integration group  
25 will commence the presentations describing NUREG-0696. He

1 will be followed by Mr. Leo Beltracchi who will cover the  
2 safety parameter display and the nuclear data link systems.  
3 Mr. Steve Ramos will cover the technical support center and  
4 the emergency operations facility.

5           Before we get started I would like to remind you  
6 that we do have a register for any of you who want to make a  
7 statement this afternoon. There is a time period allotted  
8 for that, and we do require you to register to make a  
9 statement. That does not apply to questions during the  
10 presentations which are for the purpose of clarification.  
11 You do not need to register for that.

12           We have divided the room into two sections, the  
13 smoking section on the left and the non-smoking section on  
14 the right. We would request you abide by that.

15           We also would request that when you are asking  
16 questions or making a statement that you go to one of the  
17 microphones and identify yourself. It will be necessary  
18 each time you make a statement to reidentify yourself since  
19 we are taping the presentation.

20           Before I turn the meeting over to Mr. Minners I  
21 would like to show our first vu-graph to set the tone of the  
22 meeting.

23           (Slide.)

24           Let's proceed now with Mr. Minners.

25           MR. MINNERS: I thought they told me I was going

1 to be the keynote speaker, and I misunderstood them. I  
2 guess it is the keystone speaker.

3 (Laughter.)

4 The reason that we are here is because people have  
5 perceived that our requirements were going down this path in  
6 the area of emergency planning. We were going off in one  
7 direction with one group and another direction with another  
8 group, and we realized that, and the industry realized that,  
9 and so we tried to get ourselves organized and integrate  
10 some of the requirements for the Emergency Response  
11 Facilities, which is now the term we are using for these  
12 requirements.

13 These consisted of the Lessons Learned  
14 recommendations for a technical support center and also for  
15 a safety parameter display. And in parallel to that but  
16 having started much earlier was the development of Reg Guide  
17 1.97 which was then called Instruments to Follow the Course  
18 of an Accident. And the unifying theme of all these things  
19 seemed to be the information, the data requirements, and  
20 they all needed data on the plant, and the facilities were  
21 just a means of displaying the data.

22 So the report that we finally issued, NUREG-0696,  
23 is an attempt to try to give functional requirements for the  
24 facilities which are going to use the data that comes out of  
25 the plant during accident situations.

1           We met with AIF, which represented, I believe,  
2 most of the industry back in May and June, wrote a draft,  
3 the precursor to 0696, got some comments, and rewrote it,  
4 and then decided that we should go out and get more public  
5 comment. So we have published a draft version of 0696 which  
6 we have distributed widely. I think everybody has gotten a  
7 copy. There were copies available as you came in if you did  
8 not have one.

9           And now what we would like to have is comments  
10 from the industry and from other interested members of the  
11 public on what you think about this. We are sincerely  
12 interested in your comments, and most of all we are  
13 interested in having comments that have some basis.

14           The industry is obviously a source of much  
15 technical information. You have more technical information  
16 than the Commission does, and we sorely need that kind of  
17 technical information to have a basis for these requirements  
18 or for eliminating some of these requirements.

19           Now, I think you also have all been given an  
20 agenda for today's session. We made a similar presentation  
21 in Philadelphia yesterday, and it worked out that when we  
22 started at 8:30 with the presentations and questions, we  
23 finished up our presentation about 11:30, and then that left  
24 the rest of the afternoon until 5:00 for people to have a  
25 little more chance at discussion, or make statements, or

1 whatever they wished to do, and it seemed to work out.

2           So we will accept questions during the  
3 presentations if they are of a clarifying nature, but don't  
4 interrupt the flow of the presentation. If you don't  
5 understand something or it is not clear in some way, ask the  
6 question, and we will try to straighten it out. But if it  
7 is going to get into something rather long and detailed, we  
8 would not address that until later in the afternoon. And in  
9 the afternoon I will go down the list of people who have  
10 signed up. There is a list outside. If you wish to make a  
11 statement or a comment, or even if you wish to ask further  
12 questions, put your name on the list.

13           I am going to go down in the order they are  
14 written down and we will listen to you. And if there is any  
15 extra time before 5:00, people who have not signed up can  
16 give any further comments that they have.

17           Our presumption is that people have read the  
18 report. The presentation today is just to reorient people  
19 and maybe give a little more of the background of the why  
20 and the how of what the material is. But hopefully you have  
21 all read the report, and you have your questions and  
22 comments developed.

23           Our purpose here is to have a workshop. We are  
24 here to try to explain what this report means, what its  
25 intent is. We will discuss it with you, we will receive

1 your comments, and we will try not to defend it. If we slip  
2 over into a little defensive posture, forgive us. It is  
3 hard not to. But it is not our intent to defend it. We  
4 just want to explain it. We don't really want to argue with  
5 anybody. I would like to discuss it with people and look at  
6 all the issues.

7           It might be well to remind people to look at this  
8 NUREG report, if and when it is issued, in the proper  
9 perspective. It is not a Commission rule. It does not  
10 carry force of law. It is in the same kind of form as a  
11 Regulatory Guide, and although this may be a distinction  
12 which the industry thinks does not show much difference, it  
13 is only an acceptable method for complying with the rule  
14 that requires emergency response plans in facilities; and if  
15 a licensee or applicant has a different way of doing it, he  
16 is welcome to come in and present that.

17           Now, everybody recognizes that it is much more  
18 difficult with your own ideas. It is going to take more  
19 time, so in effect, this report carries a lot of weight; and  
20 therefore, I would hope that people would try to get the  
21 requirements modified to what they think they should be and  
22 not hope that well, this is only guidance and when it comes  
23 to my plant, I will show my particular characteristics and  
24 get an exception.

25           The intention is to try to fix it up in this



1 report, if possible, recognizing that there may be unique  
2 situations which people may want to come in after the report  
3 is issued and have some different way of doing business.  
4 But the intent is to have the report generic and cover all  
5 of the plants.

6           We would like to have written comments from you  
7 because they will be more useful to us, especially the  
8 basis, as I said earlier. Comments which say we like it, we  
9 don't like it, or it should be this, or it should be that,  
10 these are all right, but they really are not very helpful.

11           We don't do as good a job as possibly we should in  
12 presenting the bases for our requirements and guidance, and  
13 that is one of the purposes of this meeting. But I think  
14 the industry and other people should also, when they make  
15 comments, try to explain why they want them that way.

16           There is a tendency on your part, as there should  
17 be, to look at the practicality of the requirements and say  
18 if it is expensive, or hard to do, or impractical, that it  
19 should not be done. But as a regulator, although we  
20 recognize those factors, our basic purpose is safety, and we  
21 need to have some kind of a safety rationale that explains  
22 why the requirements should be modified or phrased in a  
23 different way or whatever. So your bases are necessary, as  
24 well as your comments.

25           Now, my understanding is that -- there is probably

1 somebody here from AIF that can confirm this -- that there  
2 is going to be a meeting of AIF in August. I think it is  
3 August 28, but don't count on me. Contact AIF. They will  
4 gather industry representatives together to coordinate the  
5 comments and submit them to us. We would like to have it  
6 done that way as much as possible.

7           What that does for us is integrate the comments of  
8 industry. You all have a wide spectrum of comments, and  
9 some people want it one way, and some people want it the  
10 other way. And if you get these individual comments, it is  
11 up to the Commission to make a compromise; and I think it  
12 may be more appropriate if an industry group made the  
13 compromise and presented it to the Commission as an industry  
14 position. I think that is a useful function for the AIF to  
15 do.

16           If people want to make individual comments to us,  
17 they are certainly welcome, but I think a generic approach  
18 from AIF is helpful, both from a technical point of view and  
19 from an administrative point of view, in that presumably we  
20 will not have duplicate comments that we are going to have  
21 to take care of.

22           Now, our schedule for 0896 is it has been  
23 published in the Federal Register, I believe on Friday,  
24 although I have not seen the notice. And if that is true,  
25 the comment period would end 45 days later, at the end of

1 September. We would then take those comments, revise the  
2 report, and hopefully issue it at the end of October or the  
3 beginning of November.

4           The schedule, I think, is rather important. We  
5 have an implementation schedule which, if we are going to  
6 meet it, we are going to have to get our guidance out quite  
7 early so that people can start designing and ordering  
8 equipment, although I would hope people have started some of  
9 their studies and development of purchase specifications and  
10 things like that earlier than today because the requirements  
11 have been around for quite a while.

12           We hope at least you have done your philosophical  
13 thinking and need only look at the details.

14           Okay. Are there any questions on how we are going  
15 to run the meeting and what we are going to do with the  
16 report?

17           (No response.)

18           I would like to give a brief introduction on what  
19 the report is. May I have the first slide?

20           (Slide.)

21           Although the Commission had requirements for  
22 emergency plans and facilities for a long time, I don't  
23 think it was really until Three Mile Island that people  
24 understood what that should mean.

25           Looking at Three Mile Island people saw that there

1 was a necessity for improvements in several areas.  
2 Obviously, management of the accident was one of them. One  
3 of the big areas was having data available to the operator  
4 and to the technical support people.

5           Radiological assessment was a difficult area.  
6 that is part of the data requirements. The cooperation and  
7 coordination with state and local officials was a difficult  
8 area which needed help, and also the problem of dealing with  
9 the public in general.

10           Now, the report, 0696, is not going to take care  
11 of all these areas. 0696 is a set of requirements for the  
12 facilities. The emergency plan will give the organization  
13 and the staffing, and there are other reports that give  
14 guidance on what action levels should be and things like  
15 that. The 0696 is only basically the brick and mortar to  
16 help support the emergency organization of a plant.

17           (Slide.)

18           Now, in these facilities we have defined four  
19 elements: the safety parameter display, the technical  
20 support center, the emergency operations facility, and the  
21 nuclear data link. And they are all related basically by  
22 their common need for data from the plants.

23           The safety parameter display is less of an  
24 emergency system than the other elements. That is a monitor  
25 for the operator to look at which gives him an overall plant

1 system level kind of alarm so he can just look at that and  
2 say I'm okay or I'm not okay. That is the purpose of that.

3           The technical support center is a place where the  
4 people who are going to give technical support to the  
5 control room will remain. It is obvious -- I think  
6 everybody has recognized that -- that you can't put  
7 everybody in the control room. You need some place to put  
8 these people, and you need facilities and tools for them to  
9 do their job. Basically, in the technical support center  
10 their attention is directed towards the plant and onsite.

11           The third element is the emergency operations  
12 facility which has the -- primary purpose of coordinating  
13 with the off-site agencies, state and local, things like  
14 that, and also the press.

15           The fourth element is the nuclear data link which  
16 is what we think we require to discharge our  
17 responsibilities in monitoring licensees and activities  
18 during an event.

19           Now, on the last slide -- so the four elements  
20 kind of give a graded response. The safety parameter  
21 display would be used primarily before accidents. TSC and  
22 EOF -- the TSC will be activated for the next level of  
23 accidents, and then if severity is greater, we will activate  
24 the EOF. The nuclear data link is capable of transmitting  
25 data continuously.

1           The point I want to make is the last bullet on  
2 this slide, which is that our guidance is based on the  
3 premise that the control room is the place where the  
4 accident will be controlled. That is where the shift  
5 supervisor is, the person in charge, and the operators are  
6 going to be doing the plant manipulations. These other  
7 facilities are support or monitoring facilities, and they  
8 are not supposed to be controlling the plant. They might  
9 give management and things like that, but the control is in  
10 the control room.

11           With that I would like to introduce Leo Beltracchi  
12 who will discuss the safety parameter display.

13           MR. BELTRACCHI: Thank you, Warren.

14           May I have the first slide, please?

15           (Slide.)

16           Can everybody read that?

17           The purpose of the safety parameter display system  
18 is to provide a display of a minimum set of plant parameters  
19 from which the safety status of operation may be assessed by  
20 control room personnel. It is basically a monitoring  
21 system, and it is to aid in the detection of abnormal  
22 operating conditions.

23           It is also to allow the operator to assess in a  
24 very quick and rapid manner that the plant is operating  
25 safely.

1           May I have the next slide, please?

2           (Slide.)

3           The scope of the display system should contain the  
4 magnitudes and trends of parameters or derived variables  
5 that have been selected in the minimum set, and I would  
6 emphasize the trends and/or rates of these parameters, since  
7 this will assist the operator in transients to understand  
8 whether the plant has become stabilized or is diverging from  
9 a stabilized condition.

10          The display is to be used during normal and  
11 abnormal conditions, and duplication of the display from the  
12 control room should be provided in a technical support  
13 center and emergency operating facility.

14          In terms of functional considerations its main  
15 purpose is to serve as an operating aid for the detection of  
16 abnormal operating conditions. It is to be used in all  
17 plant operating modes. It should be capable of functioning  
18 during and following events expected to occur during the  
19 life of the plant.

20          It should have flexible design to allow for future  
21 modifications; that is, it should be expandable. And  
22 emergency procedures should specify the limits of the use of  
23 the safety parameter display system to the operator such  
24 that he would be able to know when he would switch and go to  
25 a 1-E qualified display system for accident monitoring,

1 close accident monitoring.

2           The system is to be located in the control room  
3 and should have the following characteristics. It should be  
4 easily recognized by control room personnel, readily  
5 accessible, readily visible. It should not obscure full  
6 visual access to other display systems. Relative to size it  
7 should be sufficient to be readable from operating stations  
8 by the shift supervisor, the shift technical advisor, and at  
9 least one reactor operator.

10           Let me qualify the last. The reason why that is  
11 there is that many utilities have asked whether it would be  
12 possible to break portions of the display and make it work  
13 station dependent, and that is why we have accommodated the  
14 one reactor operator in this list.

15           The staffing of the control room in terms of  
16 design should require no additional personnel. It should be  
17 for the operation of the safety parameter display system.  
18 This can be achieved with the current operating staff.

19           (Slide.)

20           In terms of data requirements it should use  
21 signals from Reg Guide 1.97 sensors when the variables are  
22 common to the safety parameter display system set; that is,  
23 it should be isolated. Also, it should be isolated in a  
24 form of I-E isolation devices.

25           The data validation should be achieved prior to



1 display to the operator. This is a requirement that has not  
2 quite been amplified upon in SUREG-0696, so I would like to  
3 spend a moment on it.

4           What I mean by validation here is it should be  
5 checked in the form of its validity with respect to either a  
6 redundant sensor or another secondary variable to assure  
7 that the reading that is being presented to the operator is  
8 proper.

9           Also, should this not validate properly, then  
10 means should be provided to notify the operator of the  
11 discrepancy to allow him to resolve the issue and determine  
12 what the cause is.

13           In terms of display considerations it should be  
14 use of human factors engineering to enhance the functional  
15 effectiveness. One form of this would be the use of pattern  
16 coding techniques to assist operators' memory recall by  
17 dividing the normal ranges of the parameters, as well as the  
18 abnormal ranges of parameters, or at least code the readings  
19 such that the operator would be able to detect this very  
20 quickly.

21           There is, in addition, several psychological  
22 issues that could be brought to bear in the design that  
23 would influence the human factors engineering -- such things  
24 as to assure the display is designed in a manner so that it  
25 would not present an overload of information, yet it is

1 presented in a manner that would allow the operator to make  
2 a decision very quickly and achieve a closure in that  
3 decision to assess that the plant is operating safely or  
4 that it is operating unsafely.

5           Furthermore, this should be done in a manner by  
6 which the operator is in control of the display. He should  
7 not have to require an inordinate amount of interface in  
8 order to determine that the plant is operating safely or  
9 unsafely.

10           There should be a single display format required  
11 for each mode of operation, and should there be -- there  
12 should be additional display formats, as appropriate, to  
13 monitor and present parameters that will be allowed.

14           The main function of the latter statement is to  
15 assist in the diagnosis of a detected problem. Remember,  
16 the safety parameter display system is only a detection aid.

17           VOICE: Can you amplify on the word "mode?"

18           MR. BELTRACCHI: There are usually operating modes  
19 defined in the specifications, criticality being one.

20           VOICE: You mean that for hot shutdown or standby  
21 -- that is what you are referring to?

22           MR. BELTRACCHI: Yes.

23           VOICE: Are these slides going to be made available?

24           MR. RAMOS: Would people who ask questions try to  
25 get to a microphone or stand up so that everybody in the

1 room can hear the question?

2 MR. BELTRACCHI: Will the slides be available?

3 MR. DAVIS: We can get copies. If you leave your  
4 name, we can provide them to you.

5 VOICE: Who should we leave our name with?

6 VOICE: One of the girls outside.

7 MR. BELTRACCHI: Next slide.

8 (Slide.)

9 In terms of the design criteria for the system,  
10 the system need not be Class 1-E. However, should you elect  
11 to design the system totally 1-E, we would not object to  
12 that at all.

13 (Laughter.)

14 While there have been people that have talked --  
15 and I think it is important to think in terms of the total  
16 use and scope of a system -- if you want to use the system  
17 for close accident monitoring, I would like you to consider  
18 the fact that it should be a 1-E interface.

19 The sensors and signal conditioners should be  
20 Class 1-E qualified, and of course that means the display  
21 portion of the system with respect to its interface to the  
22 sensor portion of the system will have to be isolated. The  
23 system need not be -- not meet the single failure criterion.

24 The unavailability goal is for the system -- is 1  
25 times 10 to the -3 per year, and I will come back to this

1 unavailability issue in a later slide. Furthermore, the  
2 system should be capable of functioning during and following  
3 an operating base earthquake; and our concern here is that  
4 this is the very time that we would expect the operator  
5 would want to know the safety status of his plant, and it  
6 would be a very critical issue.

7 (Slide.)

8 In terms of verification and validation criteria,  
9 this is to apply to the design, development, qualification,  
10 and installation of the system. And the validation that I  
11 am talking about here is a one-time effort in the initial  
12 phases of the project, whereas the validation of the data  
13 would be a real time ongoing process that is used within the  
14 display system.

15 The V&V should be conducted by independent  
16 qualified personnel other than the designer-developer. The  
17 objective of that is to achieve a highly reliable and  
18 available system, and it is perceived that if the  
19 designer-developer were to conduct his own qualification, he  
20 would overlook errors. This is one way of attempting to  
21 reduce --

22 VOICE: Can you give me an example of what you  
23 mean by "developer?" Company A develops it and --

24 MR. BELTRACCHI: If you mean specifically, the  
25 ideal situation would be if a utility were purchasing or

1 procuring this equipment from somebody, that the utility  
2 could conduct their own verification and validation while it  
3 is being designed and developed. This would have the  
4 benefit of not only becoming aware of what the system is,  
5 but becoming very well associated with the system, achieving  
6 a high reliability.

7           It also reduces our need as regulators to have to  
8 check every finite step of the process. It would allow us  
9 to conduct an auditing. However, many utilities that I have  
10 talked to claim that they do not have these type of  
11 personnel.

12           If you become associated with or if you are aware  
13 of, say, like the RESAR 414 project on integrated protection  
14 systems, the staff did allow Westinghouse in that case to  
15 conduct their own verification and validation, because they  
16 showed us that they had an independent group that was not  
17 the original designers and developer. However, they were  
18 qualified people in that they had done previous design and  
19 development, and we allowed them to use that group to verify  
20 and validate the system.

21           Does that answer your question?

22           VOICE: Yes.

23           MR. BELTRACCHI: Given that you can show  
24 independence, we will allow you to use a group within the  
25 same company.

1 Yes?

2 VOICE: What exactly do you mean by "independent?"

3 MR. BELTRACCHI: From the original designer and  
4 developer.

5 VOICE: Right.

6 MR. BELTRACCHI: You cannot take the designer and  
7 have him verify his own work. Don't have him within the  
8 same work.

9 VOICE: That would just apply perhaps to a single  
10 person, but if a utility is involved in the development of  
11 this independent system, what -- how removed from the actual  
12 design does the utility have to be for their personnel to be  
13 qualified under independent verification?

14 MR. BELTRACCHI: I guess I would have to look at  
15 the very specific case that you would propose. In the case  
16 of Westinghouse they were able to prove to the staff that  
17 they did have independent -- they had people that were not  
18 within the same design and development group that generated  
19 the system that could be used for the verification and  
20 validation.

21 VOICE: In other words, if a system of this type  
22 were developed by the plant staff and reviewed by a  
23 utility's engineering staff, that would constitute  
24 independence.

25 MR. BELTRACCHI: That probably gets into the realm

1 of what we would accept. But again, I would like to reserve  
2 my final judgment until we proposed an organization that  
3 would do that.

4 VOICE: One more question. How does this differ  
5 from the verification that we are doing on Class 1-E systems  
6 today?

7 MR. BELTRACCHI: I think one of the major  
8 differences is in terms of the need -- many of the quality  
9 assurance people do not have the expertise that would be  
10 required to be able to conduct the independent verification  
11 and validation.

12 VOICE: Here we are talking about design, and yet  
13 on a 1-E system, an AE system is able to design a 1-E  
14 system, and they are able to provide independent  
15 verification. Why are more stringent requirements placed on  
16 this?

17 MR. BELTRACCHI: Relative to 1-E systems, as least  
18 I know speaking to the systems that I have been associated  
19 with, for example, a core protection calculator system, the  
20 RESAR 414, and the reactor protection system, we found that  
21 it had to be formalized in the past. Whether the staff got  
22 into the formalization of that -- assessing the  
23 formalization of that effort within the industry, I don't  
24 think we did.

25 Our experience was in the review of the core

1 protection calculator system we found that the staff had  
2 extended itself to where it was doing portions of the  
3 verification and validations, and we had to retrench and  
4 find a better way of doing business. And this is one way we  
5 have attempted to do this.

6 Now, if there has been a verification and  
7 validation effort in the past in the design of I-E systems,  
8 I don't think it has been very well presented to the staff.

9 VOICE: (Inaudible.)

10 MR. BELTRACCHI: I would like to separate the  
11 quality assurance -- many of the quality assurance -- at  
12 least our experience has been many of the quality assurance  
13 assessments that we made found that the quality assurance  
14 people were not qualified to make that independent --

15 VOICE: (Inaudible.)

16 MR. BELTRACCHI: It is in line, in many respects  
17 in line with the statements that you will find in Appendix B  
18 of 10 CFR 50, if that is your point.

19 VOICE: I guess it is, yes, rather than  
20 independent review by an outside organization.

21 MR. BELTRACCHI: We are not required, at least in  
22 the RESAR 414 review, that the developer and designer go out  
23 and hire an independent organization to conduct the  
24 verification and validation such as DOD requires.

25 VOICE: (Inaudible.)



1 MR. BELTRACCHI: That is correct.

2 Yes?

3 VOICE: Another point, independence of design may  
4 require, say in the area of human factors engineering,  
5 bringing in a consultant to review just that portion of the  
6 design. Is it acceptable to split that review, say if the  
7 utility has the expertise to review the engineering?

8 MR. BELTRACCHI: That would be acceptable. In  
9 fact, I'd like to stress that because human factors is an  
10 area that relative to the Lessons Learned at Three Mile  
11 Island there is much advancement that could be made.

12 May I have the next slide, please?

13 (Slide.)

14 Relative to schedule, the NRR has issued  
15 requirements, a draft set of requirements in the form of  
16 NUREG-0696 with respect to licensee's response --  
17 responses. The designs are to be submitted for NRR review  
18 by January of 1981, and a complete implementation of the  
19 system is required by January of 1982.

20 And I would like to add one or two more slides to  
21 the presentation that I made yesterday in Philadelphia in  
22 order to provide some further clarification with regard to  
23 the plant process computer, since this seemed to be an area  
24 that had many questions yesterday.

25 (Slide.)

1           The first slide will deal with many of the  
2 concerns that the staff has with regard to today's plant  
3 process computer, and I would like to remind you that the  
4 plant process computer is an item -- a component that has  
5 been considered non-safety. It is an item or a component  
6 that the staff has not reviewed its use or its  
7 implementation within the control room.

8           However, in conducting an LER survey -- and this  
9 covers the results of a survey for the last ten years -- it  
10 was very interesting to notice the distribution of the  
11 errors that resulted or were associated with the plant  
12 process computer. There was almost a linear distribution  
13 between hardware faults, software faults, and human error in  
14 the form of interface with the computer.

15           There were a total of 152 events in a period of  
16 that time. I would like to point out that there is a typo  
17 in the hardware portion. Under component failure  
18 malfunction, instead of 39.9, that is 39 percent of the  
19 total you'll find under software faults. It is not the  
20 computer that made the mistake, but generally it was a  
21 design error in the form of a specification that coded and  
22 was never verified or validated against its functional  
23 requirements.

24           It is also interesting to note that the  
25 man-computer interface errors was also a key area, and it

1 would support many of the conclusions that were reached in  
2 an EPRI report that was published in, I believe, May of 1977.

3 But the staff is concerned with these errors and  
4 the propagation of these errors onto emergency response  
5 facility and the safety parameter display system. And  
6 therefore, it was our basis that these facilities should be  
7 separate from the process computer.

8 (Slide.)

9 The next slide will deal with a draft report that  
10 was presented by --

11 VOICE: May I ask a question on the process  
12 computer?

13 MR. BELTRACCHI: Yes.

14 VOICE: Does that apply only to the existing  
15 process computers if it is the intent to replace the  
16 existing computer?

17 MR. BELTRACCHI: Let me amplify further on this  
18 previous slide on the LER errors. It was interesting to  
19 note in a Macro report -- Macro Corporation report that was  
20 done under contract to NSAC -- that is covered in the next  
21 slide -- that they categorized the current status of process  
22 computers within the industry, and they have three  
23 categories. And basically, I guess you could associate it  
24 with the various computer generations. I think it was  
25 pre-1970 to 1975 and 1975 to '80.

1           It did state that the latter courses of process  
2 computer -- the latter category of process computers  
3 probably could be modified to meet the requirements that  
4 have been presented to the staff, and certainly the staff  
5 recognizes that there are architectures within computers  
6 that could be used to address many of the functions.

7           However, I would like to point out that in the  
8 course of these LERs, in the course of trying to evaluate  
9 the trending of the LERs occurring over a period of time,  
10 and over this period of time it is noted that although it is  
11 not presented on here, we did have some work done that  
12 showed that the trend in these LERs as a function of time is  
13 increasing.

14           I am not sure whether that is due to the fact that  
15 there are more functions being done on the process computers  
16 and therefore it is subject to more LERs, or current  
17 architectures that are being used are not sufficient to  
18 address the problems.

19           So I really would like to hear some comments with  
20 regard to that. And we are certainly open to the  
21 architecture that you are going to present. But I really  
22 would like to address these issues, and these are the basis  
23 of our concerns in association with the process computer.

24           VOICE: With regard to the specific numbers of  
25 areas, what is the data base?

1           MR. BELTRACCHI: It is the LER data base that the  
2 staff has in Bethesda.

3           VOICE: Can you give me an idea of the period of  
4 time that you are talking about?

5           MR. BELTRACCHI: Yes, I can. I had an additional  
6 slide on that. The survey was conducted by using just the  
7 word computer within our data base. It covered a period of  
8 time from 1969 to present. It covered all LERs. It had  
9 computers, and in filtering that out it resulted in the  
10 order of 152 LERs that were associated with process  
11 computers.

12           I do have that broken down by plant if you like,  
13 but I don't have the information with me.

14           VOICE: It is 11 years of operation.

15           MR. BELTRACCHI: That is correct.

16           VOICE: The main process computer within the  
17 station --

18           MR. BELTRACCHI: That is the best way we could  
19 interpret the information as presented in the LER.

20           VOICE: Could you clarify for me on this process  
21 computer question, I understand you are not prohibiting the  
22 use of computers for processing the signals. You are merely  
23 prohibiting the use of the plant processing computer.

24           MR. BELTRACCHI: Maybe that is a poor way of  
25 expressing it. Our concern is we are interested in the

1 integrity of the function and the data that is being used.  
2 I think by the distribution and the type of errors that are  
3 shown here, and the fact that design errors in the software  
4 represents a significant portion of the errors, our concern  
5 is that if a programmer were to go in and change a function  
6 like a calibration or a heat calibration, although he would  
7 have trouble doing it but he did get it right, that effort  
8 would result in a modification of the safety parameter or  
9 the TSC in a portion such that when it was needed it would  
10 present wrong information to the operator or erroneous  
11 information to the operator.

12           The operator acts upon it. He aggravates rather  
13 than mitigates the situation. Integrity of function and  
14 integrity of data is basically our concern.

15           VOICE: What makes you feel that if we get -- if  
16 we do away with the plant process computer and install an  
17 additional processor that it is going to be any different  
18 with this?

19           MR. BELTRACCHI: The control is the fact that we  
20 are going to stress verification and validation, and we will  
21 probably use such tools as software sneak circuit analysis  
22 to look at some of the critical modules to assess how well  
23 the job is done. We cannot go in and do that job for you.

24           VOICE: I wouldn't expect you to, but if a new or  
25 installed (inaudible).

1 MR. BELTRACCHI: Okay. Let me stress again that  
2 our concern is the integrity of the function, the integrity  
3 of the data, and being able to accomplish this job. If you  
4 can promote an architecture that is within your process  
5 computer that will do this and will prove that failure of  
6 the other portions of the computer, failure of other  
7 portions of the data net is not going to affect the  
8 execution of this function, we are certainly willing to sit  
9 down and evaluate it.

10 VOICE: I think 0696 presently states that you can  
11 use a process computer. We will be receptive of the  
12 comments which would provide us with words that would give a  
13 criterion that would provide for security and integrity  
14 function, as Leo is talking. We were not clever enough to  
15 devise those words today. Maybe later on we will or with  
16 your help we could.

17 But based on what we could see of current process  
18 computers, they were not acceptable. Now, maybe future  
19 generations which we have not seen might be acceptable if  
20 they met certain requirements. We would have to state what  
21 those requirements are in 0696

22 VOICE: I understand your concern, but I don't  
23 understand how putting in a separate processor -- you are  
24 going to have to have separate to the same extent  
25 (inaudible) just for this particular functional loan.

1           MR. BELTRACCHI: That was not our intent. Our  
2 intent was that this could be shared. It is a function  
3 important to safety. We furthermore feel that there should  
4 be a gradation. Things in the past have either been safety  
5 or non-safety. I think one of the Lessons Learned out of  
6 Three Mile Island is there are systems important to safety,  
7 and there should be a category -- a difference between  
8 categories 1-E and non-1-E.

9           VOICE: I had a question on the data base. Did  
10 you age this data in such that you know whether is the old  
11 computer systems that are contributing, or are the new  
12 computer systems contributing their share of these failures?

13           MR. BELTRACCHI: I had an intern do a real quick  
14 reassessment of the data in terms of an NSAC report that  
15 came out. It is summarized on the next slide. And as I  
16 stated previously, one of the disturbing aspects of this is  
17 the fact that it seemed the data would trend up as a  
18 function of time. So in the most recent data it seemed  
19 there were more errors per licensed plant than in the  
20 previous older data.

21           Now, that is going to have to be checked because  
22 that was a real rapid assessment. I tried to have an  
23 assessment of time within the categories that were defined  
24 by the Macro report, that is, pre-1970, '70 to '75, and '75  
25 to '80. The disturbing aspect was if you normalized the



1 data and tried to evaluate errors per plant, it trended up.  
2 Whether that is due to the fact that there are more  
3 functions being performed on the plant process computer and  
4 therefore you would expect more LERs to develop, I am not  
5 sure. I don't know its cause.

6 Yes?

7 VOICE: Leo, from a boiling water reactor point of  
8 view, I don't know the requirements to report computer  
9 problems on LERs.

10 MR. BELTRACCHI: The nature of these where you  
11 performed a technical violation or a surveillance  
12 requirement, or you achieved a higher operating limit, the  
13 spectrum was rather wide.

14 Yes?

15 VOICE: If we design the system to meet these  
16 emergency response facilities, would you object then to the  
17 system being expanded to now take over the requirements that  
18 are associated with process computer, that we maintain the  
19 same level of quality control?

20 MR. BELTRACCHI: Probably not, provided that the  
21 failure of your process portion or your process elements  
22 would not impact this portion of the system, and there are  
23 ways that that can be achieved.

24 Yes?

25 VOICE: Since the wording of 0696 is kind of

1 proscriptive and strict in a sense, will that be clarified  
2 and this interpretation, meaning the data and the function  
3 being the prime requirements --

4 MR. BELTRACCHI: I think Warren just asked for  
5 your assistance in this area, if I understood his point of  
6 clarification. We would recommend that you make an attempt  
7 to provide alternates to that wording in the form of  
8 functional approach or to achieve the integrity of the  
9 function and security of the data.

10 Yes?

11 VOICE: For your data on the front here there has  
12 been no attempt to try to see whether these errors actually  
13 would have affected the types of data that you are looking  
14 at from tech support centers.

15 MR. BELTRACCHI: That is correct, but I think you  
16 can look at portions of the hardware component failures, and  
17 you know you are going to lose the system, especially if its  
18 power supply or electrical supply -- or component failures,  
19 if it is a monolithic type of design, a component failure  
20 will probably shut you down.

21 If you have a design where you can get functional  
22 redundancy or you have a lot of not working or maybe failure  
23 of a component does not tear the total system down, then I  
24 agree you can still achieve the function. I think the staff  
25 recognizes there are many computer architects out there that

1 probably could satisfy our requirements.

2           We have not specified that in the form of a  
3 functional nature within 0696. Our concern was strictly  
4 with the process computer, and the basis of our association,  
5 which has been very limited, and the concerns that have  
6 resulted from that association.

7           Could I try to get this last slide across and then  
8 attempt to address some of the other issues, and then I will  
9 take questions.

10           There is a draft report by -- it was authored by  
11 NSAC. It had to do with a survey of computer systems and  
12 interface guidelines for nuclear power plants. The draft  
13 was published in 1980. The number is given at the bottom of  
14 the slide. And I imagine it will be out in formal form  
15 within a month or so. However, there were some interesting  
16 points that were brought up in the report with respect to  
17 availability.

18           It said that as a result of their survey, if the  
19 availability was higher than 99.8 percent, it could not be  
20 achieved without -- without accepted unreasonable cost. 002  
21 is probably within the tolerance of what we would accept.  
22 But they also recommended that availability should be  
23 demonstrated during a test period of at least 1,000 hours.

24           Yes?

25           VOICE: In the NUREG you say .01 unavailability

1 and .001 unavailability. Do you mean percent?

2 MR. BELTRACCHI: Unavailability would be the small  
3 number. Availability would be the large number.

4 VOICE: (Inaudible).

5 MR. BELTRACCHI: An availability of 1 times 10 to  
6 the -3 would work out as eight hours per year. It is also  
7 interesting to note that the expandability -- in terms of  
8 expandability, that they require that all -- they  
9 recommended that all hardware and software should be capable  
10 of easy expansion within minimum down time to accommodate  
11 growth and relative to the life span. And I am sure this is  
12 a rather important area.

13 A completely new system should have a minimum life  
14 span of approximately ten years, and it is really dependent  
15 upon the existence of spare parts. And I am sure that many  
16 of you have some of the older computers, and you have pretty  
17 much learned to live with that problem and recognize what  
18 your availability problems are.

19 At this point I guess I have completed the main  
20 portion of the talk, and I am open to questions.

21 Yes.

22 VOICE: (Inaudible). I would like to explore  
23 (Inaudible). If I understand you correctly, you do not want  
24 to use any kind of a signal (Inaudible), but it is  
25 permissible to use the (Inaudible).

1 MR. BELTRACCHI: Input?

2 VOICE: (Inaudible).

3 MR. BELTRACCHI: In the sense that you would --  
4 well, okay. My only concern there would be with the failure  
5 with the plant computer resulting in the failure of the  
6 signal to the safety parameter display.

7 VOICE: No.

8 MR. BELTRACCHI: Okay. Again, I want to get back  
9 and stress the functional integrity of the function and the  
10 security of the data.

11 VOICE: The unavailability is bandied around a lot  
12 without defining it. What defines unavailability on a  
13 system? Is it total failure of the system? Is it a failure  
14 of the smallest part of the system? What is unavailability?

15 MR. BELTRACCHI: Failure of the function in terms  
16 of the operator not being able to assess the safety status  
17 of the plant through the display.

18 VOICE: If one parameter fails and you have some  
19 backup for the operator to assess the safety of the plant,  
20 that does not constitute unavailability.

21 MR. BELTRACCHI: If you're saying that one  
22 parameter failed -- I guess we are now getting into some of  
23 the details. Either we would have to cover that through  
24 technical specifications or a look at the specific proposal,  
25 but I would sort of suspect that it probably -- something

1 could be worked out in that area. I don't know what you  
2 would propose.

3 If in essence it said that one signal failed, and  
4 he had within close proximity another signal he could look  
5 at on the board --

6 VOICE: Right. That definition is very important  
7 because this number is going to be the biggest bone of  
8 contention, I believe, and we have to come up with a  
9 definition for it. There is no point in talking about the  
10 number without defining what it contains.

11 MR. BELTRACCHI: You are also proposing a solution  
12 for which I don't know all the details either.

13 Yes?

14 VOICE: I would like to back up to something you  
15 mentioned earlier. You said that the SPDS must be designed  
16 to withstand an OBE. I take it that that does not apply to  
17 the displays in the TSC or elsewhere since neither of those  
18 facilities are seismic in the first place.

19 MR. BELTRACCHI: That is correct. Along that line  
20 and as a point of clarification, the SPDS and displays in  
21 the TSC need not be seismically OBE.

22 Yes?

23 VOICE: Are you then also saying that the computer  
24 itself as part of the data acquisition system (Inaudible);  
25 and therefore must be designed to seismic Class 1-E and/or

1 must be installed in a seismic Class 1 structure?

2 MR. BELTRACCHI: No. It all depends on where you  
3 structure your interface with respect to the sensors. 0696  
4 states that the sensors and the signal conditions are either  
5 in the form of isolation devices or preamplifiers, what have  
6 you.

7 The Class 1-E, the industry has requested or there  
8 have been elements of the industry that have requested the  
9 establishment of a common data base such that it could be  
10 drawn upon by many components, such as a plant process  
11 computer, SPDS, TSC, whatever. And it was within that  
12 element that our concern was that if you do that, you should  
13 provide at least -- that information be OBE as a link or as  
14 a component of the safety parameter display system. It all  
15 depends on where you locate your isolation device in terms  
16 of what portion of it you want to have 1-E versus non-1-E  
17 but yet meet the requirements of OBE.

18 Yes?

19 VOICE: In relation also to this OBE thing we  
20 really don't see any problems with using existing sensors or  
21 properly isolating them and using the existing criteria for  
22 Class 1-E signals. However, the computer in this case seems  
23 to be the problem in question. I don't know that there is  
24 one that could qualify.

25 MR. BELTRACCHI: I would like to point out that

1 the core protection calculator system which was reviewed  
2 from '75 to '78 is currently in use.

3 VOICE: Internal as well as (Inaudible)?

4 MR. BELTRACCHI: The electronics, that is correct.

5 MR. DANIELS: George Daniels. With regard to  
6 qualifications of the OBE, I would point out that as of  
7 right now there is no standard which addresses OBE  
8 qualification. Okay. That will be a problem in approaching  
9 this specific type of situation.

10 IEEE 344.75 really tells you or your vendor how to  
11 qualify a piece of equipment to an SSE, and that will create  
12 ultimately some sort of --

13 MR. BELTRACCHI: I agree, and I think I tried to  
14 address this earlier in a comment with respect to  
15 categorization of standards from l-E to non-l-E, and this is  
16 an area that probably does need additional work.

17 Yes?

18 MR. O'BRIEN: John O'Brien. I would like to get  
19 into the location of the safety parameter display to get a  
20 little clearer picture of that. Your emphasis on making it  
21 available to the shift supervisor -- shift technical  
22 supervisor leaves me wondering where you really pictured  
23 this display.

24 I am dealing with a nuclear net control room, and  
25 we are looking at the display in the front of the control



1 room; but you are suggesting perhaps that the display be in  
2 the back.

3 MR. BELTRACCHI: The requirements on this would be  
4 to provide -- you are correct in the sense that it is to  
5 provide an overview of the plant, and therefore, it should  
6 be located where it is easily accessible to the shift  
7 technical supervisor.

8 I don't know specifically the details of nuclear  
9 net as to -- in a sense are you talking about the back of  
10 the horseshoe?

11 MR. O'BRIEN: We were looking at putting it  
12 (Inaudible) the main panel of the horseshoe, but then the  
13 tech shift supervisor, his console is in the back of the  
14 horseshoe.

15 MR. BELTRACCHI: I would have to look at the  
16 specifics of that.

17 MR. O'BRIEN: I was just trying to --

18 MR. BELTRACCHI: It should be really accessible to  
19 the shift supervisor and the shift technical advisor. You  
20 may want to duplicate it within the control room.

21 VOICE: I have a question on the CBE  
22 qualification. (Inaudible).

23 MR. BELTRACCHI: We had a call for that, and I  
24 recognize this may be an area -- however, I do want to point  
25 out that in -- I know there are hardened CRTs on the

1 market. I have not made a one-to-one comparison to ensure  
2 that it would meet the OBE for every plant.

3 VOICE: (Inaudible).

4 MR. BELTRACCHI: Again, we did not go out and say  
5 use CRTs exclusively. Display is an area where you are free  
6 to look at many designs.

7 VOICE: (Inaudible).

8 MR. BELTRACCHI: I don't think you will find the  
9 word "CRT" in the computer --

10 VOICE: (Inaudible).

11 MR. BELTRACCHI: We tried to be -- we tried to be  
12 general in nature rather than design specific.

13 VOICE: Also, the non-safety sensors are going  
14 into the safety parameter display system. Reg Guide 1.97  
15 (Inaudible). How will you meet your OBE qualifications?

16 MR. BELTRACCHI: We would have to look at the  
17 specifics. There are an awful lot of parameters in 1.97,  
18 but they're all not -- they are not all Class 1-E  
19 categorization.

20 VOICE: They are category number 5 (Inaudible) and  
21 you are trying to put the same parameters into your --

22 MR. BELTRACCHI: I would like to stress that the  
23 safety parameter display system should consist of the macro  
24 variables, the prime variables. It should not in essence  
25 consist of the status of a valve or component. The failure

1 of those systems will be reflected upon the prime variables,  
2 and I think that is consistent with the objective of keeping  
3 a minimum set of prime variables so you can simplify the  
4 problem of interpretation for the operator.

5 VOICE: (Inaudible).

6 MR. BELTRACCHI: We might flood him with  
7 information, and he won't be able to find a needle in a  
8 haystack.

9 VOICE: (Inaudible).

10 MR. BELTRACCHI: I did not say -- I said that the  
11 set, the minimum set would probably be a subset of 1.97. I  
12 did not say use 1.97 exclusively.

13 VOICE: Okay. And that goes to the second part of  
14 the question. You want isolation -- sensors in isolation to  
15 be Class 1-E. A good example is meteorological data and  
16 environmental data will be non-1-E type of data.

17 MR. BELTRACCHI: Would you expect to include that  
18 in your safety parameter display?

19 VOICE: Meteorological panel -- meteorological  
20 data.

21 MR. BELTRACCHI: I would envision if you are that  
22 far out, you know, I would expect that there be a much  
23 better lead indicator closer to the core that would tell you  
24 that you had a problem, and therefore, I would consider that  
25 that relative to a minimum set would be a gross

1 amplification.

2 Yes?

3 VOICE: If this OBE qualified system is located in  
4 the technical support center which is non --

5 MR. BELTRACCHI: Wait, wait, wait. The technical  
6 support center display duplication does not have to be OBE  
7 qualified.

8 VOICE: What design we were considering was using  
9 a computer room facility in the technical support center  
10 that we are building to house the process monitor that would  
11 also derive the plant safety status display. The building  
12 we are considering constructing would not be seismically  
13 qualified. The system that would be put in there, would it  
14 still be --

15 MR. BELTRACCHI: I had not thought of that one.

16 VOICE: This is, I think, a real problem because  
17 we are running out of space to put these systems into the  
18 control room, okay, and since we were constructing a new  
19 facility, we thought this would be an optimum place to put  
20 the processing system itself.

21 MR. BELTRACCHI: There is no way you can break  
22 that portion out, the safety parameter display portion out.

23 VOICE: I think the concept a lot of utilities are  
24 looking out is one central type of computer system that  
25 would respond to all of your logical functions. I think

1 that integrated design approach is one that is being  
2 commonly considered.

3 MR. BELTRACCHI: I would agree, but then in terms  
4 of the size of the safety parameter display or its  
5 requirements on a total system, I could envision a dedicated  
6 system that would really be a small portion of that.

7 VOICE: The problem is the signal conditioning and  
8 the logic. If you bring these systems in, okay, I think it  
9 is pretty considerably more effective (Inaudible).

10 MR. BELTRACCHI: If you bring them into one  
11 central area and you intend to use non-OBE qualified  
12 equipment, that means if you were to have an operating base  
13 earthquake, you would lose an awful lot of interface across  
14 the board. Can you tolerate that?

15 VOICE: The building would be substantially  
16 non-seismic designed.

17 MR. BELTRACCHI: You have not answered my question.

18 (Laughter.)

19 VOICE: The intent of the guideline here is that  
20 an operating-designed earthquake, you have to show that you  
21 will not lose this plant safety status display. That is the  
22 overall consideration.

23 MR. BELTRACCHI: That is correct.

24 Yes?

25 MR. COMPTON: Byron Compton, Washington Public

1 Power. I want to get back to one thing that you said that I  
2 don't think comes through very clearly in here. You said  
3 for a safety parameter to display you wanted to use a subset  
4 of 1.97?

5 MR. BELTRACCHI: I thought that was stated fairly  
6 well in 0696.

7 MR. COMPTON: It says minimum is 1.97, all types.

8 MR. BELTRACCHI: That is a misinterpretation.

9 (Laughter.)

10 MR. COMPTON: If you are trying to show that on  
11 page 8, it does not come through very clear. Everything  
12 that matches 1.97 must match the same qualification.

13 MR. BELTRACCHI: The intent was not to use all the  
14 parameters in 1.97 because it will get us back to where we  
15 are today in terms of control board, and the intent is  
16 really to minimize the overall key variables which the  
17 operator -- by which the operator would be able to make an  
18 assessment of the safety status of the plant. By definition  
19 that would be a subset of what is in 1.97, and I think  
20 probably a subset of what is in Category A and B.

21 VOICE: It is going to mean some new derived  
22 variables, isn't it?

23 MR. BELTRACCHI: It could well be derived  
24 variables from variables that are there, that is correct.  
25 It all depends on what you choose as your minimum set.

1 There are some people that have talked about trying to keep  
2 coolant mass inventory in the primary system. That, of  
3 course, is a derived variable.

4 MR. RAMOS: You are taking a very narrow look at  
5 the words on page 4. That minimum data set from Reg Guide  
6 1.97 is taking the four components of the emergency response  
7 facility as a whole. For the TSC and the EOF, for example,  
8 that is the minimum data set. It is expected that the SPDS  
9 would be a subset of that.

10 MR. COMPTON: Right. (Inaudible).

11 MR. RAMOS: Your common data acquisition system  
12 would have that as a minimum set, and you would pull out of  
13 that acquisition system whatever you needed to meet the SPDS  
14 requirements.

15 MR. COMPTON: Okay. Then anything that is not  
16 Class 1-E input or non-safety input still has to meet OBE,  
17 right?

18 MR. MINNERS: Only if it is used in the safety  
19 parameter display. There are four elements. The four  
20 elements together will have at least the Reg Guide 1.97 set  
21 of variables. Each one will not have all of the Reg Guide  
22 1.97 variables. They will only have whatever they need. So  
23 for the safety parameter display you will have a few  
24 variables from the larger set of Reg Guide 1.97 variables  
25 that will be selected for its function, and those few

1 variables will have to have OBE qualified instrument  
2 channels.

3 MR. BELTRACCHI: Let me amplify on that further.  
4 Roughly a week ago NSAC made a presentation to ACRS. They  
5 defined in that presentation for both BWRs and PWRs a set of  
6 parameters they were proposing for the safety parameter  
7 display system; that was a subset of what was currently -- I  
8 believe currently in 1.97. I have not made a one-for-one  
9 comparison, but I think that is a subset. And it only  
10 consisted, I think, of on the order of maybe 15 parameters.

11 VOICE: For a plant that was about 35 different  
12 variables when you considered the different loops. The  
13 problem I see in that area is that it seems -- and this was  
14 brought out in that presentation -- a lot of the items in  
15 1.97 which are supposedly supposed to provide this sort of  
16 monitoring were determined prior to really determining what  
17 their functional use would be. And it seems that when we  
18 define the functional use via the safety parameter display  
19 system, the needs of the tech support center and support  
20 staff, that that should be fed back into 1.97 to modify the  
21 basic data list.

22 MR. BELTRACCHI: Your concern was dwelled upon for  
23 about two days at ACRS. Let's not go over it now.

24 (Laughter.)

25 The staff is fully aware of that, and we have a



1 letter from the ACRS.

2 VOICE: My real question relates to schedule.  
3 Since he brought that up while I was standing here, I  
4 thought I'd hit that.

5 Relative to schedule, implementation of a system  
6 with this sort of reliability or trying to approach this  
7 sort of reliability -- and we have been in contact with a  
8 number of vendors that provide very reliable equipment that  
9 cannot bid to that sort of specification.

10 The schedule that you have there of full  
11 implementation by January of 1982 is impossible by most of  
12 the vendors we contacted that in that development and  
13 delivery time put things beyond 18 months.

14 I am wondering what sort of determination went  
15 into developing those dates, whether that was just a yearly  
16 extension of what seems to be a January 1 deadline put out  
17 by 0578 that has been carried through to --

18 MR. BELTRACCHI: Of course there is the pressure  
19 of time in terms of the elapsed time since Three Mile  
20 Island, and furthermore, I think you may have to start  
21 thinking in terms of modularity with respect to your design.

22 I get the impression that what the industry would  
23 like to do is to insert the total system, and then that will  
24 encompass everything. I don't know whether we're going to  
25 have the luxury of that.

1           VOICE: Well, we have been working with a group of  
2 utilities since November of last year with this concept in  
3 mind. We would have looked ahead and saw the direction  
4 things were going, and we developed a system to handle this  
5 which would be expandable and start with the minimum  
6 information and address some of the increased needs.

7           And just on that basis, going through the normal  
8 development, we cannot meet the January 1, 1982 date, and we  
9 started last November.

10          MR. MINNERS: That is the kind of written comment  
11 which we are soliciting, and especially if you can provide  
12 the facts which show what your lead times are and design  
13 times and that kind of thing to support your contention that  
14 it is too short a schedule. And we are receptive to those  
15 kinds of comments.

16          VOICE: I would like to point out that we recently  
17 put out a proposal for bids for software which had a January  
18 1982 deadline on it that the vendors said they would have  
19 trouble meeting.

20          MR. BELTRACCHI: That point is also brought out in  
21 our report.

22                 Yes?

23          VOICE: In response to that, the AIF meeting that  
24 is being held next week is also going to consolidate  
25 industry comments on the schedules that the plants can

1 meet. AIF has conducted a survey for all utilities and  
2 owners groups. They promised NRC that they would come back  
3 with the best range of schedules for plants, and that is  
4 going to be consolidated next week at AIF. So if anybody  
5 has any input to schedules or whatever, they should get that  
6 to the AIF.

7 MR. BELTRACCHI: Let me make one other point  
8 relative to this. I think it is important that the industry  
9 try to consider standardization either along the lines of  
10 owners groups or vendor groups. It is going to minimize the  
11 NRC's effort in trying to conduct the review, and it should  
12 be able to shorten the schedule for final implementation.

13 Yes?

14 MR. MYERS: One of the significant problems we  
15 found is in the area of schedules, vendor bidding, etcetera  
16 (Inaudible) without standards and degree of acceptability  
17 for not only the computer main frame or whatever, but also  
18 all processors, routing the cable, and considerations that  
19 we normally get into in the SSE areas. We are looking at an  
20 exceptionally extended period of time to evaluate that.

21 Considering in a plant when you have an earthquake  
22 you don't know whether it was an OBE or not, it is a  
23 question of how we validate the information. I think that  
24 needs to be addressed.

25 Probably recognizing that fact, the OBE is more a

1 design goal rather than an actual verified QA piece of  
2 paper. Then it might be addressed more reasonably and help  
3 out in the scheduled implementation.

4 MR. BELTRACCHI: How do you measure that? That is  
5 our problem.

6 MR. MYERS: Very difficult. (Inaudible).

7 MR. BELTRACCHI: This may be an area where  
8 standardization -- I don't know whether it could be achieved  
9 or not -- but standardization certainly would help.

10 MR. MYERS: Standardization processes take years,  
11 as you are aware, and the example of the Arkansas core  
12 protection calculator (Inaudible) for the SPDS and elsewhere  
13 here.

14 MR. BELTRACCHI: That is true, but it is  
15 SSE-qualified.

16 MR. MYERS: I understand.

17 MR. BELTRACCHI: Yes?

18 VOICE: From what I have heard we have two sets of  
19 criteria, one for the safety parameter display system has to  
20 be in an OBE building, an OBE processor, a data acquisition  
21 system and processor, and have OBE-type displays, and  
22 availability for eight hours (Inaudible). You still retain  
23 001 availability, but some of the other systems'  
24 requirements (Inaudible), so in fact, unless you are going  
25 to end up with dual systems for those functions unless you

1 can (Inaudible).

2 MR. MINNERS: Well, we tried to write what we  
3 required for each element of the thing, and then it is up to  
4 the designer to integrate the design. We did not want to  
5 give one set of requirements for all elements. You know, we  
6 recognize the problem is that if you have something which is  
7 an integrated system, then only one part of it has to meet  
8 higher requirements than the rest. It makes the whole  
9 system meet the higher requirements. That is not the only  
10 design possible

11 VOICE: What I am really saying is that you cannot  
12 -- we don't know of a computer that can do graphics, display  
13 events with great flexibility, and using CRTs. We don't  
14 know of one for the SPDS system. This one could be used,  
15 though, for the technical support center provided it meets  
16 the other criteria.

17 But it seems what you are really telling us from a  
18 practical standpoint is that the higher level requirements  
19 for the SPDS system are going to preclude using computers,  
20 graphics, and CRTs unless somehow we can find something that  
21 can be qualified.

22 MR. BELTRACCHI: Not necessarily, because I have  
23 had computer vendors calling me telling me that their  
24 computers can do it.

25 (Laughter.)

1 I don't want to name them publicly. You can see  
2 me afterwards, and I will.

3 VOICE: (Inaudible).

4 MR. BELTRACCHI: I know relative to hardened CRTS  
5 the DCD has several sources. Now, yesterday there was a  
6 gentleman that said that he had looked into that and said  
7 that they would basically shock load it, but they would not  
8 take a wide spectrum. So although -- after thinking about  
9 it, you know, in terms of shock loading, an impulse should  
10 contain all your frequencies, so I guess it is a question of  
11 amplitude.

12 VOICE: (Inaudible).

13 MR. BELTRACCHI: As I said, I know that DCD has  
14 many considerably hardened -- I have not made a one-to-one  
15 comparison. I don't know whether they will need OBE.

16 VOICE: (Inaudible). Relative to this schedule in  
17 1982, on page 9 you say that detailed guides (Inaudible) are  
18 going to be published separately. When are we going to get  
19 those guides, and how are we going to input them into our  
20 system design if we have to submit the design by January 1,  
21 1981?

22 In addition, your schedule lists that the NRC will  
23 (Inaudible). What happens if your schedule slips and you  
24 don't complete your review design, and you don't get back to  
25 us on time to meet any of our technical design requirements?

1 MR. MINNERS: Let me discuss the additional  
2 detailed guidance.

3 VOICE: Would you speak up, please?

4 MR. MINNERS: Is that better?

5 VOICE: A little bit.

6 MR. MINNERS: Let me address the question of  
7 additional detailed requirements. There is some difference  
8 of opinion in the staff report that they are desirable or  
9 necessary, and 0696 currently says we are going to give you  
10 something, and drafts of these detailed requirements have  
11 been developed.

12 I think a question that I would like to ask the  
13 industry is whether you want this. Is the material in 0696  
14 now sufficient, or is further information necessary, or is  
15 further information desirable?

16 I think we all realize how the regulatory process  
17 goes, and if we give you more information, you may not like  
18 it, and you may have to be so conservative to cover all  
19 generic requirements; that it may exclude some things.

20 And I really would like people to think about  
21 that, plus the problem of the time to produce those kind of  
22 detailed requirements.

23 VOICE: I think that is a point very well taken,  
24 and I think most of us -- everybody can comment on that.  
25 Most of us would like to see the functional needs defined

1 rather than being prescriptive, and there are certain  
2 portions of 0696 that become very prescriptive. I don't  
3 think there is a need to be that prescriptive.

4 I certainly would not want to see additional  
5 detailed requirements coming out, because what we end up  
6 with is something that again gets over-specified, and it  
7 becomes impossible to meet.

8 If we ended up with some modification to 0696, I  
9 think we would be satisfied with that in that a number of  
10 things which I am sure will be addressed later when we talk  
11 about EOF. Because of the type of facilities we are  
12 constructing, we are not planning on having the same type of  
13 separation simply because of building space. In other  
14 words, some of the things that you say should be in the EOF  
15 we have space to do in other facilities and feel that is  
16 where it should be done because of equipment location,  
17 proximity, and space availability. I think becoming very  
18 prescriptive has a great danger to it.

19 MR. MINNERS: If we don't become prescriptive, it  
20 increases the chances that when you come in and we review  
21 it, increases the chances that we will not approve it. We  
22 have all been through this before, and I would like to hear  
23 what the industry has to say, because I have heard the  
24 opposite of what you say.

25 I think when you get down into the design level



1 and purchase level of people, they would like to have a  
2 piece of paper they can put a rubber stamp on and send it  
3 out to the vendor. You can see why. It is much easier for  
4 a designer if he has detailed requirements.

5 VOICE: We have not been all that satisfied with  
6 the vendors' response.

7 MR. MINNERS: Okay.

8 MR. BELTRACCHI: Yes?

9 VOICE: (Inaudible) designed to earthquake  
10 criteria, and operators have been using them for years. I  
11 have a hard time understanding why the CBE requirement is  
12 being placed on the safety parameter display. The safety  
13 parameter display, the tech support center, that is being  
14 used as an operator aid, and we even talk ourselves as being  
15 used by supervisors for overview. All those things are  
16 already on display, and they are qualified.

17 You know, I can understand, you know, wanting to  
18 do more and do more and do more, but yet with the state we  
19 talk about of computer systems, displays and stuff and the  
20 development and all, I have a very hard time trying to  
21 understand why you are trying to provide for those 15  
22 parameters on the board. You can highlight, you can do  
23 something else rather than putting in as an additional  
24 requirement.

25 MR. BELTRACCHI: I will address that issue, and

1 the issue is fairly simple, and it is fairly basic. Both  
2 the Enrico Fermi incident and the Three Mile Island  
3 accident, there is a very common thread. The post-mortem  
4 analysis stated that the information was all located in the  
5 control room. It was all there. But the problem was it was  
6 so diffuse that the operator could not integrate it.

7 The purpose of the safety parameter display system  
8 is to provide that integration and concentration, and  
9 because of that importance to safety, we have placed these  
10 requirements on it.

11 VOICE: It sounds like you are saying that the  
12 board today is inadequate.

13 MR. BELTRACCHI: In terms of the critical minimum  
14 set of parameters in a human factors interface, yes.

15 MR. MINNERS: Let me try to expand on the  
16 rationale for having the safety parameter display, the  
17 safety parameter display to be qualified to the CBE. The  
18 rationale is if you had an earthquake, you would have a  
19 large number of alarms that would be given on the control  
20 board which would confuse the operator, and that is exactly  
21 the purpose of the safety parameter display, to give him  
22 some place to go when he has confusion and to know whether  
23 he is safe or whether he is unsafe, to put it simply.

24 And an earthquake is a case in which an operator  
25 does not know what is going to happen, and you are going to

1 have all these alarms going off; so that is the rationale  
2 for having such a requirement.

3 We realize that the plant is designed to survive  
4 the earthquake and nothing should happen to it, and that it  
5 will still be able to operate and certainly able to shut  
6 down. But it is the confusion. You don't want the operator  
7 to see some alarm and then do the wrong thing, and then he  
8 could be the one that puts the plant in the unsafe condition  
9 rather than it being a direct result of the earthquake.

10 VOICE: I think you can take any transient going  
11 on. There are alarms on all the transients that go on. I  
12 think the operators concentrate first on annunciators and  
13 then on parameters that are important to the plant.

14 MR. MINNERS: Our perception is that he does  
15 concentrate, and sometimes he does concentrate on the wrong  
16 thing. I think there are plenty of examples where you have  
17 alarms in the secondary system, and he is concentrating on  
18 the secondary system trying to get that straightened away,  
19 and that is not his real problem.

20 That is what the safety parameter display is  
21 supposed to do, focus his attention on the primary thing  
22 which is the reactor.

23 MR. BELTRACCHI: First, on annunciators, they may  
24 not be safety-related annunciators.

25 VOICE: First of all you are making the assumption

1 you are going to have an accident and an earthquake together.

2 MR. MINNERS: No, that is not the assumption. I  
3 tried to explain that.

4 VOICE: You are going to have -- the system is not  
5 qualified for the OBE. It is still going to be available  
6 most of the time. It is likely in the event that if you do  
7 have an accident, the system is going to be available. You  
8 are also forgetting about the requirement we have to go  
9 through a human factors evaluation of the control room and  
10 making the necessary corrections such that the existing  
11 displays are meaningful and are located such that they are  
12 not confusing to the operator and can be used by him.

13 MR. MINNERS: Well, I --

14 VOICE: The one single event, the earthquake, you  
15 have existing parameters to fall back on.

16 MR. MINNERS: That is correct. Let me try to -- I  
17 don't think I have gotten my point across, and let me say it  
18 again. I'm not trying to argue with you. I just don't  
19 think you have understood what I said. Let me try it again.

20 We realize that during an earthquake the plant is  
21 designed to survive the earthquake, and therefore we will  
22 not have an accident. We are not presuming an accident.  
23 But during an earthquake you will certainly have a large  
24 number of alarms going off because the earthquake is going  
25 to do things to the non-safety equipment and probably some

1 of the safety equipment that is going to cause alarms. And  
2 he is going to have mass alarms on his board.

3 VOICE: Are you sure?

4 MR. MINNERS: Am I sure?

5 VOICE: Yes.

6 MR. MINNERS: Yes, I am sure, yes.

7 VOICE: I'm not.

8 MR. MINNERS: Fine. If you can make that  
9 demonstration, I think I would accept it. The people I have  
10 talked to have said what I am describing to you. If you  
11 think that what you say is right and have some way of making  
12 a demonstration, I would be interested to see it because  
13 that is an interesting point.

14 If you have had experience in fossil plants that  
15 have gone through earthquakes and you don't get alarms, that  
16 would be interesting information. That is not what I have  
17 been told. I don't know how else you would go about proving  
18 it.

19 VOICE: Pardon me.

20 MR. MINNERS: I don't know how else you would go  
21 about making a demonstration except to --

22 VOICE: You are making an assumption because you  
23 don't know you are going to have them. You are saying you  
24 don't know; therefore, they will be. I don't think that is  
25 valid either.

1 MR. MINNERS: No. The people I have talked to  
2 have said that this is the experience, that during such  
3 events you get alarms. It certainly --

4 VOICE: Which people have you talked to?

5 MR. MINNERS: I'm sorry. I cannot give you a list.

6 VOICE: How many of them have experience in a  
7 control room?

8 MR. MINNERS: I agree, I have very limited  
9 experience.

10 VOICE: How many people you talked to have  
11 experience in a control room?

12 MR. MINNERS: I'll put the questions back to you.  
13 How many people you have talked to have experience in a  
14 control room during an earthquake? That is the question.  
15 Neither one of us really knows, but we have to go on the  
16 best information we have now. If you have better  
17 information than I do, I would welcome it. I would  
18 encourage you to provide it, because it would help us make a  
19 better decision.

20 VOICE: My only point is you are limiting what we  
21 can do because of one event design basis earthquake --

22 MR. MINNERS: You have misunderstood it. I think  
23 you are distorting what we are doing slightly. We have not  
24 asked for a design basis earthquake. We have asked for an  
25 OBE, which is not the design basis earthquake.

1 VOICE: You are still limiting our flexibility.

2 MR. MINNERS: For one event.

3 VOICE: For answering the Kemeny Commission and  
4 the Rogovin Report. We are not keeping up with the state of  
5 the art, the operator displays --

6 MR. MINNERS: That would be an excellent comment  
7 to make, that we think you are designing for an extreme  
8 event, and that is a lesson to be learned from Three Mile  
9 Island, that you should not design for extreme events,  
10 because the majority of events are not those, and you want  
11 to have the best system for the non-extreme events. That is  
12 a good comment. If you sent that comment in, I think people  
13 would consider it very carefully, but --

14 MR. MYERS: In your description of the confusion  
15 in the control room, obviously if you do have a lot of  
16 alarms, yes, there is confusion. However, in an earthquake  
17 event, the first thing you would have to verify before you  
18 went to the SPDS is that it was less than an OBE; it was  
19 within its qualification. If not, then you could not rely  
20 on it or you would have to go through a validation process  
21 to validate SPDS information against the SSE qualified  
22 information already in the control room.

23 As I said, there are no instruments in our plant  
24 that are directly readout type. Yes, you have had less than  
25 an OBE, or no, you have no more than an OBE. Not having had

1 that information, a validation process would have to occur.

2 Yes, you can go to the CRT, but you would have to  
3 sit there and validate against the SSE. That process in  
4 itself would force the operator to look at other parameters.

5 MR. WINNERS: That is a probability argument. The  
6 probability of having greater than an OBE is very small, and  
7 the Commission has chosen not to design against it. We will  
8 take the chance that once in so many times you get something  
9 greater than the OBE, and it misleads the operator -- a  
10 small chance.

11 MR. MYERS: So for this type of evaluation you are  
12 going to send the operator to -- when he has a known  
13 earthquake -- to a piece of information for his initial  
14 operator director that is guaranteed not to be qualified to  
15 an SSE.

16 VOICE: It does not mean it is not going to work.

17 MR. MYERS: I want to make sure that --

18 MR. WINNERS: I don't think -- is your comment  
19 that -- there is some weakness in our argument that we don't  
20 have it qualified to SSE and maybe we should reconsider and  
21 qualify it to SSE.

22 (Laughter.)

23 MR. MYERS: My comment is he has to go to SSE  
24 equipment anyway to do validation, and with the other items  
25 mentioned here perhaps we can talk about a tradeoff of



1 guaranteed paper vendors going to do shaker tests on  
2 computers, multiplexers and everything, as compared to good  
3 engineering design, shock testing, whatever. There is a  
4 wide spectrum of good engineering (Inaudible).

5 MR. MINNERS: And that is the comment that was  
6 made before, and I think that is a very good comment, and we  
7 have struggled with that also. We don't want to eliminate  
8 computers if we don't have to, but at the moment the  
9 consensus has been that somehow we had to address this  
10 earthquake issue as I have tried to explain it.

11 If it is not a problem, if we have overestimated  
12 the problem, and when a plant goes through an earthquake you  
13 don't even know it, we don't have a very good argument. We  
14 are going on the best information, which I will admit is not  
15 very complete.

16 I don't know how you make it complete, and any aid  
17 that we can get which says hey, you are wrong because, will  
18 certainly be looked at very carefully. If we have a comment  
19 that says you are wrong, I don't think we will give it very  
20 much thought unless it has some basis behind it, because you  
21 know, we think our unsupported opinions are better than your  
22 unsupported opinions.

23 (Laughter.)

24 MR. MC CREE: One place you might look is the  
25 Japanese experience. There was a BWR a few years ago that

1 did have a rather significant earthquake. At least the  
2 plant was just fine. In terms of how many alarms they had,  
3 I don't know.

4 MR. MINNERS: That is the first question. I am  
5 sure the plants are okay.

6 MR. MC CREE: The operators did not do anything  
7 wrong in that case in terms of what I heard. In terms of  
8 the basic issue though, I wonder if an approach which would  
9 result in faster implementation or perhaps one that would  
10 meet your schedule is to take the human factors review of  
11 the control board as the prime indicators which would allow  
12 the operator to not be confused in the event of an  
13 earthquake, and then have the SPDS not qualified on paper  
14 for an OBE.

15 But there I think that might get equipment in  
16 faster that would have more flexibility to provide more  
17 useful information to the operator, still be covered for the  
18 OBE by the control board, and perhaps not the control boards  
19 that are not in plants today, but reconfigured or somewhat  
20 rearranged. I think that might address your concerns and  
21 ours.

22 MR. MINNERS: I think the operator training can be  
23 allowed. As with any instrument, he is going to have to be  
24 trained and instructed in what the safety parameter display  
25 can do and what it cannot do. I mean, he cannot believe

1 that that is all he has to look at, and he has to have  
2 explained to him under what conditions it is good and under  
3 what conditions it is bad, and what he does after he looks  
4 at it.

5           You cannot just look at the equipment. You have  
6 to look at the whole training and operating program.

7           VOICE: I have one other question. In the event  
8 of this OPE, suppose you cannot find a computer manufacturer  
9 that can qualify his equipment to this? What is this going  
10 to do to your Nuclear Data Link, because your Nuclear Data  
11 Link is going to be very dependent upon this?

12           MR. MINNERS: The Nuclear Data Link cannot be  
13 qualified because it is going to go on telephone lines and  
14 (Inaudible).

15           MR. BELTRACCHI: There is no requirement on --

16           VOICE: (Inaudible) to send it over the phone to  
17 your computer terminals.

18           MR. MINNERS: I am missing your point then.

19           VOICE: If we cannot find something that is going  
20 to qualify for this, how do we process these signals to get  
21 them into a configuration that we can send to you in  
22 Washington?

23           MR. MINNERS: Are you on the seismic issue still  
24 or another issue?

25           VOICE: Yes.

1 MR. BELTRACCHI: You do that today in the form of  
2 use of signals from safety systems. Okay? In fact --

3 MR. MINNERS: Isn't the answer to your question,  
4 if you cannot find a computer that meets the OBE  
5 requirements, you will have to do something else for the  
6 safety parameter display and have a non-seismic computer for  
7 other purposes, including processing the data for the  
8 Nuclear Data Link.

9 VOICE: In other words, you are saying if you  
10 cannot get a computer, we are going to have to hard-wire the  
11 SPDS?

12 MR. MINNERS: I don't think that is desirable. I  
13 guess it is a problem that has to be worked on, but we are  
14 not willing to just now say you cannot buy a non-seismic  
15 computer.

16 VOICE: No. I didn't say that. I just said what  
17 if. What about computers on the other end? Are they going  
18 to have to do the same thing?

19 MR. MINNERS: No. As I tried to say, the  
20 telephone lines between the plants and NRC headquarters are  
21 not seismically qualified, so there is no use in making any  
22 of the Nuclear Data Links seismically qualified above some --

23 VOICE: We cannot hear you in the back.

24 MR. MINNERS: -- Above some moderate level. We  
25 would like to -- we will have time in the afternoon

1 session. I think we are getting beyond the clarifying  
2 question. We are getting into the area of discussion, which  
3 is fine, but I think we would just like to get through the  
4 presentation. So we will move on to Steve Ramos who will go  
5 into the technical support center and the emergency  
6 operations facility.

7 MR. RAMOS: I am Steve Ramos, and I am going to  
8 cover the technical support center, and following that, the  
9 emergency operations facility.

10 The slide here has one error in it in the first  
11 bullet in that --

12 VOICE: We cannot hear you.

13 MR. RAMOS: Can you hear me back there now?

14 (Slide.)

15 As I started to say, the first slide has an error  
16 in it in that we changed our posture in NUREG-0696 in that  
17 it is optional to demand the TSC during the notification of  
18 an unusual event in the alert stage. It is required to  
19 demand it during the increased alert situation.

20 It also says in NUREG-0696 that we are working on  
21 graded staffing for the TSC, EOP, and that hopefully that  
22 will be out in about a month or two.

23 VOICE: Is that an incorrect statement in the  
24 first bullet or a correct statement?

25 MR. RAMOS: That is an incorrect statement in the

1 first bullet in that it is optional during the notification  
2 on the alert level, and it is required in the site area  
3 emergency and general emergency.

4           It is anticipated that you will start manning it  
5 during the alert stage. You won't have as many people in  
6 there. But it is not a requirement. It is optional.

7           One of the contentions that we have had over the  
8 past few weeks is the location of the TSC. Our requirement  
9 is that the near -- near the control room. Our druthers  
10 would be that it would be directly adjacent to the control  
11 room. So if you went out of the control room into another  
12 room, you would be in the TSC.

13           We realize that some of the plants in existence  
14 right now don't have room or won't make room, but they  
15 really don't have room.

16           On an original draft of NUREG-0696 we had the  
17 distance of 50 feet. At the insistence of the industry and  
18 our own in house discussions, we decided to first relax it  
19 to five minutes and decided that was too much time, that a  
20 person needed a TSC in the control room or he would be away  
21 from his primary station, and five minutes -- the person  
22 would be out for ten minutes, so we reduced it to two  
23 minutes. That is an easy walking distance between the two  
24 facilities.

25           The reason why we want it close we thought was

1 obvious, but from all the arguments and discussion we had on  
2 the subject, it seemed to be not completely clear. We need  
3 to have -- at least Three Mile Island indicated to all of us  
4 that we need to have ready access, face-to-face access  
5 between the people in charge in the control room and the  
6 people in charge in the TSC.

7           There needs to be ready access for the people to  
8 certain components which may not be displayed in the TSC.  
9 Would took as a size based on 25 people, giving each person  
10 75 square feet of working space, and that is where we got  
11 the figure of 1,875 feet -- square feet, as a typical TSC  
12 size. If you desire to have more people than that, then  
13 obviously you are going to need more room. That does not  
14 include the space that is allocated for the NRC, and it  
15 should be a separate room that can handle about five people.

16           VOICE: (Inaudible).

17           MR. RAMOS: The transcriber is having trouble  
18 picking up the questions. If you want your questions to be  
19 recorded -- and this transcript will be available to anybody  
20 who wants it -- you have to use the microphone.

21           MR. ZELL: My name is John Zell. I would like a  
22 clarification on the basis for 75 square foot per person,  
23 please.

24           (Laughter.)

25           MR. RAMOS: It is the standard size space that GSA

1 has for a work -- GS-9, GS-10 level. That is where it came  
2 from. That is where the 75 square feet came from.

3 VOICE: Then it has a basis in (Inaudible).

4 MR. RAMOS: We asked AIF to give us a typical  
5 size. We asked them for three months, and we never got  
6 anything, so we said well, we will take this and use this.  
7 And the document is out for comment. If you people feel  
8 that 1,875 square feet is too large or too small, then tell  
9 us in your comments. We are not sure that 1,875 square feet  
10 is enough space.

11 VOICE: Why is it necessary for the NRC to have a  
12 private room in the TSC? Can it be located anywhere at all?

13 MR. RAMOS: We consider that it is necessary, and  
14 we feel that we need a space where we can get away from what  
15 is going on in the TSC and the control room to make a  
16 decision, if we have to make one, directly onsite.

17 VOICE: Why not get out of the TSC into another  
18 location?

19 MR. RAMOS: We are asking for a room that is  
20 separate, part of the TSC complex but divorced from the TSC  
21 itself. I am talking about a separate room not just a work  
22 room.

23 VOICE: I understand that is what you are saying.

24 MR. RAMOS: It will handle five people.

25 VOICE: That is on the basis of the prescriptive



1 75 square feet per person again.

2 MR. RAMOS: That is right.

3 VOICE: (Inaudible) the NRC required us to start  
4 on plans on a permanent TSC to be implemented by January 1,  
5 1981. Many of us started to build our technical support  
6 centers then because it takes six to 12 months to build such  
7 a center, and we don't have any rooms, private rooms, for  
8 the NRC in our design. And those structures are being built  
9 now in very, very limited space facilities on limited space  
10 sites.

11 MR. RAMOS: We understand the problem that you're  
12 going through right now, because the criteria did not come  
13 out a year ago. They probably should have. Still, this is  
14 what the NRC decided that they wanted to have, and that is  
15 what we are putting in the criteria.

16 VOICE: Does this NRC room have to have the same  
17 criteria and habitability --

18 (Laughter.)

19 MR. RAMOS: That is the reason why we made it part  
20 of the TSC.

21 (Laughter.)

22 We did not want you to just get rid of us.

23 (Laughter.)

24 We just want a place where we can go and take all  
25 the data that we have to make a decision on without the

1 influence of anybody else.

2 VOICE: As was pointed out, many of us have  
3 started construction or at least have the engineering design  
4 for new facilities, and this moving target that we are  
5 trying to hit is getting tougher and tougher. I don't have  
6 any problem with square feet, but I have problems with  
7 moving walls and things.

8 On this habitability question, perhaps that could  
9 be modified a little bit. Would it be acceptable to have  
10 the NRC office space available after 24 hours?

11 MR. RAMOS: What do you mean after 24 hours?

12 VOICE: Twenty-four hours after the accident. I  
13 have an 18,000 square foot facility that will have the lower  
14 floors available, including a large TSC instrument readout  
15 room, that will be available from time zero. The other two  
16 floors do not become available until 24 hours after the  
17 accident.

18 MR. RAMOS: You have lost me.

19 VOICE: Radiological conditions on the upper  
20 floors (Inaudible) make them usable for other normal office  
21 functions during normal operation. That would be an idea  
22 area for the NRC, but it would not be available for 24 hours.

23 MR. RAMOS: Why don't you make that as a comment  
24 and provide it to us, and we will look at it? I am not  
25 going to give you a decision on it right now.

1 VOICE: Let me ask a question which I mean very  
2 sincerely, and that is, when can we anticipate that the  
3 requirements for the emergency offsite facility, as well as  
4 the technical support center, will stop changing?

5 MR. RAMOS: The purpose of 0696 was to do that.  
6 We had a directive from the NRC's Executive Director for  
7 Operations to form this committee, the Safety Data  
8 Integration Group, which is made up from members from all  
9 the offices. And the purpose is to integrate a system and  
10 to finalize it.

11 VOICE: Okay. Thank you.

12 MR. MINNERS: In fact, that is why some of the  
13 things we are doing are rather rushed. Issuing the report,  
14 and announcing the meeting, and getting comments back and  
15 all that, I think we are on a very fast schedule, and we ask  
16 for your cooperation in some of the inconveniences that that  
17 is bringing us. But we are trying to get the requirements  
18 out as soon as we can, because we realize that you need them  
19 to be able to do your designs.

20 MR. RAMOS: Also, that is the reason why the  
21 January 1, 1981 date was changed, because we knew that there  
22 was a considerable amount of change that would be required,  
23 and we were anticipating that these requirements will be  
24 finalized, if our schedule can be held to, by October of  
25 this year, depending on what comments that we get from the

1 meetings that we have here and formally from AIF and  
2 individuals.

3 VOICE: Meeting the requirements of 0696, the two  
4 minute criterion, as near to the control room as possible  
5 (Inaudible) somewhat flexible because of the recognition  
6 that there is problems, physical problems in designing a TSC  
7 in an existing plant.

8 I raise the question: Is it possible to consider  
9 to meet the visual face-to-face exposure and observation of  
10 other parameters, to use the picture phone concept between  
11 the control room and the TSC in lieu of a stringent  
12 requirement of some preselected time?

13 MR. RAMOS: Two minutes was an interim choice and  
14 not really all that strict. The intent of the face-to-face  
15 communication between the people in the TSC and the control  
16 room is a direct result of Three Mile Island and the people  
17 that were up there and in charge.

18 We have looked at some closed circuit television,  
19 telephone/video circuits, and we don't consider that to be  
20 adequate to meet the face-to-face requirements.

21 Yes?

22 MR. ABEL: I have another question on location. I  
23 am Jim Abel, Commonwealth Edison Company. We are well along  
24 in construction at several of our operating plants on these  
25 technical support centers. I suspect we will not meet the

1 two minute requirement.

2           Could you explain what alternatives we might offer  
3 to the two minute requirement, or more details?

4           MR. RAMOS: As we have told most industry that  
5 cannot meet the two minutes but can meet three minutes or  
6 possibly four minutes, to present their case individually  
7 and the rationale and the reasons why they cannot meet that  
8 requirement. We will take it on an individual case basis.

9           I would suggest that you get that into us as soon  
10 as you can so we can review it.

11           MR. ABEL: (Inaudible) indicated the locations and  
12 estimated times to the control room.

13           MR. RAMOS: I will direct the team leader to look  
14 at them, but you have to understand, too, that he has had  
15 the same moving target that you have had, and therefore, he  
16 did not have the two minute requirement at that time.

17           Now, that does not mean that an emergency plan  
18 would not have been accepted or rejected based on that  
19 requirement of two minutes. The requirement in 0654 said  
20 you had to have it. The requirements in January 1980 say  
21 you have to have a basic rudimentary EOF and TSC.

22           What we are trying to do in 0696 is to give you  
23 the criteria for the final system configuration. It has  
24 been hard work for us, too, to develop that, and we have  
25 been working on it for roughly two months now.

1 Yes?

2 VOICE: You just alluded a moment ago to a changed  
3 date for construction of the technical support center. I  
4 think I missed something there.

5 MR. RAMOS: We will get to the schedule at the  
6 very end, and I will address it at that time.

7 VOICE: You say in 0696 that the technical support  
8 center has to be able to staff 25 people. Is there some  
9 consideration for plant size taken into account here?

10 MR. RAMOS: No.

11 VOICE: If we only have a staff of 40 people and  
12 we would only have 15 people in the technical support  
13 center, we would go ahead and submit that for comment and  
14 review also, is that correct?

15 MR. RAMOS: Yes, you can.

16 VOICE: Okay.

17 MR. RAMOS: We are working on staffing  
18 requirements based on flow, functional data, and functions  
19 to be performed by each individual.

20 VOICE: Since we are running behind on our  
21 presentations, would it be possible to ask these questions  
22 this afternoon?

23 MR. RAMOS: Yes.

24 MR. MINNERS: Thank you.

25 MR. RAMOS: The structure, as we said in

1 NUREG-0696, it must be substantial. We have done that  
2 because some people wanted to convert other buildings,  
3 butler buildings and what have you, that really would not be  
4 satisfactory.

5           Communications, I think it is pretty clear. I am  
6 not going to go into it.

7           Another item that has had a lot of discussion is  
8 the unavailability factors for the --

9           VOICE: Excuse me. Relative to structure you say  
10 that the winds and floods with a 100-year recurrence  
11 frequency are acceptable as a design basis. What if that is  
12 more stringent than the total design basis of the plant?

13           (Laughter.)

14           Such as by a factor of two?

15           MR. RAMOS: What else would you like us to use as  
16 a criteria?

17           VOICE: How about the FSAR?

18           MR. RAMOS: I would not want to get into arguments  
19 about the FSAR.

20           VOICE: It seems we are trying to design a  
21 facility here that is much more stringent in certain  
22 aspects, because your requirement is very prescriptive, than  
23 comparable requirements for the total plant. And I don't  
24 think that is reasonable.

25           MR. RAMOS: If you had seen the draft on what we

1 had written, the substantial structure, you would not make  
2 that statement. But we thought we had made it general  
3 enough and would cover a large enough spectrum to allow you  
4 a certain amount of latitude in design. Our objective is to  
5 have a substantial structure.

6 MR. MINNERS: I don't consider that to be  
7 prescriptive. I think that is a rather broad criteria.

8 What form would you suggest that be put in, in  
9 that it is more what you think is not prescriptive? How  
10 would you say it?

11 VOICE: I think the licensing basis of the plant  
12 given in the FSAR for similar type structures could be  
13 stated here instead of something like that --

14 MR. MINNERS: That is more than we want. Most  
15 plants, I think, are designed for more than the 100-year  
16 flood.

17 VOICE: I would like to see a show of hands of  
18 plants that are.

19 MR. MINNERS: All the new siting criteria are  
20 going to be --

21 VOICE: (Inaudible).

22 MR. RAMOS: Let me go on and finish.

23 VOICE: This is a very serious concern of ours due  
24 to the age of our plant and the conditions under which it  
25 was built. I think we would prefer seeing something more



1 along the lines of FSAR being spelled out as well. It is a  
2 very touchy issue. We have a 50 megawatt unit.

3 MR. RAMOS: As I said, make your proposal and  
4 submit it.

5 Okay. Getting on to the unavailability factor, we  
6 have said that originally we had the same criteria as there  
7 was for the SPDS, .001. After due consideration and the  
8 fact that TSC and EOF are not designed to actually control  
9 the reactor, we backed off and made it .01 unavailability  
10 factor. However, we did retain the .001 for individual  
11 parameters.

12 The data set for the TSC is Reg Guide 1.97. That  
13 is the minimum requirement.

14 (Slide.)

15 VOICE: Would you say that again, please?

16 MR. RAMOS: The minimum data set for the TSC is  
17 Reg Guide 1.97.

18 If you go across -- raise that up, would you,  
19 please?

20 VOICE: Perhaps I misconstrued your meaning in the  
21 draft Reg Guide we have available, but on page 13 of the  
22 guide you say, "The total system shall be designed to  
23 achieve the function of unavailability" (Inaudible). You  
24 say, "The TSC systems, including power supply, shall have  
25 less than .001 unavailability."

1 MR. RAMOS: That is an error we picked up in  
2 Philadelphia. Overall it is .01. Various components,  
3 individual components, that includes power supplies, .001.

4 VOICE: System overall, .01.

5 MR. RAMOS: Correct. That is principally to  
6 ensure -- not ensure but to allow you not to have two  
7 computers to meet that need.

8 VOICE: I am not sure which one has to have .01  
9 and which one has to have .001.

10 MR. MINNERS: It is a difficult problem and was  
11 pointed out before. The definition of when it is  
12 unavailable is a difficult definition, and it is not  
13 provided; but the intent was -- the overall function of the  
14 TSC should have an unavailability of .01.

15 We also gave guidance on what we thought  
16 individual systems should have for an unavailability, each  
17 system that went into the TSC, each instrument system, of 10  
18 to the -3.

19 VOICE: (Inaudible).

20 VOICE: Is there some way to improve the  
21 microphones on the table there? We can't hear.

22 MR. RAMOS: Can you hear this one?

23 VOICE: No.

24 MR. RAMOS: The second line reiterates basically  
25 what I covered on the TSC during the last few minutes, and I

1 will just show you that.

2 (Slide.)

3 Let's get into the EOF. This is the basic  
4 functional criteria. Let me back up. The TSC slide was  
5 correct. This is the slide that is incorrect. I did not  
6 mark it on the paper.

7 The EOF is not required to be manned during the  
8 alert stage. The TSC is required to be manned during the  
9 alert stage.

10 This slide should say that the EOF activation is  
11 required for site emergency and general emergency levels of  
12 response and is optional for the lesser conditions. I  
13 apologize.

14 It seems that the EOF is another one that has a  
15 large bearing --a contention about where it should be  
16 located. We spent about three hours with the Commission on  
17 where it should be located. The Commission had had some  
18 discussions with some foreign countries, and in particular  
19 Britain, and they said they would have the EOF at from three  
20 to ten miles; and at the same time they said it would be  
21 outside their evacuation zone.

22 I had a discussion with them a couple of weeks  
23 ago, and the three to ten miles comes from the fact that  
24 that is where they will have what we are basically calling  
25 an operational control center, which is one where the state

1 and local in the United States -- whereby the local  
2 constabulary can be. And the three to ten miles comes from  
3 the fact that if there happens to be a nearby town, that is  
4 where they would have that facility.

5 Further discussions with them concerning EOF as we  
6 define it and as they are defining it, they are looking from  
7 one to three miles. They still contend that for their  
8 largest facility they would probably not have to evacuate  
9 any greater than three miles.

10 VOICE: Who is looking for one to three?

11 MR. RAMOS: The British. That is where some of  
12 the arguments that we got from the Commission in our  
13 discussion -- reiterating what we went through. So we were  
14 directed in 0696 to change it to read no further than five  
15 to ten miles. Obviously, we probably would accept something  
16 that went 10 1/2 miles or possibly 11 miles if 0696 stays  
17 the way it is. It depends upon the comments, and we had  
18 many comments from people who said they would like to have  
19 it one to three miles away, because they want to design the  
20 system to handle the 99 percent of these situations where  
21 you will not have to evacuate and not have it out so far,  
22 because they will not be able to control what they needed to  
23 control, such as at Three Mile Island.

24 The Commission further said that wherever it was  
25 located, if it was one mile, five miles, ten miles, it had

1 to be constructed with the habitability requirements such  
2 that if you had to evacuate, you would not evacuate the  
3 ECF. They felt that at that time the data flow to the  
4 local, the state, and whoever needed the information on  
5 meteorological and radiological data, that was the time they  
6 really needed it in a positive flow. So 0696 was written to  
7 accommodate those changes. And you can build it anywhere in  
8 the ten-mile radius as it stands right now.

9           If we have sufficient comments to say that it  
10 should be in closer, we will present those to the  
11 Commission, and they will then make a further determination  
12 whether or not to change 0696.

13           VOICE: For sufficient justification do you think  
14 they would go more than ten?

15           MR. RAMOS: As I said, no, I don't think they will  
16 go much beyond ten, but near ten miles, based on the  
17 discussion we had with them. As I say, we will probably  
18 accept 10 1/2 miles or 11 miles. If you say you want it 20  
19 miles away, then it will not be accepted.

20           VOICE: For those plants that have five-mile EPZs,  
21 would one mile be acceptable?

22           MR. RAMOS: We think so, yes. It still must meet  
23 the habitability requirements.

24           VOICE: Right.

25           MR. RAMOS: Let me reiterate what I just said.

1 You asked if a five-mile EPZ -- would one mile be  
2 acceptable? If you had a ten-mile EPZ, one mile would still  
3 be acceptable. Anywhere in the ten-mile area is acceptable  
4 as long as it meets the habitability requirements.

5 VOICE: Do you mean the same as control room  
6 habitability ten miles away?

7 MR. RAMOS: I am saying that there must be the  
8 shielding, the control ventilation system there, that the  
9 people do not have to evacuate during an evacuation. You  
10 design the system to handle that type of radiation.

11 VOICE: (Inaudible).

12 MR. RAMOS: It may not be required if you're  
13 outside --

14 VOICE: (Inaudible).

15 MR. RAMOS: Strictly based on that.

16 VOICE: Would you comment on the apparent conflict  
17 in the writeup in the draft of 0696 which first talks about  
18 the purpose of the EOF being to, one, evaluate radiological  
19 conditions, and two, to coordinate and communicate with the  
20 various governmental agencies involved?

21 If those are the primary functions, again we have  
22 had a problem with prescription because you are calling for  
23 all the same data to be available in the EOF that is  
24 available in the TSC. As a little example, we would propose  
25 doing all the radiological evaluations in the TSC. However,

1 we would then have the EOF or our equivalent thereof be the  
2 place to meet with all the various agencies involved.

3           Would you comment on that?

4           MR. RAMOS: We don't consider that a conflict in  
5 roles. The primary purpose of the EOF is to do radiological  
6 and meteorological monitoring so you can plot a plume if  
7 there is a plume, to map the area as far as radiation levels  
8 are concerned. You have a place where all the portable and  
9 mobile monitoring teams can get their data into a central  
10 place. You have evacuation routes already there, so you can  
11 coordinate with the state and locals to let them know which  
12 areas should be evacuated. You have the communications  
13 there with the NRC, the state, or the local, and of course  
14 the TSC. There is also the role of the EOF to do recovery  
15 operations later on.

16           Now, the reason why we used that same data base  
17 for the TSC and the EOF is because initially before -- the  
18 TSC will perform the functions of the EOF, -- it will shift  
19 when that is manned. The TSC will have different displays  
20 from the EOF as we envision it. We expect the displays,  
21 except for the SPDS, we expect the displays in the EOF will  
22 be primarily oriented to offsite control and offsite  
23 radiation monitoring and recovery operations.

24           We expect the TSC to be primarily attuned to  
25 handling support of the control room in plant system

1 operation.

2 VOICE: I understand that, but the SPDS, for  
3 example, is not needed to evaluate offsite consequences; and  
4 secondly, why cannot the radiological evaluation functions  
5 be done from the TSC which is sufficiently large to  
6 accommodate additional personnel?

7 MR. RAMOS: Primarily because we want the EOF  
8 offsite. We don't want the TSC to be overly burdened with  
9 handling the offsite problem. The TSC is designed to handle  
10 the control room support.

11 MR. MINNERS: There was also some desire to  
12 separate people. We want to try -- the EOF is going to have  
13 some management of the accident and people who have that  
14 responsibility, and we wanted to separate the managers for  
15 the technical support from the control room. We think there  
16 is a necessity for that and that that is one of the reasons  
17 for having the various facilities.

18 . We think that if you get everybody so close  
19 together that you are just going to have everybody giving  
20 direct orders to everybody, and it is not going to work out.

21 VOICE: My concern is primarily with this  
22 instrumentation, and the instrumentation is of primary use  
23 to those who would evaluate the offsite consequences. Those  
24 same people will be utility or licensee personnel. The rest  
25 of the EOF functions I have no quarrel with being outside



1 this particular area.

2 MR. MINNERS: In my view I don't look at offsite  
3 consequences being evaluated solely by offsite monitors or  
4 plant effluent monitors. I think that you are going to have  
5 to look at the reactor status to make any kind of balanced  
6 decision about what you are going to do offsite. Once you  
7 start getting stuff coming out, it is too late.

8 VOICE: (Inaudible).

9 MR. MINNERS: That is an argument for doing that,  
10 and the counterargument is you don't want to put all those  
11 people in the technical support center. You still want to  
12 have separation, so in order to keep separation of people  
13 and keep some of these -- so you don't have to process a  
14 whole bunch of people through the security of the onsite  
15 center, you have an offsite center; and to make up for that  
16 you put the data in the center, and it is costing you  
17 something to do that. Agreed.

18 MR. RAMOS: We are saying it only has to be  
19 available. In your design you set up what displays you  
20 think you need to have in there, and we are not specifying  
21 what those displays are in the TCF. We are saying the data  
22 must be available.

23 Now, you must have displays in there for the  
24 radiological and meteorological monitoring obviously.

25 VOICE: But you don't need those in the tech

1 support center.

2 MR. RAMOS: That is right. You would need them in  
3 the initial stages. You could have them there if you wanted  
4 them there.

5 VOICE: They could be in the control room with a  
6 dedicated link to the EOF.

7 MR. RAMOS: I don't know if you would want to put  
8 them in the control room.

9 MR. MINNERS: You guys are having a private  
10 conversation.

11 VOICE: We cannot hear.

12 VOICE: We have been working -- I think most  
13 people have been working towards a January 1, 1981  
14 deadline. Given that deadline, I know we are well along in  
15 construction, and I would think everybody else is, at least  
16 in trying to meet that deadline.

17 What we are coming up with now are a lot of  
18 criteria that invalidate designs that were started by us.

19 MR. RAMOS: I understand that.

20 VOICE: I don't think that we -- what you are  
21 saying is forget it, do it our way and throw it away. It is  
22 no good. We made a mistake. We are sorry.

23 One of the initial comments we made when this  
24 whole thing started was we were -- you decided to implement  
25 all the TBI requirements via letters and via NUREGs which

1 are outside the normal procedure, assuring us that you would  
2 act in good faith, that we committed to these letters and  
3 NUREGs. We acted in good faith, and we started implementing  
4 these designs, and now you are coming back and saying sorry,  
5 we were kidding.

6 MR. MINNERS: What would you suggest that we do to  
7 try to correct the situation? We understand the situation.  
8 You just don't want to hear us say mea culpa. What do you  
9 want us to do?

10 VOICE: I think you have to accept alternatives to  
11 what you are proposing here, and a big one -- and a big one  
12 is the handling of our radiological analysis. (Inaudible).

13 MR. RAMOS: If you go to NUREG-0654, which was  
14 issued last January, and if we go to the October 10 memo  
15 that was signed off by Eisenhut which covers requirements  
16 for meteorological and radiological data, they are much more  
17 stringent there than we have laid out in 0696.

18 The question is do you want us to do that, or do  
19 we want to do this thing logically and come up with a system  
20 that will handle emergency response? That is what we have  
21 tried to do at the direction of our EDC.

22 VOICE: A system that will accommodate existing  
23 work that is underway, existing design.

24 MR. RAMOS: Let me finish. Realizing that we have  
25 the 1-1-81 date, we presented the Commission an alternate

1 date, the end date. We asked AIF and other industry people  
2 if we changed the date to April 1982, can you meet this  
3 date, and we were told yes. So the end date was partially  
4 developed by industry, the April 1982 date, meaning that  
5 they could meet that date. And number two, that is what we  
6 went to the Commission and said -- we know we cannot meet  
7 the 1-1-81 date, and we will give them functional criteria.  
8 And again, industry asked us not to tell us how to do it but  
9 only what the functions are, and we tried to do that.

10           And on 1-1-81 we will have the industry give us  
11 their descriptions which we will then review. We will take  
12 three months to review them, and I think we can meet that  
13 date, in order to meet an April 1982 date.

14           Now, the only criteria that ever changed in all of  
15 this which was laid out in 0578 for the SPDS, the  
16 requirement for the SPDS, was in January 1981 you had to  
17 submit your conceptual design for approval and by 1-1-82 you  
18 had to have it installed and operational. That has never  
19 changed.

20           VOICE: That was 0585.

21           MR. RAMOS: Right. 0585.

22           MR. MINNERS: We sympathize with you. You are the  
23 people who have to do it, and you have the hard job. I am  
24 not sure that it is very fruitful to discuss the  
25 implementation schedule where we are now.

1           VOICE: My concern is not the schedule. My  
2 concern is that trying to meet the 1-1-81 schedule we  
3 committed a large sum of money and started construction on  
4 facilities, directing functions to each facility as we could  
5 accommodate within the designs, and you are saying now that  
6 that is no good.

7           MR. MINNERS: No, we have not said that. This is  
8 a proposed NUREG. If it conflicts with what you are  
9 constructing, I would suggest you provide us with comments  
10 of how we should modify it so that your facility would come  
11 under this NUREG and give us a rationale of why that is okay.

12           VOICE: Your reactions from the comments were that  
13 you would not accept what was being proposed.

14           MR. MINNERS: I have forgotten the specifics but --

15           VOICE: What he is proposing happens to be very  
16 similar to --

17           MR. MINNERS: What was the proposal?

18           MR. RAMOS: Give us the details again. I forget  
19 the exact proposal.

20           VOICE: Okay. For our technical support center we  
21 are planning an 18,000 square foot building, four different  
22 levels, two above grade, two below grade. That will give us  
23 plenty of room to accommodate people. The TSC instrument  
24 room, the heart of the TSC, is around 1,000 square feet  
25 itself. There is no problem with personnel crowding here

1 now.

2 All we are proposing is that to avoid the  
3 duplication of instrumentation in the EOF we do the primary  
4 radiological evaluation, a portion of that evaluation which  
5 requires plant readouts, that that be done in the technical  
6 support center, and any further evaluation and discussion  
7 can indeed be done in the EOF.

8 MR. RAMOS: How far apart?

9 VOICE: Our EOF is split into two buildings, and  
10 one is perhaps about three-quarters of a mile away, and the  
11 other one is about a quarter of a mile.

12 MR. MINNERS: I agree that there might be some  
13 inefficiency and extra cost, but is there a real problem in  
14 taking that radiological display and putting it in the EOF?  
15 It seems to me like you just have to run some more wires.

16 (Laughter.)

17 You know, it is money. I agree with that. But it  
18 is not like you have to build a whole new structure. I  
19 agree it is inefficient, and it is not the optimum cost.

20 VOICE: (Inaudible). We went into our Public  
21 Service Commission for construction authorization to build  
22 one type of structure for our EOF -- for one of the EOF  
23 buildings which will be required, and now you come out with  
24 additional requirements, habitability requirements, the  
25 ventilation system, as well as shielding requirements that

1 go along with habitability; and so we are being forced to  
2 redesign it.

3 MR. MINNERS: What was your original rationale for  
4 not having any filters or whatever that you did not put on  
5 the plant?

6 VOICE: (Inaudible) potential habitability  
7 problems (Inaudible).

8 MR. MINNERS: Yes. There is an excellent comment  
9 which I wish the industry would write in and give the  
10 rationale for. I think there are differences in the staff  
11 and within the NRC on that point. And you know, if things  
12 have changed, pointed out that things have changed and maybe  
13 you don't think there's a good basis for the change.

14 MR. HALL: You stated in here that all the sets of  
15 Reg Guide 1.97 must be available in the TSC and the EOF,  
16 including radiological and meteorological data. This is on  
17 page 13, Section I. However, in the middle of the sentence  
18 -- in the middle of the paragraph you state that, "The trend  
19 information (Inaudible) plant systems (Inaudible) must also  
20 be there."

21 Is this over and above or different from the  
22 requirements of Reg Guide 1.97?

23 MR. RAMOS: No, no. You take the data coming in  
24 from Reg Guide 1.97 and have the capability of trending it  
25 and displaying it.

1 MR. HALL: As long as we display what is in 1.97  
2 we would not be out of the realm of your requirements.

3 MR. RAMOS: That is right.

4 VOICE: I would like to get back to the question  
5 of nearsite, offsite business. Apparently you are now  
6 saying that the EOF must be offsite rather than nearsite, or  
7 that it is not being within the controlled area which can be  
8 a substantial site. And I'm not clear whether or not you're  
9 actually saying that or not.

10 MR. RAMOS: Maybe that is what I said in words,  
11 but the intent is that it be nearsite but outside the  
12 security boundary. It has to be outside the security  
13 boundary.

14 VOICE: Then the FEMA criteria in NUREG-0654  
15 holds. It must be within one mile of the reactor facility.  
16 That is what the FEMA criteria currently says.

17 VOICE: (Inaudible).

18 VOICE: Now, what if we take the three functions  
19 that are required, and you say now that they have to be in  
20 adjacent buildings or in a single structure. How adjacent  
21 is adjacent to you in terms of adjacent buildings?

22 MR. RAMOS: I don't think you want me to tell you  
23 that they have to be five feet apart. I think you have to  
24 lay this out in your plan and give it to us for review.

25 VOICE: Is it acceptable to have one of those



1 (Inaudible)?

2 MR. RAMOS: That might be acceptable. I am not  
3 going to answer that right now. I think it might be  
4 acceptable. I have to look at it.

5 VOICE: One more question. With respect to the  
6 habitability of the EOF, the Commissioners are saying they  
7 don't think it should be relocated. What about the new  
8 facility portion of this EOF where you have to have a place  
9 for the 20 newsmen?

10 Do we have to make a specific room habitable for  
11 the 20 newsmen in this EOF that is habitable, or can  
12 that portion of the EOF -- can that function be relocated to  
13 another location?

14 MR. RAMOS: The portion about newsmen is an  
15 optional requirement for the EOF. It has always been an  
16 optional requirement. I think originally in 06S4 it was a  
17 detailed requirement, but it was relaxed to make it an  
18 optional requirement so that some utilities have gone to the  
19 Visitors Center, for example, and made that their press  
20 briefing and what have you.

21 VOICE: With respect to (Inaudible) all of the  
22 locations that we have (Inaudible) were submitted November  
23 9, 1979, and we have not heard one word about it on our  
24 submitted upgrade emergency plan for our facility.

25 Your review of the emergency operation facility

1 (Inaudible) in and of themselves, or is this a separate  
2 review?

3 MR. RAMOS: We are going to do it separately.  
4 That is the reason why we want the design and your concept  
5 of the system by 1 January 1981; and we have set up a  
6 special team to review all of those in the three-month  
7 period. If we get them earlier, obviously we will review  
8 them earlier.

9 VOICE: How do you resolve conflicts between the  
10 two groups that are reviewing the emergency plan per se and  
11 FEMA and yourselves?

12 MR. RAMOS: The two groups that you are talking  
13 about in the NRC are in the same office, so I don't see a  
14 problem. As far as FEMA is concerned, we will have to  
15 coordinate through our steering committee with FEMA to  
16 reconcile any problems there; but they are working with us  
17 to revise 0654 based on the comments that were received, and  
18 we are trying to reconcile any differences there.

19 VOICE: Are you going to address staffing next?

20 MR. RAMOS: In a minute.

21 VOICE: Is your --

22 MR. RAMOS: Let me finish the presentation, and  
23 then we will go on.

24 VOICE: Just one comment. Did I hear you say on  
25 1-1-81 (Inaudible)? I thought it was just going to be the

1 safety parameter display system.

2 MR. RAMOS: No, no. At the very end we will go  
3 through the revised schedule. But to answer your specific  
4 question, the entire system for emergency response  
5 facilities has to be submitted on 1-1-81.

6 VOICE: Is this for operating plants or  
7 (Inaudible)?

8 MR. RAMOS: It is for all facilities.

9 (Discussion off the record.)

10 MR. MINNERS: It is obvious that an applicant does  
11 not have to have his plan submitted and reviewed until he  
12 gets his license. He can adjust his schedule to that.

13 MR. RAMOS: Unless he is trying to meet 0694  
14 requirements, which may, you know, if you have to do a fuel  
15 load in January 1982, you would have to get your plans in  
16 now.

17 Staffing, we are doing another -- the same review  
18 that we are doing for the TSC we are doing on the EOF, and  
19 we expect to get that done in about two months. We are  
20 doing the same kind of functional and communication flow  
21 through the EOF to determine what is required -- what type  
22 of people are required in the EOF.

23 Size, we again use 75 square feet per person.

24 We discussed habitability and structure.

25 The unavailability factor is the same for the EOF

1 as it is for the TSC.

2 Next slide.

3 (Slide.)

4 VOICE: Excuse me. Does that mean that we have to  
5 have qualified communication lines to maintain that  
6 unavailability of .001 for individual parameters?

7 MR. RAMOS: Yes.

8 VOICE: So we cannot use telephone lines.

9 MR. RAMOS: You may not be able to unless you can  
10 provide -- show the redundancy necessary to meet the .001  
11 criteria.

12 VOICE: What sort of seismic qualification does  
13 that take?

14 MR. RAMOS: We have not laid any seismic  
15 qualifications.

16 MR. MINNERS: There are no seismic qualifications  
17 on the EOF and TSC.

18 VOICE: So that -- so we do not have to meet that  
19 availability in the case of a seismic event.

20 MR. RAMOS: That is right.

21 MR. MINNERS: They are two separate things.  
22 Unavailability is to try to give some criteria for the  
23 normal random failure rate of equipment, and earthquake  
24 addresses the question of design adequacy, and they are  
25 really two separate things. Earthquakes and unavailability

1 do not mix. They are separate things.

2 VOICE: To what extent do we have to factor in  
3 other weather conditions: ice storms, the tornadoes?

4 VOICE: I think the statement is that  
5 environmental conditions that are expected during the  
6 lifetime of the plant. Is that the way we stated it? I  
7 think that is the way we stated it.

8 VOICE: I guess we would like a clear definition  
9 of where that line falls.

10 MR. MINNERS: I was just criticized for saying  
11 that once in 100 years is too prescriptive. I am not trying  
12 to argue with you. I am just trying to illustrate the  
13 problem. And I think a good forum for you is the AIF. And  
14 where one person wants it one way and another person wants  
15 it another, if through the AIF or some other mechanism you  
16 could come to what you think is a generally acceptable  
17 position for all of the industry, it would be very useful to  
18 us.

19 The way it is now I am going to listen to the guy  
20 who says one in 100 years is going to be too prescriptive,  
21 and you who say once in the lifetime of the plant or  
22 whatever we say is not prescriptive enough and make my own  
23 judgment.

24 VOICE: I didn't say that I was the same person.

25 (Laughter.)

1 MR. MINNERS: I've got a problem.

2 VOICE: (Inaudible) logical FSAR basis, and  
3 applying that to structures with a reasonable engineering  
4 judgment sort of criteria (Inaudible) based on proximity or  
5 non-proximity to the site. I think that has to be  
6 considered.

7 MR. MINNERS: I think on a case-by-case basis if  
8 you came in and said my plan is only designed for this  
9 flood, there is no use in designing the technical supports  
10 for a higher flood, except there is a fault in the logic.

11 VOICE: I am glad you finally said that.

12 MR. MINNERS: There is a fault in that logic in  
13 that if your plant is only designed for a low flood level,  
14 just for discussion wouldn't it be nice to have the systems  
15 that are supposed to take care of emergencies be able to  
16 survive that flood level so they could take care of the  
17 plant during those flood conditions?

18 VOICE: Not if you never expect that flood to  
19 (Inaudible).

20 MR. MINNERS: But the expected flood is the one we  
21 are trying to define. That is the one you expect to occur  
22 during the lifetime of the plant. It seems like a  
23 reasonable design criterion.

24 VOICE: Requirements sometimes go beyond what is  
25 expected really.

1 MR. MINNERS: I recognize that criticism, that  
2 things tend to get ratcheted, but everybody has that  
3 problem. And on the opposite side, some people don't even  
4 meet what is obviously the intent. Everybody has those  
5 problems. I don't think it is fruitful to discuss those.  
6 That is a separate issue that the Commission has to  
7 discipline itself better on applying its regulations.

8 Let's try to get the guidance down to say what we  
9 think it ought to say, and then the next step, be sure that  
10 it is properly implemented.

11 VOICE: All right. I don't want to dwell on  
12 that. In terms of staffing there is a statement here on  
13 page 16, item C, "A senior member of a licensing plant for  
14 corporate management shall be in charge of all activities in  
15 the ECF."

16 Could you comment on what you mean by "all  
17 activities," especially since this includes interface with  
18 the public and press.

19 MR. RAMOS: The corporate structure, the person  
20 who has been designated to be in charge of the ECF for all  
21 offsite recovery type of operations.

22 VOICE: In other words, we can interpret that to  
23 mean that all public releases that are made through the ECF  
24 go through a central person who will be responsible then for  
25 verifying that, so we don't fall in the same trap as we did

1 at TMI, including NRC.

2 MR. RAMOS: That is the reason why our NRC person  
3 will be there to try to coordinate that.

4 MR. MINNERS: At the last presentation in  
5 Philadelphia we were criticized for that, saying that based  
6 on this person's evaluation that the utilities really could  
7 not do that function; so not everybody thinks that is the  
8 way to go.

9 VOICE: That is true. Most of us are not  
10 privileged to have been in the Philadelphia meeting, so some  
11 of these references to what goes on in Philadelphia I think  
12 require that sort of clarification.

13 MR. MINNERS: I am just telling you to explain  
14 what --

15 VOICE: (Inaudible) and coordinating the  
16 Commission, the utility, and other state or local  
17 organization working out of the ECF. Certainly the  
18 licensee's responsibility to present that information in a  
19 clear and concise manner, rather than having several  
20 spokesmen present differing views.

21 MR. RAMOS: That is one of the intents.

22 VOICE: I would like a clarification on what I  
23 thought you said. Did I hear you say that the  
24 unavailability is the same as the technical support center?

25 MR. RAMOS: Yes.



1 VOICE: It is of concern to me because one is .01  
2 and the other is .001.

3 MR. RAMOS: They are both .01 overall and .001 for  
4 individual components.

5 VOICE: You might want to clarify that. That is  
6 not clear in the written material.

7 MR. RAMOS: Okay.

8 VOICE: Does that mean to say if you have a  
9 failure or something in the EOF (Inaudible) and that is  
10 acceptable?

11 MR. RAMOS: Yes. To answer your question, yes.  
12 You have to look at the function of the EOF, and you have to  
13 look at the function of the TSC.

14 VOICE: That is one of the things we would like  
15 clarification on. If something fails in the EOF and you  
16 don't have the data to display in there (Inaudible) as long  
17 as we don't get a (Inaudible).

18 MR. RAMOS: There is an LCL requirement that if it  
19 is down for over eight hours you have to make a report, and  
20 you have to report what your compensatory measures are. A  
21 compensatory measure in that case may be that you shift that  
22 function to the TSC while you get it back up DC.

23 VOICE: Relative to the numbers on page 19, could  
24 you specifically say which one is .01 and which one is  
25 .001? One is at the top of the page, and one is at the end

1 of the paragraph.

2 MR. RAMOS: The overall EOF -- the one at the  
3 bottom of the page, the bottom of the second paragraph  
4 should have read .01. That is an error. The EOF data  
5 system, that is referring to the overall data system, shall  
6 have less than .01 availability instead of .001.

7 The one at the top of the page referring to  
8 instrumentation and power supplies is .001.

9 Again, just to reiterate, the functions and the  
10 various requirements on the EOF is on this slide.

11 I have one more slide which I am going to delay  
12 until after the NDL, which is the overall schedule, and we  
13 will go over the overall schedule at that time.

14 Now I would like to turn it back over to Mr.  
15 Beltracchi who will cover the NDL, the Nuclear Data Link.

16 MR. BELTRACCHI: The NDL was to be covered by our  
17 Office of Inspection and Enforcement. However, they were  
18 not able to have a representative here, so I have been  
19 associated with the project for a while, but I may not have  
20 all of the latest details. I think I can give you a general  
21 overview of where it stands relative to NUREG-0696.

22 May I have the first slide, please?

23 (Slide.)

24 In this first slide there is an identification of  
25 roles of the NRC in emergencies, starting with the

1 monitoring and advisory. That is above the dashed line.  
2 Direction, management control, and constraints below the  
3 dashed line. Let me address the former first.

4           With respect to monitoring, the Nuclear Data Link  
5 is to provide information so that the NRC would be able to  
6 verify and evaluate data from multiple sources to assure  
7 that proper and adequate operational protective measures are  
8 being taken and to inform the public.

9           In terms of advisory, to provide requested or  
10 volunteered assistance in diagnosing the situation and  
11 isolating critical problems. This could consist of  
12 protective action determinations and advise other concerned  
13 agencies.

14           The actions above the line would probably  
15 represent 98 percent of the cases, and certainly the major  
16 -- majority of the cases. With respect to actions below the  
17 line, we would perceive this to be a very, very small  
18 percentage of the cases, and it would deal with the  
19 direction in terms of -- to assume initiative in making  
20 operational decisions regarding licensee's actions to be  
21 taken.

22           With respect to management control, take tasking  
23 of the licensee and supervision of the implementation of the  
24 actions ordered. Of course, the constraint would be that  
25 the NRC would not physically operate the facility.

1           With respect to actions below the line, this would  
2 probably be, as our current thinking would go, be  
3 implemented by regional people as they arrived at the plant.

4           VOICE: Can you give us an example of when you  
5 might take the two actions below the line and what situation  
6 you might do it in?

7           MR. BELTRACCHI: It is awfully hard to come out  
8 with a specific example. I think in emergencies that the  
9 NRC is directed to respond to a critical event. We have to  
10 be prepared to do so. If we are told to make decisions and  
11 respond to that and be at the site, and if the utility were  
12 not able to, say, execute -- the management of the utility  
13 was not able to execute what would be needed to control the  
14 accident or to mitigate the accident, we may very well be  
15 ordered to attempt to take that function.

16           VOICE: You feel this would only be in a case --

17           MR. BELTRACCHI: Believe me, we do not look  
18 forward to anything like that. We would only expect that to  
19 be in a very extreme condition.

20           VOICE: That raises some concern among those of us  
21 who have reviewed this, as well as the public relations  
22 thing. Who is going to be responsible for news releases?  
23 Are we going to end up with NRC giving news releases and the  
24 licensee giving news releases as well?

25           I think that has been clarified, but there was

1 some concern (Inaudible).

2 MR. BELTRACCHI: Of course, relative to --  
3 relative to overall safety, the primary function is with the  
4 operator, and that is where it should be. We feel it is  
5 only in extreme cases, and it is very hard to define the  
6 boundaries of that.

7 We may find as an agency we are directed to do so  
8 by higher elements within the government.

9 VOICE: What sort of responsibilities when that  
10 small portion is taken --

11 (Laughter.)

12 Because now the facility passes out of the  
13 licensee's control

14 MR. BELTRACCHI: The constraint is not physical  
15 operation.

16 VOICE: There is very little difference between  
17 somebody directly manipulating a control and somebody who  
18 has control of that person's license qualifications or  
19 currency of license qualifications, and telling him you move  
20 that control because I cannot touch that control, but I am  
21 telling you to do it.

22 MR. BELTRACCHI: You raise a good point, and I  
23 think relative to a lot of the details, the 2 percent  
24 probably have not been thought out in terms of the legal  
25 aspects because of the majority of the effort has gone into

1 the 98 percent and probably does require additional  
2 clarification.

3 VOICE: I think that 2 percent is very important.

4 MR. BELTRACCHI: I know the 2 percent is very,  
5 very critical to what --

6 MR. MINNERS: What does the 2 percent have to do  
7 with the design of the Nuclear Data Link? It really is not  
8 whether it is some other slight different variation than you  
9 understand, and it is not going to change the design of the  
10 Nuclear Data Link, which is really what we are trying to  
11 address at the moment. You have other problems.

12 VOICE: I would like to talk about the Nuclear  
13 Data Link more than its role in emergencies. I did not see  
14 anything on that slide -- I thought this was kind of  
15 introductory.

16 MR. BELTRACCHI: It is, but let me relate the  
17 Nuclear Data Link -- it would probably be more associated  
18 with the items above the line since you cannot do remote  
19 control.

20 VOICE: My last comment on the ECF under  
21 monitoring, the item "and inform the public," I thought that  
22 would take place from the ECF (Inaudible).

23 MR. RAMOS: As far as the releases coming directly  
24 out of the plant that is correct. Now, obviously -- can you  
25 hear me back there?

1 VOICE: Yes.

2 MR. RAMOS: Obviously we are going to have to make  
3 releases to the people in Washington, to FEMA, to the  
4 various other agencies, and that may come out in the press  
5 also. The intent is to -- the intent is to establish  
6 communication between the ECF, TSC, and NRC to make sure  
7 that what we do release is coordinated.

8 VOICE: Okay. I guess --

9 MR. MINNERS: Don't interpret this slide as to  
10 what is going to be done at headquarters. This slide is  
11 what the NRC is going to do during an emergency, and we have  
12 regional people who are going to be onsite, and we have  
13 people at headquarters, and we have people here and there.  
14 This is the total function of the NRC, and people tend to  
15 look at this slide as what is going to be done at  
16 headquarters. That is incorrect

17 MR. BELTRACCHI: You cannot do remote control with  
18 a hundred points when you look at a control room, and there  
19 are thousands of points that exist.

20 VOICE: I appreciate that clarification. Even  
21 onsite, the small point of informing the public per the ECF  
22 specification is that of the senior licensing management  
23 designee.

24 MR. MINNERS: I hope we have all learned that  
25 lesson, that we ought to have one place.

1 VOICE: Right.

2 MR. BELTRACCHI: May I have the next slide, please?

3 (Slide.)

4 This slide presents some of the anticipated NRC  
5 actions. I guess I am -- I have to get around front, but it  
6 will address the making of recommendations on -- to protect  
7 public health and safety, the advice and counseling to the  
8 licensee, providing evaluative information, and determine  
9 significance of events, coordinating onsite assistance to  
10 licensee, possibly directing licensee to take or not to take  
11 specific actions. This is further amplification of the  
12 first slide.

13 (Slide.)

14 Relative to the emergency response summary, this  
15 deals with how the portions of the emergency would interact  
16 with the operations center in terms of notification on a hot  
17 line to the duty officer at our operations center in  
18 Bethesda. The licensee is to maintain open and continuous  
19 communication channels. Headquarters and regions  
20 notification procedures would be initiated. Regional  
21 director and support staff would leave for a site, and  
22 because of the various distances between the regional  
23 headquarters and sites, that may take anywhere from two to  
24 eight hours. The resident inspector would be notified, and  
25 that would take about an hour.



1           The operations center would be manned in  
2 Bethesda. That will anywhere from five minutes to an hour  
3 with a staff of approximately 60 people. It would be a  
4 single voice line to the site during the initial phases.

5           (Slide.)

6           In terms of the NDL design features, there will be  
7 approximately 100 data points from each PWR and BWR  
8 parameters according to the initial specifications or  
9 initial thinking along these lines. The parameters would be  
10 samples collected and processed once per minute. There  
11 would be 30 minutes of pre-event data, and the sample  
12 parameters would also contain some transient analysis,  
13 particularly looking, I think, for flux and pressure  
14 anomalies, the details of which were presented in the  
15 specifications on the link. Within the headquarters in  
16 Bethesda I think we were thinking on the order of having the  
17 capability of storing two weeks of event data.

18           We would also have event alerting of key  
19 parameters, and data would be presented to the operations  
20 center in standard format and protocol as we received it  
21 over the link.

22           (Slide.)

23           Specific data would consist of the same as Reg  
24 Guide 1.97 variables to be presented in engineering units.  
25 They would be digitized and formatted for transmission, and

1 this will be covered through an interface.

2 (Slide.)

3 And that will give details of the data format  
4 transmission requirements and the environmental and  
5 performance criteria of the equipment at the various plants.

6 In terms of a schedule, the activities are defined  
7 in the lefthand column. We have had Sandia as a contractor  
8 to do a feasibility study on the link, and the activities  
9 involve such factor as a context study down through a lab  
10 lockup and installation and testing, software and hardware  
11 procurement and development down to an initial operation  
12 which I think was called for in '84.

13 So that pretty much covers the Nuclear Data Link.  
14 I recognize I have gone over this very quickly, but if there  
15 are any questions, I will try to answer them.

16 VOICE: What is the intent of the NRC in Bethesda  
17 in the high resolution flux and continuum pressure  
18 information that has been requested?

19 MR. BELTRACCHI: The intent there was just really  
20 to try to get some information to help us understand the  
21 event. The transient data, the resolution of one minute.  
22 you would not -- you would miss a spike or things of that  
23 nature, so we really felt there had to be some additional  
24 data that would be presented and a final resolution.

25 VOICE: Is there anything that can be done in

1 Bethesda that cannot be done locally if one knows that there  
2 is a reactivity spike, or a transient going on, or a  
3 containment pressure spike?

4 MR. BELTRACCHI: The intent was to try to define  
5 that. If there are any other approaches that you could take  
6 and, say, implement in analog fashion and determine that  
7 there was a spike, or peak, or something like that and then  
8 convert it to digital and then transmit it, I am sure that  
9 would be acceptable.

10 VOICE: What is the use going to be made of it in  
11 Bethesda?

12 MR. BELTRACCHI: Just to understand the initiation  
13 of the event.

14 VOICE: Why can't that be transmitted in some kind  
15 of tertiary fashion rather than having a direct transmission?

16 MR. MINNERS: What do you mean by tertiary?

17 VOICE: Why does it need to be on a direct data  
18 link? I don't understand, unless the intent is actually to  
19 have someone sitting in Bethesda who is going to grab the  
20 phone if he sees an anomaly in the source range indication  
21 all of a sudden. That just seems absurd.

22 MR. BELTRACCHI: One of the bases for the link in  
23 the first place was to improve communications and to ensure  
24 that the NRC would receive valid data. I think the Crystal  
25 River event was a good example of that.

1 VOICE: But this sort of data seems to be probably  
2 the type of data that would be the most unreliable and  
3 certainly the most difficult to make any kind of decisions  
4 on from a remote location. And additionally, it requires  
5 special consideration because of the high sampling rate.



6 MR. BELTRACCHI: The high sampling rate is an  
7 area, because of the pressure to try to get a spec out --  
8 there are other solutions to the high sampling rate that  
9 could be done in the form of analog monitoring. So if that  
10 is what your real concern is, propose an alternative to that.

11 VOICE: You mentioned trend data. Is that not  
12 something that the Bethesda operations center would develop  
13 from the data at the high sampling rate? We would just  
14 provide the raw data and the rates digitized, and then any  
15 trending by your system?



16 MR. BELTRACCHI: Yes. That was the intent. The  
17 trending would be performed on the displays at the  
18 operations center.

19 VOICE: Not trying to provide data plus bursts of  
20 data (Inaudible).



21 MR. BELTRACCHI: If you are referring to the fact  
22 -- I know there was one time a concept presented within the  
23 NRC of having a link where the plant process computer or the  
24 plant's computer -- let me phrase it that way -- have them  
25 perform the trending and then send the information back. I





**IMAGE EVALUATION  
TEST TARGET (MT-3)**




**MICROCOPY RESOLUTION TEST CHART**







**IMAGE EVALUATION  
TEST TARGET (MT-3)**



**MICROCOPY RESOLUTION TEST CHART**



1 think that would be a complex approach to the problem.  
2 However, I would not want to totally rule it out. I would  
3 expect that the link would be more of a case of sending  
4 sample data to NRC and then let NRC operate on the data,  
5 present it in its various trends and displays within the  
6 operations center.

7 VOICE: (Inaudible) two week data storage will  
8 allow you to recall and trend?

9 MR. BELTRACCHI: Yes, yes.

10 VOICE: This really is not in the Nuclear Data  
11 Link section, but I think the question goes to that area.  
12 On page 9 of the report it was indicated it may be desirable  
13 to provide interactive (Inaudible) between the plant  
14 emergency facilities and NRC headquarters.

15 Could you explain? It seems to go to the item you  
16 were just discussing. Is it desirable or isn't it?

17 MR. RAMOS: You do make that statement. You do  
18 make that statement.

19 VOICE: Fourth paragraph from the bottom.

20 MR. RAMOS: I know. I know what paragraph you are  
21 talking about.

22 MR. MINNERS: We have been hassled about this  
23 before. We know where it is.

24 (Laughter.)

25 MR. RAMOS: That is something we are still

1 studying. That is the reason why it is put in there as a  
2 vague requirement. We do not intend to provide interaction  
3 with your computer except perhaps in one mode that they are  
4 considering just to activate the flow.

5 The other type of interaction we are talking about  
6 is primarily to exchange data back and forth between the two<sup>o</sup>  
7 facilities -- either one of the three facilities.

8 VOICE: Exchange data and what? I guess I am not  
9 real sure.

10 MR. RAMOS: If you have a particular display that  
11 we are misinterpreting, if we had to have a display that  
12 says it looks like, you know, this is happening, and you  
13 have a similar display that shows that is not happening, we  
14 want to exchange that type of information.

15 VOICE: (Inaudible).

16 MR. RAMOS: That would be handled over the --

17 MR. BELTRACCHI: There would be other means of  
18 communication. The Nuclear Data Link was primarily a  
19 one-way data flow from the plant to the NRC with the  
20 exception of such things as maybe error checking or manual  
21 initiation to start the data as a provision -- as an  
22 alternate provision.

23 MR. RAMOS: Don't take the interactive capability  
24 there to mean necessarily computer-to-computer interaction.

25 VOICE: That is the way most people would take it.



1 MR. RAMOS: I understand.

2 VOICE: Will you clarify this at a later date?

3 MR. RAMOS: We will clarify it before the final  
4 edition is put out.

5 MR. BELTRACCHI: Question?

6 VOICE: In the letter of March 12, 1980 from  
7 Eisenhower you set forth parameters for PWRs and BWRs. The  
8 parameters you would like for the Nuclear Data Link, is this  
9 part of the NUREG-CR-1451?

10 MR. BELTRACCHI: Is that the Sandia report?

11 VOICE: Yes.

12 MR. BELTRACCHI: What has happened since then, we  
13 have gone back and tried to make a comparison with Reg Guide  
14 1.97 to make sure Reg Guide 1.97 had the variables, so that  
15 would be consistent with what it's called in the NUREG --

16 VOICE: Certain reactors in the United States do  
17 not fit the criteria of this document.

18 MR. BELTRACCHI: We recognize that.

19 VOICE: What will our guidelines be?

20 MR. BELTRACCHI: There will be blank forms, a  
21 format. We recognize there will not be data, and the  
22 intelligence that will have to be built into the operations  
23 center computer will recognize that and act accordingly.

24 VOICE: Do you propose that we send our  
25 meteorological data over the Nuclear Data Link to you?

1 MR. MINNERS: The meteorological data that is  
2 required by Reg Guide 1.97 is a very minimum set. I think  
3 it is just wind speed and direction. I think we even have  
4 eliminated any temperature measurements.

5 You are referring to the requirements of 0654.

6 VOICE: It is reported in several places that we  
7 have to send meteorological data to you. Do we have to send  
8 it over the Nuclear Data Link?

9 MR. MINNERS: Yes. We envision only one flow of  
10 data back and forth.

11 VOICE: If there was a question that we could not  
12 send this through a computer at the plant, this makes it  
13 complicated. Can we use it as throughput through our  
14 computer and then put it on the Nuclear Data Link as  
15 straight data?

16 MR. RAMOS: Probably. You would have to show us  
17 that in your design concept.

18 MR. BELTRACCHI: (Inaudible) be less than say the  
19 availability of the link.

20 VOICE: That is going to be a common problem  
21 anywhere you go.

22 MR. BELTRACCHI: Again, you are looking at the  
23 weakest link in a system here. What is the weakest link?  
24 If you are adding an additional -- in order to get the  
25 information into the Nuclear Data Link, you are adding

1 something that is weaker than the entire link, then we would  
2 be concerned. That data would probably not be there when it  
3 was needed.

4           Again, I would sort of suspect that there is a lot  
5 of flexibility in design approaches to this. There should  
6 be a solution to the problem.

7           VOICE: I am sure there is. It is just a matter  
8 of whether you all will accept the solution.

9           MR. COMPTON: The reference was made a little bit  
10 ago to 0654. Are you talking about the minimum  
11 meteorological data set, or are you talking about the  
12 appendix that says (Inaudible)?

13           MR. MINNERS: I think we decided from the meeting  
14 in Philadelphia that there may be inconsistencies between  
15 0654 and 0696, and we are going to have to go back and look  
16 at that.

17           My understanding of the intent now is that what is  
18 being put into Reg Guide 1.97, no more than that data will  
19 be sent on the Nuclear Data Link, and that includes a very  
20 limited set of meteorological data. As I remember it, it is  
21 only wind speed and direction. But we have to go back and  
22 be sure those two documents are consistent, and 0654 is also  
23 in the process of being revised and modified.

24           MR. GOLDEN: I would add, Reg Guide 1.23, the new  
25 draft out, has the same kind of --

1 MR. RAMOS: That is the intent.

2 MR. GOLDEN: 1.23 conflicts with 0654 which  
3 conflicts with NDL. So really what you are saying is that  
4 NDL should replace 0654 and 1.23.

5 MR. MINNERS: The meteorological people revised  
6 Reg Guide 1.97 which is going to go into the NDL. My  
7 understanding is they did that to make it consistent with  
8 what they were proposing for Reg Guide 1.23.

9 MR. GOLDEN: That might be the case (Inaudible).  
10 What you are proposing, just in summary, is the NDL concept  
11 of meteorological data will satisfy 0654 when it ultimately  
12 comes out and Reg Guide 1.23 when it comes out.

13 MR. MINNERS: Correct.

14 MR. BELTRACCHI: Yes?

15 MR. GRIMES: On the meteorological data you could  
16 have a microprocessor (Inaudible). I am bothered by the  
17 term "plant process computer" in your -- towards the end.  
18 I'm trying to see why it is that you don't want to use the  
19 plant processor computer. Is it because it does not meet  
20 the criteria?

21 MR. MINNERS: We would like to get through the  
22 presentation, and that is a very good subject which I think  
23 we could discuss in detail after lunch. May we do that?  
24 Let's try to complete the presentation.

25 Are there any more questions on the Nuclear Data

1 Link?

2 VOICE: I have a particular comment. (Inaudible)  
3 that a battery backup (Inaudible). I don't know how some of  
4 this equipment would work off of batteries without an  
5 intermediate device.

6 MR. BELTRACCHI: I guess I would have to, you know  
7 -- I guess I would have to look at the various specific  
8 devices you were proposing.

9 VOICE: Most of the equipment is AC-operated. In  
10 fact, all of it is, whether it be communication equipment or  
11 the computer equipment. So that your comment of battery  
12 infers that the equipment is operated directly from a DC  
13 power source. I think you are being too narrow if you want  
14 us to take this literally.

15 VOICE: (Inaudible).

16 MR. BELTRACCHI: Okay, okay. Good point.

17 MR. MINNERS: Okay. I think -- let me -- I think  
18 we are through with the Nuclear Data Link. Let me make a  
19 clarification, and then we will put on the slide on  
20 implementation.

21 We have had some discussion about interaction  
22 between the utility, the NPC, state and local authorities  
23 and other federal authorities. I think we have to be  
24 careful with what we are saying. Maybe we all realize the  
25 qualifications that we put on these things without stating

1 them.

2           When we say the senior utility person is going to  
3 be in charge of the EOF, I think we know what that means.  
4 The utility cannot be in charge of the NRC. It cannot be in  
5 charge of the state and local people in the direct sense  
6 that he can give them orders. We and they are independent  
7 people. He is a coordinator, and I think we all have  
8 realized from Three Mile Island that it would be best to  
9 have coordinated statements come out on what is happening  
10 during an accident.

11           That does not prohibit state and local authorities  
12 or the NRC to make press statements if they think those are  
13 necessary. I don't think you can stand here now and say  
14 that we are going to do it a certain way exactly, that no  
15 press release or press statement will go out unless it is  
16 approved by a senior utility person. So we have to  
17 recognize that besides the utility there are other  
18 organizations which are independent of them, and certainly  
19 during an accident there has to be coordination, but there  
20 is no direct control. I just want to make that point clear.

21           VOICE: (Inaudible).

22           MR. MINNERS: And that is why we are trying to put  
23 up these facilities. First of all, there is going to be an  
24 organization on paper, and just because it is on paper it  
25 does not mean it has to be followed during an accident. We

1 hope that by having adequate facilities that that will  
2 strengthen the impetus to follow the organization that is on  
3 paper. If you have no facilities and just an organization,  
4 people may not even read the piece of paper; but if you have  
5 a facility, that gives you a lot more ability to direct  
6 people in the way the organization is on paper. And that is  
7 the one purpose of these emergency response facilities.

8           That is why we think we need the ECF outside the  
9 security fence, so that we can get these other people in  
10 there all in one place and be able to talk to them.

11           All right. Let's have a last item which is the  
12 implementation schedule for all this material.

13           MR. RAMOS: Evidently you won't be able to see  
14 this, but in the August 1st letter that Darrell Eisenhut put  
15 out it has the schedule in there in the last page with the  
16 direction to use that for planning purposes. This is the  
17 schedule that we gave to the Commission as how we envisaged  
18 being able to meet the April 1982 date.

19           Some of those bars in there go all the way back to  
20 June and earlier, because we feel that a lot of facilities  
21 have already started some of that planning and started their  
22 equipment procurement and what have you.

23           The critical dates that have been changed from the  
24 previous documents is the 1 January 1981 date, and by that  
25 date we expect to have from everyone -- prior to that date,

1 if possible -- your concept description on how you propose  
2 to meet the requirements of 0696.

3           On January 1, 1982 we expect the SPDS to be fully  
4 operational. On April 1, 1982 we expect the TSC and EOF  
5 fully operational. Currently the way Reg Guide 1.97 is  
6 written, those new facilities that are coming on line here  
7 in the near future would have to meet all of Reg Guide 1.97  
8 requirements by June of 1982, and those that have to backfit  
9 or upgrade -- operating plants, that is -- would have to  
10 meet the January 1983 date requirements.

11           So although we expect a fully operational TSC and  
12 EOF, you may not have the final data flow in except maybe  
13 through a process computer or something else where you  
14 already have the data until you finally get the full 1.97  
15 requirements in. This is a change from the previous  
16 requirement of having a fully operational TSC by January 1,  
17 1981.

18           Do you have any questions?

19           MR. MINNERS: Well, fine. Okay. I don't think  
20 that means that you agree with it.

21           Let's see. It is now 12:15. Let's reconvene at  
22 1:30 for the afternoon session which will be devoted to  
23 comments, questions, and whatever else you would like to do.

24           (Whereupon, at 12:15 p.m., the workshop was  
25 recessed for lunch, to be reconvened at 1:30 p.m., the same



- 1 day.)
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

## 1 AFTERNOON SESSION

2 (1:30 p.m.)

3 MR. DAVIS: We are ready to start the afternoon  
4 session. A couple of announcements before we do.

5 We have a form here you can fill out if you are  
6 interested in getting a transcript of this workshop. You  
7 have a couple of choices. You can pick up the form, take it  
8 back with you, and then mail it to Alderson Reporting in  
9 Washington, D.C., and the address is on the bottom of the  
10 form. The other thing you may do is just sign the form and  
11 give it to this gentleman here on my right, and he will take  
12 it back then and make arrangements to send the transcript to  
13 you. I am told it is 45 cents per page.

14 The afternoon session will begin as a comment  
15 period, and we will start with the individuals on the list  
16 as they appear. There was one person who was on the list  
17 first that asked me a question as to whether or not he could  
18 have somebody substitute for him. I guess the answer to  
19 that is yes, but then he goes to the bottom of the list.

20 MR. MINNERS: Okay. Let me remind you, especially  
21 in this session if you wish to make a comment, please come  
22 to the microphones, identify yourself and make your comment.

23 All right. I am going to proceed down the list in  
24 the order that people signed up. I will cut it off at  
25 5:00. If there is time, people who have not signed up on

1 the list of people who want to come back again and make  
2 another comment, we will get to you.

3 Okay. Let's start.

4 Mr. Bradley from SMUD.

5 MR. BRADLEY: Ed Bradley, Sacramento Municipal  
6 Utility District.

7 What will be the NRC staff qualifications at the  
8 TSC and EOF concerning their expertise and qualifications?

9 MR. MINNERS: Say that again. I missed something.

10 MR. BRADLEY: What will be the NRC staff  
11 qualifications at the TSC and the EOF?

12 MR. RAMOS: That is still under development at a  
13 joint group at I&E deciding what that should be.

14 MR. BRADLEY: Our plant management has a big  
15 difficulty with that since most of the NRC people were  
16 brought up with Westinghouse or the Navy program, and since  
17 we have a B&W plant there is a lot of differences; and if we  
18 have somebody we don't know coming in and telling us what  
19 switch to pull, we are not going to believe them. There is  
20 a credibility gap there.

21 MR. MINNERS: I am willing to discuss that  
22 question with you, but I guess we both recognize that does  
23 not have much impact on the design of the emergency response  
24 facilities. Whether our people are qualified or unqualified  
25 really is not going to affect these requirements.

1           If you would like to discuss it, I think that is a  
2 good thing to discuss. I am willing to discuss philosophy,  
3 and maybe the region would be willing to discuss what their  
4 plans are for having people, because it is going to be the  
5 regional people who are going to be at the plant.

6           MR. BRADLEY: There are two computer systems, the  
7 SPDS and the NDL. Why the redundancy? Can't we get by with  
8 one system? Wouldn't that be a cost benefit on that?

9           MR. MINNERS: The intent -- we are not specifying  
10 whether you need one, two, or more. We have said what each  
11 function has to be, and how you satisfy those functions is  
12 up to the designer. And we have had some discussions by us  
13 requiring OBE on the safety parameter display that makes you  
14 have at least two systems or may make you have two systems.  
15 I understand that.

16           We are not specifying how many computers you have  
17 to have. We want the functions. We don't care much how you  
18 do it, whether you use two computers or three computers.

19           MR. BRADLEY: In 0696 there is a mention that the  
20 NRC wants their own private terminal. Is the NEC going to  
21 purchase that on their own, or is it up to the utility to  
22 purchase that?

23           MR. MINNERS: For the NDL we are going to have the  
24 utility provide that terminal.

25           MR. BRADLEY: Can't you guys share?

1           MR. MINNERS: The site -- what we have called the  
2 site transmission unit will be owned and purchased by the  
3 NRC. At least that is the concept now.

4           MR. BRADLEY: The site transmission to Bethesda?

5           MR. MINNERS: It is called a site transmission  
6 unit, and it is the unit that is going to take the process  
7 data and manipulate it so it can be transmitted --

8           MR. BELTRACCHI: The concept was or the concept as  
9 it is currently being proposed is to have a site  
10 transmission unit that would have a receptacle wherein the  
11 utility would be able to provide the information in  
12 formatted form, and the site transmission would take it and  
13 store it and transmit the data.

14           There is a point of interface, and that point of  
15 interface will be covered through an interface which remains  
16 yet to be developed.

17           MR. BRADLEY: Okay. We'll have the SPDS and the  
18 NDL in the TSC, is that correct?

19           MR. BELTRACCHI: The SPDS is there. I don't think  
20 we have specified any --

21           MR. MINNEPS: I don't know what you mean by the  
22 NDL.

23           MR. BRADLEY: Nuclear Data Link. Do you want all  
24 that data information at the tech support center and the ECF?

25           MR. MINNERS: We want the same data base.

1 MR. BELTRACCHI: That is covered by Reg Guide 1.97.

2 MR. BRADLEY: You want your own private NRC  
3 terminal at both of those locations also?

4 MR. MINNERS: No.

5 MR. BRADLEY: One terminal would be sufficient at  
6 each of the locations?

7 MR. MINNERS: You are confusing us. Would you  
8 define "terminal?"

9 MR. BRADLEY: Whatever the CRT display or whatever  
10 display is decided upon, would one display be sufficient at  
11 each of the locations?

12 MR. BELTRACCHI: For what purpose?

13 MR. BRADLEY: For the Nuclear Data Link.

14 MR. MINNERS: We don't intend to have any display  
15 of the Nuclear Data Link at the site. That display would be  
16 at the NRC headquarters. All we want is a plug that we can  
17 plug into from headquarters, not to have that information as  
18 it is provided on the Nuclear Data Link display.

19 Obviously that data comes from the same common  
20 data base, and it is going to be displayed in possibly a  
21 different form in the TSC and EOF. Our people are going to  
22 look over your people's shoulders in those facilities to  
23 look at the same instruments you are looking at. We don't  
24 want a private display in the TSC or EOF. In fact, one of  
25 the concerns is we want to look at the same information you

1 look at so we can talk the same language.

2           And one of the concerns with a Nuclear Data Link  
3 is some people have suggested that not only should the data  
4 be from a common data base, but your display should be  
5 transmitted over the data link so that we see it presented  
6 in exactly the same form.

7           That is not the current concept, but people are  
8 saying if you don't do it that way, how do you assure that  
9 you are not going to get miscommunication where you, the  
10 Commission, could manipulate the data a bit differently and  
11 therefore get a different interpretation or something and  
12 add to the confusion.

13           MR. BRADLEY: 0654 talks about backup tech support  
14 center and a backup EOF. If we meet the habitability  
15 requirements that you are mentioning in 0696, is it  
16 necessary then to have a backup TSC and EOF?

17           MR. MINNERS: No, no. One TSC and one EOF is the  
18 current design concept.

19           MR. RAMOS: In Philadelphia they brought up the  
20 point in some cases where they would like to have the option  
21 of having an alternate EOF and possibly a TSC, similar to  
22 what was approved for Arkansas as far as the TSC was  
23 concerned. But in our discussion with the Commission on  
24 July 11 it was said that we would only have the three  
25 facilities, the control room TSC and EOF, for controlling

1 accidents.

2           That is our requirement. If you want to have an  
3 alternate --

4           MR. BRADLEY: You make mention in there that if  
5 the TSC becomes uninhabitable that the function is then  
6 split back to the control room and the EOF. In that case  
7 will you require a backup TSC?

8           MR. RAMOS: I don't think it is worded like you  
9 said. I think it is worded that in those cases where you  
10 choose to have a primary TSC -- and that is the Arkansas  
11 option -- where they have a primary TSC, I believe it is on  
12 their turbine base, which is not habitable, and it becomes  
13 non-habitable, then it shifts to their alternate TSC. And  
14 they understand that they have to have the data requirements  
15 in both places, and that is what that is referring to. It  
16 is giving you that option.

17           If you do not have room inside the reactor  
18 building and you want to build a non-habitable TSC, for  
19 example, on the turbine bay, and you want to have a  
20 habitable TSC near, then we would accept that option.

21           MR. BRADLEY: Okay.

22           MR. RAMOS: But the intent is to have only one  
23 TSC, so if you make it habitable and it is right near the  
24 control room, that would be the only TSC required.

25           MR. BRADLEY: That is all my questions.



1 MR. MINNERS: Okay. Mr. Abel of Commonwealth  
2 Edison.

3 MR. ABEL: First, I would like to thank you for  
4 this opportunity to comment. I am not going to go into  
5 specific questions on the NUREG because we have a large  
6 number of what we consider to be substantial questions and  
7 comments that we will submit in writing.

8 I would hope that one of the things you have  
9 gotten out of this meeting is that is probably true of all  
10 utility companies present. I would also like to urge that  
11 the staff work closely, as you suggested, with the AIF  
12 subcommittee that is working on this NUREG. I believe there  
13 are still substantial improvements that can be made, if not  
14 in the intent of the report, at least in the wording of some  
15 of the sections.

16 MR. MINNERS: We would appreciate any specific  
17 rewordings that you would suggest. It would be better to  
18 give us a specific rewording rather than to say it needs  
19 improvement, because everything needs improvement.

20 MR. ABEL: Right. I understand that. I believe  
21 that is what the AIF subcommittee is working on.

22 This morning it was mentioned that the schedule  
23 for completion of the technical support center requirements  
24 of 1-1-81 would be delayed until 1-1-82. I hope that is  
25 going to be documented in some formal way so we can stop

1 work on the 0578 requirements that are currently under way.

2 MR. RAMOS: It has already been documented by Mr.  
3 Eisenhut in his letter to all the licensees for planning  
4 purposes, and there is a clarification letter coming out on  
5 Lessons Learned items, and that has been cranked into that  
6 letter. And there is also a workshop on those Lessons  
7 Learned items I think in September.

8 MR. ABEL: One thing you might consider -- I read  
9 the letter transmitting the NUREG-0696 -- it is not clear we  
10 are being given specific relief from the 0578 requirements.  
11 That was my point.

12 MR. RAMOS: It was intended that way to use it for  
13 planning, and it was supposed to be clarified in the  
14 clarification letter on Lessons Learned items which will be  
15 -- as I said, there will be a workshop on it, as I recall in  
16 the middle of September.

17 MR. ABEL: The last item I would like to discuss  
18 in some detail is this schedule that has been developed for  
19 this. Primarily my comment is I think it is premature to be  
20 establishing a 1-1-82 date for implementation of these  
21 requirements, primarily because it appears that it has taken  
22 nearly a year to develop the criteria document that we are  
23 discussing today. We are being given four months to develop  
24 designs in response to those criteria and something less  
25 than 12 months to install those designs.

1           I don't believe that a highly compressed schedule  
2 of this kind is going to allow us to meet the intent of all  
3 this entire approach, which is to improve an integrated  
4 system for handling emergency conditions.

5           Granted, I understand the urgency, but I feel with  
6 the vast scope we are trying to incorporate in this single  
7 document, it is unrealistic to establish that schedule.

8           And finally --

9           MR. MINNERS: In your written comments I would  
10 hope you would provide some more supporting material which  
11 would demonstrate your contention that the schedule is too  
12 short, which I am sure that you can do.

13           MR. ABEL: Well, my final comment is that -- on  
14 the schedule is that I don't feel its completion date can at  
15 all be established by us, by Commonwealth Edison, until we  
16 have an approved design from the NRC. And an example, case  
17 in point is our commitments on 0578 for the technical  
18 support center.

19           We proceeded in good faith, have designed, have  
20 purchased all the equipment, and have the buildings well  
21 under way in construction, and now the requirement has  
22 changed, and I do not think we can go through that again a  
23 second time.

24           So my suggestion is that you tie the schedule to  
25 be established when your detailed review of our design is

1 completed. I think we will know what it is we are  
2 scheduling then, and you will have a much better idea of  
3 where we are going also.

4 Thank you.

5 MR. MINNERS: Thank you.

6 Mr. Ewbank of Detroit Edison.

7 MR. EWBANK: Most of my comments were covered this  
8 morning, but there is still one on page 15 where you have a  
9 limiting condition for operation. The EOF is not  
10 operational for a period of eight hours -- exceeding eight  
11 hours, correction -- what does this mean?

12 MR. RAMOS: If you cannot perform the functions of  
13 the EOF for a period of eight hours for some reason such as  
14 the equipment is down, or it is flooded, or what have you,  
15 then you have got to make a report stating what you are  
16 going to do to compensate for the fact that you cannot  
17 perform that function. That is what the LCO is for.

18 MR. EWBANK: This is in addition to your .01  
19 unavailability then.

20 MR. MINNERS: The .01 unavailability is a design  
21 goal. That is what the guy is going to try to design to,  
22 and the LCO is the thing that implements that design goal  
23 and says that is what you are actually going to be held to.

24 Mr. Golden of Commonwealth.

25 MR. GOLDEN: My thunder for my first question was

1 stolen, but I would like to have the point elaborated since  
2 we have to develop technical specifications for the  
3 non-operation of the EOF and TSC. It is quite vague as to  
4 what is meant; for instance, does it mean that you cannot  
5 turn the lights on because there is no replacement bulb?  
6 Does that mean it is non-functional?

7           One can elaborate many different criteria. It  
8 seems to me it is a very vague statement.

9           MR. MINNERS: I don't think it is any more vague  
10 than the usual tech spec thing of operable.

11           MR. GOLDEN: Does this mean we have to send out a  
12 person at every shift to a facility that is 10 miles from  
13 the plant to check on its operability? The implication is  
14 there.

15           MR. MINNERS: I don't know what the surveillance  
16 requirement would be. There would be some surveillance  
17 requirements on the EOF, whatever that may be.

18           MR. GOLDEN: A second point was not touched on  
19 this morning --

20           MR. MINNERS: But I do not see why you couldn't  
21 have -- if that is a problem, you could have some kind of a  
22 remote way of testing the facility if that is a problem.

23           MR. GOLDEN: It gets back to what is defined as  
24 non-operation.

25           MR. MINNERS: Let's discuss that some more. That

1 is a problem, and I am not sure that you want us to define  
2 it better. We have never in any documentation that I know  
3 of defined operable any better than in the tech specs, and  
4 it has been worked out over the years of what operable  
5 means, and people now understand that.

6 I think it is one of those problems that you  
7 really cannot define. It is one of those words that you  
8 have to use a lot so that everybody understands what it  
9 means. If we get too specific, you will accuse us of being  
10 too prescriptive.

11 MR. GOLDEN: I take it if the filtration system is  
12 not functioning, the TSC is considered non-operable even  
13 though there is no radioactivity or contamination in the  
14 area. That would constitute, I take it, non-operation.

15 MR. MINNERS: Part of its function is to be able  
16 to function during conditions in which there is  
17 radioactivity, so it can't perform its function. It is not  
18 operable.

19 MR. GOLDEN: If the data link is not operable for  
20 one reason or another, that defines non-operation even  
21 though all other functions in EOF can be covered.

22 MR. MINNERS: I don't think -- you brought up a  
23 question I had not thought about. The Nuclear Data Link is  
24 not part of the TSC or EOF, and we have not put any  
25 operability requirements yet on the Nuclear Data Link.

1           MR. GOLDEN: It is a subset of all the other  
2 information that has to go into the TSC. I guess I was  
3 using the Nuclear Data Link in a generic sense. It just  
4 seems to be a point --

5           MR. MINNERS: That is going to be a difficult  
6 point to resolve. I don't know how to do it now. That is,  
7 to say how much data could be unavailable, and you could  
8 still consider the facility to be functional. And it is  
9 like an ECCS system. I mean, you know, you have two trains,  
10 and one is out. You can define it -- we have different  
11 definitions for how much of the equipment is out, and we are  
12 going to have to work that out on these facilities.

13           I think that is a very detailed thing that is  
14 going to have to be worked out once the facility is  
15 designed, and that is all I know how to say right now.

16           MR. GOLDEN: This is related to a question that  
17 came up just a little bit back concerning the backup EOF  
18 concept. If this concept which apparently -- which was in  
19 0654 and now apparently superseded by the non-requirement  
20 for the backup, if the utility -- I am not saying Edison is  
21 going to do that -- if a utility were to choose the backup  
22 concept, would the primary EOF have to be designed to the  
23 habitability requirements and must the backup be within ten  
24 miles?

25           MR. RAMOS: That is a difficult question to answer.

1 MR. GOLDEN: That is why I asked it.

2 (Laughter.)

3 MR. RAMOS: Without looking at the details. We  
4 are not preventing you from having the backup concept. The  
5 backup would have to meet the habitability requirements.

6 MR. GOLDEN: Why would they have to meet the  
7 habitability requirements in either case, because if the  
8 first is not habitable, then you would move to the second;  
9 so it does not seem to me that you would have to have the  
10 habitability requirements on either one if you went to the  
11 backup concept.

12 MR. RAMOS: Okay. Let me back up and say that if  
13 it is within the ten mile EPZ and your backup is within the  
14 ten mile EPZ --

15 MR. GOLDEN: That is the second part of the  
16 question.

17 MR. RAMOS: I realize that. If it is within the  
18 ten mile EPZ, and that is where you have moved to and you  
19 get to the point where you have to evacuate, you will not be  
20 able to evacuate that facility. I mean, by design you will  
21 not be able to evacuate it.

22 If you move it outside the ten mile EPZ and you  
23 have to evacuate the area, the ten mile area, then obviously  
24 it does not have a habitability requirement because it is  
25 outside the ten mile area.



1 Does that answer your question?

2 MR. GOLDEN: By that you are saying that neither  
3 the primary nor the secondary EOF would have to have or meet  
4 the habitability requirements, and that the backup could be  
5 outside the ten mile area. Is that what you are saying?

6 MR. RAMOS: That is what I am saying. I will also  
7 say that both of them will have to have all of the data  
8 requirements.

9 MR. GOLDEN: I realize that. I was specifically  
10 referring to the habitability requirements.

11 MR. MINNERS: I think we had some misunderstanding  
12 in the previous meeting. If your EOF is at 9.9 miles, the  
13 habitability requirements will probably be very minimal.

14 MR. GOLDEN: I am not making any reference to the  
15 particular type of requirements. I am just saying that the  
16 backup concept is still a viable one apparently, and that  
17 neither facility really would need to meet such stringent  
18 habitability requirements if you went to that particular  
19 concept.

20 And second of all, there is no mileage requirement  
21 on the backup system. That is all I wanted to know.

22 Another point which was not --

23 (Laughter.)

24 MR. RAMOS: What kind of mileage were you thinking  
25 about?

1 MR. GOLDEN: About 50 miles.

2 MR. RAMOS: I am sure we would not accept that.

3 MR. MINNERS: You just pointed up a hole. We are  
4 going to have to put some mileage requirement.

5 MR. GOLDEN: We will probably be discussing it  
6 further anyway. That would just more or less be a backup,  
7 but that would be discussed further. But I just wanted to  
8 get a feel for where we stood.

9 Another subject which was not touched upon this  
10 morning but which is very critical, in the EOF concept it  
11 talks about the mobile systems, and it talks about for  
12 communications a backup -- a primary and a backup, which  
13 because they are mobile, they are radiocommunication links.

14 Getting access to the airway use is extremely  
15 difficult just to get a single channel. This implies that  
16 we must get two channels. We could not even get the single  
17 channel. We had to piggyback our communications on top of  
18 our divisions through an override feature -- our divisions  
19 being the people that service the areas and who already have  
20 radiocommunications.

21 Would you elaborate on how a utility could go  
22 about getting these two additional channels for this primary  
23 and backup mobile system?

24 MR. RAMOS: FEMA has a direct line with the FCC on  
25 emergency communications, and we will bring it up in the

1 next Steering Committee meeting we have with FEMA. But --  
2 as something to consider -- but I would suggest that you  
3 contact the FEMA regional office and go through them,  
4 because they can probably get the frequency for you.

5 MR. GOLDEN: I think they already tried. I'm not  
6 positive.

7 MR. RAMOS: There is this --

8 MR. GOLDEN: Why would the need for a backup  
9 system on this particular point --

10 MR. RAMOS: We did not lay down a requirement for  
11 a backup for the mobile. We made the requirement between  
12 the TSC and the EOF, and NRC and EOF or TSC. We did not lay  
13 down a communication requirement.

14 MR. GOLDEN: Let me read two sentences then.  
15 Perhaps you can tell me why they are not linked.

16 MR. RAMOS: What page?

17 MR. GOLDEN: It says, "Mobile communication links  
18 will be necessary for communication with field monitoring  
19 teams." The next sentence, "Reliable primary and backup  
20 means of communication are required."

21 Are you indicating that those two sentences are  
22 not linked? Or I would switch the order. I would put the  
23 backup and primary prior to that sentence and then have them  
24 -- the relationship with the mobiles removed and placed  
25 afterwards.

1 MR. RAMOS: Let me look into that in more detail.

2 MR. GOLDEN: Okay. Possibly it was not intended  
3 to read that way then. Very good. Thank you.

4 MR. MINNERS: Mr. O'Brien of Illinois Power  
5 Company.

6 MR. O'BRIEN: I really have only two comments that  
7 remain after this morning's discussion. The first one deals  
8 with the use of the process computer, and we have discussed  
9 it quite a bit this morning, but I am still quite concerned  
10 about it.

11 The way the NUREG stands it would seem that no  
12 amount of design or planning for an upgrade of an existing  
13 system would let us use the process computer.

14 MR. MINNERS: The way it is written now I think  
15 that is a correct statement.

16 MR. O'BRIEN. And it would seem for future control  
17 rooms like our Unit 2 control room, which we are probably  
18 several years away from starting the design on, we will have  
19 to implement a completely separate computer system even  
20 though we might be able to implement much of what is really  
21 needed in the main control boards. So this is something  
22 that is of quite a bit of concern to us.

23 Specifically in my case we are dealing with a  
24 control room that has six process 4500 Honeywell processors  
25 in it now, and on our process radiation monitoring system, a

1 completely redundant digital system with something like 150  
2 microprocessors.

3 The other point deals with the ECF.

4 MR. MINNERS: That sounds like to me that you have  
5 enough equipment that some of it could be dedicated to the  
6 safety function, and if properly controlled and assuring the  
7 functional integrity and security, that that might be  
8 acceptable.

9 What we need is some words that will state that so  
10 people will understand what is required without having just  
11 a prohibition, a blanket prohibition of process computers.  
12 But we have -- I have not been able to get anybody who knows  
13 anything about computers to write down such statements which  
14 they would be satisfied with.

15 MR. O'BRIEN: As far as the NUREG is concerned.

16 MR. MINNERS: As far as the NUREG -- let me  
17 explain something in this NUREG that I encouraged. When we  
18 got to some of the tough points, and there were quite a few,  
19 and the question came what should we write down, I pointed  
20 out this was a document which was a draft document that was  
21 going to go out for comment, and we would get more comments  
22 and better comments if we took the tougher side of the  
23 alternatives before us rather than the weaker side.

24 If we put down the final -- the weakest position,  
25 people would all say that is great and go along with it. So

1 in some of these things, and I think the process computer  
2 may be an example of that, we took a position in the draft  
3 which probably reflects the most conservative way that we  
4 are looking at it now. And part of the reason of putting it  
5 down that way was to encourage comments.

6 It does not mean that we do not think this is a  
7 way we might go. It is just -- we had several alternatives,  
8 and we thought we would get better comments by putting down  
9 a tougher position, and you might want to recognize that in  
10 making your comments.

11 MR. O'BRIEN: I hope we can get it worked out in  
12 the NUREG.

13 MR. RAMOS: In those comments we are looking for  
14 the rationale of why we should do it in that way.

15 MR. O'BRIEN: My final point deals with the ECF  
16 and the need for the safety parameter display, and perhaps  
17 your staffing requirements will explain that to us a little  
18 bit better. But I have the gut feel that the safety  
19 parameter display is going to be the display that is going  
20 to control the communications or the data link requirements  
21 between the plant and the ECF.

22 What we have looked at is something that is going  
23 to require ten megahertz connection and microwave or  
24 something like that, and we cannot handle it over telephone  
25 circuits. We would like to see -- if we cannot get by with

1 something at a much lower speed, what can be handled in  
2 telephone circuits, if we could.

3 MR. BELTRACCHI: Could you amplify on why you feel  
4 that you need that high a --

5 MR. O'BRIEN: What we were looking at is driving  
6 CRTs and EOF directly from the computers in the plant.

7 MR. BELTRACCHI: I understand.

8 MR. O'BRIEN: We were not looking at putting a  
9 processor in the EOF.

10 Thank you.

11 MR. RAMOS: Let me back up to a question asked  
12 earlier on the ability -- the EOF or backup EOF. In  
13 thinking about what the Commissioners said, if you happen to  
14 be in the primary EOF, wherever it happens to be, and the  
15 decision to evacuate comes up, that flow of traffic or that  
16 flow of data cannot be stopped to allow those people to  
17 evacuate. You have to take that into consideration when you  
18 design a primary and a backup EOF. The data must flow.

19 MR. MASTERS: Which data do you mean?

20 MR. RAMOS: Meteorological, radiological, the data  
21 that is going to the state and locals to control evacuation.

22 MR. BRADLEY: I have a question. I am Ed Bradley,  
23 SMUD.

24 If the decision is made to evacuate the general  
25 population due to a PAG -- exceeding a PAG, does that same

1 criteria -- is that in effect for the workers at the EOF  
2 since they are radiation workers and can accept higher doses  
3 rather than the general population?

4 MR. RAMOS: They are not radiation workers, all of  
5 them. There are going to be state and local people,  
6 newspaper reporters. You're talking about people inside the  
7 EOF.

8 MR. BRADLEY: Yes.

9 MR. RAMOS: The intent is for them not to have to  
10 move, so if you make it habitable with the controlled  
11 ventilation system, it wouldn't have to be --

12 MR. WINNERS: The same dose limits can be put on  
13 the workers in the EOF as the general population. Would you  
14 allow the workers to get a higher dose?

15 MR. RAMOS: Is that your question?

16 MR. BRADLEY: Yes.

17 MR. WINNERS: I think you have to qualify it. I  
18 think in an accident situation people are going to be making  
19 balancing judgments of whether it is better to evacuate or  
20 whether to leave people where they are, and I am not sure --  
21 I don't know what you would do with the general population  
22 in that situation. That is a very difficult situation to  
23 try to predict exactly what you do.

24 With the general psychology now some people are  
25 saying that you should not give the population any dose at



1 all, and of course, that is the ideal. But I think you have  
2 to recognize the possibility, however remote it may be, that  
3 you could have an uncontrolled accident, and in that  
4 situation I do not think -- you may not have -- be able to  
5 limit the doses to the people to the lowest level that you  
6 would like to, and that is the purpose.

7 I think that is just recognizing the extremes of  
8 reality, so I just want to qualify the question. There is a  
9 difference between what you design to and what may actually  
10 happen, and you have to recognize what may actually happen  
11 as well as your design requirements.

12 Okay. Mr. Cowan of WPPSS.

13 MR. COWAN: Again, I won't elaborate on any of the  
14 questions I feel were answered this morning. However, my  
15 company will be submitting detailed comments, either  
16 separately to the request by the Commission for comment, or  
17 through AIF, or perhaps both.

18 The items I would like to chat about briefly are  
19 not questions so much as perhaps statements, the positions  
20 as the way we feel them now.

21 MR. MISNERS: That is encouraging. We would like  
22 to hear what people think as well as questions.

23 MR. COWAN: It is a matter of philosophy perhaps,  
24 but I think it is true to say that what we are dealing with  
25 here is four basic information streams that we are talking

1 about. They flow one of four places. All of those flows  
2 are for information only, and I think that is acknowledged  
3 by everyone.

4           However, I feel, and our position is, that what we  
5 have in front of us, 0696, at this point and others prior to  
6 it have what we call a built-in ratchet in it. You state  
7 that they do not have to be completely designed to l-E or to  
8 seismic one. However, the next sentence says typically are,  
9 but the goal is to do so.

10           And I am sorry, gentlemen, but that is part of the  
11 problem in our business. We never get done. We are always  
12 open-ended. You have heard other folks say the same thing  
13 in different ways.

14           You have defined more in 0696, but you have still  
15 left the door open, and it is still awfully hard, you know,  
16 to get the job done.

17           MR. MINNERS: Do I infer from that that you have a  
18 suggestion that we do not put in those extra sentences and  
19 say that this is it, and that is all we are going to require?

20           MR. COWAN: If you said non-l-E and non-seismic,  
21 we would have been better off, better off for us for certain.

22           Let me go on --

23           MR. MINNERS: Could you give me a page reference  
24 on where we say what you say we said or later?

25           MR. COWAN: I don't have them in front of me. One

1 of my guys can look them up.

2 MR. MINNERS: Later, if you have a chance, would  
3 you point it out to me? I would like to look at that.

4 MR. COWAN: Let me go on. The discussion this  
5 morning, I believe, led me to believe at least that you are  
6 definitely thinking of extra requirements for SPDS as versus  
7 the other three, OBE, for example, added on to this  
8 information stream.

9 MR. MINNERS: We think the SPDS has a higher  
10 safety function than the other things.

11 MR. COWAN: The alternative to get that if we  
12 cannot buy computers is to hard-wire, and if you carry the  
13 ratchet process to the other information flows, we are  
14 hard-wiring to the point of unreasonableness.

15 I don't think it is anybody's intent, and I hope  
16 it is not yours, to do so. We are talking information flow,  
17 not control.

18 I think in the bottom line sense I think -- and  
19 you can put this in the category of trying harder -- but  
20 words lead us into trouble when you may not intend it. I  
21 think C-96, you'd better work harder on it.

22 Finally --

23 MR. MINNERS: You will have some specific examples  
24 or specifics when you have your written comments, I hope.

25 MR. COWAN: Yes. Finally, on the tech spec item,

1 eight hours, we find that -- I guess basically thinking that  
2 is unreasonable since, for example, diesels are a seven-day  
3 tech spec, and they are a safety system. Here we are  
4 talking about an information system with an eight-hour  
5 requirement on it, and I find -- we find that unreasonable.  
6 We find there is no basis for it.

7 MR. MINNERS: Let me discuss that a little bit.  
8 With the diesels you have redundant diesels and you have  
9 offsite power, and it is hard to draw an exact analogy with  
10 the safety parameter display. But do you think the control  
11 board is a backup to that?

12 MR. COWAN: Sure.

13 MR. MINNERS: Okay. And I think we have said that  
14 you don't have to shut down if you are out eight hours. You  
15 just have to show what compensating measures you could take  
16 to compensate for the outage of the safety parameter  
17 display. If you lose all your diesels, you are going to  
18 have to shut down your plant, okay? But if you lose your  
19 safety parameter display, we are not requiring you to shut  
20 down. We are just requiring you to tell us what you are  
21 going to do to bring the level of safety back up to what it  
22 was or near to what it was. So --

23 MR. COWAN: Why eight hours? What is the basis  
24 for eight hours? You didn't say shut down; you said report.

25 MR. MINNERS: Because I think the eight hours is

1 consistent with the reliability criterion that we put down.

2 MR. COWAN: Which has been challenged.

3 MR. MINNERS: If we change the reliability  
4 requirement, we probably should change the tech spec  
5 requirement.

6 MR. COWAN: Okay. Thank you.

7 MR. MINNERS: Mr. Sale of Washington Public Power.

8 MR. SHAH: He just left. He had one comment.

9 MR. MINNERS: Are you Mr. Shah?

10 MR. SHAH: Right. I am Shah.

11 MR. MINNERS: Could I have you use the microphone  
12 so we make sure we get it recorded?

13 MR. SHAH: Could we use multiple rooms for a  
14 technical support center as long as you meet the space  
15 requirement?

16 MR. MINNERS: What?

17 MR. SHAH: Rooms.

18 MR. RAMOS: That opens up the other box that was  
19 opened up earlier about distances away from the site as far  
20 as the EOP is concerned. When you say multiple rooms, do  
21 you mean a group of rooms that are --

22 MR. SHAH: In the same neighborhood, in the same  
23 area, maybe upstairs, downstairs, as long as we provide a  
24 display at all those locations.

25 MR. RAMOS: They probably will be acceptable. We

1 would have to see it as you lay it out.

2 MR. MINNERS: I am not even sure you would have to  
3 have the full display at all locations. You could  
4 distribute the display.

5 MR. RAMOS: Depending on the functions. But if  
6 you tried to move it around several buildings onsite, that  
7 would not be acceptable.

8 MR. SPAH: I just want to reconfirm on SPDS that  
9 the computer, the (Inaudible).

10 MR. BELTRACCHI: We would accept the 99.8 that was  
11 stated by Macro, .002.

12 MR. MINNERS: I guess there is a problem there. I  
13 think we have written down 1 times 10 to the -3, and I am  
14 not quite sure what Leo is saying. He is going to keep it  
15 written as 1 and accept a 2.

16 (Laughter.)

17 MR. BELTRACCHI: Close it up and --

18 MR. MINNERS: I would hope that --

19 VOICE: (Inaudible).

20 MR. MINNERS: Pardon?

21 VOICE: (Inaudible).

22 MR. BELTRACCHI: You are quoting the Macro  
23 report. Technologically you can.

24 MR. MINNERS: But practically you cannot.

25 VOICE: (Inaudible).

1           MR. MINNERS: I think our goal will be that if we  
2 are going to accept 99.8 that we will write it as 99.8. If  
3 the next draft comes out with 99.9, we mean 99.9. I don't  
4 want to give the sense -- the sense is that we are going to  
5 write down one thing and accept another.

6           MR. SHAH: Okay. With this OBE requirement on  
7 SPDS and this kind of unavailability, there is a potential  
8 that we might have to go to a hard wire system. And also,  
9 listening to the people in industry, we are talking like 25  
10 parameters or maybe less. So it might be defeating the  
11 purpose where you want to have more flexibility in your  
12 display. And so I think that the OBE requirements should  
13 seriously be looked into. Otherwise, people might be forced  
14 into a hard wire system and --

15           MR. MINNERS: Let me address that point because I  
16 think it is a good one. I think we have been properly  
17 accused of hindering the use of computers in nuclear power  
18 plants because of our requirements, and people see that the  
19 computers have some futures which from a human factors  
20 standpoint are very good. And we would not like to exclude  
21 computers because of some requirements, so we are  
22 sympathetic to using computers.

23           I think most of the people who are working on the  
24 report envision computers, and hope that we can have both;  
25 that we can have our cake and eat it, too. But if we cannot

1 get the OBE -- we want the OBE, and we want computers, and  
2 maybe there is some way you can suggest that we have some  
3 other additional means -- or I don't know exactly how to  
4 express it -- in which the problem I have expressed about  
5 the OBE could be handled.

6           There was one suggestion that maybe some of the  
7 instruments on the control board would be grouped, and they  
8 are qualified equipment, and during an earthquake we would  
9 use those rather than using the safety parameters.

10           MR. SHAH: Or you could use that to verify.

11           MR. MINNERS: I am not sure that is an acceptable  
12 way. Perhaps someone who had thought about it more could  
13 provide that as a comment.

14           MR. SHAH: Okay. So if we go to that -- my second  
15 part of the same question is if we go to hard wire systems,  
16 then can we use the plant process computer for TSC and EOF?

17           MR. BAMOS: Only if you can show the security --  
18 what we discussed earlier this morning, that the functional  
19 requirements be met without any degradation at all. We have  
20 already discussed in great detail this morning the fact that  
21 some process computers may be capable of meeting all our  
22 goals. If they can and it can be shown that conclusively  
23 and then verified by some means, then we probably would  
24 accept that.

25           MR. SHAH: Okay. That's all.



1           MR. HALL: Along the same line of his question,  
2 you are not placing any restrictions as far as the OBE on  
3 this as far as using the plant process computer for the TSC  
4 and the ECF, if some other means is made to -- whereby the  
5 SPDS is set to your requirement, is that correct?

6           MR. RAMOS: That is correct.

7           MR. HALL: That would include the plant computer,  
8 the process computer, if you had some other means for the  
9 SPDS.

10          MR. MINNERS: No, I don't think it says that. The  
11 objection to the process computer has nothing to do with its  
12 seismic qualification. It is concerned with the security  
13 and integrity of that computer and the information that it  
14 processes.

15          We feel since it has other operational programs in  
16 it that you cannot maintain -- at least the ones we have  
17 seen do not maintain security, and people can go in and  
18 change those other programs and inadvertently change these  
19 safety functions.

20          That is our concern. It has nothing to do with  
21 seismic qualifications.

22          MR. HALL: Your statement in here only applies to  
23 the SPDS. If we can show that the computer is available,  
24 just the availability of the computer --

25          MR. MINNERS: Correct.

1           MR. RAMOS: If you can meet the unavailability  
2 factors as defined and you can demonstrate that because you  
3 have a security system, for example, that monitors everybody  
4 going in and out that it does not overload it to the point  
5 that if we had an emergency that we could not use it. That  
6 is the kind of concern that we are worried about.

7           You are going to have to demonstrate in your  
8 design, in the process computer whatever design you have can  
9 meet the needs of the EOF and the TSC functionally.

10          MR. MINNERS: Mr. Compton of Washington Public  
11 Power.

12          MR. COMPTON: I have some questions on some things  
13 that we did not get into this morning. One of the things  
14 that you have for the SPDS is for early recognition of  
15 abnormal values in data trends. Would you explain further  
16 what this means?

17          Does this mean that we are to do limit checking  
18 and alarming or leave that out? We have alarms going off  
19 already. We don't want more confusing the operator.

20          MR. BELTRACCHI: At one time alarming was in  
21 there. However, you don't see it there now. I would expect  
22 that in terms of detection it would be the use of such  
23 things as meter coding or the equivalent of meter coding.  
24 For example, if your temperature rates are going positive,  
25 you could locate such things as trends of temperatures. If

1 the display were to contain several temperatures or if you  
2 were to integrate your display such that it would contain  
3 several temperatures and one was deviating from the normal  
4 trend, I mean that certainly would be one way of doing it.

5 Other aspects might be such things as, oh, the  
6 normal -- say, a process limit achieving saturation on the  
7 primary coolant, and hence, the display such that the  
8 operator would recognize that.

9 VOICE: (Inaudible).

10 MR. BELTRACCHI: Meter coding, if you take like a  
11 circular dial or anything like that you might have for a  
12 hard wired approach, you might have something like a green  
13 band. The EPRI reports dealt with this considerably on the  
14 review of the control rooms.

15 Normal bands, as well as abnormal bands, they  
16 would be an aid to the operator to recognize when he is in  
17 an abnormal condition.

18 Does that help you any?

19 MR. COMPTON: Yes. That gets into my second  
20 question: what you mean in 0696 when you say "pattern and  
21 coding techniques to aid the operator." This is what you  
22 are talking about, things like that.

23 MR. BELTRACCHI: Yes.

24 MR. COMPTON: Changing the CRT is a thing like  
25 that.

1 MR. BELTRACCHI: That would be one way, yes.

2 MR. COMPTON: Okay. Okay. In the document also  
3 you use the term that we should have time history displays  
4 and trend displays. Would you explain the difference?

5 MR. BELTRACCHI: I guess we are really giving you  
6 an option -- okay, time history and trends would be the same  
7 in that particular case.

8 MR. MINNERS: I envision that time history -- a  
9 strip chart would give you time history, okay. But you  
10 might have a meter which just showed whether the trend was  
11 positive or negative. It just would give you the  
12 instantaneous derivative without telling you what had  
13 happened in the past.

14 MR. BELTRACCHI: I guess I would consider that  
15 rate.

16 (Laughter.)

17 MR. COMPTON: That's why they all appear in  
18 different places.

19 MR. MINNERS: What do you mean?

20 MR. BELTRACCHI: Well, no. At what time I had a  
21 version of this that had both rate/trend.

22 MR. MINNERS: Rate is just a quantification of  
23 trend. Rate says how fast -- you are going in a certain  
24 direction and at a certain rate. You know what the  
25 quantification is. Trend is just that you are on -- you are

1 going in a certain direction, but it does not say how fast  
2 you are going there.

3           It says that the temperature is decreasing, but I  
4 cannot tell you it is going at so many degrees per minute or  
5 whatever it might be.

6           MR. BELTRACCHI: Let me also state that relative  
7 to the control room reviews that are coming up, I strongly  
8 feel that it is really that information while the operator  
9 is in a transient -- while the plant is in a transient, that  
10 he really has very little of the rate and/or trend  
11 information displayed to him, so that he can tell whether  
12 the plant has been stabilized.

13           And it is that type of information that I think is  
14 going to -- they could use a good review in order to assess  
15 what aspects of those -- what parameters should really be  
16 displayed to the operator so he can make that assessment  
17 during a transient.

18           MR. COMPTON: Okay. Another item that was talked  
19 about some this morning is the SPDS and the OBE requirements  
20 on that. If we have something that is a partial loss of  
21 function -- let's say a printer that will not be able to  
22 print out a complete trend, but we still have a display --

23           MR. BELTRACCHI: You have not lost function then.  
24 I would consider that to be the interpretation.

25           MR. COMPTON: Okay. Very good.

1           In regard to the unavailability that is being put  
2 here and what you had this morning on that report, was that  
3 for a single channel computer, or were your numbers for --

4           MR. BELTRACCHI: I did not attempt to make that  
5 design -- the unavailability was for the safety parameter  
6 display system.

7           MR. COMPTON: But now, like the report you  
8 referenced this morning that said anything greater than 99.8  
9 percent availability was very --

10          MR. BELTRACCHI: Very costly.

11          MR. COMPTON: Is that 99.8 achievable with single,  
12 or is that redundant?

13          MR. BELTRACCHI: I would suspect portions would be  
14 redundant. I don't think you could expect to achieve that  
15 -- I can't remember whether the statement was made very  
16 clearly in the Macro report, but they stated that you  
17 probably would not achieve 99.8 with a monolithic type  
18 design. You know, portions would have to be --

19          MR. COMPTON: I don't believe that is possible  
20 with a single system.

21          MR. BELTRACCHI: A monolithic design, that would  
22 probably be very difficult to achieve.

23          MR. COMPTON: Okay. So I believe that you --  
24 instead of just coming out with this 0696 and applying it  
25 across the board with those kind of availabilities, I see

1 what you are trying to do, infuse some of the aerospace and  
2 military requirements and reliability -- unavailability, and  
3 you should have a plan for infusing it in stages rather than  
4 trying to apply it across the board.

5 MR. BELTRACCHI: And the reason why that number is  
6 stated is it would have been very easy to say Class 1-E  
7 throughout, but in recognition of the human factors and the  
8 interface, we recognize there would have to be some other  
9 approach taken. And in order to take another approach you  
10 are going to have to draw some sort of criteria and  
11 guidelines.

12 Now, in safety systems you look at 10 to the -4 in  
13 terms of unavailability, and since this is a function that  
14 is important to safety, we felt that 10 to the -3 would be  
15 an appropriate goal. And I think I stated a band of  
16 acceptance criteria as unofficial, even though it is not in  
17 writing because I have only seen the Macro report this week.

18 MR. COMPTON: Okay, but -- you are still trying to  
19 -- the power industry has been one that has been going on.  
20 We have a lot of nuclear power plants at different stages  
21 and ages. And all of a sudden you are just going to infuse  
22 this whole thing right in there and --

23 MR. MINNERS: I thought we were staging it,  
24 because we are only requiring one little thing to have  
25 reliability requirements. We are not applying reliability

1 to the whole plant.

2 Do you think the stage is too big, we should take  
3 a smaller bite?

4 MR. COMPTON: In terms of the time frame that it  
5 is going to take to implement the systems. You have not  
6 looked at the time frame that it takes to implement a large  
7 data system. It takes 32 months is what a vendor is going  
8 to quote you on a training simulator. We have less than 32  
9 months for an operating plant, and a training simulator does  
10 not have to meet that. Anything that is going out with V&V  
11 has a longer schedule on it than that.

12 MR. MINNERS: Is that what you mean by stages?  
13 You don't have enough time?

14 MR. COMPTON: Right. And then you are --

15 MR. MINNERS: Okay. I understand. I think I  
16 understand your comment then.

17 MR. BELTRACCHI: To some extent your comments are  
18 also reflected in the Macro report in terms of the needs --  
19 the needs for the industry to have additional time to  
20 develop and install.

21 MR. MINNERS: Let me ask you a question. One of  
22 the previous gentlemen who stood up thought that the safety  
23 parameter display was going to take 25 parameters. My  
24 conception was that it was going to take a half a dozen or  
25 at the most a dozen.



1 MR. SHAH: All I used, the man from Point Beach,  
2 he said four loops. That is 25.

3 MR. MINNERS: It seems like a lot of parameters  
4 for a concise display.

5 VOICE: Well, NSAC came up with a list of, I  
6 think, 15 or 16, and then if you say well, we have -- and in  
7 that 15 or 16 they had hot loop temperature, cold loop  
8 temperature. So if you recognize you have a four loop  
9 plant, and if you are going to display each loop separately,  
10 then you have to get up to that number. If you say you are  
11 also going to display all sensors of a given parameter, like  
12 pressurizer level, you could probably end up with even more,  
13 maybe 40 or so.

14 MR. BELTRACCHI: I think relative to the NSAC list  
15 there were probably only 5 or 6 parameters associated with  
16 any particular safety function, and I think that is an  
17 important point to make in terms of the display. And it  
18 gets around to the items of being able to -- for the  
19 operator to evaluate that function and evaluate it quickly.

20 I believe a display could be put together that it  
21 would allow him to do that.

22 MR. MINNERS: Mr. Schworer of SNUPPS.

23 MR. SCHWOERER: I have four comments here. Some  
24 of them really follow from this morning.

25 We are also concerned about the prohibition

1 against use of the process computer. In SNUPPS plants,  
2 which you know are later plants, we have a reliable state of  
3 the art process computer that has dual processors, dual  
4 memories fail-over feature, and it is as good a computer as  
5 what we could go out and buy today for the tech support  
6 center.

7 I would suggest the way you handle this thing in  
8 NUREG-0694 is simply to delete the prohibition against use  
9 of these process computers, and that is on about three  
10 pages, pages 4, 13, and 19; and let the NUREG document  
11 simply state the reliability goals.

12 That is comment one.

13 MR. MINNERS: I do not think that reliability  
14 goals really address those kinds of questions of security.  
15 I mean, you can draw the analogy to sabotage in a plant. I  
16 mean, what reliability goals you put on your plant does not  
17 say anything about whether the plant is secure against  
18 sabotage; and I do not see how reliability goals would tell  
19 a designer that his software has to have certain security  
20 features to it.

21 MR. SCHWOERER: I am not a computer man myself,  
22 but it seems to me you could expand the conventional  
23 reliability thing. That is the second thing. You have  
24 unavailability, and I am not sure how it will be measured.  
25 Let's say the unavailability that you agree to is .002. Is

1 that a tenth of an hour out of 100, 2 hours out of 1000, 17  
2 hours a year?

3 MR. BELTRACCHI: Seventeen hours out of a year.

4 MR. SCHWOERER: I think for surveillance purposes  
5 it is going to be critical to define how you measure that,  
6 and then it would seem to me that you could fold into this  
7 total reliability number the threat to reliability, if you  
8 will, of having a programmer go in and monkey around with  
9 the programs in a computer.

10 In our security computer, for example, we are  
11 doing things to prevent just that kind of thing.

12 MR. BELTRACCHI: Those were the very concerns why  
13 it was stated other than the process computer, okay. And  
14 maybe those were the underlying reasons behind it, and we  
15 should have listed those instead of saying not use the  
16 process computer.

17 MR. SCHWOERER: We really would rather see you  
18 just state the goals.

19 The second one, we are also bothered about this  
20 OBE requirement for the SPDS, and I think the real concern  
21 here is that we see a tradeoff here between a design to meet  
22 an OBE and a design that has the maximum capability,  
23 flexibility and value to the operator.

24 I guess our feeling is that the SPDS is something  
25 that is going to evolve over some years as people get

1 experience with it.

2           We also feel that ultimately -- we are concerned  
3 that the number of parameters that NSAC has defined or some  
4 subset of those is not necessarily all the information that  
5 could go into an SPDS. For example, you could go through  
6 the emergency procedures that have been developed, look at  
7 the things that the operator has to do. He has to verify  
8 that reactor trip as occurred, turbine trip has occurred,  
9 that safety injection has occurred, and all these things.

10           It seems to us that with a flexible computer-based  
11 SPDS, this additional information could come in. And so  
12 whoever is looking at this thing could not only assess that  
13 yes, an accident is happening, but he could assess whether  
14 the plant is responding the way it should respond to the  
15 accident.

16           He could also differentiate between, let's say, a  
17 LOCA and a steam generator tube rupture. But I think the  
18 technology to develop this kind of a display is going to  
19 take quite a while to develop. It seems to me that it ought  
20 to be checked out on a simulator and this sort of thing.

21           It seems to me if we go with a hard OBE  
22 requirement, we are very likely to lose some of the  
23 flexibility and hence, some of the ultimate capability.

24           I further say that as was pointed out this  
25 morning, the control board is designed to an SSE. That is

1 the primary thing that an operator is trained to use. And  
2 we feel that gives adequate assurance that in case of an OBE  
3 we are not going to have a disaster.

4 MR. BELTRACCHI: I would like to address those  
5 comments. In terms of function, the safety parameter  
6 display system was basically, again, an aid for detection.  
7 I would agree that if you were to consider expanding it into  
8 diagnostics and to have an aid to assist the operator to  
9 diagnose, then it becomes a bigger system.

10 But I think we have to be extremely careful to  
11 keep it dedicated to the extent of detection. Otherwise, we  
12 can very easily get back to the situation where we have on  
13 the control board today in terms of the amount of  
14 information and information overload -- I think it is  
15 important to keep the functions separated. And to some  
16 extent the EPRI work -- there is EPRI work going on in  
17 various programs which I'm sure you are familiar with.

18 MR. SCHWOERER: There is a difference of opinion  
19 on that one.

20 The last point has to do with the distance between  
21 the control room and the technical support center. Your two  
22 minute guideline is a problem for us in the SNUPPS design,  
23 in part because we have one two-unit site.

24 I guess our feeling is that the time -- well, the  
25 distance here ought to be flexible, and there ought to be

1 some allowance for trading off the distance versus the  
2 amount of data and quality of data displayed in the tech  
3 support center.

4 We do not feel that from the standpoint of the  
5 operators of the plant that it is desirable to have  
6 face-to-face contact. We just do not perceive the need to  
7 have this face-to-face contact between the people that we  
8 will assign to the technical support center and the ones we  
9 will have in the control room.

10 You referred to Three Mile Island as the basis for  
11 feeling that face-to-face contact was necessary, and I would  
12 submit that Three Mile Island may not be relevant, in that  
13 Three Mile Island did not have the kind of a tech support  
14 center that we are going to have.

15 So I don't know. I guess this leads me to a final  
16 question, and I really wonder if the two minute requirement  
17 is based more on the desire of the NRC to have an NRC man be  
18 able to run back and forth between the two areas rather than  
19 from a standpoint of plant operability.

20 MR. RAMOS: The desire of the NRC is to have the  
21 TSC next to the control room. We backed off to initially  
22 five minutes and two minutes.

23 MR. SCHWOERER: I don't understand why. It seems  
24 to me that is kind of an archaic notion, that in this day  
25 and age of information transfer and so on why must they be

1 so close together?

2 MR. MINNERS: We discussed that in the last  
3 meeting. I guess the way I expressed it then is the only  
4 way I know how. It is a difficult thing to quantify,  
5 face-to-face contact, and it is your perception of how human  
6 communication goes. But my experience is that there is a  
7 big difference between telephone and electronic  
8 communication and face-to-face.

9 If I thought other means of communication were  
10 satisfactory, I would not be here. The reason I am here is  
11 because I think face-to-face communication is necessary to  
12 get the ideas across. These are not simple concepts, and  
13 during an accident confusion will be very easy.

14 MR. SCHWOERER: It could also be that face-to-face  
15 contact could only add to the confusion. It is hard to  
16 say. But it does seem to us that there ought to be a  
17 capability for tradeoff here. For example, we are kind of  
18 going down the road of trying to get the entire computer  
19 data base available into the tech support center so that the  
20 man in the technical support center can call up anything  
21 that can be called up from the control room.

22 I think if you a very complete set of information  
23 in the tech support center, as compared to some, maybe a  
24 minimum list which would be Reg Guide 1.97, it would seem to  
25 me there is less need for this kind of close communication.

1 And I think your Reg Guide or your NUREG should recognize  
2 that.

3 MR. MINNERS: Your comment on the NRC wanting to  
4 go back and forth between the TSC and the control room is  
5 not something I have ever heard or sensed anybody say in the  
6 Commission. We are going to have people in both places, and  
7 I do not even see -- I don't see much need for the NRC to be  
8 running back and forth.

9 The only thing I've heard is this face-to-face  
10 communication between the people, which is basically the  
11 utility people who are going to have to deal with the  
12 accident, and that is our concern; and we really aren't  
13 thinking of the NRC.

14 MR. SCHWOERER: Thank you.

15 MR. MINNERS: Mr. Roller of Portland General  
16 Electric.

17 MR. ROLLER: My question has been answered.

18 MR. MINNERS: Okay. Mr. Cardinale of Sargent  
19 Lundy. Do I have your name right?

20 MR. CARDINALE: I am Dan Cardinale of Sargent and  
21 Lundy Engineers. I have several questions, some of which  
22 have been addressed in varying degrees up until this point,  
23 so I will try to be brief.

24 The first problem is finding questions.

25 (Laughter.)



1           These are more in the line of comments rather than  
2 questions.

3           MR. MINNERS: Fine.

4           MR. CARDINALE: To whip the horse of  
5 unavailability once more, I am still confused by the  
6 requirement that a piece of equipment be described as  
7 meeting an unavailability of .001 or .002 or whatever the  
8 number is that we wind up with, because we have not talked  
9 yet about how that will be measured and whether that will be  
10 a precondition of operation, or whether it will be an  
11 unavailability measured after operation over a period of  
12 time.

13           And the way things go I can see -- I can envision  
14 that this will be defined as a precondition of operation for  
15 a demonstration that an unavailability of .001 or .002 be  
16 applied to, say, a computer purchase for a safety parameter  
17 display system.

18           And I would suggest to you that it would be  
19 extremely difficult to achieve that kind of a  
20 demonstration. It probably would make the problems with  
21 meeting IEEE 323 qualifications seem easy. And over the  
22 period of time we are talking about, I would describe the  
23 problem of demonstrating an unavailability of that magnitude  
24 as virtually impossible.

25           The unavailability programs that were developed

1 for the space program were developed over periods of many,  
2 many years to the point they are at now; and there are many  
3 levels -- many levels of unavailability being considered.  
4 There is component testing, component life testing, and then  
5 there is fault tree analysis, and then there is systems  
6 testing, and you have not addressed those questions at all  
7 as to what level this unavailability is going to be imposed  
8 upon the design of the equipment that you are saying must  
9 meet certain levels of unavailability.

10           MR. MINNERS: That is our problem. What we want  
11 to do is two things: to tell the designer, first of all,  
12 what constitutes design adequacy and environmental  
13 qualification, those kinds of things; and we do that by  
14 saying OPE and those kinds of things. But we still have to  
15 deal with this random failure rate. We previously did it  
16 with single failures, which is not too applicable to  
17 computers, and we have not thought of anything better than  
18 what we specified in 0696. And we recognize it has  
19 problems, and it is going to be one of the first  
20 applications in a regulation of something like this.  
21 Alternatives would be welcome.

22           MR. CARDINALE: Sure. I would suggest that you  
23 should adjust your thinking in terms of achieving this  
24 unavailability as a goal and think about developing a  
25 long-range program that will take many years to get all the

1 pieces in place, because you are not talking about a single  
2 piece of equipment. You are talking about an entire  
3 industry developing the technology to build a complicated  
4 system, computer-based data transmission system, and coming  
5 up with overall unavailability numbers.

6 I would submit that you just cannot do this in the  
7 time frame that you are considering. That is all I wanted  
8 to say about that point.

9 With respect to the distance, again another horse  
10 that has been whipped, the distance between the technical  
11 support center and the main control room, the original  
12 version of the functional requirements of the emergency  
13 response facilities had a 50-yard limitation between the  
14 technical support center and the main control room. And at  
15 the June 19th meeting with the AIF there was some comment on  
16 that, and the AIF went away, and the new version came out,  
17 and the 50 yards was changed to 2 minutes.

18 I do not see too much of a difference in those two  
19 definitions of proximity. I would suggest in this case that  
20 the requirements of what we are trying to achieve be thought  
21 about a little bit more.

22 The comments have been made, which I support, that  
23 there does not seem to be a legitimate need to have  
24 face-to-face communication between the occupants of the TSC  
25 and the occupants of the main control room. But I would

1 like to bring up another tangential idea to this.

2           We are talking about having 28 people in the  
3 technical support center. We have not talked really about a  
4 management plan, or at least I am not sure that we have  
5 talked about it, about how these 28 people will be  
6 coordinated, or chains of command, or whether that will be  
7 an NRC-imposed decision, or whether it will be part of a  
8 utility's emergency response plan.

9           It would seem to me that with 28 people or even  
10 with 15 people in a technical support center, you would not  
11 necessarily want to have these 15 people or 28 people all  
12 running to have face-to-face communication with the main  
13 control room. As a matter of fact --

14           MR. MINNERS: Let me interrupt you before we  
15 proceed.

16           MR. CARDINALE: I am very close to the end of the  
17 thought. It would seem to me that there would be basically  
18 a chain of command within the technical support center with  
19 people who were doing various monitoring, monitoring various  
20 displays; I imagine multiple operators, maybe one -- one to  
21 six perhaps leading up to a central technical support center  
22 coordinator or main operator, with the rest of the people  
23 doing analysis functions basically out of the way in the  
24 back of the room. And any decisions that would have to be  
25 made and transmitted to the operators in the main control

1 room should be made through a designated person, perhaps the  
2 lead coordinator himself or perhaps through a specially  
3 designated person.

4           Now, that kind of communication I would envision  
5 going on between, say, this person that is designated and  
6 the senior reactor operator, not even a reactor operator. I  
7 am talking about the senior reactor operator. So I don't  
8 see a lot of confusion resulting from the lack of  
9 face-to-face communication.

10           I think a telephone line, or closed circuit cable  
11 TV, or something like that would be more than adequate,  
12 which would allow you to put this TSC out almost any place  
13 on the site boundary -- within the site boundary.

14           MR. MINNERS: This document does not address the  
15 whole emergency response problem, and we probably have not  
16 got it all documented. There obviously has to be an  
17 emergency plan or some other document which says who is  
18 going to do what. Okay.

19           And all this document is trying to do is to  
20 provide the facilities for those people. Maybe it is a fair  
21 criticism to say you cannot design the facilities until you  
22 know what the people are going to do, but that is a chicken  
23 and egg syndrome, and I don't know which one comes first.

24           We are trying to take bite-size pieces of the  
25 problem and solve them. It has to be agreed there are other

1 places which say what the plant's emergency organization is  
2 going to be. As far as this face-to-face communication,  
3 there is a requirement now; one of the short-term  
4 requirements that was put out is that there be a procedure  
5 for limiting access to the control room, and that would  
6 apply to the TSC.

7           The people in the TSC who have blue badges can go  
8 into the control room. The people in the TSC who don't have  
9 blue badges cannot go into the control room. That is the  
10 kind of thing I would conceive of being developed and  
11 implemented in plants.

12           And, yes, we endorse having a strong chain of  
13 command, but I guess we are still saying -- what we are  
14 still staying is the chain of command needs face-to-face  
15 contact, and that is where we have a difference in  
16 philosophy which I am not sure that either of us can be --  
17 can bring any facts to convince the other.

18           MR. CARDINALE: Okay. We will let that go. I  
19 will let my comments stand then.

20           MR. MINNERS: I welcome your comment. I am  
21 interested to hear it. I am just trying to explain some of  
22 the other facets.

23           MR. CARDINALE: Another point, sort of a  
24 motherhood and apple pie type of comment, in that operations  
25 people or people of certain responsibilities need to have

1 the data presented to them to perform their functions  
2 obviously. I think a similar comment is we don't want to  
3 present any data to them which we do not need, because it  
4 tends to muddy the waters.

5 I would just like to pass the comment that I do  
6 not see that the people in the main control room who are  
7 responsible for operating the plant, protecting the plant,  
8 monitoring the boundaries of radiation, and monitoring the  
9 release points for radiation have to know what the radiation  
10 dose is half a mile or a mile outside the plant.

11 Once the radiation has gotten to that point they  
12 really have no control over it at all. And to require  
13 offsite radiation information, which is part of the 1.97  
14 data base, in the main control room I do not feel is doing a  
15 service to the operator or the safe operation of the plant.

16 Similarly, I don't feel that providing a wealth of  
17 in-plant data to the people in the emergency operation  
18 facility will do them any good or help them do their job any  
19 better either.

20 MR. WINNERS: There is a fine point there I would  
21 like to explain. I agree with you that you should not  
22 continuously present the people information which may  
23 confuse them and is unnecessary to their function; but I  
24 also don't want to be in the position of not letting people  
25 go and get information which they think they may need, so

1 the way we stated it is it should be available.

2 Now, what is presented and displayed continuously  
3 should be that information which is required for the  
4 function of whatever particular element you are talking  
5 about.

6 What we also think is almost all of the  
7 information should be made available to almost everyone  
8 because it is hard to think of beforehand what information a  
9 person might want in an accident. If I have some guy who  
10 cannot prevent the accident because he cannot get access to  
11 data, I think that is bad, and it does not sound to me like  
12 a terrible requirement to make the data available.

13 Now, to have it displayed all the time, that is a  
14 different problem but there is a distinction between  
15 display and availability.

16 MR. CARDINALE: I would agree with that. I don't  
17 see any -- perhaps you have a greater vision than I in this  
18 area -- but I don't see any information in which the  
19 operator would want to know what is downwind dispersion was  
20 outside of the plant boundaries.

21 I think we are basically diluting the operator's  
22 function where he should be concerned with protecting the  
23 plant, what is left of it, with radiological control  
24 practices outside the plant boundaries. And the purpose of  
25 that -- the purpose of that is that you have to, if you are



1 going to present this data and make it available to the  
2 operator -- you are going to have to have a greater degree  
3 of prewired on-line radiation monitoring systems outside the  
4 plant boundary, which could be handled by means of portable  
5 -- portable means, or techniques or something like that.

6 MR. MINNERS: As far as having radiation data  
7 presented to the operator, if all of these facilities are  
8 fully manned, I would agree with you that he does not have  
9 to know that, but there is going to be an initial period in  
10 which the control room is the only place that is going to be  
11 able to manage the whole accident, including offsite  
12 response.

13 So if you have something that happens, and I may  
14 exaggerate like I like to -- happen in five minutes, and you  
15 are going to get offsite doses, the control room is the only  
16 place that can do that function.

17 MR. CARDINALE: If the accident happens and  
18 develops that rapidly, I would suggest to you that he would  
19 have his hands full trying to look at the core and protect  
20 the core without looking at the offsite radiation.

21 MR. MINNERS: But somebody has to protect the  
22 public in that situation, and how does that get done? It  
23 may not be a reactor accident.

24 MR. CARDINALE: Well, I think we have thrown that  
25 one --

1           MR. MINNERS: The operator may not have to do  
2 anything at all. His system may be perfectly safe. He just  
3 has spilled some stuff on the floor, and he has this big  
4 puff going out over the fields, and he has to do something  
5 about that.

6           And so maybe I do have a different vision than you  
7 do, but I think you can conceive of situations in which the  
8 operator is the only person who can direct the offsite  
9 response and needs some information.

10          MR. CARDINALE: He would know that from monitoring  
11 his discharge points. He would know that that is going on.

12          I am concerned about a proliferation of radiation  
13 monitoring equipment out in the boundaries, outside the  
14 plant boundary itself.

15          MR. MINNERS: If we had these nice computer  
16 displays, which hopefully we will not prohibit, all he has  
17 to do -- it is not that big a deal. He just presses the  
18 right button, and the radiation measurements come up on the  
19 screen, so you know --

20          MR. CARDINALE: If they are available.

21          MR. MINNERS: If they are available. I don't  
22 think that is a big confusion to the operator. Maybe if we  
23 start hard wiring things we are going to have human factors  
24 problems.

25          MR. COMPTON: This morning I thought I heard you

1 say (Inaudible) data set for SPDS can be less than the full  
2 set for 1.97, and it only has to be that to determine the  
3 safety of the plant.

4 MR. MINNERS: That is for the SPDS, but I believe--

5 MR. COMPTON: You are talking about operators, so--

6 MR. MINNERS: I think all of the information in  
7 Reg Guide 1.97 must be displayed in the control room. That  
8 is what the Reg Guide said. That is right.

9 MR. COMPTON: That is a different issue.

10 VOICE: (Inaudible).

11 MR. MINNERS: Am I defending it? I will try. I  
12 will take on anything.

13 (Laughter.)

14 MR. COMPTON: (Inaudible).

15 MR. MINNERS: The concern was -- it does not have  
16 to be an SPDS, but he was talking about Reg Guide 1.97.

17 MR. CARDINALE: I was, that is right. It was a  
18 separate topic.

19 MR. MINNERS: You have made that clear.

20 MR. CARDINALE: The last comment I had was --  
21 well, it is first a question. Am I correct in assuming that  
22 the present concept of the NDL is that it is a real time  
23 data transmission system?

24 MR. BELTRACCHI: Let me address that. Real time  
25 to the extent that we see it one second later in the

1 operations center in Bethesda after, say, the real time  
2 occurred in the plant. The answer to that question is no.

3 Real time, I would say, the true definition of  
4 real time, the answer to that is no, and I would say that it  
5 is probably more like on the order of five minutes from the  
6 time of the reading to the time it should be in Bethesda,  
7 okay? Does that pretty much answer your question? At least  
8 that is what our thinking was, and we haven't really gotten  
9 it all down in writing.

10 MR. CARDINALE: The significance of my question is  
11 that I see little justification for providing real time or  
12 near real time data transmission to Bethesda. We are  
13 talking about a certain number of points at the present time.

14 By putting in a real time data transmission  
15 system, it would impose restraints upon a system design that  
16 would be very difficult to expand, whereas if you wanted to  
17 expand the system for more data, like a bulk data storage  
18 transmission type of thing, that might give you data 15  
19 minutes after it happened or a half an hour after it  
20 happened. But it probably would serve your purposes just as  
21 well and cost less in terms of total equipment and also have  
22 greater flexibility.

23 MR. BELTRACCHI: We ran into the very same issues  
24 when we conducted a feasibility study of this.

25 MR. CARDINALE: That's all I have.

1 coolant system integrity, and that parameter went out, I  
2 would say that the function went out.

3 MR. HALL: If we only had the one, that would  
4 preclude the plant as well as the rest of them, too.

5 MR. MINNERS: I mean in the TSC or the SPDS, you  
6 might have it in the control room.

7 MR. HALL: There was some question on our part  
8 concerning the eight-hour reporting time, especially for  
9 operational and criteria for operability based on your  
10 recently issued tech specs for accident monitoring systems.  
11 You give us up to as much as seven days to repair failed  
12 instruments in that area.

13 MR. RAMOS: That is just time to repair. We are  
14 telling you when you have to make an LER, you have to make a  
15 notification if the system is down. If it is down for eight  
16 hours or you anticipate it will be done for more than eight  
17 hours, then you report it; then you report what compensatory  
18 measures you are going to take during the time you need to  
19 repair it.

20 MR. HALL: And this gets back to a particular  
21 instrument that may be on this list for accident  
22 monitoring. You give us three days or seven days in the  
23 case of only one failed instrument.

24 MR. RAMOS: We did not specify length of time to  
25 repair it.

1 MR. MINNERS: Thank you.

2 Mr. Hall of Consumers Power.

3 MR. HALL: Warren Hall, Consumers Power Company.

4 I won't beat the dead horse of the computer and the  
5 unavailability again. I think the previous two or three  
6 gentlemen have pretty well expressed our feelings on this,  
7 and we feel pretty much basically the same way. So I will  
8 pass on that one.

9 I do have some questions, though. You stated  
10 earlier -- there was some question earlier about the  
11 operational criteria for these various centers concerning  
12 tech specs; and you stated that you did not think we would  
13 like you to define operability for us. So I am going to ask  
14 a question that maybe would define operability.

15 Do you mean operability in the sense that one  
16 sensor that feeds the system that feeds these areas goes  
17 out, or do you mean when the total system goes out?

18 MR. RAMOS: When the function goes out. If you  
19 have enough parameters that do not allow you to meet the  
20 functional criteria, then the system is out. It would be  
21 out if you could not -- did not have enough parameters to do  
22 your trending and do your analysis to support the control  
23 room. Okay. Well, I --

24 MR. MINNERS: If you had only one parameter, which  
25 I do not think would be the case, which indicated reactor

1 MR. HALL: We just have to tell you that it is  
2 down and what we are going to do.

3 MR. RAMOS: And what you are going to do to ensure  
4 that you can meet the functions of the TSC, ECF, or whatever  
5 is out.

6 MR. MINNERS: It is a very mild tech spec  
7 requirement. I think maybe that is what is bothering you.  
8 You don't believe we would give you such an easy one.

9 (Laughter.)

10 MR. HALL: That is not really the problem.

11 (Laughter.)

12 I was just wondering what to do in the meantime.

13 MR. RAMOS: If the ECF were out, you might want to  
14 bring in more people.

15 MR. HALL: That gets back to the main concern for  
16 the SPDS in the first place, the dispersion of information  
17 in the control room; so if it were out, you may want to  
18 augment your staff.

19 Okay. You made a statement that the TSC will  
20 function as the primary information source to the ECF and to  
21 the NRC for plant operations. I guess I don't quite --

22 MR. MINNERS: I did not hear the first part.

23 MR. HALL: The TSC will function as the primary  
24 information source to the ECF and to the NRC for plant  
25 operations.

1           MR. RAMOS: I don't believe I said that. That is  
2 not the function of the TSC.

3           MR. HALL: It is in your Reg Guide.

4           (Laughter.)

5           MR. MINNERS: What page?

6           MR. HALL: Page 9, second paragraph, next to the  
7 last sentence.

8           MR. RAMOS: Okay, okay. That is the primary  
9 information source for plant operation; that is, for the  
10 person in charge in the TSC will coordinate with the person  
11 in charge of the EOF and discuss what the problems are as  
12 far as plant operation is concerned and also with the NRC.

13           MR. MINNERS: I think you narrowly define it as  
14 data and not information.

15           MR. HALL: I just read the statement.

16           MR. MINNERS: We must have heard you wrong. Go  
17 ahead.

18           MR. HALL: I just read the statement and wanted  
19 some clarification as to what the statement meant.

20           MR. MINNERS: We think we've got it straight.  
21 Keep going.

22           (Laughter.)

23           MR. HALL: Would you clarify so that when you do  
24 this again others will know? Before I came we had about six  
25 or eight people say ask them what they are talking about



1 here.

2 MR. MINNERS: Is that your question?

3 MR. HALL: You have answered my question.

4 The location of the tech support center, again I  
5 received earlier this week a kind of critique from the ACRS  
6 meeting that was held in July, I believe, when this was  
7 discussed, and the two minute time limit was also stated  
8 there. But somehow in the summary of NUREG-0696 -- of this  
9 NUREG discussion, there they indicated that there was an  
10 approximately 600-foot distance associated with this two  
11 minute walking distance. And I just wondered what validity  
12 there was to that statement.

13 MR. RAMOS: I don't think we have ever specified  
14 the distance as being 600 feet. I know there was some  
15 discussion among some of the ACRS engineers saying that two  
16 minutes roughly was 600 feet, but I don't recall it ever  
17 being --

18 MR. HALL: There is no validity to that statement  
19 then. Would you entertain any validity to that statement?

20 MR. MINNERS: We originally had a distance in, and  
21 we took it out. You said the proper criterion is time, and  
22 we put time in.

23 MR. HALL: I saw the distance statement and  
24 wondered if perhaps there was any validity to it.

25 Something that I have not heard addressed yet

1 today was raised in our minds when we reviewed this, and it  
2 has to do with radiological monitoring in the tech support  
3 center and/or the EOF.

4 We are in agreement that radiation monitoring is a  
5 necessity in the TSC, it being onsite, and the requirements  
6 for habitability and so forth; but we have a feeling that  
7 perhaps the permanent radiation monitoring for items such as  
8 particulate matter and iodines are not going to be  
9 sufficient; that we would prefer to see something on the  
10 order of a portable radiation monitor being brought into the  
11 room. We could take samples, take them to the lab, and get  
12 a better assurance that this is the case.

13 When we cite TMI, gain which we don't like to do,  
14 where they had an erroneous reading on a permanent monitor,  
15 this --

16 MR. MINNERS: This must be a health physicist  
17 talking to a non-health physicist.

18 MR. HALL: No.

19 MR. MINNERS: I have heard this comment before,  
20 and I think I am misunderstanding what you mean by  
21 portable. I think you mean manual. You want to be able to  
22 take a sample and take it to the radiation lab and measure  
23 the sample. You could have a permanently installed meter  
24 which is not the meter itself, or the sampler was not  
25 necessarily portable, but the sample would be removable and

1 taken to some place --

2 MR. HALL: We were thinking more about the big  
3 type where you set it on a roller and roll it in there. We  
4 think you would get a better idea were you able to do this,  
5 especially for particulates and iodines.

6 MR. MINNERS: Why couldn't you bolt that to the  
7 wall?

8 MR. HALL: Touche.

9 MR. MINNERS: People want to have it portable so  
10 they can use it during normal operation in the plant, and  
11 then when the accident comes, they trundle it to the TSC and  
12 use it. Our objection to that was how can we be assured  
13 that the equipment will be available when we need it? The  
14 health physics technician may have put it some place where  
15 nobody knows where it is.

16 MR. HALL: The question was asked of me to ask  
17 more on the basis of the type of equipment you may be  
18 looking for.

19 MR. RAMOS: We have not specified type.

20 MR. HALL: We realize that.

21 MR. MINNERS: I don't think it has to be on-line  
22 automatic. I think that is the way I would phrase it.

23 MR. HALL: That answers my question.

24 The tech support center technical data and data  
25 systems where you set as a minimum the Reg Guide 1.97 types

1 will be available there. Also, there was a statement in  
2 here that said, "In addition, all sensor data and calculated  
3 parameters provided in the ECF from variables not specified  
4 in Reg Guide 1.97 shall be available in the TSC on a callup  
5 basis." And we were wondering what you may have had in mind  
6 when that statement was added.

7 MR. RAMOS: Those calculations from the  
8 environmental data and things like that.

9 MR. HALL: We have environmental data and  
10 radiological data available through 1.97.

11 MR. RAMOS: Then you won't need it.

12 MR. MINNERS: That is a limited set. For your  
13 purposes you may want a lot more environmental data than is  
14 required by 1.97.

15 MR. HALL: That is what I am asking. Do you have  
16 anything in mind? What do your statements here, and this is  
17 very -- you know, we could say everything that is in 1.97 is  
18 sufficient to satisfy the requirements.

19 MR. MINNERS: My understanding -- I don't think it  
20 is written down this way in the Guide -- is that all we are  
21 going to ask for in 1.97 is wind direction and wind speed  
22 and infer meteorological conditions from that. But also  
23 available but not necessarily qualified to these  
24 requirements would be the net tower temperatures, okay. And  
25 if you take those temperatures, they should be distributed

1 to the TSC. I think that is what he means.

2 MR. RAMOS: And the reason is that in initial  
3 stages before you man the EOF, the TSC must function as the  
4 -- do the EOF function.

5 MR. HALL: I will leave you with a parting thought  
6 -- that is my last question -- but bear in mind, most  
7 companies that have plant process computers have all this  
8 data available on them already, rather than having to go  
9 through it again for a second computer should that be  
10 necessary.

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. MINNERS: Mr. Lipke of Wisconsin Electric  
2 Power.

3 MR. LIPKE: We got in some discussion this morning  
4 during the questions accompanying your presentation  
5 regarding a comparison of a functional bases versis  
6 proscriptive techniques.

7 And most of the people here suggested that you  
8 give a functional bases instead of telling us exactly the  
9 technique to accomplish those functions. And I guess I  
10 would like to reiterate that thought.

11 At the same time, I would like to point out some  
12 differences in determining what category a thing falls in or  
13 not. You had brought up the questions about the 100 year  
14 wind and the 100 year flood as an example of where we wanted  
15 functional bases, and then told us -- I told you that we did  
16 not want them.

17 Well, I agree that giving a 100 year wind and a  
18 100 year flood are two meteorological conditions that are  
19 indeed a functional bases. It happens that we don't  
20 particularly agree with that basis, although that is the  
21 type of guidance -- you know -- we think we ought to have.

22 That is a type of function --

23 MR. MINNERS: You may disagree with the number,  
24 but you think the form is correct; you just disagree with

25

1 the number.

2 MR. LIPKE: That is correct. And we disagree with  
3 the number on the basis of the fact that there have been a  
4 number of licensing actions in the not too distant past that  
5 have accepted other criteria, particularly on the side of  
6 the flood basis.

7 The wind is not too big of a problem. Looking at  
8 it the other way, to give an example, one where we have too  
9 much proscription and insufficient discussion of function,  
10 is with respect to the emergency offsite center -- facility,  
11 the EOF.

12 There, I think, we would like to have more  
13 discussions of the functions that ought to be carried out  
14 and substantially less proscription, and let us propose some  
15 alternatives to the Commission whereby we think we could  
16 meet them, as I discussed with you earlier this morning.  
17 Certainly, there is nothing wrong with the Commission giving  
18 us examples of possible acceptable techniques.

19 But historically throughout all the regulatory  
20 guides, and so forth, the function is clearly spelled out,  
21 and it is stated that the licensee is free to propose  
22 alternative techniques.

23 And I guess we would still like some of that  
24 freedom to really do the job right for our particular  
25 facility, our particular site, and our particular conditions.

1           And we would like to be free to propose certain  
2 alternatives to you. Along those lines, I question the  
3 justification for making EOF habitability standards meeting  
4 those of the control room. It seems we first came up with  
5 the idea in this country that we ought to have a technical  
6 support center where everybody could gather together and  
7 follow and criticize and assist in the event of an accident.

8           And so we developed a TSC. Now we are developing  
9 really a second TSC in the form of an EOF. And I really  
10 think at some point we have to draw the line and say -- you  
11 know -- look, one function in one place, and one in  
12 another. And they are not equally critical.

13           Certainly, the control room is the primary plant  
14 you have to defend at all costs, and the technical support  
15 center is important, but something slightly less; but then  
16 the EOF is still less. And the functional criteria that are  
17 set forth each of these facilities that have been proposed  
18 should reflect a step by step gradation of criteria that are  
19 appropriate to the facilities.

20           One small comment on --

21           MR. MINNERS: I heard a Commissioner propose the  
22 opposite gradation to what you proposed, just as a comment.  
23 Is that possibly because the EOF in his thought was going to  
24 contain civilians; it should have better protection than  
25 the control room.



1           MR. LIPKE: All right. If we want to follow that  
2 line of reasoning, then we can say, okay, let's do that.  
3 But then let's in fact have some gradation. We cannot have  
4 -- continue to multiply these facilities and say that they  
5 are all equally important. I think there has to be a  
6 recognized philosophy behind them.

7           Someone behind just remarked now that, you know,  
8 the people in the control room are civilians too, which is a  
9 good point.

10           We don't totally understand how one can argue that  
11 a strict limiting condition for operation for the EOF -- and  
12 I foresee all kinds of difficulties in trying to carry that  
13 out, this eight hour unavailability business. There has  
14 been no mention of putting emergency power into an EOF yet.  
15 And yet that seems to be what is implied here because if  
16 you cannot have power, you cannot run your HBAC.

17           If you cannot run your HBAC, you don't have  
18 habitability assured. So now all of a sudden we are into  
19 putting emergency power into the EOF, again a problem with  
20 graded importance of facilities, I believe.

21           I would like to just, in closing here, just recap  
22 a comment that I made earlier this morning, that there is no  
23 reason for introducing non-radiological data into the EOF.  
24 If one argues that the EOF's primary function is  
25 radiological evaluation and support and subsequent

1 communication with the various authorities involved --

2 MR. MINNERS: I don't think you said that quite  
3 right. You are welcome to your opinion, but you said if its  
4 primary function is offsite, it would not require any data,  
5 but it would have the secondary function of looking at the  
6 plant.

7 Do you really mean that if its only function is to  
8 interact with offsite, it has no need for plant data. You  
9 said if its primary function is to interact with the offsite  
10 people it has no need --

11 MR. LIPKE: It is the way you spelled it out in  
12 0696. We take it that the primary function is -- perhaps --  
13 let's not say "primary." Let's say the first function is  
14 radiological evaluation; the second function is  
15 communication with offsite authorities.

16 MR. MINNERS: And the third function is overview of  
17 the whole plant.

18 MR. LIPKE: If the third function is overview of  
19 the whole plant, perhaps that ought to be carried out in the  
20 technical support center.

21 MR. MINNERS: Now I understand your comment.

22 MR. LIPKE: Okay. Thank you.

23 MR. MINNERS: Mr. Schellin of Wisconsin Public  
24 Power.

25 MR. SCHELLIN: I will try and eliminate the

1 comments that have gone before me as I have gone done my  
2 list.

3           You mentioned an NRC workshop. Could you  
4 elaborate on that? I think you said relative to 0578 or  
5 some other Lessons Learned item coming up sometime in  
6 September.

7           MR. RAMOS: There should be a letter coming out in  
8 the next week or so signed by Mr. Eisenhut discussing -- and  
9 also a Federal Register notice discussing a workshop. And I  
10 believe the date is in September, the mid part of September  
11 to discuss the clarification of the Lessons Learned item,  
12 including whatever changes in schedule that they are coming  
13 up with.

14           And it could be the whole gamut of the Lessons  
15 Learned items.

16           MR. SCHELLIN: Is this on a regional basis or in  
17 Bethesda or --

18           MR. RAMOS: I cannot really address that.

19           VOICE: I think it is regional.

20           MR. RAMOS: It will be run similar to the  
21 emergency planning workshops where we had four meetings in  
22 January; in this case they will go Region I, II, III, and  
23 then a meeting in an intermediate point; say, Los Vegas.  
24 That, I believe, will be the fourth point.

25           MR. SCHELLIN: Will this try and address

1 region-specific items?

2 MR. RAMOS: I cannot address that because I am not  
3 involved with it. I only know about it because of  
4 associating with the Lessons Learned people.

5 MR. MINNERS: Why don't you give Tom Telford  
6 (phonetic) a call; he can give you the details.

7 MR. SCHELLIN: In terms of the process computer, I  
8 am not going to beat that. But relative to that and the  
9 unavailability being -- one of the items that should be  
10 inserted in place of the restriction on the process computer  
11 is some functional wording relative to the security of the  
12 systems that are processing the SPDS.

13 I think what we have been talking back and forth  
14 is really that point, as you have raised it, not whether it  
15 is done in the process computer, a main frame, a number of  
16 minis.

17 What we are talking about is what sort of process  
18 is allowed to change the programming because, certainly, the  
19 flexibility that we have to design into the system requires  
20 changes for the better. So that is a general observation.

21 I won't hit CBE and seismic requirements again.

22 I think one thing we are losing site of is the  
23 fact that the SPDS must be verified by the control board  
24 instrumentation, which is the most reliable source, before  
25 the operator really can use it or believe it or take any

1 actions.

2           So it is really a key in the overall mosaic or  
3 puzzle that he has to figure out. And we should not be too  
4 prescriptive in that respect because we still want him to  
5 use the most reliable safety-related indications from the  
6 control board.

7           And we should not draw him away from those.

8           MR. MINNERS: There have to be procedures and  
9 training for the use of the SPDS which would address that  
10 point.

11           MR. BELTRACCHI: There also is the item that I  
12 tried to stress again this morning: the validation of the  
13 data before it is presented to the operator, an online  
14 validation which could either be done through redundancy or  
15 secondary sensors.

16           MR. SCHELLIN: I guess one of the items that might  
17 come up in that is, say, during a seismic event, it would be  
18 very hard, I think, if you are using instrumentation, that  
19 uses, maybe, a forced balance where you rely on masses being  
20 moved. I think it would be extremely difficult to design a  
21 program that works during an event; it may work well before  
22 and after, and --

23           MR. BELTRACCHI: I agree.

24           MR. SCHELLIN: You may run into some dichotomies  
25 there.

1 MR. BELTRACCHI: That is recognized in the form of  
2 some of the recordings or some of the things that the staff  
3 has accepted in the past with respect to Reg Guide 1.97 or  
4 post-accident monitoring.

5 MR. SCHELLIN: Okay. I think when we refer to Reg  
6 Guide 1.97, I think we are referring to a document that is  
7 moving and changing in parallel to this NUREG, and it is  
8 very difficult to try and design a system to meet items in a  
9 reg guide which change from draft to draft and month to  
10 month.

11 Is there any anticipation of a formal process for  
12 review and comment of Reg Guide 1.97 to try and firm up a  
13 target?

14 MR. MINNERS: The Reg Guide 1.97 has gone through  
15 its public comment period. It was presented to the ACRS who  
16 said to do some more work on it, and NRC is now considering  
17 that direction by the ACRS.

18 We had hoped to have the reg guide out in October  
19 at the same time that 0696 went out. That may not be  
20 possible now.

21 The ACRS directed us to redo 1.97 and have it  
22 finished by the end of the year.

23 MR. SCHELLIN: One of the problems, then, is the  
24 feedback from something like 0696 comments which address  
25 things on a functional need basis feeding back into 1.97,

1 which was developed without some of those functional needs  
2 being considered.

3 I think that was addressed also this morning.

4 MR. MINNERS: I would agree with what you say with  
5 a little qualification; I do not think we were completely  
6 unaware of the functional requirements. We just did not do  
7 it systematically.

8 MR. SCHELLIN: Well, I think one of the great  
9 areas of impact -- and this certainly affects the ordering  
10 of equipment for installation -- is the vasculating,  
11 changes, and qualification of specific parameter --  
12 parameters that are required for 1.97.

13 And you will certainly agree that that has changed  
14 greatly. In fact, I am not sure whether 0696 refers to the  
15 same qualification levels as are in draft to rev two. I  
16 think 0696 has A,B,C and the other one has one, two, three,  
17 four, which is entirely different in meaning.

18 So that cognizance has to be factored in. One of  
19 the things that I think should be considered and was brought  
20 up very poingantly is the previous commitments for 0578,  
21 which either have not been reviewed and have been proceeded  
22 on by the utilities or have been reviewed and approved and  
23 are now being changed or altered.

24 I think this shold be sufficient basis for  
25 exceptions or changes in schedule or function. And I think

1 that was spelled out very clearly in terms of looking at  
2 things relative to where things are located and whether it  
3 is the TSC or ECF.

4 MR. MINNERS: We think we recognize that, at least  
5 in the instance where we modified the 1/1/81 date for the TSC.

6 MR. SCHELLIN: I think that is recognizing  
7 realism, yes.

8 I think that flexibility should be included in the  
9 future. I am unclear as to what the diagram in 0696 of the  
10 computer system was meant to be. If it was meant to be a  
11 prescriptive item, it borders on the functional. But where  
12 it is addressed in the text on page 4, it talks about this  
13 being a functional flow of information, more or less. And I  
14 think really what we are talking about is a functional flow  
15 in the final document.

16 That should be spelled out rather than keying on  
17 whether a certain function is taking place in a processor or  
18 whether it is a data transmission.

19 The two minute location was covered very well.

20 The SFDS states that the data acquisition, the  
21 sensors and signals shall be designed and qualified to Class  
22 1-E standards.

23 Can you talk about that a bit?

24 MR. BELTRACCHI: That is in the context of  
25 interfacing a non-safety system with a safety system.



1 MR. SCHELLIN: So, beyond the isolator there is no  
2 restriction outside good engineering design?

3 MR. BELTRACCHI: Other than what is stated in the  
4 -- other than what is stated in the report.

5 MR. SCHELLIN: Okay. Not addressing process  
6 computer separability, again --

7 VOICE: May I make a point? In other words, then,  
8 the Class 1-E requirement is a result of a requirement -- is  
9 that basically what you are saying?

10 It is not a requirement to be qualified to Class  
11 1-E requirements, but it is a result of that?

12 MR. BELTRACCHI: In the sense that we are using  
13 1.97 as a data base.

14 MR. SCHELLIN: If an item is Class 1-E, under 1.97  
15 we should provide appropriate isolation, but we should not  
16 factor Class 1-E on something that is not Class 1-E now?

17 MR. BELTRACCHI: Yes.

18 MR. SCHELLIN: Okay. The applicability of GDC is  
19 at best vague and in some sense contradictory to other  
20 specific items in 0696 and if certain portions of these  
21 documents are indeed required, I think, perhaps, they should  
22 be extracted and made an appendix to this document.

23 Somebody said, spell it out. The SPDS should not  
24 generate an LCO since it neither limits the operability of  
25 the plant nor degenerates the safety status of the plant

1 with its non-operation.

2 I think there should be room for some modification  
3 of systems that we are adding to the plant such that the NRC  
4 knows whether they are operable or non-operable. But I do  
5 not believe that it should become a limiting condition of  
6 operation for something which right now is not needed to  
7 operate a plant safely and is not in the future really needed  
8 to operate a plant safely, but allows for increased safety.

9 MR. MINNERS: Are you talking about the SPDS?

10 MR. SCHELLIN: Yes.

11 MR. MINNERS: I guess I disagree with your  
12 comment. Not to argue with you, but just to state our  
13 position, we think to be adequately safe, plants need a  
14 safety parameter display, and that may explain our view of  
15 why we did what we did -- just to explain our view.

16 MR. SCHELLIN: I hear it; I don't necessarily  
17 agree with it.

18 MR. MINNERS: I just want to have an understanding  
19 of what we disagree on.

20 MR. SCHELLIN: We talked about alarms and  
21 annunciator functions. We recognize -- I would like to state  
22 this for the record -- we recognize that they are needed for  
23 safe operation and in fact for the process that the operator  
24 goes through to determine whether the conditions of the  
25 plant are going toward an unsafe condition and in what

1 direction they are trending and in what area of the plant  
2 that type of change is taking place.

3 I think we should de-emphasize some of the  
4 reliance that seems to be written in 0696 relative to the  
5 SPDS trying to bypass or ignore or make these annunciators  
6 and alarms subservient to the basic instrumentation which is  
7 in the control room.

8 I think it is again a function of training, the  
9 operator capability, and control room design. Along with  
10 the SPDS, that has to be looked at to determine whether  
11 something like this is giving an increase in safety or  
12 whether it is adding additional things which still have to  
13 be considered because we cannot ignore alarms and  
14 annunciators.

15 Thank you.

16 MR. MINNERS: I think that I am going to have to  
17 give the reporter a break, and so the rest of us get one.  
18 Let's take a 10 minute break until quarter of four and come  
19 back and continue the comments.

20 I only have four more -- five more people listed,  
21 so it should not be too much longer.

22 (Recess)

23 MR. MINNERS: All right. I would like to get  
24 started again if we may.

25 Okay. The next person I have on the list is Mr.

1 Myers of Toledo Edison.

2 Is Mr. Myers still here?

3 Very good. You have stamina, sir.

4 (Laughter)

5 MR. MYERS: I needed that break.

6 First of all, we will provide detailed comment to  
7 the safety parameter integration subcommittee at AIF. We  
8 are members of that, and independently, and we will take  
9 into consideration specific recommended rewording in that.

10 MR. WINNERS: We appreciate that.

11 MR. MYERS: There are a couple of areas which we  
12 would just like to make comments on today, more having to do  
13 with the philosophy and the background.

14 MR. WINNERS: Good.

15 MR. MYERS: We, like most of the others, have been  
16 in that development for quite awhile on the tech support  
17 center and an overview of emergency response capability,  
18 whether it be facilities, plans, whatever, in discussions  
19 like this on specific facilities.

20 Most of the functional aspects which come up and  
21 reasons why or the alternatives to have done nothing but  
22 strengthen our commitments in the activities we are  
23 undergoing now, and that includes a full fledged new  
24 construction project on its way to completion here shortly.

25 So as far as the company is concerned, the aspect

1 of emergency planning facilities is now being run by our own  
2 priorities and our own time table, since you have expanded  
3 yours.

4           The company still feels liable and responsible  
5 after TMI to complete what it feels is an upgrade in a most  
6 expeditious manner.

7           However, we are concerned that some of the  
8 discussions which we have heard and some of the bases for  
9 some of the requirements seem to reflect either one aspect  
10 of TMI or trying to solve the complete TMI type syndrome  
11 with one piece of the pie.

12           And in that light, our main concern is the overall  
13 management of the accident; that is, management on the  
14 utility's side, NRC's side, FEMA, which we have not even  
15 heard from here, and I am sure is rapidly developing  
16 criteria and the numbers of men to be in certain places and  
17 little requirements too.

18           So it is -- when we came up with our detailed  
19 facilities --

20           MR. MINNERS: You don't mean to infer by that that  
21 FEMA will have requirements on the utilities?

22           MR. MYERS: I believe they will have requirements  
23 for access to facilities in an emergency, probably the same  
24 type that you say you would like, five men in the tech  
25 support center; I would expect to see FEMA saying that the

1 emergency operations facility would have a place for a  
2 five man team from FEMA.

3 MR. MINNERS: I think this document already says  
4 that. It says state and local and other federal people.

5 MR. MYERS: That is right. State and local you  
6 can quantify and you have quantified your section. FEMA we  
7 have not heard from yet, and so they are in development is  
8 my understanding.

9 MR. RAMOS: In the revision of 0654, it might be  
10 wise that we probably should take that up in the steering  
11 committee and see if that can't be put into 0654, their  
12 manning requirements.

13 MR. MYERS: That coordination, though, and the  
14 access, we recognize as being in development, and therefore  
15 we try to make our approach as flexible as possible in the  
16 early stages.

17 And it has help up quite well to date, we think,  
18 with a few significant problems. But we do want to consider  
19 that 0696 address only one part of the aspect of TMI,  
20 anticipated transient operating guidelines, Lessons Learned,  
21 trying to eke out the one thing that it is used for in many  
22 cases to try and justify certain activities, confusion in  
23 the control room in any transient, whether it be earthquake,  
24 secondary system upset, primary system upset.

25 The guidelines are set up to be symptom related so

1 that the training associated with the operator will cut  
2 through the mass of alarms and everything that we would  
3 expect during those conditions, the control room evaluation  
4 and modification, and other aspects.

5           Given that you do have the confusion anyway, you  
6 have all those parameters in there.

7           What about prioritization of alarms, functional  
8 relationships between the operator and the control board, a  
9 very important aspect in that?

10           MR. BELTRACCHI: Let me address that. I think you  
11 are well aware that NUREG-0585, section 7.1 did state that  
12 there would be -- the staff would issue guides for the  
13 review of the control room; the initial set of guides, I  
14 believe, were issued within the last week or two. They are  
15 admittedly incomplete, but at least it is a start.

16           One of our concerns in this area is in the area of  
17 alarms and their prioritizations, and we have noted this in  
18 the course of our control room audits.

19           And I expect you will probably see more on this  
20 issue in the future.

21           MR. MYERS: I understand, and it is our  
22 philosophy, just as it was observed at TMI, that the control  
23 room is too confusing during a transient, and we are anxious  
24 to support upgrading the capability of the operator to cut  
25 through that.

1           However, in justifying some of the activities that  
2 we mentioned here of distance from the control room, OBE  
3 requirements, statements were made, well, the SPDS will be  
4 that vehicle that will do that cutting through the  
5 confusion, and therefore it must meet the following  
6 requirements: it must meet OBE requirements.

7           I do not believe that is functionally required,  
8 given the other aspects, and I think that re-evaluation of  
9 the paper commitment to OBE requirements should be taken  
10 reflecting these other areas that we are involved in  
11 upgrading right now.

12           MR. WINNERS: There are a variety of control rooms  
13 and for some control rooms your statements may apply; for  
14 other control rooms, I think the SPDS is the only thing that  
15 is going to save the operator from confusion.

16           Our problem is we are writing a document for all  
17 control rooms.

18           MR. BELTRACCHI: Let me also make one other  
19 statement relative to computers because I have heard quite a  
20 bit about the seismic qualification thereof. I don't know  
21 how many of you are aware, but the core protection calculator  
22 systems are SSE qualified. They are Class 1-E. They were  
23 reviewed by the staff during the period 1975 to 1978. They  
24 are currently operational at the Arkansas facility, Arkansas  
25 Nuclear Units 1 and 2.



1           Many of the concerns we had in that area -- and I  
2 think they were on the order of 27 safety positions -- these  
3 are all documented in NUREG-0308, which was a safety  
4 evaluation report for that review.

5           If that will provide any additional source of help  
6 to you, be it so identified.

7           MR. MYERS: I respect that, Leo, and I was  
8 involved in a lead engineer on one of the follow-on plants,  
9 not only reflecting the core protection calculators, but the  
10 CESAR advanced control room concept, and I contend that  
11 although the core protection calculators are SSE qualified,  
12 that is an animal of a completely different shape than the  
13 computer systems we are looking at to be flexible,  
14 upgradable, expandable, in the time frame we are looking at  
15 in the near future here, and I do not believe it is required  
16 based on building this to support a control room in what we  
17 would consider 99 percent of the events that it expects to  
18 see during an operational life.

19           Now, you cannot tell in an earthquake whether you  
20 have had an SSE or an OBE. The dispensation that you will  
21 get by knowing that your equipment is qualified to an OBE  
22 will be of little value if you do not know whether the  
23 information it is giving you has still survived.

24           So I am concerned that we are getting into an area  
25 that the operator would then go into detailed evaluation of

1 the SPDS, ignoring the transient to try to get his equipment  
2 revalidated to make sure it is reading correctly.

3 And I think the ATOG arrangements, the control  
4 room upgrade, and the fact that we can guarantee the plant  
5 is safe for an SSE without this -- and my understanding is  
6 that this is our condition.

7 Now, you mention it is a safety function, but on a  
8 probabilistic approach, you can eliminate an SSE and go to  
9 an OBE. I would contend on a probabilistic approach, you  
10 could go below that.

11 MR. MINNERS: Your problem is even heightened --  
12 this is just a discussion. If the SPDS were not given any  
13 seismic qualification, then if any earthquake came along,  
14 what would you -- and he looked at his SPDS, he would not  
15 know whether it was valid or invalid. He would have to go  
16 back to the control board.

17 So your problem is heightened, the one of which  
18 you have an earthquake and the operator does not know what to  
19 do.

20 MR. MYERS: The operator knows exactly what to do  
21 based on the response of the plant. A plant can be shown to  
22 respond both from the control board and from the SPDS. We  
23 are not replacing the control board. We are going through a  
24 lot of evaluations to make sure we know what to look at to  
25 determine status of the plant through ATOG, and we are going

1 through a lot of evaluations and modifications in the  
2 control room so that we can reinforce that and guarantee in  
3 the safety related aspect we have covered that.

4           So, it is another -- you know -- you consider it a  
5 safety function; I think the basic philosophy on my side is  
6 it is an operator aid. And in many of the diagnostics,  
7 manual capabilities have been developed and discussed that  
8 could derive the data with an additional operator or  
9 whatever plotting that data to give you the initial  
10 diagnostic capability of a very confusing event.

11           I think that needs to be looked into much more and  
12 can be an acceptable approach to a well engineered computer  
13 system installed in a good structure with very reliable  
14 power supplies, considering the other activities.

15           And that is the approach that we are taking, I  
16 believe, that is consistent with the AIF activity.

17           And I think it does deserve some consideration on  
18 your part again or reconsideration.

19           Thank you.

20           MR. MINNERS: Mr. Gurican of I & ME.

21           MR. GURICAN: Yes. I belong to the American  
22 Electric Power Service Corporation, a parent of the I & ME  
23 Company, and we are also members of the AIF safety parameter  
24 subcommittee and we fully support what Mr. Myers has just  
25 stated.

1 I would also like to comment on a few things here  
2 that we went over this morning and again this afternoon.

3 I would not like to beat to death the  
4 unavailability question here. I fully concur that the SPDS  
5 will be an aid to the operator and help make power plants  
6 more safe and by eliminating some of the confusion of all  
7 the alarms, perhaps, that come about during an event.

8 And I feel that you may want to have a limiting  
9 condition for operation based on unavailability for that  
10 portion of this integrated system for the four functions you  
11 mentioned in this NUREG document.

12 However, I strongly disagree that any limiting  
13 conditions for operations are required for the technical  
14 support center, the emergency operations facility, or the  
15 Nuclear Data Link. I say this because I believe that in  
16 light of the Kemeny Commission and in light of the  
17 NUREG-0578 and NRC's own Lessons Learned task force and the  
18 development of the actions required in those Lessons Learned  
19 documents, both NUREG-0578 and 0585, neither of those  
20 documents have address the limiting condition for operation  
21 of these facilities, but do stress the need for emergency  
22 operations facilities to better aid the utility and the NRC  
23 and state and local governments to address emergency  
24 operations.

25 We fully concur with the idea of having adequate

1 and sufficient emergency operations capability and we have  
2 moved along that line since the issuance of NUREG-0578 to  
3 build a technical support center by 1/1/81, and now we are  
4 facing new requirements with a new scheduled deadline which  
5 we don't believe is particularly fair.

6 But we may be able to meet those requirements  
7 regardless of that fact.

8 Now, to address a specific question that I have  
9 that may not have been asked earlier and one regarding  
10 communications.

11 Under the technical support center communications,  
12 you indicate that the TSC shall have designated telephones  
13 for NRC personnel to be used to communicate with the EOF and  
14 outside locations.

15 I assume one telephone to the EOF is sufficient;  
16 I would like to know how many pay phones you would like to  
17 the other outside locations?

18 That is my only questions.

19 MR. MINNERS: Mr. Craig of WPPSS.

20 MR. CRAIG: My questions have been address already.

21 MR. MINNERS: Mr. Keopfinger of Dusquene Light?

22 Mr. Bremmer of Dairyland.

23 MR. BREMMER: Yes. The people of Dairyland would  
24 like to express that we are a co-op. There is a big  
25 distinction.

1 My first question: have there been any cost  
2 estimates performed on what this change will mean to a  
3 utility?

4 MR. MINNERS: The whole facility?

5 MR. BREMMER: The whole bag.

6 MR. MINNERS: Yes, there have been. In the NRC  
7 action plan on Three Mile Island, there are some cost  
8 estimates for each action item in the plan. And these are  
9 action items; I forget what the numbers are now.

10 MR. BREMMER: Okay. Do you know what type plant  
11 was being considered when they came up with these numbers?

12 MR. MINNERS: An average plant, whatever that  
13 meant.

14 (Laughter)

15 MR. BREMMER: What is an average plant? One  
16 gentleman mentioned something like a 1000 megawatt unit.

17 MR. MINNERS: It was probably closer to a 1000  
18 megawatt unit. You must understand that the reason the cost  
19 estimates were put in the action plan was not to try to make  
20 cost estimates for a utility's purpose but to give a  
21 relative ranking of the cost of these different items so  
22 that the decisions or priorities could be weighted by cost.

23 That was one of the elements in weighting  
24 priorities, and so the cost estimates are very rough cost  
25 estimates. We think they are good enough for their

1 purpose. We don't think they are good enough for somebody  
2 to go up to the public utility commission and say this is  
3 what it is going to cost or even come close.

4           So -- you know -- we did not deal with your kind  
5 of plant; your kind of plant -- you know -- is out at the  
6 end of the spectrum and some of that stuff is marginally  
7 applicable.

8           MR. BREMMER: I was referring specifically to the  
9 TSC, SPDS, EOF, and NDL. That was of of my main concerns.

10          MR. MINNERS: I would imagine on this that those  
11 facilities would be about the same cost no matter how big  
12 the plant is; everybody has the same systems and the same  
13 data.

14          There is small variation whether you have a 50  
15 megawatt plant or a 1000 megawatt plant. You have all the  
16 same systems, the same safety functions. You are going to  
17 have about the same cost, I would think. I cannot see a big  
18 difference.

19          MR. BREMMER: Unfortunately, that would be  
20 extremely difficult for units of a very small size. I was  
21 wondering if any special considerations will be given to  
22 units, the early plants, the ones of less than 250 megawatts  
23 thermal as FEMA has given in the emergency plan?

24          MR. MINNERS: So far it has not, and if you think  
25 you ought to get a special dispensation -- if I may put it

1 that way -- I would suggest that you write someone asking  
2 for it.

3 I think you are a very unique case.

4 MR. BREMMER: I just wanted to point out some of  
5 the unique features and I do not disagree with many of the  
6 reasons behind some of the additions in the new systems and  
7 some of the post-TMI actions that have been required.

8 It is a matter of implementation, and it can be  
9 extremely difficult for old units. For instance, at our  
10 unit, we essentially, except for newly added equipment, have  
11 no class 1-E equipment. We may be fortunate that we do not  
12 have a Class 1-E computer from some of the discussions  
13 mentioned today.

14 We were originally considered a zero seismic  
15 area. We have no seismic criteria right now, although we  
16 are in a battle to maintain the minimum seismic criteria  
17 that we can.

18 As far as redundant power supplies go, when we  
19 start talking about reliability and such, originally we had  
20 one essential buss; now we have three.

21 The capability of the original buss is  
22 approximately 130 amps. Our second and third busses are  
23 eight amps each, interfacing the original equipment that we  
24 are saddled with to try to develop the remainder of the  
25 outputs of which there may be upwards of 100; this was



1 built with Foxboro equipment.

2           Basically on these current loops, you can hang 600  
3 ohms of load. The equipment is very difficult to get from  
4 Foxboro any longer. Most of these loops are put to the full  
5 extent that they can be.

6           In addition, the adding of new transmitters, new  
7 loops, we have been adding them throughout the years. We  
8 would have to make in some cases new penetrations in our  
9 reactor vessel to do this.

10           The reliability-unavailability factor at our  
11 plant, we do not have a great deal of problem with what has  
12 been written in this because our logics are basically one  
13 out of two. Our instrumentation has to work.

14           A very disturbing general comment is the attitude  
15 that we see many times expressed from the NRC. Being a  
16 small utility, everything that we have to comply with is  
17 very important. It is a very important cost consideration.

18           You gentlemen this afternoon alone have made small  
19 comments like, "What is a little more cost, two or three  
20 more people, press the right button, only one little thing,  
21 only two more wires."

22           Each of these, if you really get down into the  
23 nuts and bolts area, is a considerable dollar commitment.

24           To come to some specifics, I discussed this with  
25 our project manager in the NRC; when I call to get cost

1 estimates on some of the equipment to comply with the TMI  
2 changes, I no longer identify myself as being with a reactor.

3 First, I give them the criteria of what I want a  
4 system, a component to do. In three cases that I will  
5 mention here, I was trying to buy hydrogen analyzers, which  
6 by the way we have -- are losing an argument.

7 We do not have zirconium clad fuel; we have  
8 stainless steel clad fuel. The source of hydrogen in the  
9 event of an accident at our plant would be extremely small,  
10 yet we still have to buy two hydrogen analyzers.

11 MR. MINNERS: Hydrogen recombiners are not being  
12 installed in plants because of --

13 MR. BREMMER: I did not say recombiners. I said  
14 analyzers. The first one that we found by a company -- and  
15 I have documentation to back up these statements -- was  
16 quoted at \$2000.

17 When they found out we were going to use it for a  
18 TMI fix, they had a special TMI package: \$54,000 for  
19 essentially the same thing. The major change that we could  
20 finally determine from that was they changed their copper  
21 tubing in the unit to stainless steel. That is the major  
22 change. We cannot afford \$54,000 additional for a unit like  
23 that.

24 And in needing two of them -- we have an  
25 approximate million dollar budget for hardware for next

1 year.

2 Another case, an air compressor company quoted us  
3 a \$900 cost for one that met the criteria that was  
4 required. When they sent us the quote in the mail, it went  
5 up to \$5000.

6 We have tried hard. We were going to by the end  
7 of this year-- as a result of this meeting, we are going to  
8 have to regroup. We did not get a copy of this document  
9 until we walked in here today. Our technical support center  
10 was going to be by the end of this year, having 28 inputs  
11 going into it through a computer, and it would have been  
12 available shortly after the beginning of this coming year  
13 with the Nuclear Data Link if you had asked for it and if it  
14 had been required.

15 We have been moving on this, and in this direction  
16 all the work I have done to date with these new requirements  
17 -- you know -- it is wasted.

18 We cannot salvage what we have proposed and make  
19 them meet this requirement.

20 MR. MINNERS: Did you get your car in with AIF  
21 when that document was being developed?

22 MR. BREMMER: Part of my problem is within the  
23 last four or five months, I have joined this utility, and I  
24 have been involved in the industry, but I have not  
25 specifically been able to address this problem. That is

1 unfortunate.

2 MR. MINNERS: Okay.

3 MR. BREMMER: Another case, in trying to meet the  
4 deadline by the end of this year, we went out to buy certain  
5 radiation monitors. The vendor was billing them as being  
6 fully qualified; at the time they were the only ones  
7 billing it as being fully qualified to the requirements  
8 specified in the TMI documents.

9 After ordering it, because of the long lead times  
10 involved, we found out it was still undergoing  
11 qualifications. We asked for specific information to  
12 continue our detailed design and found out they could not  
13 supply it.

14 So vendors are not only increasing their prices,  
15 they are misrepresenting some of their materials that they  
16 are trying to sell to us.

17 And in mentioning specific equipment, this is very  
18 bad because we have had very few people to go to to supply  
19 us this equipment, and when they know there is a small  
20 market for a short period of time, they are going to jack  
21 that price up.

22 And we cannot afford it. Larger utilities are  
23 going to outlast us; we may be the smallest plant, but we  
24 don't intend to be the first one to go under if we can help  
25 it.

1           MR. MINNERS: Do you think we are specifying  
2 particular equipment? We are trying not to.

3           MR. BREMMER: We get forced into ordering it, and  
4 there is one person we can go to and mentioning this one  
5 computer that is seismically qualified, that is bad.

6           In another case, even Foxboro tried to make a  
7 change in safety related systems; they insisted we drop our  
8 10 CFB 21 criteria. They insisted before they supply it.  
9 Our plant will not be allowed to operate after January 1 if  
10 we don't make the change by the end of the year.

11           So what do you do? It is the only compatible  
12 equipment that we can use. We dropped the Part 21 and we  
13 bought it and we put it in because we want to continue to  
14 operate.

15           I would also like to say with many of the  
16 requirements that are being required -- we are being  
17 required to meet -- and as I mentioned before, I don't  
18 disagree that we have to upgrade some of the things, but we  
19 are looking at the SPDS, the TEC, the EOF, the NDL, the  
20 environmental qualifications.

21           Our plant did not have them when it was built. We  
22 are havig to go back and next month we have a very important  
23 meeting on environmental qualifications. It is going to be  
24 a significant change.

25           The emergency plan -- the sequence of events

1 recorder, we don't have one of those, but we are being  
2 pushed closer and closer to it, and alternate shutdown panel.

3 I would propose in order for us to meet all these  
4 requirements, that we are almost going to have to  
5 reinstrument our plant because we do not have like the newer  
6 plants do, isolation amplifiers that may have an extra one  
7 or two or three signal taps.

8 Ours are a closed loop. Our TSC was going to be  
9 hard wired. We in all cases but one were able to rob  
10 signals out of non-safety related loops to feed our TSC;  
11 the one because we cannot interface to it; it has the  
12 maximum instrumentation on it possible, we are hanging a  
13 clamp-on ampmeter on it. We cannot add another  
14 transmitter.

15 We are planning to follow this up with a detailed  
16 -- with our concerns and ask for a detailed description of  
17 the parameters that you want from us and other plants of an  
18 older nature, of a small plant nature.

19 We will propose following our FSAR versus  
20 specific criteria mentioned here in the NUREG in that  
21 seismic -- other environmental conditions. Our control  
22 room, if hit by a tornado could be ripped right out.

23 There is some question in our group as to what  
24 habitability means. We will address that question later  
25 also. The project manager, Jim Shea, for our unit said that

1 feedback of the nature of the problems we were running into  
2 in procuring equipment, that we should try to air it as  
3 frequently as we can to allow you to help, to help make you  
4 aware of the problems we are running into.

5 In good faith, we were trying to meet the July 1  
6 deadline, 1981, and we are making plans for July 1, 1982.

7 We have spent considerable manpower, money, and  
8 right now I see very little of what we have done today as --  
9 to date as salvageable.

10 MR. MINNERS: Mr. Given of Sargent-Lundy.

11 MR. GIVEN: I have a few additional questions, and  
12 I don't think we got them addressed earlier today, one of  
13 which deals with the data base for the emergency facilities.

14 They have pretty much entirely been denoted as  
15 being Reg Guide 1.97; however, one of the requirements in  
16 the technical support center is to be able to evaluate plant  
17 conditions leading to the accident, and I am not sure that  
18 with the Reg Guide 1.97 data base you can really evaluate  
19 the conditions leading to an event, accident, whatever this  
20 happens to be.

21 I am wondering if the two requirements are really  
22 consistent.

23 MR. RAMOS: 1.97 are minimum requirements. In  
24 most cases there will have to be some additional items that  
25 are plant specific that you will have to put in there.

1 Those are the very minimum requirements that we see.

2 MR. GIVEN: What you are saying is we have to put  
3 in more parameters than what the requirements really are.

4 MR. MINNERS: You have to satisfy the function;  
5 if the minimum parameters in 1.97 don't satisfy that  
6 function, you would have to put in more.

7 MR. GIVEN: Also, one of the items that was  
8 brought up when we were talking about the schedule for  
9 implementation this morning left me a little bit confused:  
10 I am not sure what the lead time is for submittal of the  
11 design for these emergency facilities for plants that are  
12 not operating or are near term operating license plants.

13 In other words, there should be a lead time in  
14 which this data would need to be submitted in order to  
15 ensure an operating license by a certain date, and I am not  
16 sure what that span of time really is.

17 MR. RAMOS: NUREG-0694 lays out those requirements  
18 that must be met before you get a fuel load or low power  
19 license and also for a full power license. And in some  
20 cases, specifically to meet the requirements of 0654 -- for  
21 example, for a full power license, you have to meet the  
22 requirements for 0654 which says that you have to have the  
23 TSC and the EOF, and it means that you have to meet 0696  
24 requirements because that is where the criteria for the  
25 facilities is laid out.



1 MR. GIVEN: But we were discussing this morning  
2 -- one of the items on your schedule showed --

3 MR. RAMOS: You have to back up from the date that  
4 you are shooting for for your fuel load to meet the ultimate  
5 requirement of June of 1982 if you are coming on line before  
6 then to get your criteria in -- your design in for review.

7 So I don't know when your plant is due to come up.

8 MR. GIVEN: Some of the plants I am thinking of,  
9 we would be looking for an operating license after June of  
10 82, even --

11 MR. RAMOS: So you back that up to whatever time  
12 frame is required to meet the requirements of 0694.

13 MR. GIVEN: That is the question I am asking.

14 MR. MINNERS: If they are after June of 82, they  
15 are going to have to meet those June 82 requirements in  
16 order to get a license.

17 MR. GIVEN: When does the design have to be  
18 submitted for your review?

19 MR. MINNERS: We have not specified that, and we  
20 are leaving that to the licensee people to say, hey, I need  
21 so much time to get this reviewed so I make my license on  
22 time.

23 We don't tell you when to submit your FSAR.

24 MR. RAMOS: You have to back it up from when you  
25 want to make your fuel load and decide how much time it

1 takes you to install the equipment in the facilities and  
2 that it is going to take us roughly a month or two months to  
3 review and approve your proposal.

4 MR. GIVEN: Okay. A month or two months or three  
5 months is the number we are looking at.

6 MR. RAMOS: Yes.

7 MR. MINNERS: Do you want to know how long it  
8 would take us to review a proposal?

9 MR. GIVEN: Yes. We would have to have the plan  
10 submitted by January 1. Right?

11 MR. MINNERS: Right. You better sit down with  
12 your project manager and work out a schedule. We can give  
13 you an off the head number of what it might take, but that  
14 does not mean that the people would be available to do the  
15 review.

16 There has to be some scheduling. You have to go  
17 to your project manager and work up a schedule of when you  
18 can get your license and when you have to submit stuff.  
19 That is what project managers are for.

20 MR. RAMOS: That is what we are doing in some of  
21 the cases that are looking for a low power license, fuel  
22 load, low power license for November 82, for example.

23 MR. GIVEN: And the implementation schedule that  
24 you showed us this morning, then, is strictly for operating  
25 plants or near term licenses?

1 MR. RAMOS: Yes.

2 MR. MINNERS: And it also defines the time in  
3 which plants that get a license after that date are going to  
4 have to meet the requirements.

5 So if you get a license after June 1982, you have  
6 to meet those requirements.

7 MR. GIVEN: Will the staffing requirement  
8 documents for the TSC and the EOF provide guidelines for  
9 what type of displays and how many displays will be required  
10 in each of those facilities?

11 MR. RAMOS: Our analysis will go through that; it  
12 was not our intention to provide you that because AIF and  
13 other industry people have told us they don't want us to  
14 tell them that.

15 MR. MINNERS: We will make it available to you,  
16 but it won't be a requirement.

17 MR. GIVEN: That is why I say guidelines. I am  
18 not saying a requirement; I am saying guidelines.

19 MR. MINNERS: I will show you our analysis and you  
20 can take what guidance you want from it.

21 MR. GIVEN: One last question --

22 MR. SHAH: How do you get that number?

23 MR. RAMOS: As I said earlier this morning, we are  
24 in the process of developing that, and it should be ready in  
25 about two months.

1           MR. GIVEN: The last question I have concerns the  
2 Nuclear Data Link and one of the requirements of the Nuclear  
3 Data Link is the capability of providing data for 30 minutes  
4 pre-event. I wonder how that is taken care of in relation  
5 to the real time data being transmitted after the event or  
6 after you initiate the transmission.

7           MR. MINNERS: Okay. Relative to that, I know we  
8 had two schools of thought. One was transmit it continually  
9 or periodically. That school of thought was -- the  
10 rationale for that school of thought was it would validate  
11 the fact that the Link was operational.

12           Okay, the more limiting case was the one where you  
13 would transmit it after you had detected that you had an  
14 event, say, like a safety injection and let that  
15 automatically initiate the transmittal.

16           I think if you sit down and look at the numbers on  
17 it that 30 minutes -- that past 30 minutes of data could  
18 probably be transmitted within the first minute of the event  
19 -- okay -- or at least the feasibility study proved that that  
20 was the case.

21           MR. GIVEN: So that last 30 minutes of data would  
22 be sandwiched in within the other data.

23           MR. BELTRACCHI: Yes, within the first five  
24 minutes of the event you could probably not only send the  
25 last 30 minutes of data, but also each minute of collected

1 data or each minute of sample data. Okay?

2 MR. RAMOS: You are asking us to give you an  
3 answer on something that has not been completely defined by I  
4 E E and Research.

5 MR. BELTRACCHI: That will come out in an  
6 interface spec that is yet to be specified.

7 MR. MINNERS: That ends the list of people that I  
8 have in front of me.

9 Are there anyother people that would like to make  
10 comments?

11 The gentleman in the back. Please identify  
12 yourself.

13 MR. BURNS: I guess I hsave more of a question:  
14 if you could talk a little bit about the power supply  
15 requirements for the habitability equipment for the tech  
16 support center and the ECF.

17 What are your views on the requirements for that?

18 MR. RAMOS: Your question again, please?

19 MR. BURNS: The power supply questions for the  
20 habitability equipment for the EOF and the tech support  
21 center.

22 I guess what I am basically getting at is: a  
23 reliable power supply, is that sufficient, or are you --

24 MR. RAMOS: We gave you an unavailability factor of  
25 .001.

1 MR. BURNS: That applies to?

2 MR. RAMOS: That applies to all the equipment.

3 MR. BURNS: I was reading that to be  
4 instrumentation for data collection and not necessarily the  
5 --

6 MR. RAMOS: We gave .001 for power supply just as  
7 we did for the single parameter requirement. We gave an  
8 overall system reliability or unavailability of .01. But we  
9 specified specifically for power supply that it be .001. In  
10 other words, you set up whatever power supplies you need,  
11 redundant power supplies you need to meet the .001  
12 unavailability factor.

13 I am not going to tell you how to do it. I am not  
14 going to tell you to hook it up to the diesel or anything  
15 else.

16 That is part of your design.

17 VOICE: Okay. Thank you.

18 MR. MINNERS: What company were you from again,  
19 please, Mr. Burns?

20 MR. BURNS: Northern States Power.

21 MR. MINNERS: Yes, sir, in the back.

22 MR. PASSMAN: Neil Passman from the Power  
23 Authority of New York.

24 Habitability requirements on control rooms now go  
25 further than radiation protection. They go into gaseous

1 release and protection from noxious gases.

2 Are you requiring any of that to be included in  
3 the habitability for the TSC or the EOF?

4 Chlorine gas is an example.

5 MR. RAMOS: We did not really consider that, but  
6 it is a good point, and we will -- we welcome your comment  
7 and we will consider it.

8 MR. PASSMAN: Basically, our comment is going to  
9 be that it should not be there, if it is.

10 MR. RAMOS: Tell us your rationale for why not.

11 MR. PASSMAN: Basically what we are looking at  
12 here is an accident; the centers would be manned on a low  
13 probability basis.

14 In other words, the period of time they would be  
15 manned over the total life of the plant is expected to be  
16 very small. The probability of having a gaseous release at  
17 the time they were manned then becomes proportionately  
18 smaller than, say, the control room which is manned  
19 continuously over the life of the plant.

20 Therefore, we think it should not be a  
21 consideration.

22 MR. MINNERS: It sounds like it is the same  
23 argument for not having earthquake requirements.

24 MR. PASSMAN: It is more restrictive than that  
25 because you would -- you assume the earthquake was the

1 condition that presented the problem.

2 I don't think the gaseous release presents any  
3 additional problems to the control room people since the  
4 control room is built to protect against it.

5 MR. MINNERS: And the plant is built --

6 MR. PASSMAN: I don't think you envision manning  
7 the technical support center or the operations support  
8 center on a gaseous release.

9 MR. RAMOS: I think you are right. It is to be  
10 manned when you get to the alert stage, and that is directly  
11 defined in 0610 as something to do with the reactors.

12 MR. MINNERS: My first impression is we would  
13 agree with you, but we always put the caveat on we will  
14 think about it and then put our final decision in the report.

15 MR. PASSMAN: Okay, fine.

16 MR. MINNERS: Yes, sir?

17 MR. O'BRIEN: One more, if I may.

18 Without saying anything more about the process  
19 computer, I think the target is different than what I  
20 thought it was.

21 This business of security is a new wrinkle that  
22 came in today as far as I am concerned.

23 I am wondering -- again, this is what we are  
24 trying to tell you. I think we would like to see what  
25 criteria you want us to meet and then we can decide whether



1 we can meet it with the process computer.

2 But up until today I don't think we had any  
3 inkling that you were worried about the security of the  
4 software on the process computer and therefore we could not  
5 use it.

6 MR. MINNERS: Okay. I am glad the meeting has  
7 served a purpose, at least that one.

8 MR. O'BRIEN: I would like to pull your leg just a  
9 little bit on the safety parameter display. There was a  
10 statement made by one of the gentlemen up there this  
11 afternoon that could be interpreted that a plant that does  
12 not have a safety parameter display is an unsafe plant, and  
13 I don't think we want to say that.

14 Thank you.

15 MR. MINNERS: Is there anybody else?

16 (No response)

17 Thank you very much.

18 (Thereupon, at 4:32 p.m., the meeting in the  
19 above-entitled matter was adjourned.)

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

\_\_\_\_\_

in the matter of: WORKSHOP - EMERGENCY RESPONSE FACILITIES - NUREG-0696

Date of Proceeding: August 26, 1980

Docket Number: \_\_\_\_\_

Place of Proceeding: Chicago, Illinois

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

David S. Barker

Official Reporter (Typed)



(SIGNATURE OF REPORTER)