(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | TNSNP1 (2) | 00-000-00 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT 58

CON'T
01 REPORT SOURCE L (6) | 05000327 (7) | 071880 (8) | 092800 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With unit in mode 3 during testing ice bed temperature exceeded the T.S. 3.6.5.1
03 limit of 27 degrees F. Maintenance personnel were working in ice condenser. There
04 was no danger to the health and safety of the public. Previously, the temperature
05 exceeded 27 degrees F, 7/16/80. (see LER 80079)
06
07
08

09 SYSTEM CODE SB (11) | CAUSE CODE X (12) | CAUSE SUBCODE X (13) | COMPONENT CODE XXXXXX (14) | COMP SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 142 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER W120

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Between 0700 and 1500C, 7/18/80, maintenance personnel entered and exited the ice
11 condenser to perform work. The ice condenser was not given sufficient recovery time
12 between personnel entries and exits to reduce the ice bed temperature and consequently
13 the temperature exceeded 27 degrees F at 1510C. All maintenance work ceased at 1530C
14 and ice bed temperature reduced to 27 degrees F, 19 1/2 hours later.

15 FACILITY STATUS B (28) | % POWER 000 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 NUMBER 000 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 TYPE Z (42) | DESCRIPTION NA

PUBLICITY
20 ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8009080367

Name of Preparer G. B. Kirk
G. B. Kirk

Phone 615-842-8317