

Docket Nos. 50-10/237/249
50-254/265

SEP 20 1976

Commonwealth Edison Company
ATTN: Mr. R. L. Bolger
Assistant Vice President
Post Office Box 767
Chicago, Illinois 60690

Gentlemen:

RE: DRESDEN NUCLEAR POWER STATION, UNIT NOS. 1/2/3
QUAD CITIES NUCLEAR POWER STATION, UNIT NOS. 1/2

In our letter dated May 11, 1976, we requested that you conduct an examination of your facilities to compare its existing fire protection provisions with the guidelines in the Standard Review Plan 9.5.1, "Fire Protection," dated May 1, 1976, which included Branch Technical Position APCSB 9.5-1. We are enclosing a copy of Appendix A to Branch Technical Position APCSB 9.5-1, "Guidelines for Fire Protection For Nuclear Power Plants Docketed Prior to July 1, 1976" (Enclosure 1). This document presents certain acceptable alternatives for operating plants to the positions given in APCSB 9.5-1. We are sending this to you for your information because we will be using Appendix A in our evaluation of your plants.

After reviewing the licensee submittals made to date in response to our letter, we believe your initial response may not adequately present the results of your fire hazards analysis. We stress that in order to begin a re-evaluation of the fire protection program of your facilities, you must perform a fire hazards analysis with the assistance and technical direction of a qualified fire protection engineer. In order for us to evaluate your fire hazards analysis we require that you submit the results in sufficient detail. To provide further guidance, we are enclosing a copy of "Supplementary Guidance on Information Needed For Fire Protection Program Evaluation" (Enclosure 2). This document indicates the type of information that will enable us to evaluate the total fire hazards analysis for your facilities. This type of information may or may not be included in the detailed point-by-point comparison with Standard Review Plan 9.5.1 depending upon how you present that information.

OFFICE →

SURNAME →

DATE →

8009101002

POOR ORIGINAL

SEP 30 1976

In addition, we request at this time that you propose Technical Specifications for your present fire protection systems and inform us of the date you intend to meet Section B of Appendix A "Administrative Procedures, Controls and Fire Brigade". Your presently scheduled submittal should include the information indicated by Enclosure 2 and proposed Technical Specifications for the fire protection systems of your facilities.

Sincerely,

Original signed by:
Karl R. Goller

Karl R. Goller, Assistant Director
for Operating Reactors
Division of Operating Reactors

Enclosures:

1. Appendix A to Branch Technical Position APCS 9.5-1
2. Supplementary Guidance

cc w/enc1:
See next page

~~XXXXXXXXXX~~
DISTRIBUTION

Docket (5) JRBuchanan
NRC PDR (5) ACRS (16)
Local PDR (2)
ORB #2 Reading
VStello
TJCarter
DLZiemann
RMDiggs (2)
WEConverse
RDSilver
PWO'Connor
MGrotenhuis
TWambach
OELD - Swanson/Treby/Karman
OI&E (3)
WButler
VBenaroya
DEisenhut
TBAbernathy

OFFICE →	DOR:ORB #2 <i>WEC</i>	DOR:ORB #2 <i>RS</i>	DOR:ORB #2 <i>fwl</i>	DOR:ORB #1 <i>jm</i>	DOR:ORB #2 <i>DZ</i>	DOR:AD/OR <i>KR</i>
SURNAME →	WEConverse	RDSilver	PWO'Connor;ah	TWambach	DLZiemann	KRGoller
DATE →	9/29/76	9/29/76	9/29/76	9/29/76	9/29/76	9/30/76

SEP 30 1976

cc w/enclosures:

Mr. Charles Whitmore
President and Chairman
Iowa-Illinois Gas and
Electric Company
206 East Second Avenue
Davenport, Iowa 52801

Mr. John W. Rowe
Isham, Lincoln & Beale
Counselors at Law
One First National Plaza, 42nd Floor
Chicago, Illinois 60603

Anthony Z. Roisman, Esquire
Roisman, Kessler and Cashdan
1025 15th Street, N. W., 5th Floor
Washington, D. C. 20005

Moline Public Library
504 - 17th Street
Moline, Illinois 61265

Morris Public Library
604 Liberty Street
Morris, Illinois 604

OFFICE →					
NAME →					
DATE →					