

Appendix A

NOTICE OF VIOLATION

Commonwealth Edison Company

Docket No. 50-010; 50-237; 50-249

Based on the inspection conducted on June 28-29, and July 8, 1977, certain of your activities appear to be in noncompliance with NRC requirements, as noted below. Item 1 is an infraction and item 2 is a deficiency.

1. Contrary to 10 CFR 71.3, Type B quantities of byproduct material were delivered to a carrier for transport on sixty-six occasions during January, February, and March 1977 without authorization by the Commission.
2. Contrary to Technical Specification 6.6.C.1, gaseous radionuclides released from the Unit 2/3 chimney and the Unit 2/3 reactor building ventilation stack have not been adequately quantified and reported.

8009120

717