



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555  
August 29, 1980

TERA

Docket No. 50-344

Mr. Charles Goodwin, Jr.  
Assistant Vice President  
Portland General Electric Company  
121 S. W. Salmon Street  
Portland, Oregon 97204

Dear Mr. Goodwin:

SUBJECT: Environmental Qualification of Electrical Equipment


This letter transmits an Order which requires information to support the environmental qualification of safety related electrical equipment at the Trojan Nuclear Plant.

The Commission's Memorandum and Order of May 23, 1980 addresses safety related electrical equipment exposed to a harsh environment, inside or outside containment, resulting from an accident. The Order requires that all such equipment in operating reactors be fully qualified by June 30, 1982.

To complete this objective, you are required to submit, by November 1, 1980, all information to support a safety evaluation of the aforementioned equipment. If your facility had an established commitment date before November 1, 1980, it is fully expected that your submittal will be not later than that commitment date. If your facility's commitment date is past without a complete submittal, it is strongly recommended that actions be expedited since they have already impacted the staff review schedule.

Briefings were held with all interested licensees during the week of July 17, 1980. Enforcement actions relative to this Order were discussed during these briefings.

Sincerely,

  
Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Enclosure: Order

cc: See next page

8009190 308

Mr. Charles Goodwin, Jr.  
Portland General Electric Company

cc: Mr. J. W. Durham, Esquire  
Vice President and Corporate Counsel  
Portland General Electric Company  
121 S.W. Salmon Street  
Portland, Oregon 97204

Donald W. Godard, Supervisor  
Siting and Regulation  
Oregon Department of Energy  
Labor and Industries Building  
Room 111  
Salem, Oregon 97310

Columbia County Courthouse  
Law Library, Circuit Court Room  
St. Helens, Oregon 97501

Ms. Nina Bell  
728 S.E. 26th Street  
Portland, Oregon 97214

Michael Malmros, Resident Inspector  
U. S. Nuclear Regulatory Commission  
Trojan Nuclear Plant  
P. O. Box 0  
Rainier, Oregon 97043

Mr. Eugene R. Rosolie  
Coalition for Safe Power  
215 S. E. 9th Avenue  
Portland, Oregon 97214

Robert M. Hunt, Chairman  
Board of County Commissioners  
Columbia County  
St. Helens, Oregon 97051

Director, Technical Assessment Division  
Office of Radiation Programs (AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection Agency  
Region X Office  
ATTN: EIS COORDINATOR  
1200 6th Avenue  
Seattle, Washington 98101