

(412) 456-6000

DUQUESNE LIGHT COMPANY Beaver Valley Power Station Post Office Box 4 Shippingport, PA 15077

September 16, 1980 BVPS/LC:JDS:396

Memorandum of Telephone Conversation Clarification of NUREG 0578 Item 2.1.4

Mr. William J. Ross, Licensing Project Manager United States Nuclear Regulatory Commission Office of Nuclear Reactor Regulation Division of Licensing Washington, D. C. 20555

Dear M.. Ross:

This memorandum confirms our telephone conversation of September 9, 1980 concerning the basis for selecting the essential system in our submittal on the above reference. The following statement was given as our response to your question.

"The basis for selecting those systems which are designated as "Essential" for CIA and CIB isolation signals in our response to Item 2.1.4 of NUREG 0578 was a review of the accident analysis in Section 14 of the BVPS FSAR and the BVPS Emergency Operating Procedures. Based on this review, those systems which are required to operate or be operable to take the proper emergency actions to mitigate the consequences of an accident, prevent core damage or limit radioactive release to the environment were classified as essential for the particular containment isolation signal involved."

If you have any questions, please contact me.

8009230 711 P

J. D. Sieber Nor Robs, 10

J. D. Sieber AC Superintendent Licensing & Compliance

RFB:ba