

730



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
631 PARK AVENUE  
KING OF PRUSSIA, PENNSYLVANIA 19406

September 10, 1980


Docket No. 50-213

Connecticut Yankee Atomic Power Company  
ATTN: Mr. W. G. Council  
Vice President - Nuclear  
Engineering and Operations  
P. O. Box 270  
Hartford, Connecticut 06101

Gentlemen:

The enclosed IE Circular No. 80-21, "Regulation of Refueling Crews," is forwarded to you for information. No written response is required. If you desire additional information regarding this matter, please contact this office.

Sincerely,

  
Boyce H. Grier  
Director

Enclosures:

1. IE Circular No. 80-21
2. List of Recently Issued IE Circulars

CONTACT: D. L. Capton  
(215-337-5266)

cc w/encls:

R. Graves, Plant Superintendent  
D. G. Diedrick, Manager of Quality Assurance  
J. R. Himmelwright, Licensing Safeguards Engineer

8009230 779

SSINS No.: 6820  
Accession No.:  
8006190081  
IEC 80-21

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

September 10, 1980

DUPLICATE

IE Circular No. 80-21: REGULATION OF REFUELING CREWS

Description of Circumstances:

Recent inspections of refueling activities indicate that some licensees have misinterpreted the regulatory requirements applicable to fuel handling activities. Therefore, it appears appropriate to identify those specific regulatory requirements that are applicable to core alterations which include reactivity manipulations that may result from the handling of fuel elements, control rods, etc.

A. 10 CFR Requirements

1. 10 CFR 50.2(f) and 10 CFR 55.4:

"Controls" when used with respect to a nuclear reactor means apparatus and mechanisms, the manipulation of which directly affect the reactivity or power level of the reactor.

2. 10 CFR 50.54(i):

Except as provided in 55.9 of this chapter, the licensee shall not permit the manipulation of the controls of any facility by anyone who is not a licensed operator or senior operator as provided in Part 55 of this chapter.

3. 10 CFR 55.3:

No person may perform the function of an operator as defined in this part except as authorized by a license issued by the Commission;

4. 10 CFR 55.4:

"Operator" is any individual who manipulates a control of a facility. An individual is deemed to manipulate a control if he directs another to manipulate a control.

"Senior Operator" is any individual designated by a facility licensee under Part 50 of this chapter to direct the licensed activities of licensed operators.

5. 10 CFR 55.9:

Nothing in this part shall be deemed to require a license for:

- a. An individual who manipulates the controls of a research or training reactor as part of his training as a student in a

nuclear engineering course under the direction and in the presence of a licensed operator or senior operator;

- b. An individual who manipulates the controls of a facility as a part of his training to qualify for an operator license under this part under the direction and in the presence of a licensed operator or senior operator.

#### B. Technical Specifications

Standard Technical Specifications require that all core alterations be directly supervised by either a Licensed Senior Reactor Operator or a Senior Reactor Operator limited to fuel handling, who has no other concurrent responsibilities during this operation. The NRC interprets the term "directly supervised" to mean that the SRO is supervising the core alterations from the refueling deck.

We note that the Licensed Senior Reactor Operator limited to fuel handling classification was developed for specialized fuel handling crews. In this case an individual identified as a Refueling Foreman is responsible for refueling activities subject to the following provisions:

1. The foreman shall have a Senior Operator's License limited to the fuel handling duties.
2. The foreman shall directly supervise (from the refueling deck) the movement of fuel in and out of the reactor.
3. The unlicensed members of the crew shall participate in appropriate facility administered training programs and be facility certified to perform their duties.
4. Direct communication will be maintained with a licensed individual in the control room when fuel movements over the core are being made.
5. The foreman will exercise indirect supervision over all other fuel handling operations.

Based on the NRC regulations delineated in Item A above, the individual manipulating the fuel-handling equipment over the reactor must be an NRC Licensed Reactor Operator (RO) unless the facility Technical Specifications include provisions for the operation to be supervised by an SRO or SRO limited to fuel-handling as described in Item B. During any core alteration, a licensed individual must also be observing reactivity monitors in the Control Room with appropriate communications established with personnel on the fuel handling equipment. In addition, personnel participating directly in the core alternations must meet the qualification and training requirements committed to in the FSAR or fuel loading application, i.e., ANSI N18.1-1971 or ANSI/ANS 3.1-1978.

Recommended Action for Licensee Consideration

Our routine inspection program for refueling activities is based on the above NRC requirements. Therefore, we recommend that all reactor licensees review procedures and practices to assure that the individuals responsible for and participating in refueling activities are in conformance with the above requirements.

No written response to this Circular is required. If you require additional information with regard to this subject, please contact this office.

RECENTLY ISSUED  
IE CIRCULARS

Circular No.	Subject	Date of Issue	Issued to
80-20	Changes in Safe-Slab Tank Dimensions	8/21/80	All holders of a Part 50 or Part 70 Fuel Facility License
80-19	Noncompliance with Licensee Requirements	8/26/80	All holders of a medical license
80-18	10 CFR 50.59 Safety Evaluations for Changes to Radioactive Waste Treatment Systems	8/22/80	All holders of a power reactor OL or CP
80-17	Fuel Pin Damage Due to Water Jet from Baffle Plate Corner	7/23/80	All holders of a PWR power reactor OL or CP
80-16	Operational Deficiencies In Rosemount Model 510DU Trip Units And Model 1152 Pressure Transmitters	6/27/80	All holders of a power reactor OL or CP
80-15	Loss of Reactor Coolant Pump Cooling and Natural Circulation Cooldown	6/20/80	All holders of a power reactor OL or CP
80-14	Radioactive Contamination of Plant Demineralized Water System and Resultant Internal Contamination of Personnel	6/24/80	All holders of a power or research reactor OL or CP, and fuel cycle licensees
80-13	Grid Strap Damage in Westinghouse Fuel Assemblies	5/18/80	All holders of a power reactor OL or CP
80-12	Valve-Shaft-To-Actuator Key May Fall Out of Place When Mounted Below Horizontal Axis	5/14/80	All holders of a power reactor OL or CP
80-11	Emergency Diesel Generator Lube Oil Cooler Failures	5/13/80	All holders of a power reactor OL or CP
80-10	Failure to Maintain Environmental Qualification of Equipment	4/29/80	All holders of a power reactor OL or CP