



Portland General Electric Company



Tic

August 25, 1980

Trojan Nuclear Plant  
Docket 50-344  
License NPF-1

Mr. R. H. Engelken, Director  
U. S. Nuclear Regulatory Commission  
Region V  
Suite 202, Walnut Creek Plaza  
1990 N. California Blvd.  
Walnut Creek, CA 94596

Dear Mr. Engelken:

Pursuant to discussions with members of your staff (Phil Johnson), we would like to update our previous response of July 2, 1980 to IE Bulletin 80-03 dealing with Containment penetration welds. At the time of our response, we were missing documentation for 14 Containment penetration welds (19 penetrations). Documentation has been found for the welds identified in Table I of the attachment to our July 2, 1980 response as Item 1 (Penetration P-1-1), Item 51 (Penetration P-57-1) and Item 74 (Penetration P-39-1). Unfortunately, we are still unable to locate the documentation for the other 11 welds; however, we have substantive evidence that the examinations were performed and will continue to research our records in an attempt to locate the missing documentation for these penetrations and welds.

This letter supersedes the letter submitted on August 14, 1980; please disregard that letter. Should you have further questions, please do not hesitate to contact me.

Sincerely,

C. Goodwin, Jr.  
Assistant Vice President  
Thermal Plant Operation and  
Maintenance

CG/GAZ/4sa5A3

c: Mr. Lynn Frank, Director  
State of Oregon  
Department of Energy

8009240 375

80-228