LICENSEE EVENT REPORT

	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 7 8	M A P P S 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5 CAT 58
0 1 7 8	SOURCE L 6 0 5 0 - 0 2 9 3 7 0 8 2 1 8 0 8 0 9 1 9 8 0 9 SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
	On August 21, 1980 at approximately 0440 hours while performing surveillance test
0 2	
0 3	#8.5.5.4 on the RCIC system a motor overload alarm was received on MO 1301-62 valve.
0 4	Investigation revealed the protective alarm was generated by the valves thermal overload
0 5	device which is utilized for annunciation only. Automatic operation of the valve was
06	still available. Until an investigation of the cause of the alarm was completed,
0 7	manual operation of the valve was utilized. Following maintenance, the valve was
0 8	tested and the RCIC system was returned to service.
0 9	SYSTEM CAUSE CAUSE SUBCODE COMPONENT CODE SUBCODE SUBC
	TO REPORT NUMBER 21 22 23 24 26 27 28 29 29 20 21 22
	ACTION FUTURE EFFECT SHUTDOWN HOURS 22 ATTACHMENT NPRD-4 PRIME COMP. COMPONENT MANUFACTURER SUBMITTED FORM SUB. SUPPLIER MANUFACTURER LA [18] X [19] Z [20] Z [21] O O O O N (23) N (24) N (25) T 1 4 7 (26)
	33 34 35 36 37 40 41 42 43 44 47 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
110	The valve's Westinghouse thermal overload device was replaced. Analysis indicates
	that the thermal overload rating is approximately 1.0 ampere. The valve motor operator
1 2	at approximately 1.3 amperes. Evaluation of the capacity rating of these devices is
1 3	being reviewed. No failed component was identified however as a precaution the
7 8	above device was replaced.
15	FACILITY SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 E 28 1 0 0 29 N.A. B 31 Surveillance Testing
	ACTIVITY CONTENT 12 13 44 45 46 10 12 13 12 13 13 14 15 16 12 13 12 13 15 16 16 16 16 16 16 16 16 16 16 16 16 16
7 8	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
7 8	9 PERSONNEL INJURIES 13 80
18	NUMBER DESCRIPTION 41 N.A.
7 8	9 11 12 LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION 43
1 9	N.A.
	PUBLICITY ISSUED DESCRIPTION 45 8 009240 464
7 8	N.A. N.A. 80 5
	NAME OF PREPARED M. Thomas McLoughlin